

APR 27 1983

Docket Nos. 50-329/330

MEMORANDUM FOR Elinor G. Adensam, Chief  
Licensing Branch No. 4  
Division of Licensing

FROM: Ronald W. Hernan, Project Manager  
Licensing Branch No. 4  
Division of Licensing

SUBJECT: NOTICE OF MEETING - MIDLAND PLANT, UNITS 1 AND 2

DATE AND TIME: May 11, 1983  
9:00 a.m. - 3:00 p.m.

LOCATION: Room P-110  
Phillips Building  
Bethesda, Maryland

PURPOSE: To discuss topics related to SER Open Item No. 7  
and Confirmatory Item No. 7 in regard to natural  
circulation and RV head vent. (See attached agenda)

PARTICIPANTS: 1/ NRC Consumers Power Company  
 W. Jensen - RSB L. Gibson, et al.  
 W. Kennedy - PTRB Babcock & Wilcox  
 R. Hernan - LB #4 C. Gally, et al.

Ronald W. Hernan, Project Manager  
Licensing Branch No. 4  
Division of Licensing

Enclosure:  
cc: See next page

1/ Meetings between NRC technical staff and applicants for licenses are open for interested members of the public, petitioners, intervenors, or other parties to attend as observers pursuant to "Open Meeting and Statement of NRC Staff Policy", 43 Federal Register 28058, 6/28/78.

8305040336 B5J427  
PDR ADOCK 05000329  
E PDR

OFFICE	DL:LB#4	DL:LB#4				
SURNAME	RHernan:eb	EAdensam				
DATE	4/27/83	4/27/83				

MIDLAND

Mr. J. W. Cook  
Vice President  
Consumers Power Company  
1945 West Parnall Road  
Jackson, Michigan 49201

cc: Michael I. Miller, Esq.  
Ronald G. Zamarin, Esq.  
Alan S. Farnell, Esq.  
Isham, Lincoln & Beale  
Three First National Plaza,  
51st floor  
Chicago, Illinois 60602

James E. Brunner, Esq.  
Consumers Power Company  
212 West Michigan Avenue  
Jackson, Michigan 49201

Ms. Mary Sinclair  
5711 Summerset Drive  
Midland, Michigan 48640

Stewart H. Freeman  
Assistant Attorney General  
State of Michigan Environmental  
Protection Division  
720 Law Building  
Lansing, Michigan 48913

Mr. Wendell Marshall  
Route 10  
Midland, Michigan 48640

Mr. Roger W. Huston  
Suite 220  
7910 Woodmont Avenue  
Bethesda, Maryland 20814

Mr. R. B. Borsum  
Nuclear Power Generation Division  
Babcock & Wilcox  
7910 Woodmont Avenue, Suite 220  
Bethesda, Maryland 20814

Cherry & Flynn  
Suite 3700  
Three First National Plaza  
Chicago, Illinois 60602

Mr. Don van Farrowe, Chief  
Division of Radiological Health  
Department of Public Health  
P.O. Box 33035  
Lansing, Michigan 48909

Mr. Steve Gadler  
2120 Carter Avenue  
St. Paul, Minnesota 55108

U.S. Nuclear Regulatory Commission  
Resident Inspectors Office  
Route 7  
Midland, Michigan 48640

Ms. Barbara Stamiris  
5795 N. River  
Freeland, Michigan 48623

Mr. Paul A. Perry, Secretary  
Consumers Power Company  
212 W. Michigan Avenue  
Jackson, Michigan 49201

Mr. Walt Apley  
c/o Mr. Max Clausen  
Battelle Pacific North West Labs (PNWL)  
Battelle Blvd.  
SIGMA IV Building  
Richland, Washington 99352

Mr. I. Charak, Manager  
NRC Assistance Project  
Argonne National Laboratory  
9700 South Cass Avenue  
Argonne, Illinois 60439

James G. Keppler, Regional Administrator  
U.S. Nuclear Regulatory Commission,  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

cc: Lee L. Bishop  
Harmon & Weiss  
1725 I Street, N.W., Suite 506  
Washington, D. C. 20005

Mr. Ron Callen  
Michigan Public Service Commission  
6545 Mercantile Way  
P.O. Box 30221  
Lansing, Michigan 48909

Mr. Paul Rau  
Midland Daily News  
124 McDonald Street  
Midland, Michigan 48640

Billie Pirner Garde  
Director, Citizens Clinic  
for Accountable Government  
Government Accountability Project  
Institute for Policy Studies  
1901 Que Street, N.W.  
Washington, D. C. 20009

Mr. Howard Levin, Project Manager  
TERA Corporation  
7101 Wisconsin Avenue  
Bethesda, Maryland 20814

Ms. Lynne Bernabei  
Government Accountability Project  
1901 Q Street, N.W.  
Washington, D. C. 20009

## MEETING AGENDA

MAY 11, 1983 MEETING ON NATURAL CIRCULATION AND HEAD VENT

1. Analyses by Babcock & Wilcox indicate that the cooldown rate of the upper head may be limited to low as  $1.7^{\circ}\text{F/hr}$ , which would also limit the maximum depressurization rate of the reactor coolant system in approaching cold shutdown to approximately 14 psi/hr. To reach cold shutdown at a cooldown rate of  $1.7^{\circ}\text{F/hr}$  would require approximately 200 hours. The following aspects of these limitations will be discussed:
  - a) Uncertainties in the head cooling circulation and possible conservatisms.
  - b) Beneficial effects of the proposed head vent in cooling the upper head and in relieving steam when opened.
  - c) The proposed "natural circulation cooldown" approach to power testing including;
    - i. Instrumentation including reactor vessel head thermocouples
    - ii. Proposed cooldown rate and justification
    - iii. Proposed depressurization rate and justification
    - iv. Test procedure provisions in the event of head bubble formation
    - v. Extent of test temperature and pressure range and justification for not extending the test to cold shutdown
    - vi. Justification for not performing an idle loop natural circulation test and conditions under which a single loop cooldown would be required. (i.e. partial AFW failures, steam generator tube rupture.)
    - vii. Application of test data in providing guidance to the operator in natural circulation cooldown procedures.
  - d) In the event cooldown rates are limited to  $1.7^{\circ}\text{F/hr}$  can the requirements of RSB 5-1 still be met? For example:
    - i. Are pressurizer heaters required to prevent the pressurizer from cooling down faster than the reactor vessel head?
    - ii. Is an adequate supply of safety grade AFW water available?
  - e) The impact of a possible cooldown limit of  $1.7^{\circ}\text{F/hr}$  on conditions which may require rapid cooldown such as steam generator tube rupture or technical specification requirements (i.e. excessive primary system leakage, ECCS failure, containment failure etc.)

- f) The significance of possible head bubble growth into the reactor vessel hot leg nozzles which could produce loss of natural circulation and/or thermal shock (as discussed in the B&W idle loop cooldown report).
- g) The analyses of two loop cooldown which were referred to in the B&W idle loop report.
- h) Establishment of system analytical bounds for cooldown rate without bubble formation.
- i) Dynamics of the plant with a bubble in the reactor vessel head.
- j) Potential for estimating bubble size through changes in pressurizer level.
- k) Potential for head cooling through bubble formation (i.e. steam formation should accelerate head cooldown).

MEETING NOTICE DISTRIBUTION

Docket File 50-329/330

NRC PDR  
Local PDR  
TIC  
NSIC  
PRC System  
LB #4 r/f  
H. Denton/E. Case  
D. Eisenhut/R. Purple  
T. Novak  
J. Youngblood  
A. Schwencer  
G. Knighton  
C. O. Thomas  
J. Kramer  
G. Lainas  
D. Crutchfield  
W. Russell  
T. Ippolito  
W. Johnston  
D. Muller  
J. P. Knight  
L. Rubenstein  
T. Speis  
W. Houston  
F. Schroeder  
M. Ernst  
ACRS (16)  
Attorney, OELD  
D. L. Jordan, DEQA; I&E  
J. M. Taylor, DPR; I&E  
Receptionist  
Project Manager R. Hernan  
Licensing Assistant M. Duncan  
D. Hood  
J. Sniezak, IE  
J. Stone, IE

NRC PARTICIPANTS

W. Jensen  
W. Kennedy  
R. Hernan

cc: Applicant & Service List