

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401  
400 Chestnut Street Tower II

April 28, 1983

TVA BFNP TS 176 SUPPLEMENT 5

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Denton:

In the Matter of the ) Docket Nos. 50-259  
Tennessee Valley Authority ) 50-260  
50-296

In accordance with the provisions of 10 CFR Parts 50.59 and 50.90, we are enclosing 40 copies of a requested amendment to licenses DPR-33, DPR-52, and DPR-68 to change the technical specifications of Browns Ferry Nuclear Plant units 1, 2, and 3 (enclosure 1). The enclosed specifications change the stated isolation logic for the group 7 isolation valves to reflect the actual logic. Additional explanation and justification for these changes are enclosed (enclosure 2).

The enclosed specifications are administrative in nature and accordingly they are being submitted as a supplement to a pending request for technical specification change also administrative. TVA BFNP TS 176 was submitted September 14, 1982 with Supplements 1, 2, 3, and 4 submitted November 5, 1982, December 17, 1982, February 1, 1983, and April 7, 1983, respectively. Inclusion of this additional change with an existing request avoids TVA having another request pending on the Browns Ferry docket and we believe is the best method for submittal. Because this change is administrative in nature, we believe little staff review will be required.

In accordance with the requirements of 10 CFR 170.22, Class II and Class I fees totaling \$2,000 were forwarded with license amendment request TVA BFNP TS 176. Because the proposed specification revisions are only a minor addition to TS 176, we do not believe additional review fees are appropriate. Therefore, no fees will be forwarded.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

*L. M. Mills*  
L. M. Mills, Manager  
Nuclear Licensing

A001

Subscribed and sworn to before  
me this 28th day of April 1983.

*Byrant M. Lowery*  
Notary Public  
My Commission Expires 4/8/86

Enclosures  
cc: See page 2

8305040511 830428  
PDR ADDCK 05000259  
P PDR

Mr. Harold R. Denton

April 28, 1983

cc (Enclosures):

Mr. Charles R. Christopher  
Chairman, Limestone County Commission  
P.O. Box 188  
Athens, Alabama 35611

Dr. Ira L. Myers  
State Health Officer  
State Department of Public Health  
State Office Building  
Montgomery, Alabama 36104

Mr. R. J. Clark  
U.S. Nuclear Regulatory Commission  
Browns Ferry Project Manager  
7920 Norfolk Avenue  
Bethesda, Maryland, 20814

Mr. K. D. Fagan, Supervisor - Nuclear  
c/o General Electric Company  
Suite 608  
Tallan Plaza  
Chattanooga, Tennessee 37402