

3150-0011

1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
UPDATE REPORT - PREVIOUS REPORT DATE 6-22-83

UPDATE REPORT - PREVIOUS REPORT DATE 6-22-83

0	1	A	L	J	M	F	2	(2)	0	0	-	0	0	0	0	-	0	0	(3)	4	1	1	1	1	(4)			(5)										
7	9	9					14	15										25	26							30	37	CAT	56									
								LICENSE CODE												LICENSE NUMBER												LICENSE TYPE						

CON'T

REPORT SOURCE L 6 0 5 0 0 0 3 6 4 7 0 5 2 8 8 3 8 0 8 1 0 8 3 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 0030 on 5/28/83 during performance of FNP-2-STP-612.0 (Reactor Coolant Pump
03 Bus Reactor Trip Undervoltage Relay Calibration), 2A reactor coolant pump under-
04 voltage relay 27-3 was declared inoperable due to its out of Spec. condition (69.8
05 volts actual vs. 75.43 volts required). Tech. Spec. 3.3.1 and 3.3.2, in part, re-
06 quire the relay to be operable. Tech. Spec. action statement requirements were
07 met. Health/safety of the public was not affected. Similar occurrences were re-
08 ported in LER 82-026/03L-0 (Unit 2) and LER 83-022/03L-0 (Unit 2).

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE	
0	9	I	A	E	A	R	E	L	A	Y	X	D	Z
7	8	9	10	11	12	13	14	15	16	17	18	19	20
(17) LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.			
8 3		8 3		0 2 5		0 3		X		1			
21 22		23 24		25 26		27 28		29 30		31 32			
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED			
E		Z		Z		Z		0 0 0		N			
18		19		20		21		22		23			
33 34		35 36		37 38		39 40		41 42		43 44			
PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER		NPRD-4 FORM SUB.			
N		G 0 8 0		Y		N		G 0 8 0		Y			
24		25		26		27		28		29			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 This event was attributed to setpoint drift. Following adjustment of the relay

1 1 setpoint, 2A reactor coolant pump undervoltage relay was declared operable at

1 2 0045 on 5/28/83.

1 3

1 4

FACILITY STATUS (1) 5 (28) 1 0 0 (29) NA (30) METHOD OF DISCOVERY (31) B (32) Surveillance Test
 ACTIVITY CONTENT RELEASED (1) 6 (33) 2 (34) 2 (35) NA (36) LOCATION OF RELEASE NA

PERSONNEL EXPOSURES

NUMBER			TYPE		DESCRIPTION
1	7	0	0	0	NA
7	8	9	10	11	12

PERSONNEL INJURIES	NUMBER	DESCRIPTION
	41	

1 8 0 0 0 (40) NA

7 8 9 11 12

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE DESCRIPTION

8308190333 830810
PDR ADOCK 05000348
S

80

1 9 Z 42 NA PDR

PUBLICITY ISSUED DESCRIPTION (45) NA NRC USE ONLY

NAME OF PREPARER W. G. Hairston, III

PHONE: (205) 899-5156

NRC USE ONLY