

UNITED STATES  
ATOMIC ENERGY COMMISSION  
WASHINGTON, D.C. 20545

*Revised*  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

OCT 9 1969  
10/9/69

Docket No. 50-146

Saxton Nuclear Experimental Corporation  
Post Office Box 542  
Reading, Pennsylvania 19603

Attention: Mr. C. R. Montgomery  
General Manager

Gentlemen:

We have been advised by the Corps of Engineers that construction of the Raystown Dam is underway and will be completed in 1973. Your Safety Analysis Report should be revised to reflect the existence of the dam and analysis of the hazards, if any, to the Saxton nuclear power facility from the normal water level in the reservoir and from any flood level. This information should be submitted as a supplement or revision to your SAR well in advance of completion of any stage of dam construction which might affect the probability or consequences of floods at Saxton. Please advise us of your intentions in this regard.

Sincerely,

*Donald J. Skovholt*  
Donald J. Skovholt  
Assistant Director for Reactor Operations  
Division of Reactor Licensing

*I*  
*I/86*