



GPU Nuclear Corporation
Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

C321-91-2190

July 16, 1991

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Reference: GPU Nuclear response to NRCB 88-10; dated June 12, 1991

Dear Sir:


Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
NRC Bulletin 88-10 "Non-Conforming Molded Case
Circuit Breakers"

This letter is being written in response to your request for additional information to supplement the GPU Nuclear response referenced above. In that response, GPU Nuclear identified four circuit breakers at the Oyster Creek Nuclear Generating Station which had been determined to be non-traceable, as defined in NRC Bulletin 88-10.

The four circuit breakers have been returned to the original vendor in accordance with the guidance provided by NUMARC. There is no possibility that they could be installed at the Oyster Creek Station in any application.

If any further information is required, please contact Mr. John Rogers at 609-971-4893.

Sincerely,



John J. Barton
Vice President and Director
Oyster Creek

cc: Administrator, Region 1
Senior NRC Resident Inspector
Oyster Creek NRC Project Manager

\JJR

9107230410 910716
PDR ADOCK 05000219
P PDR

22055

GPU Nuclear Corporation is a subsidiary of General Public Utilities Corporation

IK21
110