

DmB-016

Docket No. 50-366

AUG 4 8 1983

LICENSEE: Georgia Power Company
 FACILITY: Hatch Unit 2
 SUBJECT: SUMMARY OF JULY 7, 1983 MEETING WITH GEORGIA POWER COMPANY CONCERN THE ANALYSIS AND REPAIR OF HATCH UNIT 2 PIPE CRACKS

Georgia Power Company (GPC) management met with the NRC staff management in Bethesda, Maryland on July 7, 1983 to explain why it believes the pipe cracking problem at Hatch Unit 2 has been resolved sufficiently to justify restart and operation of the Unit. The meeting was held at the request of the NRC staff. The agenda for th GPC presentation and the presentation slides used by GPC are provided in Enclosures 1 and 2. A list of meetings attendees is provided in Enclosure 3.

The NRC staff management informed GPC management that, as a condition to startup of the Unit, it would require that GPC 1) perform an inspection within 6 months to determine the extent that pipe crack growth has progressed since the current inspection, and 2) submit its proposed plan for performing this inspection within 30 days of receipt of an NRC order allowing startup. GPC agreed that it would meet this requirement and that it would provide a written commitment to this effect.

Original signed by
 George Rivenbark, Project Manager
 Operating Reactors Branch #4
 Division of Licensing

Enclosures:
 As stated

cc
 See next page

8308240682 830818
 PDR ADOCK 05000366
 P PDR

OFFICE ▶		ORB#4: DM				
SURNAME ▶		GRivenbark;ps				
DATE ▶		8/17/83				



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

August 18, 1983

Docket No. 50-366

LICENSEE: Georgia Power Company
FACILITY: Hatch Unit 2
SUBJECT: SUMMARY OF JULY 7, 1983 MEETING WITH GEORGIA POWER
COMPANY CONCERN THE ANALYSIS AND REPAIR OF HATCH
UNIT 2 PIPE CRACKS

Georgia Power Company (GPC) management met with the NRC staff management in Bethesda, Maryland on July 7, 1983 to explain why it believes the pipe cracking problem at Hatch Unit 2 has been resolved sufficiently to justify restart and operation of the Unit. The meeting was held at the request of the NRC staff. The agenda for the GPC presentation and the presentation slides used by GPC are provided in Enclosures 1 and 2. A list of meetings attendees is provided in Enclosure 3.

The NRC staff management informed GPC management that, as a condition to startup of the Unit, it would require that GPC 1) perform an inspection within 6 months to determine the extent that pipe crack growth has progressed since the current inspection, and 2) submit its proposed plan for performing this inspection within 30 days of receipt of an NRC order allowing startup. GPC agreed that it would meet this requirement and that it would provide a written commitment to this effect.

A handwritten signature in cursive script, appearing to read "G. Rivenbark".

George Rivenbark, Project Manager
Operating Reactors Branch #4
Division of Licensing

Enclosures:
As stated

cc
See next page

MEETING SUMMARY DISTRIBUTION

Licensee:

*Copies also sent to those people on service (cc) list for subject plant(s).

Docket File
NRC PDR
L PDR
ORB#4 Rdg
Project Manager : G. Rivenbark
JStolz
BGrimes (Emerg. Preparedness only)

OELD
NSIC
ELJordan, IE
JHTaylor, IE
ACRS (10)

NRC Meeting Participants:

W. S. Hazelton	R. K. Godby
W. V. Johnston	C. T. Jones
D. A. Kiaw	J. A. Edwards
C. Y. Cheng	G. Nead
W. Koo	L. Gucwa
P. R. Matthews	
F. Schroeder	
E. G. Case	
D. D. Vassallo	
A. R. Herdt	
G. C. Lainas	
H. Denton	
R. Vollmer	

AGENDA

HATCH UNIT 2 RECIRC & RHR IGSCC ANALYSES/REPAIRS MEETING
BETHESDA, MARYLAND
July 7, 1983

- I. INTRODUCTION
- II. INSERVICE INSPECTION
 - A. SCOPE OF EXAMINATIONS
 - B. RESULTS
 - C. EXAMINATION METHODS VALIDATION
- III. INVESTIGATION INTO THE CAUSE OF CRACKING
 - A. BACKGROUND
 - B. INVESTIGATION
 - C. SUMMARY OF CAUSE OF CRACKING
- IV. ANALYSES AND REPAIRS
- V. JUSTIFICATION FOR PLANT OPERATIONS

SCOPE OF EXAMINATIONS

RECIRCULATION SYSTEM

ASME CATEGORY B-F WELDS EXAMINED:

12" - 5 welds

23" - 1 weld

Total - 6 welds

ASME CATEGORY B-J WELDS EXAMINED:

4" - 4 welds

6" - 2 welds

12" - 41 welds

22" - 16 welds

28" - 33 welds

Total - 96 welds

TOTAL NUMBER OF RECIRCULATION SYSTEM WELDS EXAMINED:

102 welds

RHR SYSTEM

ASME CATEGORY B-F WELDS EXAMINED:

20" - 1 weld

24" - 2 welds

Total - 3 welds

ASME CATEGORY B-J WELDS EXAMINED:

20" - 2 welds

24" - 6 welds

Total - 8 welds

TOTAL NUMBER OF RHR SYSTEM WELDS EXAMINED:

11 welds

RWCU SYSTEM

ASME CATEGORY B-F WELDS EXAMINED:

6" - None, not applicable

Total - None, not applicable

ASME CATEGORY B-J WELDS EXAMINED:

6" - 5 welds

Total - 5 welds

TOTAL RWCU SYSTEM WELDS EXAMINED:

SCOPE OF EXAMINATIONS (CONT.)

TOTAL NUMBER OF RECIRCULATION, RHR, AND RWCU WELDS EXAMINED:

118 welds*


* This number equates to 85.5% of all stainless steel welds in the Class 1 portions of the Recirculation, RHR, and RWCU systems

Summary of Thru-Wall Depth Characterization
 Vs.
 Results of Destructive Testing on Selected
 IGSCC Samples at Battelle Laboratories-Dec. 1982

Weld Number	Indication Number	Destructive Testing		UT MEASURED DEPTH			
		Measured Max. Depth	% Thru Wall			Depth	% Diff.
14S-SW-11	1	.215	16.5			.244	+14%
	2	.275	21.1			No Results	N/A
	3	.205	15.7			.191	-7%
120-SW-19	1	.320	23.2			.407	+27%
	2	.235	17.0			.306	+30%
	3	.240	17.4			.408	+70%
	4	.250	18.1			.260	+4%

All depth measurements in inches

FRACTURE MECHANICS CONSIDERATIONS



FLAW EVALUATION METHODOLOGY

- 0 SELECT HIGHEST APPLIED STRESS IN SIZE OF PIPING BEING EVALUATED
- 0 USE ASME SECTION XI TABLES OR SOURCE EQUATIONS TO DETERMINE END OF INSPECTION INTERVAL "ALLOWABLE" FLAW SIZE
- 0 DETERMINE FLAW SIZE AT BEGINNING OF CYCLE FROM UT DATA
- 0 DETERMINE CRACK GROWTH USING CONSERVATIVE CRACK GROWTH CURVE TO IDENTIFY "CALCULATED" END OF CYCLE FLAW SIZE
- 0 COMPARE "CALCULATED" TO "ALLOWABLE" CRACK DEPTH AT END OF CYCLE TO DETERMINE THE NEED FOR REPAIR



WELD OVERLAY AS A REPAIR

DEVELOPMENT OF OVERLAY DESIGN

● JAN-1982 $T(\text{OVERLAY}) \geq T(\text{PIPE})$

OVERLAY STRENGTH \geq NOMINAL PIPE STRENGTH

● OCT 1982 $T(\text{OVERLAY}) \geq T(\text{PIPE MIN})$

OVERLAY STRENGTH \geq CODE REQUIRED PIPE STRENGTH

● JAN 1983 $T(\text{OVERLAY}) < \frac{T(\text{PIPE})}{4}$
(AXIAL CRACKS)

$T(\text{OVERLAY}) < \frac{T(\text{PIPE})}{2}$
(CIRCUMFERENTIAL CRACKS)

REQUIRED OVERLAY THICKNESS PER IWB-3640 WITH NO CREDIT FOR OVERLAY RESIDUAL STRESS IMPROVEMENT

● MARCH 1983 $T(\text{OVERLAY}) < 1/8" \text{ TO } 1/4"$

REQUIRED OVERLAY THICKNESS PER IWB-3640 WITH CREDIT TAKEN FOR OVERLAY RESIDUAL STRESS IMPROVEMENT



UNREPAIRED PIPE

o CONSERVATISMS

- FULL DEPTH 360° CRACK

- IWB-3640 SAFETY FACTORS

MEMBRANE 3.0

BENDING 8/π

- "C" DIMENSION THICKNESS

- (A/T) ALLOW 63% (STRESS LOWERED THAN TABULATED VALUES)

o RESULT

LOCATION	<u>U.T. SIZING</u>	<u>BEGINNING OF CYCLE ALLOWABLE</u>	RATIO
28B-10	20%	59%	2.9
28B-15	23%	60%	2.6

WELD OVERLAY REPAIRS

o CONSERVATISMS

- HIGHEST STRESSED LOCATION
- FULL DEPTH 360° CRACK
- IWB-3640 SAFETY-FACTORS

MEMBRANE 3.0
BENDING 8/π

- MINIMUM DESIGN THICKNESS
- ORIGINAL DESIGN CODE S.I.F.

o RESULT

LOCATION	U.T. SIZING		BEGINNING OF CYCLE ALLOWABLE SIZE		RATIO
	%	INCHES	%	INCHES	
12" MINI	30	0.21"	52	0.42"	2.0
12" STANDARD	32	0.22	56	0.50"	2.3
22" STANDARD	42	0.46	66	0.89	1.93

AS WELDED SURFACE
ACCEPTABLE FOR
OVERLAY TAPER
TRANSITIONS

TYPE 308L
WELD OVERLAY





Figure 2

STANDARD OVERLAY DESIGN
HATCH, UNIT 2
RECIRCULATION RISER INDICATIONS

PATENT APPLIED FOR





$$L \text{ MINIMUM} = 1.5" + C$$

C = WELD CROWN WIDTH

Figure 3
 MINI-OVERLAY DESIGN
 HATCH, UNIT 2
 RECIRCULATION RISER INDICATIONS

Hatch 2 1983 ISI Thru-Wall Estimates

12" RC

Estimates from	0% to 10%	3
"	" 11% to 20%	8
"	" 21% to 30%	11
"	" 30% to 40% (32%)	1

Therefore, estimates from 0% to 30% 22
and " " 31% to 40% 1

Large Diameter Piping (22"+28" RC and 20"+24" RHR)

Estimates from	0% to 10%	3
"	" 11% to 20%	19
"	" 21% to 30%	1
"	" 31% to 40%	2 (End Cap Weld)
"	" 41% to 50% 42%	1 (End Cap Weld)

3%
4%
overlaid
overlaid

Therefore, estimates from 0% to ~~30%~~^{23%} 13
and " " 31% to 50% 3

HATCH UNIT 2
 Pipe Crack Meeting
 July 7, 1982
 List of Attendees

<u>Name</u>	<u>Affiliation</u>
P. K. Nagata	INEL
G. Rivenbark	NRC-DL
J. M. Agold	SCS ISI Group
J. Mark Davis	SCS ISI Group
R. K. Godby	GPCO Engineering
C. T. Jones	GPCO Hatch
J.A. Edwards	Georgia Power Co.
P. C. Riccardella	Structural Integrity Assoc.
D. W. Fouts	Bechtel Power Co.
W. S. Hazelton	NRC/DE/MTEB
W. V. Johnston	NRC/DE
B. A. Kiaw	NRC/DE/MTEB
J. E. Charnley	NUTECH
L. J. Sobon	NUTECH
David Pitlairn	NUTECH
Donald P. Hill	Battelle-Columbus Labs.
C. Y. Cheng	NRC/DE/MTEB
W. Koo	NRC/DE/MTEB
Thomas P. Goeneveld	Battelle-Columbus Labs.
P. R. Matthews	NRC/NRR/DST
F. Schroeder	NRC/NRR/DST
E. G. Case	NRC/NRR/Dep. Dir.
D. B. Vassallo	NRC/NRR/DL
A. R. Herdt	NRC-Region II
G. C. Lainas	NRC/DL
H. Denton	NRC
R. Vollmer	NRC/DE
B. Epps	Southern Co. Ser.
G. Head	Georgia Power Co.
L. Gucwa	Georgia Power Co.