



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

May 12, 1983

Mr. J.M. Allan
Acting Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-065/01P-0
ER 100450 FILE 841-23
PLA-1661

Docket No. 50-387
License No. NPF-14

Dear Mr. Allan:

This transmission confirms the verbal report of May 12, 1983, by F.T. Eisenhuth to G.G. Rhoads of your staff concerning the failure to provide continuous iodine and particulate sampling of gaseous releases for a period of approximately 5 hours on May 11-12, 1983, as required by Action Statement 112 of Technical Specification 3.3.7.11. The situation of the Reactor Building, Turbine Building and Standby Gas Treatment system sample flow rate monitors being out of service appears to have occurred when the units were switched to their alternate power supply in preparation for a Loss of Offsite Power test on the Standby Gas Treatment System. Monitoring was restored at approximately 0230 on May 12, 1983, when an operator on rounds noted that the vacuum pumps were not functioning and restarted them.

This condition is considered reportable in accordance with Technical Specification 6.9.1.8.b.

H.W. Keiser
Superintendent of Plant-Susquehanna

LAK/pjg

cc: Director, Office of Inspection & Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director, Office of Management & Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

8306010313 830512
PDR ADOCK 05000387
S PDR

IE291/0