



Portland General Electric Company

Donald J. Broehl Assistant Vice President

July 12, 1983

Trojan Nuclear Plant
Docket 50-344
License NPF-1

Mr. Darrell G. Risenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington DC 20555

Dear Sir:

TROJAN NUCLEAR PLANT
NUREG-0737, Item II.D.1

The purpose of this letter is to transmit five copies of Topical Report PGE-1039, "Seismic and Dynamic Qualification of the Pressurizer Relief System". This topical report addresses the Plant-specific portions of the industry-wide effort to qualify reactor coolant system relief and safety valves under expected operating conditions for design basis transients and accidents. Topical Report PGE-1039 documents the following:

- (1) Applicability of the EPRI Safety and Relief Valve Test Program to Trojan pressurizer relief system valves,
- (2) Dynamic qualification of the Trojan safety, relief, and block valves based upon the EPRI test program,
- (3) Dynamic qualification of the modified Trojan pressurizer relief system piping and supports based upon preliminary plant-specific analysis, and
- (4) Seismic qualification of the Trojan modified pressurizer relief system piping and valves based upon preliminary analyses.

8307190219 830712
PDR ADOCK 05000344
P PDR

A046
1/5

Portland General Electric Company

Darrell G. Eisenhut

July 12, 1983

Page 2

An as-built evaluation of the modified Trojan pressurizer relief system is currently being pursued to verify the results presented in Topical Report PGE-1039. Barring any unexpected results from this evaluation, PGE considers all licensee submittal requirements pertaining to NUREG-0737 Item II.D.1 completed and this TMI action item closed.

Sincerely,



Attachment

c: Mr. Lynn Frank, Director (1)
State of Oregon
Department of Energy