

APPENDIX A

NOTICE OF VIOLATION

Duquesne Light Company  
Beaver Valley Power Station, Unit 2

Docket No. 50-412  
License NO. CPPR-105

As a result of the inspection conducted on April 11-29, 1983, and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C), the following violation was identified:

10 CFR 50, Part 50, Appendix B, Criteria XII, Control of Measuring and Test Equipment requires that measuring devices be controlled and calibrated at specified periods.

The PSAR, Section 17, Paragraph 17.1.1A states that the quality assurance program has been written to conform to 10 CFR 50, Appendix B, "QA Criteria for Nuclear Power Plants".

FCP 501, Paragraph 5.2.3 requires that Measuring and Test Equipment shall not be used when the calibration due date has expired.

Contrary to the above, on April 28, 1983, the inspector observed a torque calibration device to be in use for calibration of a torque wrench even though the calibration due date of the torque tester was April 22, 1983.

This is a Severity Level V violation (Supplement II).

Pursuant to the provisions of 10 CFR 2.201, Duquesne Light Company is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

OFFICIAL RECORD COPY

8307210215 830706  
PDR ADDCK 05000412  
Q PDR