

July 12, 1983

Mr. J.M. Allan Acting Regional Administrator, Region I U.S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION LICENSEE EVENT REPORT 83-093/01T-0 ER 100450 FILE 841-23 PLA-1744

Docket No. 50-387 License No. NPF-14

Dear Mr. Allan:

This transmission confirms the telephone report of July 12, 1983, by A. Piemontese to J. McCann of your staff, regarding surveillance testing of Containment Radiation Monitors. The "B" monitor was out of service and the surveillance test period was exceeded for the "A" monitor. The "A" monitor was in service, when required, during this period and was successfully tested upon discovery of the overdue test.

This condition is considered reportable in accordance with Technical Specification 6.9.1.8.b, and additional information regarding circumstances of the incident and corrective actions to be taken will be provided in the fourteen day follow-up report.

H.W. Keiser

Superintendent of Plant-Susquehanna

Cero

APP/pjg

cc: G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

Document Control Desk U.S. Nuclear Regulatory Commission Washington, DC 20555

8307220312 830712 PDR ADDCK 05000387 S PDR

IE29 1/0