



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

July 8, 1983

JAMES P. MCGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-051/0 - PGCC
Fire Protection Systems
Removed From Service
AECM-83/0378

Beginning on May 26, 1983, PGCC Halon fire protection systems were removed from service as needed to correct differences between the design documents and the as-built configuration. An LCO was entered in accordance with Technical Specification 3.7.6.4.

All identified differences and the corrective actions will be identified on Material Non-Conformance Report 423-83. All hardware modifications have been completed and retested satisfactorily. The LCO will be lifted when the work package is closed. This is submitted as a Special Report as the LCO time limit of 14 (fourteen) days was exceeded.

Yours truly,

J.P. McGaughy
for J. P. McGaughy

JPM:sap

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555
Member Middle South Utilities System

8307220482 830708
PDR ADOCK 05000414
PDR
S

ORIGINAL COPY

IE22
1/0

USNRC REGION II
ATLANTA, GEORGIA
JUL 18 1983
P1:28