

WEC PROPRIETARY CLASS 3

Westinghouse Energy Systems



9105210328 910514
PDR ADOCK 05000309
P PDR

ANALYSIS OF THE MAINE YANKEE REACTOR
VESSEL SECOND WALL CAPSULE
LOCATED AT 253°

E. Terek
S. L. Anderson
L. Albertin

March 1991

Work Performed Under Shop Order YARP-106

Prepared by Westinghouse Electric Corporation
for the Maine Yankee Atomic Power Company

Approved by:

T. A. Meyer

T. A. Meyer, Manager
Structural Reliability and
Plant Life Optimization

WESTINGHOUSE ELECTRIC CORPORATION
Nuclear and Advanced Technology Division
P.O. Box 355
Pittsburgh, Pennsylvania 15230-0355

PREFACE

This report has been technically reviewed and verified.

Reviewer

Sections 1 through 5, 7 and 8
Section 6

J. M. Chicots

E. P. Lippincott

J. M. Chicots
E. P. Lippincott

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
1.0	SUMMARY OF RESULTS	1-1
2.0	INTRODUCTION	2-1
3.0	BACKGROUND	3-1
4.0	DESCRIPTION OF PROGRAM	4-1
5.0	TESTING OF THE SPECIMENS FROM THE WALL CAPSULE LOCATED AT 253°	5-1
	5.1 Overview	5-1
	5.2 Charpy V-Notch Impact Test Results	5-4
	5.3 Tension Test Results	5-6
	5.4 Hardness Test Results	5-7
	5.5 Chemical Analysis Results	5-7
6.0	RADIATION ANALYSIS AND NEUTRON DOSIMETRY	6-1
	6.1 Introduction	6-1
	6.2 Discrete Ordinates Analysis	6-2
	6.3 Neutron Dosimetry	6-8
7.0	SURVEILLANCE CAPSULE REMOVAL SCHEDULE	7-1
8.0	REFERENCES	8-1
	APPENDIX A - LOAD-TIME RECORDS FOR CHARPY SPECIMEN TESTS	
	APPENDIX B - EQUIPMENT CALIBRATION DATA	

LIST OF ILLUSTRATIONS

<u>Figure</u>	<u>Title</u>	<u>Page</u>
4-1	Typical Surveillance Capsule Assembly	4-5
4-2	Typical Locations of Maine Yankee Surveillance Capsule Assemblies	4-6
4-3	Typical Tensile - Monitor Compartment Assembly	4-7
4-4	Typical Charpy Impact Compartment Assembly	4-8
5-1	Appearance of the Thermal Monitors in the Various Quartz Tubes. Melting Occurred in the One Inch Long Tubes (536°F)	5-21
5-2	Charpy V-Notch Impact Properties for the Maine Yankee Reactor Vessel Intermediate Shell Plate D-8406-1 (Longitudinal Orientation)	5-22
5-3	Charpy V-Notch Impact Properties for Maine Yankee Reactor Vessel Weld Metal	5-23
5-4	Charpy V-Notch Impact Properties for Maine Yankee Reactor Weld Heat Affected Zone Metal	5-24
5-5	Charpy V-notch Impact Properties for Maine Yankee Standard Reference Material (HSST, Plate 01)	5-25
5-6	Charpy Impact Specimen Fracture Surfaces for the Maine Yankee Reactor Vessel Intermediate Shell Plate D-8406-1 (Longitudinal Orientation)	5-26

LIST OF ILLUSTRATIONS

<u>Figure</u>	<u>Title</u>	<u>Page</u>
5-7	Charpy Impact Specimen Fracture Surfaces for Maine Yankee Reactor Vessel Weld Metal	5-27
5-8	Charpy Impact Specimen Fracture Surfaces for Maine Yankee Reactor Vessel Weld Heat Affected Zone HAZ Metal	5-28
5-9	Charpy Impact Specimen Fracture Surfaces for Maine Yankee Standard Reference Material (HSST, Plate 01)	5-29
5-10	Measured 30 ft-lb Transition Temp. Shift vs. Fluence	5-30
5-11	Measured Upper Shelf Energy Decrease vs. Fluence	5-31
5-12	Measured Upper Shelf Energy Percent Decrease vs. Fluence	5-32
5-13	Tensile Properties for Maine Yankee Reactor Vessel Intermediate Shell Plate D-8406-1 (Longitudinal Orientation)	5-33
5-14	Tensile Properties for Maine Yankee Reactor Vessel Weld Metal	5-34
5-15	Tensile Properties for Maine Yankee Reactor Vessel Weld Heat Affected Zone (HAZ) Metal	5-35
5-16	Fractured Tensile Specimens from Maine Yankee Reactor Vessel Intermediate Shell Plate D-8406-1 (Longitudinal Orientation)	5-36

LIST OF ILLUSTRATIONS

<u>Figure</u>	<u>Title</u>	<u>Page</u>
5-17	Fractured Tensile Specimens from Maine Yankee Reactor Vessel Weld Metal	5-37
5-18	Fractured Tensile Specimens from the Maine Yankee Reactor Vessel Weld Heat Affected Zone (HAZ) Metal	5-38
5-19	Engineering Stress-Strain Curves for the Maine Yankee Reactor Vessel Intermediate Shell Plate D-8406-1 Tension Specimens 1L4 and 1KM	5-39
5-20	Engineering Stress-Strain Curves for the Maine Yankee Reactor Vessel Intermediate Shell Plate D-8406-1 Tension Specimen 1JL and Weld Metal Tension Specimen 3JM	5-40
5-21	Engineering Stress-Strain Curves for the Maine Yankee Reactor Vessel Weld Metal Tension Specimens 3J7 and 3L4	5-41
5-22	Engineering Stress-Strain Curves for the Maine Yankee Reactor Vessel Weld Heat Affected Zone (HAZ) Metal Tension Specimens 4L2 and 4KK	5-42
5-23	Engineering Stress-Strain Curve for the Maine Yankee Reactor Vessel Weld Heat Affected Zone (HAZ) Metal Tension Specimen 4K1	5-43
6-1	Plan View of a Wall Surveillance Capsule	6-13

LIST OF TABLES (Cont)

<u>Table</u>	<u>Title</u>	<u>Page</u>
4-1	Chemical Composition of the Unirradiated Maine Yankee Reactor Vessel Beltline Test Materials	4-4
5-1	Charpy V-Notch Impact Data for the Maine Yankee Reactor Vessel Intermediate Shell Plate D-8406-1 Irradiated at 550°F, Fluence 1.25×10^{19} n/cm ² (E > 1.0 MeV)	5-8
5-2	Charpy V-Notch Impact Data for the Maine Yankee Reactor Vessel Weld Metal and HAZ Metal Irradiated at 550°F, Fluence 1.25×10^{19} n/cm ² (E > 1.0 MeV)	5-9
5-3	Charpy V-Notch Impact Data for the Maine Yankee Standard Reference Material (HSST-Plate 01) Irradiated at 550°F, Fluence 1.25×10^{19} n/cm ² (E > 1.0 MeV)	5-10
5-4	Instrumented Charpy Impact Test Results for the Maine Yankee Intermediate Shell Plate D-8406-1 Irradiated at 550°F, Fluence 1.25×10^{19} n/cm ² (E > 1.0 MeV)	5-11
5-5	Instrumented Charpy Impact Test Results for the Maine Yankee Weld Metal and HAZ Metal Irradiated at 550°F, Fluence 1.25×10^{19} n/cm ² (E > 1.0 MeV)	5-12
5-6	Instrumented Charpy Impact Test Results for the Maine Yankee Standard Reference Material (HSST - Plate 01) Irradiated at 550°F, Fluence 1.25×10^{19} n/cm ² (E > 1.0 MeV)	5-13
5-7	Effect of 550°F Irradiation to 1.25×10^{19} n/cm ² (E > 1.0 MeV) on Notch Toughness Properties of the Maine Yankee Reactor Vessel Surveillance Materials	5-14

LIST OF TABLES (Cont)

<u>Table</u>	<u>Title</u>	<u>Page</u>
5-8	Maine Yankee Surveillance Material 30 ft-lb Transition Temperature Shifts and Upper Shelf Energy Decreases	5-15
5-9	Tensile Properties for Maine Yankee Reactor Vessel Surveillance and Reference Material Irradiated at 550°F to 1.25×10^{19} n/cm ² (E > 1.0 MeV)	5-16
5-10	Room Temperature Rockwell B Hardness Values for the Maine Yankee Base Metal, Weld Metal and Reference Material Irradiated at 550°F, Fluence 1.25×10^{19} n/cm ² (E > 1.0 MeV)	5-17
5-11	Chemical Composition of the Four Maine Yankee Charpy Specimens Contained in the Surveillance Capsule Located at 253°	5-18
5-12	Chemistry Results from the NBS Certified Reference Standards	5-19
6-1	Calculated Fast Neutron Exposure Parameters at the Center of Capsule W-253	6-14
6-2	Calculated Fast Neutron Exposure Parameters at the Pressure Vessel Clad/Base Metal Interface	6-15
6-3	Relative Radial Distributions of Neutron Flux (E > 1.0 MeV) within the Pressure Vessel Wall	6-16

LIST OF TABLES (Cont)

<u>Table</u>	<u>Title</u>	<u>Page</u>
6-4	Relative Radial Distributions of Neutron Flux ($E > 0.1$ MeV) within the Pressure Vessel Wall	6-17
6-5	Relative Radial Distributions of Iron Atom Displacement Rate (dpa/sec) within the Pressure Vessel Wall	6-18
6-6	Nuclear Parameters for Neutron Flux Monitors	6-19
6-7	Irradiation History of Neutron Sensors Contained in Capsule W-253	6-20
6-8	Measured Sensor Activities and Reactions Rates	6-28
6-9	Summary of Neutron Dosimetry Results	6-30
6-10	Comparison of Measured and Ferret Calculated Reaction Rates at the Surveillance Capsule Center	6-31
6-11	Adjusted Neutron Energy Spectrum at the Surveillance Capsule Center	6-32
6-12	Comparison of Calculated and Measured Exposure Levels for Capsule W-253	6-33

LIST OF TABLES (Cont)

<u>Table</u>	<u>Title</u>	<u>Page</u>
6-13	Neutron Exposure Projections at Key Locations on the Pressure Vessel Clad/Base Metal Interface for Maine Yankee	6-34
6-14	Updated Lead Factors for Maine Yankee Wall Surveillance Capsules	6-35

SECTION 1.0
SUMMARY OF RESULTS

The analysis of the reactor vessel materials contained in the surveillance capsule located at 253°, the second wall capsule to be removed from the Maine Yankee reactor pressure vessel, led to the following conclusions:

- o The capsule received an average fast neutron fluence ($E > 1.0$ MeV) of 1.25×10^{19} n/cm² after 11.7 EFPY of plant operation.
- o Irradiation of the reactor vessel intermediate shell plate D-8406-1 Charpy specimens to 1.25×10^{19} n/cm² ($E > 1.0$ MeV) at 550°F resulted in a 30 and 50 ft-lb transition temperature increase of 120 and 150°F, respectively, for specimens oriented parallel to the major working direction (longitudinal orientation).
- o The weld metal Charpy specimens irradiated to 1.25×10^{19} n/cm² ($E > 1.0$ MeV) at 550°F resulted in a 30 and 50 ft-lb transition temperature increase of 260°F. This results in a 30 ft-lb transition temperature of 230°F and a 50 ft-lb transition temperature of 270°F for the weld metal.
- o Irradiation of the reactor vessel weld Heat Affected Zone (HAZ) metal Charpy specimens to 1.25×10^{19} n/cm² ($E > 1.0$ MeV) at 550°F resulted in a 30 ft-lb transition temperature increase of 90°F and a 50 ft-lb transition temperature increase of 110°F.
- o Irradiation of the reactor vessel Standard Reference Material (HSST, Plate 01) Charpy specimens to 1.25×10^{19} n/cm² ($E > 1.0$ MeV) at 550°F resulted in a 30 ft-lb transition temperature increase of 160°F and a 50 ft-lb transition temperature increase of 180°F for specimens oriented parallel to the major working direction (longitudinal orientation).

- o The average upper shelf energy of intermediate shell plate D-8406-1 showed a decrease of 35 ft-lbs after irradiation to 1.25×10^{19} n/cm² (E > 1.0 MeV) at 550°F for specimens oriented parallel to the major working direction (longitudinal orientation).
- o The average upper shelf energy of the weld metal showed a decrease of 39 ft-lbs after irradiation to 1.25×10^{19} n/cm² (E > 1.0 MeV) at 550°F.
- o The calculated end-of-life (32 EFPY) maximum neutron fluence (E > 1.0 MeV) for the Maine Yankee reactor vessel clad/base metal interface is 2.22×10^{19} n/cm² assuming the cycle 8 core power distribution.
- o Based on an EOL (32 EFPY) clad/base metal interface fluence of 2.22×10^{19} n/cm² (E>1.0 MeV) and Regulatory Guide 1.99 Revision 2 the intermediate shell plate D-8406-1 and weld metal, contained in the Maine Yankee Reactor Vessel Surveillance Program, are expected to exhibit an USE of at least 50 ft-lbs of energy through EOL (32 EFPY).


SECTION 2.0 INTRODUCTION

This report presents the results of the examination of the capsule located at 253°, the second wall capsule to be removed from the Maine Yankee reactor vessel in the continuing surveillance program which monitors the effects of neutron irradiation on the Maine Yankee reactor pressure vessel materials under actual operating conditions.

The surveillance program for the Maine Yankee reactor pressure vessel materials was designed by Combustion Engineering, Inc to the requirements of ASTM 185-70. The design was advanced for its time and the program is comparable to the more recent program identified in ASTM E185-73. Per Maine Yankee a complete description of the surveillance program has been reported by Combustion Engineering, Inc in CENPD-37 "Summary Report on Manufacture of Test Specimens and Assembly of Capsules for Irradiation Surveillance of Maine Yankee Reactor Vessel Materials".

Westinghouse Power Systems personnel were contracted to aid in the preparation of procedures for removing the capsule located at 253° from the reactor and its shipment to the Westinghouse Science and Technology Center Metallographic Hot Cell Facility where the postirradiation mechanical testing of the Charpy V-notch impact and tensile surveillance specimens was performed.

This report summarizes the testing of and the postirradiation data obtained from the second wall surveillance capsule to be removed from the Maine Yankee reactor vessel and discusses the analysis of these data. The data are compared to the results of tests performed on unirradiated and irradiated material from the other surveillance capsules removed for the reactor vessel. [1,2,3,4,5]



SECTION 3.0 BACKGROUND

The ability of the large steel pressure vessel containing the reactor core and its primary coolant to resist fracture constitutes an important factor in ensuring safety in the nuclear industry. The beltline region of the reactor pressure vessel is the most critical region of the vessel because it is subjected to significant fast neutron bombardment. The overall effects of fast neutron irradiation on the mechanical properties of low alloy, ferritic pressure vessel steels such as SA533 Grade B Class 1 (base material of the Maine Yankee reactor pressure vessel beltline) are well documented in the literature. Generally, low alloy ferritic materials show an increase in hardness and tensile properties and a decrease in ductility and toughness under certain conditions of irradiation.

The method, recommended by 10CFR50 Appendix G^[6], for performing analyses to guard against fast fracture in reactor pressure vessels is presented in "Protection Against Nonductile Failure," Appendix G to Section III of the ASME Boiler and Pressure Vessel Code.^[8] The method uses fracture mechanics concepts and is based on the reference nil-ductility temperature (RT_{NDT}).

The initial RT_{NDT} of the vessel material was established as follows:

- 1) Determine a temperature T_{NDT} that is at or above the nil-ductility transition temperature by drop weight tests.
- 2) At a temperature not greater than $T_{NDT} + 60^{\circ}\text{F}$, each specimen of the C_V test shall exhibit at least 35 mils lateral expansion and not less than 50 ft-lb absorbed energy. When these requirements are met, T_{NDT} is the reference temperature RT_{NDT} .
- 3) If the requirements of (2) above are not met, conduct additional C_V tests in groups of three specimens to determine the temperature T_{C_V} at which they are met. In this case the reference temperature $RT_{NDT} = T_{C_V} - 60^{\circ}\text{F}$. Thus, the reference temperature RT_{NDT} is the higher of T_{NDT} and $(T_{C_V} - 60^{\circ}\text{F})$.

- 4) If the C_V test has not been performed at $T_{NDT} + 60^\circ F$, or when the C_V test at $T_{NDT} + 60^\circ F$ does not exhibit a minimum of 50 ft-lb and 35 mils lateral expansion, a temperature representing a minimum of 50 ft-lb and 35 mils lateral expansion may be obtained from a full C_V impact curve developed from the minimum data points of all the C_V tests performed.

The RT_{NDT} of a given material is used to index that material to a reference stress intensity factor curve (K_{IR} curve) which appears in Appendix G of the ASME Code. The K_{IR} curve is a lower bound of dynamic, crack arrest, and static fracture toughness results obtained from several heats of pressure vessel steel. When a given material is indexed to the K_{IR} curve, allowable stress intensity factors can be obtained for this material as a function of temperature. Allowable operating limits can then be determined using these allowable stress intensity factors.

RT_{NDT} and, in turn, the operating limits of nuclear power plants can be adjusted to account for the effects of radiation on the reactor vessel material properties. The radiation embrittlement changes in mechanical properties of a given reactor pressure vessel steel can be monitored by a reactor vessel surveillance program such as the Maine Yankee Reactor Vessel Radiation Surveillance Program, in which a surveillance capsule is periodically removed from the operating nuclear reactor and the encapsulated specimens are tested. The increase in the average Charpy V-notch 30 ft-lb temperature (ΔRT_{NDT}) due to irradiation is added to the original RT_{NDT} to adjust the RT_{NDT} for radiation embrittlement. This adjusted RT_{NDT} (RT_{NDT} initial + ΔRT_{NDT}) is used to index the material to the K_{IR} curve and, in turn, to set operating limits for the nuclear power plant which take into account the effects of irradiation on the reactor vessel materials.

SECTION 4.0 DESCRIPTION OF PROGRAM

Eight surveillance capsules for monitoring the effects of neutron radiation exposure on the Maine Yankee reactor pressure vessel core region material were inserted in the reactor vessel prior to initial plant start-up. A typical surveillance capsule assembly is shown in Figure 4-1. The eight irradiation capsule assemblies are located at radial positions about the core, with their axial positions bisected by the midplane of the core. The capsule assemblies are contained in capsule holders positioned circumferentially about the core at locations which include regions of maximum flux as shown in Figure 4-2. The two accelerated capsule assemblies were located near the outside wall of the core support barrel and so obtain the maximum vessel fluence in 1 or 2 years. The six initial vessel wall capsule assemblies were located near the inside wall of the reactor vessel.

Per Reference 39, a replacement wall capsule was installed in the vacated location at 263" during the Cycle 12 refueling outage. The replacement capsule was fabricated by Combustion Engineering (CE) and is similar in design to the surveillance capsule removed from that location. This replacement capsule had some minor design changes to facilitate installation. The contents of the capsule included:

CE supplied dosimeters similar to the original design except the Sulfur dosimeter was replaced by Neptunium 237 encapsulated in Vanadium.

Hanford Engineering Development Laboratory (HEDL) dosimeter sets.

Maine Yankee surveillance weld Charpy specimens.

The second wall capsule located at 253°F was removed after 11.7 effective full power years of plant operation. This capsule contained Charpy V-notch and tensile specimens from intermediate shell plate D-8406-1, weld metal and weld heat-affected zone (HAZ) material. This capsule also contained Charpy specimens made from standard reference material (SRM) HSST Plate 01.

The chemical composition of the Maine Yankee beltline materials is presented in Table 4-1^[1]. The chemical analysis reported in Table 4-1 was obtained from unirradiated material used in the beltline region of the Maine Yankee Reactor Vessel.

The Maine Yankee reactor vessel was fabricated from 9-11/16-inch thick steel plate to ASME specification SA533 Grade B, with Class 1 mechanical properties. The Maine Yankee surveillance materials are made from the same material. The steel plates were purchased from Lukens Steel Company, and the heat treatment of the plates was as follows:

Austenitized: 1550° - 1650°F for 4 hours and water-quenched
Tempered: 1225°±25°F for 4 hours and air-cooled
Stress Relieved: 1150°±25°F for 40 hours and furnace-cooled to 600°
(plate & welds)

Because the lower and intermediate shell courses of the reactor vessel experience the highest fluences in the entire vessel, selection of candidate materials was restricted to the six plates used to fabricate the reactor beltline region. Plate D-8406-1, exhibiting the highest NDT as determined by the drop weight test, was selected as the source for the base and HAZ metal surveillance materials.

Weld metal test material was fabricated by submerged arc-welding lower shell plates D-8407-1 and D-8407-3. Weld HAZ test material was fabricated by welding together intermediate shell plates D-8406-1 and D-8406-2.

All test specimens were machined from the 1/4 thickness location of the base metal plate. Test specimens represent material taken at least one plate thickness from the quenched end. Longitudinal base metal specimens were oriented with the longitudinal axis of the specimen parallel to the major rolling direction of the plate whereas transverse base metal specimens were oriented with the longitudinal axis normal to the major rolling direction. Weld tension specimens were parallel to the weld direction. The axis of the notch of the Charpy specimens was machined perpendicular to the major surfaces of the plate.

The capsule contained fission threshold detectors (U-238) and threshold detectors of nickel (Ni), titanium (Ti), iron (Fe), sulfur (S), copper (Cu) with known cobalt (Co) content and Cobalt (Co) to monitor the thermal neutron exposure. The flux monitors were located in the three tensile-monitor assemblies as shown in Figure 4-3.

Thermal monitors made from low-melting eutectic alloys sealed in quartz tubes were included in the capsule and were located in the three tensile-monitor assemblies as shown in Figure 4-3. The composition of the alloys and their melting points are as follows:

<u>Chemical Composition</u>	<u>Melting Temperature</u>	
	<u>(°C)</u>	<u>(°F)</u>
80% Au, 20% Sn	280	536
90% Pb, 5% Sn, 5% Ag	292	558
97.5% Pb, 2.5% Ag	304	580
97.5% Pb, 0.75% Sn, 1.75% Ag	310	590

Contained in Figure 4-4 is a typical Charpy impact compartment assembly.

TABLE 4-1

Chemical Composition of the Unirradiated Maine Yankee
Reactor Vessel Beltline Test Materials *

Matl	Code Numbers and Type							
	D8406-2 Plate	D8407-1 Plate	D8407-2 Plate	D8407-3 Plate	D8406-1 Plate	D8406-3 Plate	D8406-1/ D8406-2 Weld	D8407-1/ D8407-3 Weld
Si	21	23	24	24	22	24	19	22
S	015	011	010	010	013	013	010	012
P	009	008	007	007	013	010	014	015
Mn	1.29	1.40	1.38	1.38	1.27	1.38	1.08	1.38
C	23	25	25	24	22	24	13	14
Cr	10	11	11	13	11	06	07	07
Ni	56	62	62	65	59	62	16	78
Mo	57	59	57	60	57	57	55	55
B	0008	0003	0003	0003	0004	0004	0002	0002
Cb	< 01	< 01	< 01	< 01	< 01	< 01	< 01	< 01
V	001	002	002	002	< 001	< 001	003	003
Co	011	012	012	012	010	012	005	013
N	007	007	007	007	006	008	006	012
Cu	17	24	23	13	15	12	27	36
Al	027	020	017	023	021	022	001	004
Ti	< 01	< 01	< 01	< 01	< 01	< 01	< 01	< 01
W	01	01	01	01	01	01	01	01
As	< 01	< 01	< 01	< 01	01	01	01	01
Sn	003	008	006	001	009	007	003	001
Zr	002	002	002	002	001	001	001	002

* Chemical Composition as Reported in Reference 1.




Figure 4-1. Typical Surveillance Capsule Assembly




Figure 4-2. Typical Locations of Maine Yankee Surveillance Capsule Assemblies




Figure 4-3. Typical Tensile - Monitor Compartment Assembly




Figure 4-4. Typical Charpy Impact Compartment Assembly

SECTION 5.0
TESTING OF SPECIMENS FROM THE WALL CAPSULE LOCATED AT 253°

5.1 Overview

The post-irradiation mechanical testing of the Charpy V-notch and tensile specimens, contained in the surveillance capsule removed from the 253° location, was performed at the Westinghouse Science and Technology Center Hot Cell Laboratory with consultation by Westinghouse Power Systems personnel. Maine Yankee personnel participated in choosing test temperatures for the testing of the Charpy specimens contained in the surveillance capsule. Testing was performed in accordance with 10CFR50, Appendices G and H^[6], ASTM Specification E185-82^[10] and Westinghouse Procedure MHL 8402, Revision 1 as modified by RMF Procedures 8102, Revision 1 and 8103, Revision 1.

Upon receipt of the capsule at the laboratory, the specimens and spacer blocks were carefully removed, inspected for identification number, and checked against the master list supplied by the Maine Yankee Atomic Power Co. No discrepancies were found.

The surveillance capsule had four low melting eutectic alloy thermal monitors which were removed from Blocks 3541, 3573, and 3514. The thermal monitors were encapsulated in quartz tubes of 1, 1.25, 1.50, and 1.75 inches long and had melting temperatures of 536°, 558°, 580° and 590°F, respectively. Examination of the thermal monitors in the various quartz tubes indicated melting of the material in the 1 inch tubes (536°F). Hence the maximum temperatures to which the test specimens were exposed was less than 558°F. Figure 5-1 shows the condition of the thermal monitors.

The Charpy impact tests were performed per ASTM Specification E23-88^[11] and RMF Procedure 8103, Revision 1 on a Tinius-Olsen Model 74, 358J machine. The tup (striker) of the Charpy machine is instrumented with an Effects Technology Model 500 instrumentation system. With this system, load-time and energy-time signals can be recorded in addition to the standard measurement of Charpy

energy (E_D). From the load-time curve, the load of general yielding (P_{GY}), the time to general yielding (t_{GY}), the maximum load (P_M), and the time to maximum load (t_M) can be determined. Under some test conditions, a sharp drop in load indicative of fast fracture was observed. The load at which fast fracture was initiated is identified as the fast fracture load (P_F), and the load at which fast fracture terminated is identified as the arrest load (P_A).

The energy at maximum load (E_M) was determined by comparing the energy-time record and the load-time record. The energy at maximum load is roughly equivalent to the energy required to initiate a crack in the specimen. Therefore, the propagation energy for the crack (E_p) is the difference between the total energy to fracture (E_D) and the energy at maximum load.

The yield stress (σ_Y) is calculated from the three-point bend formula having the following expression:

$$\sigma_Y = P_{GY} * [L / (B * (W-a)^2 * C)] \quad (1)$$

where the constant C is dependent on the notch flank angle (ϕ), notch root radius (ρ), and the type of loading (i.e., pure bending or three-point bending). In three-point bending a Charpy specimen in which $\phi = 45^\circ$ and $\rho = 0.010$ ", Equation 1 is valid with $C = 1.21$. Therefore (for $L = 4W$),

$$\sigma_Y = P_{GY} * [L / (B * (W-a)^2 * 1.21)] = [3.3 P_{GY} W] / [B (W-a)^2] \quad (2)$$

For the Charpy specimens, $B = 0.394$ in., $W = 0.394$ in., and $a = 0.079$ in. Equation 2 then reduces to:

$$\sigma_Y = 33.3 * P_{GY} \quad (3)$$

where σ_Y is in units of psi and P_{GY} is in units of lbs. The flow stress was calculated from the average of the yield and maximum loads, also using the three-point bend formula.

Percent shear was determined from post-fracture photographs using the ratio-of-areas methods in compliance with ASTM Specification A370-88^[12]. The lateral expansion was measured using a dial gage rig similar to that shown in the same specification.

Tension tests were performed on a 20,000-pound Instron, split-console test machine (Model 1115) per ASTM Specification E8-89b^[13] and E21-79(1988)^[14], and RMF Procedure 8102, Revision 1. All pull rods, grips, and pins were made of Inconel 718 hardened to HRC45. The upper pull rod was connected through a universal joint to improve axially of loading. The tests were conducted at a constant crosshead speed of 0.05 inches per minute throughout the test.

Extension measurements were made with a linear variable displacement transducer (LVDT) extensometer. The extensometer knife edges were spring-loaded to the specimen and operated through specimen failure. The extensometer gage length is 1.00 inch. The extensometer is rated as Class B-2 per ASTM E83-85^[15].

Elevated test temperatures were obtained with a three-zone electric resistance split-tube furnace with a 9-inch hot zone. All tests were conducted in air.

Because of the difficulty in remotely attaching a thermocouple directly to the specimen, the following procedure was used to monitor specimen temperature: Chromel-alumel thermocouples were inserted in shallow holes in the center and each end of the gage section of a dummy specimen and in each grip. In the test configuration, with a slight load on the specimen, a plot of specimen temperature versus upper and lower grip and controller temperatures was developed over the range of room temperature to 550°F (288°C). The upper grip was used to control the furnace temperature. During the actual testing, the grip temperatures were used to obtain desired specimen temperatures. Experiments indicated that this method is accurate to $\pm 2^\circ\text{F}$.

The yield load, ultimate load, fracture load, total elongation, and uniform elongation were determined directly from the load-extension curve. The yield strength, ultimate strength, and fracture strength were calculated using the original cross-sectional area. The final diameter and final gage length were determined from post-fracture photographs. The fracture area used to calculate the fracture stress (true stress at fracture) and percent reduction in area was computed using the final diameter measurement.

Rockwell B hardness values were obtained with a RAMS Rockford Hardness Tester Model No. 30-R.

5.2 Charpy V-Notch Impact Test Results

The results of Charpy V-notch impact tests performed on the various materials contained in the Maine Yankee wall capsule located at 253° irradiated at 550°F to 1.25×10^{19} n/cm² ($E > 1.0$ MeV) are presented in Tables 5-1 through 5-6 and are compared with unirradiated results^[1] as shown in Figures 5-2 through 5-5. The transition temperature increases and upper shelf energy decreases for the various materials contained in the Maine Yankee wall capsule located at 253° are summarized in Table 5-7.

Irradiation of the reactor vessel intermediate shell plate D-8406-1 Charpy specimens to 1.25×10^{19} n/cm² ($E > 1.0$ MeV) at 550F (Figure 5-2) resulted in a 30 ft-lb transition temperature increase of 120°F and a 50 ft-lb transition temperature increase of 150°F for specimens oriented parallel to the major working direction (longitudinal orientation). This results in a 30 ft-lb transition temperature of 120°F and a 50 ft-lb transition temperature of 175°F.

The average upper shelf energy (USE) of the intermediate shell plate D-8406-1 Charpy specimens (longitudinal orientation) resulted in a decrease of 35 ft-lbs after irradiation to 1.25×10^{19} n/cm² ($E > 1.0$ MeV) at 550°F. This results in an USE of 105 ft-lbs (Figure 5-2).

Irradiation of the reactor vessel core region weld metal Charpy specimens to 1.25×10^{19} n/cm² (E > 1.0 MeV) at 550°F (Figure 5-3) resulted in a 30 and 50 ft-lb transition temperature increase of 260°F. This resulted in a 30 ft-lb transition temperature of 230°F and a 50 ft-lb transition temperature of 270°F.

The average upper shelf energy (USE) of the reactor vessel core region weld metal resulted in a energy decrease of 39 ft-lbs after irradiation to 1.25×10^{19} n/cm² (E > 1.0 MeV) at 550°F. This resulted in an USE of 66 ft-lb (Figure 5-3).

Irradiation of the reactor vessel weld metal Heat-Affected Zone (HAZ) specimens to 1.25×10^{19} n/cm² (E > 1.0 MeV) at 550°F (Figure 5-4) resulted in a 30 ft-lb transition temperature increase of 90°F and a 50 ft-lb transition temperature increase of 110°F. This results in a 30 ft-lb transition temperature of 30°F and a 50 ft-lb transition temperature of 65°F

The average upper shelf energy (USE) of the reactor vessel HAZ metal resulted in an decrease of 37 ft-lbs after irradiation to 1.25×10^{19} n/cm² (E > 1.0 MeV) at 550°F. This resulted in an USE of 98 ft-lb (Figure 5-4).

Irradiation of the Standard Reference Material (SRM) HSST - Plate 01 to 1.25×10^{19} n/cm² (E > 1.0 MeV) at 550°F (Figure 5-5) resulted in a 30 ft-lb transition temperature increase of 160°F and a 50 ft-lb transition temperature increase of 180°F for specimens oriented parallel to the major working direction (longitudinal orientation). This results in a 30 ft-lb transition temperature of 175°F and a 50 ft-lb transition temperature of 220°F.

The average upper shelf energy (USE) of the Standard Reference Material (SRM) HSST - Plate 01 Charpy specimens (longitudinal orientation) resulted in a decrease of 34 ft-lbs after irradiation to 1.25×10^{19} n/cm² (E > 1.0 MeV) at 550°F. This results in an USE of 96 ft-lbs (Figure 5-5).

The fracture appearance of each irradiated Charpy specimen from the various materials is shown in Figures 5-6 through 5-9 and show an increasingly ductile or tougher appearance with increasing test temperature.

A comparison of the 30 ft-lb transition temperature increases and the upper shelf energy decreases for the various Maine Yankee surveillance materials with predicted increases using the methods of NRC Regulatory Guide 1.99, Revision 2^[7] is presented in Table 5-8. This comparison indicates that the 30 ft-lb transition temperature increases and USE decreases resulting from irradiation to 1.25×10^{19} n/cm² (E > 1.0 MeV) are in close agreement with Regulatory Guide 1.99, Revision 2 predictions.

Figure 5-10 is a plot of the measured 30 ft-lb transition temperature shift vs. fluence.

Figure 5-11 is a plot of the measured upper shelf energy decrease vs. fluence.

Figure 5-12 is a plot of the measured upper shelf energy percent decrease vs. fluence.

5.3 Tension Test Results

The results of tension tests performed on the reactor vessel intermediate shell plate D-8406-1 (longitudinal orientation), weld metal and weld HAZ metal irradiated to 1.25×10^{19} n/cm² (E > 1.0 MeV) at 550°F are shown in Table 5-9 and are compared with unirradiated results^[1] as shown in Figures 5-13, 5-14 and 5-15.

Irradiation of the reactor vessel intermediate shell plate B-8406-1 tensile specimens to 1.25×10^{19} n/cm² (E > 1.0 MeV) at 550°F (Figure 5-13) resulted in an increase of 15 to 20 ksi in 0.2 percent offset yield strength and an increase of 10 to 17 ksi in ultimate tensile strength for specimens oriented with the longitudinal axis parallel to the major working direction of the plate (longitudinal orientation)

Irradiation of the reactor vessel weld metal tensile specimens to 1.25×10^{19} n/cm² (E > 1.0 MeV) at 550°F (Figure 5-14) resulted in an increase of 27 to 36 ksi for the 0.2 percent offset yield strength and an increase of 22 to 28 ksi for the ultimate tensile strength.

Irradiation of the reactor vessel weld HAZ metal tensile specimens to 1.25×10^{19} n/cm² (E > 1.0 MeV) at 550°F (Figure 5-15) resulted in an increase of 14 to 18 ksi for the 0.2 percent offset yield strength and an increase of 11 to 18 ksi for the ultimate tensile strength.

The fractured tension specimens for the reactor vessel intermediate shell plate B-8406-1 tensile specimens are shown in Figure 5-16.

The fractured tension specimens for the weld metal are shown in Figure 5-17.

The fractured tension specimens for the weld HAZ metal are shown in Figure 5-18.

Engineering stress-strain curves for the tension specimens are shown in figures 5-19 through 5-23.

5.4 Hardness Test Results

The results of Rockwell B hardness tests are presented in Table 5-9.

5.5 Chemical Analysis Results

A chemical analysis using Inductively Coupled Plasma Spectrometry (ICPS) was performed on irradiated weld specimens 312 and 3A2 and SRM specimens 61D and 61E and is reported in Table 5-11. The chemistry results from the NBS certified reference standards are reported in Table 5-12.

TABLE 5-1
 CHARPY V-NOTCH IMPACT DATA FOR THE MAINE YANKEE
 REACTOR VESSEL INTERMEDIATE SHELL PLATE D-8406-1 IRRADIATED
 AT 550°F, FLUENCE 1.25×10^{19} n/cm² (E > 1.0 MeV)

<u>Sample No.</u>	<u>Temperature</u>		<u>Impact Energy</u>		<u>Lateral</u>	<u>Expansion</u>	<u>Shear</u>
	<u>(°F)</u>	<u>(°C)</u>	<u>(ft-lb)</u>	<u>(J)</u>	<u>(mils)</u>	<u>(mm)</u>	
	<u>Longitudinal Orientation</u>						
12T	25	(- 4)	7.0	(9.5)	7.0	(0.18)	5
13E	110	(43)	28.0	(38.0)	26.0	(0.66)	20
121	115	(46)	26.0	(35.5)	26.0	(0.66)	20
15M	125	(52)	27.0	(36.5)	26.0	(0.55)	20
124	135	(57)	42.0	(57.0)	36.0	(0.91)	30
12C	175	(79)	43.0	(58.5)	38.0	(0.97)	35
126	180	(82)	57.0	(77.5)	50.0	(1.27)	50
12M	185	(85)	57.0	(77.5)	49.0	(1.24)	50
12P	230	(110)	86.0	(116.5)	67.0	(1.70)	90
12D	250	(121)	99.0	(134.0)	78.0	(1.98)	100
12U	325	(163)	113.0	(153.0)	85.0	(2.16)	100
13K	400	(204)	104.0	(141.5)	86.0	(2.18)	100

TABLE 5-2
 CHARPY V-NOTCH IMPACT DATA FOR THE MAINE YANKEE REACTOR
 VESSEL WELD METAL AND HAZ METAL IRRADIATED AT
 550°F, FLUENCE 1.25×10^{19} n/cm² (E > 1.0 MeV)

<u>Sample No.</u>	<u>Temperature</u>		<u>Impact Energy</u>		<u>Lateral Expansion</u>		<u>Shear (%)</u>	
	<u>(°F)</u>	<u>(°C)</u>	<u>(ft-lb)</u>	<u>(J)</u>	<u>(mils)</u>	<u>(mm)</u>		
<u>Weld Metal</u>								
37K	0	(-18)	3.0	(4.0)	4.0	(0.10)	5	
31J	15	(- 9)	5.0	(7.0)	5.0	(0.13)	5	
32L	180	(82)	13.0	(17.5)	13.0	(0.33)	20	
32A	185	(85)	24.0	(32.5)	23.0	(0.58)	25	
35D	220	(104)	26.0	(35.5)	26.0	(0.66)	60	
32K	240	(116)	35.0	(47.5)	39.0	(0.99)	85	
3A2	255	(124)	42.0	(57.0)	38.0	(0.97)	90	
33M	260	(127)	50.0	(68.0)	44.0	(1.12)	95	
37J	300	(149)	52.0	(70.5)	51.0	(1.30)	95	
317	340	(171)	63.0	(85.5)	62.0	(1.57)	100	
36C	400	(204)	67.0	(91.0)	56.0	(1.42)	100	
312	425	(218)	68.0	(92.0)	59.0	(1.50)	100	
<u>HAZ Metal</u>								
47Y	- 30	(-34)	13.0	(17.5)	9.0	(0.23)	10	
43J	0	(-18)	27.0	(36.5)	22.0	(0.56)	25	
463	10	(-23)	BAD TEST (MACHINE MALFUNCTION)-					-
433	20	(- 7)	21.0	(28.5)	21.0	(0.53)	20	
47C	20	(- 7)	46.0	(62.5)	33.0	(0.84)	50	
47J	35	(2)	50.0	(68.0)	37.0	(0.94)	65	
47T	75	(24)	42.0	(57.0)	30.0	(0.76)	75	
43B	80	(27)	53.0	(72.0)	43.0	(1.09)	85	
46Y	100	(38)	71.0	(96.5)	55.0	(1.40)	95	
43K	125	(52)	108.0	(146.5)	80.0	(2.03)	100	
46U	205	(96)	94.0	(127.5)	69.0	(1.75)	100	
473	230	(110)	94.0	(127.5)	72.0	(1.83)	100	

TABLE 5-3
 CHARPY V-NOTCH IMPACT DATA FOR THE MAINE YANKEE STANDARD
 REFERENCE MATERIAL (HSST - PLATE 01) IRRADIATED AT
 550°F, FLUENCE 1.25×10^{19} n/cm² (E > 1.0 MeV)

<u>Sample No.</u>	<u>Temperature</u>		<u>Impact Energy</u>		<u>Lateral Expansion</u>		<u>Shear (%)</u>
	<u>(°F)</u>	<u>(°C)</u>	<u>(ft-lb)</u>	<u>(J)</u>	<u>(mils)</u>	<u>(mm)</u>	
61E	40	(4)	5.0	(7.0)	10.0	(0.25)	5
61A	115	(46)	17.0	(23.0)	16.0	(0.41)	15
61P	120	(49)	14.0	(19.0)	12.0	(0.30)	15
61C	155	(68)	18.0	(24.5)	16.0	(0.41)	20
61M	175	(79)	27.0	(36.5)	26.0	(0.66)	35
627	185	(85)	33.0	(44.5)	29.0	(0.74)	35
62A	210	(99)	38.0	(51.5)	35.0	(0.89)	45
61A	215	(102)	26.0	(35.5)	27.0	(0.69)	40
61D	230	(110)	72.0	(97.5)	57.0	(1.45)	95
61T	250	(121)	89.0	(120.5)	69.0	(1.75)	100
61U	300	(149)	93.0	(126.0)	76.0	(1.93)	100
61J	400	(204)	107.0	(145.5)	90.0	(2.29)	100

TABLE 5-4

INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR THE MAINE YANKEE INTERMEDIATE SHELL
 PLATE D-8406-1 IRRADIATED AT 550°F, FLUENCE 1.25×10^{19} n/cm² (E > 1.0 MeV)

Sample Number	Test Temp (°F)	Charpy Energy (ft-lb)	Normalized Energies			Yield Load (kips)	Time to Yield (μsec)	Maximum Load (kips)	Time to Maximum (μsec)	Fracture Load (kips)	Arrest Load (kips)	Yield Stress (ksi)	Flow Stress (ksi)
			Charpy Ed/A	Maximum Em/A	Prop Ep/A								
12T	25	7.0	56	32	24	1.55	200	3.15	245	3.15	0.30	61	83
13E	110	28.0	225	182	43	3.25	175	4.15	480	4.15	0.11	107	122
121	115	28.0	209	167	42	3.15	125	4.05	435	4.05	0.25	104	118
15M	126	27.0	217	166	52	3.55	135	4.80	400	4.50	0.35	117	134
124	135	42.0	338	208	132	3.05	95	4.20	480	4.05	0.40	101	130
12C	175	43.0	346	200	145	3.90	285	3.90	575	3.90	1.65	96	112
128	180	57.0	459	285	194	3.30	125	4.35	610	4.15	1.45	109	127
12M	185	57.0	459	333	126	3.60	145	4.80	590	4.75	1.75	120	140
12P	230	86.0	592	284	409	3.00	135	4.10	700	3.35	2.30	99	117
12D	250	99.0	797	237	580	3.00	135	4.35	505	--	--	99	115
12U	325	113.0	910	273	637	3.15	180	4.50	645	--	--	104	127
13K	400	104.0	837	243	595	2.45	95	3.70	630	--	--	81	102

Longitudinal Orientation (RW)

*Fully ductile fracture, no arrest load.

TABLE 5-5
 INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR THE MAINE YANKEE
 WELD METAL AND HAZ METAL IRRADIATED AT 550°F, FLUENCE 1.25×10^{19} n/cm² (E > 1.0 MeV)

Sample Number	Test Temp (°F)	Charpy Energy (ft-lb)	Normalized Energies		Yield Load (kips)	Time to Yield (usec)	Maximum Load (kips)	Time to Maximum (usec)	Fracture Load (kips)	Arrest Load (kips)	Yield Stress (ksi)	Flow Stress (ksi)
			Charpy Ed/A (ft-lb/in ²)	Maximum Prop Ep/A								
<u>Weld Metal</u>												
24 COMPUTER MALFUNCTION												
37K	0	3.0	40	17	3.40	25	4.50	30	4.50	0.07	113	131
31J	15	5.0	45	59	3.55	125	3.80	170	3.50	0.80	117	121
32L	180	13.0	193	28	4.05	125	4.75	370	4.75	0.75	134	145
32A	185	24.0	209	93	3.35	170	4.35	375	4.35	2.20	111	127
35D	220	26.0	282	100	3.80	230	3.80	395	3.80	3.80	93	109
32K	240	35.0	338	187	3.45	190	4.20	485	3.95	2.15	114	127
3A2	255	42.0	403	137	3.00	145	3.95	385	3.85	3.50	100	115
33M	280	50.0	419	170	2.85	210	3.90	510	3.80	3.25	94	112
37J	300	52.0	175	333	3.10	200	4.00	500	--	--	102	117
317	340	63.0	507	374	3.15	235	3.90	485	--	--	104	115
36G	400	67.0	540	165	3.60	135	4.55	450	--	--	119	135
312	425	68.0	548	202	3.60	135	4.55	450	--	--	119	135
<u>HAZ Metal</u>												
47Y	30	13.0	105	94	4.25	115	4.90	225	4.75	0.11	141	152
43J	0	27.0	217	183	4.60	165	5.20	405	5.15	1.05	153	162
463	10	BAD TEST MACHINE MALFUNCTION										
433	20	21.0	169	124	3.70	135	4.40	310	4.30	0.60	132	133
470	20	46.0	370	256	4.10	200	5.15	550	5.05	2.05	136	154
47J	35	50.0	403	223	3.35	155	4.25	545	4.25	2.35	112	126
47T	75	42.0	338	169	3.15	165	4.00	470	4.00	2.95	103	118
43B	80	53.0	427	245	3.55	270	4.80	640	4.50	2.85	117	135
46Y	100	71.0	572	301	3.80	180	5.00	610	4.55	3.50	126	146
43K	125	108.0	870	294	3.70	135	4.85	625	--	--	122	141
46U	205	94.0	757	276	2.85	145	4.00	695	--	--	94	113
473	230	94.0	757	283	3.00	135	4.70	630	--	--	100	127

*Fully ductile fracture, no arrest load.

TABLE 5-6

INSTRUMENTED CHARPY IMPACT TEST RESULTS FOR THE MAINE YANKEE STANDARD REFERENCE MATERIAL (HSST - PLATE 01) IRRADIATED AT 550°F, FLUENCE 1.25×10^{19} n/cm² (E > 1.0 MeV)

Sample Number	Test Temp (°F)	Charpy Energy (ft-lb)	Normalized Energies		Yield Load (kips)	Time to Yield (μsec)	Maximum Load (kips)	Time to Maximum (μsec)	Fracture Load (kips)	Arrest Load (kips)	Yield Stress (ksi)	Flow Stress (ksi)
			Charpy Ed/A	Maximum Em/A								
Longitudinal Orientation (RW)												
			Ed/A (ft-lb/in ²)	Prop Ep/A								
61E	40	5.0	40	10	2.55	105	4.05	145	4.05	0.01	84	102
61A	115	17.0	137	30	2.85	115	3.90	310	3.90	0.04	95	112
61P	120	14.0	113	30	COMPUTER MALFUNCTION	-	-	-	-	-	-	-
61C	155	18.0	145	77	3.30	145	3.70	235	3.60	0.08	109	116
61M	175	27.0	217	78	2.75	125	3.75	400	3.65	1.50	91	107
627	185	33.0	268	70	3.75	185	4.65	480	4.65	0.90	124	139
62A	210	38.0	306	102	2.85	155	4.00	560	3.90	1.55	93	113
61A	215	28.0	209	78	2.95	125	3.80	370	3.80	0.90	97	112
61D	230	72.0	580	306	3.30	190	4.70	830	4.25	3.40	109	132
61T	250	89.0	717	424	3.80	155	4.85	625	-*	-*	118	140
61U	300	93.0	749	458	3.55	155	4.85	625	-*	-*	117	139
61J	400	107.0	862	590	3.25	155	4.60	630	-*	-*	108	130

*Fully ductile fracture, no arrest load.

TABLE 5-7

EFFECT OF 550 °F IRRADIATION TO 1.25×10^{19} n/cm² (E > 1.0 MeV)

ON NOTCH TOUGHNESS PROPERTIES OF THE MAINE YANKEE REACTOR VESSEL SURVEILLANCE MATERIALS

Material	Average 30 ft-lb (2)		Average 35 mil (2)		Average 50 ft-lb (2)		Average Energy (1,2)		
	Unirradiated	Irradiated	Unirradiated	Irradiated	Unirradiated	Irradiated	Unirradiated	Irradiated	
	Temperature (°F)	Temperature (°F)	Temperature (°F)	Temperature (°F)	Temperature (°F)	Temperature (°F)	Absorption at	Full Shear (ft-lb) (3)	
	ΔT	ΔT	ΔT	ΔT	ΔT	ΔT		Δ (ft-lb)	
Plate DR406-1 (Longitudinal) Orientation)	0	120	10	150	140	150	140	105	35
	-30	230	-15	240	255	260	270	105	39
HAZ Metal	-60	30	-55	55	110	110	65	135	37
	15	175	25	200	175	180	220	130	34

(1) Unirradiated data presented here was taken from CR 75-269 Table 13 [1].

(2) The "AVERAGE" is defined as the value read from the curve fitted through the data points of the Charpy tests (Figures 5-2 through 5-5).

(3) Unirradiated values of average upper shelf energy presented here may not represent the average of data points with > 90% shear.

TABLE 5-8

MAINE YANKEE SURVEILLANCE MATERIAL 30 FT-LB TRANSITION
TEMPERATURE SHIFTS AND UPPER SHELF ENERGY DECREASES

Material	Capsule	Fluence 10^{19} n/cm ²	Measured 30 ft-lb	Measured Upper	
			Temperature Shift (°F)	Shelf Energy Decrease ⁽¹⁾ (ft-lb)	(%)
Plate D-8406-1 (Longitudinal Orientation)	W-263	0.572	97.0	113.0	15.0
	W-253	1.25	120.0	105.0	19.0
	A-25	1.79	120.0	96.0	31.0
	A-35	6.53	185.0	85.0	39.0
Plate D-8406-1 (Transverse) Orientation)	W-263	0.572	93.0	96.0	16.0
	W-253	1.25	---	---	--
	A-25	1.79	---	---	--
	A-35	6.53	195.0	71.0	38.0
Weld Metal	W-263	0.572	222.0	59.0	44.0
	W-253	1.25	260.0	66.0	37.0
	A-25	1.79	270.0	57.0	45.0
	A-35	6.53	345.0	50.0	53.0
HAZ Metal	W-263	0.572	91.0	103.0	22.0
	W-253	1.25	90.0	98.0	27.0
	A-25	1.79	85.0	103.0	23.0
	A-35	6.53	155.0	94.0	30.0
SRM (HSST - Plate 01) (Longitudinal Orientation)	W-263	0.572	---	---	--
	W-253	1.25	160.0	96.0	26.0
	A-25	1.79	150.0	100.0	23.0
	A-35	6.53	---	---	--

(1) The measured USE (% decrease) reported here for capsules A-25, A-35 and W-263 is from the capsule analysis reports [3,4,5]. The measured USE (% decrease) reported here for capsule W-253 is based on the data presented in Table 5-7.

TABLE 5-9
 TENSILE PROPERTIES FOR MAINE YANKEE REACTOR VESSEL SURVEILLANCE AND REFERENCE MATERIAL
 IRRADIATED AT 550°F TO 1.25×10^{19} n/cm² (E > 1.0 MeV)

<u>Material</u>	<u>Sample Number</u>	<u>Test Temp. (°F)</u>	<u>0.2% Yield Strength (ksi)</u>	<u>Ultimate Strength (ksi)</u>	<u>Fracture Load (kip)</u>	<u>Fracture Stress (ksi)</u>	<u>Fracture Strength (ksi)</u>	<u>Uniform Elongation (%)</u>	<u>Total Elongation (%)</u>	<u>Reduction in Area (%)</u>
Plate D-8408-1	1L4	74	80.5	101.4	3.30	183.3	67.2	13.5	26.1	63
	1KM	300	74.4	94.7	3.20	181.1	65.2	12.8	23.1	64
	1JL	580	68.8	93.7	3.35	200.9	68.2	10.5	21.3	66
Weld, Plates D-8408-1 and D-8407-3	3JM	74	107.0	115.1	4.00	152.2	81.5	12.7	24.8	46
	3J7	300	93.7	105.9	3.90	171.8	79.5	12.0	21.6	54
	3L4	580	87.6	105.9	4.20	174.6	85.6	10.5	17.9	51
HAZ, Plate D-8408-1	4L2	74	74.9	101.9	3.50	194.4	71.3	10.5	21.9	63
	4KK	300	73.3	95.7	3.20	181.1	65.2	9.8	19.5	64
	4K1	580	73.3	96.8	3.60	185.7	73.3	9.8	18.5	61

TABLE 5-10
 ROOM TEMPERATURE ROCKWELL B HARDNESS VALUES FOR THE MAINE
 YANKEE BASE METAL, WELD METAL AND REFERENCE MATERIAL
 IRRADIATED AT 550°F, FLUENCE 1.25×10^{19} n/cm² (E > 1.0 MeV)

<u>Specimen Identification</u>	<u>Rockwell B Hardness</u>			<u>Average</u>
(1) <u>Base Metal (Long.)</u>				
12D	96	97	96	96
13E	94	94	96	95
12P	96	97	96	96
12M	97	96	97	97
121	95	96	98	96
13K	95	97	96	96
12T	93	95	93	94
12C	94	96	96	95
124	92	96	96	95
12U	94	98	98	97
126	95	96	97	96
15M	95	97	97	96
(2) <u>Weld Metal</u>				
37K	100	104	100	101
32A	100	101	100	100
35D	99	99	99	99
31J	100	100	100	100
32L	100	100	100	100
37J	100	100	99	100
32K	100	101	100	100
312	100	100	100	100
33M	100	100	100	100
36C	100	100	100	100
317	94	101	101	99
3A2	99	100	100	100
(3) <u>Standard Reference Material</u>				
614	95	98	96	96
61P	95	98	98	97
61C	95	97	98	97
61A	87	97	97	94
61M	98	98	98	98
61E	96	97	98	97
61D	97	97	97	97
61J	93	97	97	96
627	96	98	97	97
62A	97	97	98	97
61U	92	95	97	95
61T	93	94	94	94

TABLE 5-11

Chemical Composition of Four Maine Yankee Charpy
Specimens contained in the Surveillance Capsule Located at 253*

Specimen No.	Chemical Composition (wt.%)			
	Standard Reference Metal		Weld Metal	
	61E	61D	3A2	312
Fe	MATRIX ELEMENT: Remainder by Difference			
Co	0.0086	0.0082	0.0169	0.0161
Cu	0.173	0.170	0.432	0.356
Cr	0.080	0.080	0.071	0.069
Mn	1.524	1.487	1.369	1.334
Mo	0.577	0.556	0.504	0.487
Ni	0.665	0.654	0.745	0.728
P	0.0112	0.0104	0.0174	0.0149
V	<0.005	<0.005	<0.005	<0.005
Al	0.0244	0.0232	<0.0035	0.0128
As	<0.0030	0.0066	0.0034	<0.0030
B	0.0084	0.0079	0.0070	0.0064
Nb	<0.007	<0.007	<0.007	<0.007
Sn	0.0154	0.0145	0.0072	0.0064
Ti	0.0051	0.0045	0.0046	0.0036
W	0.0062	0.0069	<0.00504	<0.0050
Zr	<0.019	<0.019	<0.019	<0.019
C	0.221	0.215	0.130	0.126
S	0.0174	0.0174	0.0068	0.0177
Si	0.198	0.077	0.218	0.192
N	0.0079	0.0071	0.0141	0.0086

Analyses	Method of Analysis
Metals	ICPS, Inductively Coupled Plasma Spectrometry
Carbon	EC-12, LECO Carbon Analyzer
Sulfur	Combustion/titration
Silicon	Dissolution/gravimetric
Nitrogen	LECO NITROX

TABLE 5-12
Chemistry Results from the NBS
Certified Reference Standards

Material ID	Low Alloy Steel: NBS Certified Reference Standards			
	NBS 361		NBS 362	
	Certified	Measured	Certified	Measured
=====				
<u>Metals</u>	<u>Concentration in Weight Percent</u>			
Fe	95.60	(matrix)	95.30	(matrix)
Co	0.032	0.0305	0.30	0.3205
Cu	0.042	0.041	0.50	0.506
Cr	0.694	0.692	0.30	0.302
Mn	0.66	0.656	1.04	1.046
Mo	0.19	0.192	0.068	0.065
Ni	2.00	1.992	0.59	0.577
P	0.014	0.0177	0.041	0.0406
V	0.011	0.009	0.040	0.042
Al	0.021	0.0191	0.095	0.0793
As	0.017	0.0177	0.092	0.0920
B	0.00037	0.00035	0.0025	0.00253
Nb	0.022	0.018	0.29	0.315
Sn	0.010	0.0100	0.016	0.0172
Ti	0.020	0.0235	0.084	0.0995
W	0.017	0.0187	0.20	0.2103
Zr	0.009	0.012	0.19	0.203
C	0.383	0.381	0.160	0.159
S	0.014	N.A.	0.036	0.0360
Si	0.222	0.219	0.39	N.A.

* Matrix element calculated as difference for material balance. ()
Tentative value, certified \pm 100% of value. t
N.A. - Not analyzed

TABLE 5-12 (con't)
Chemistry Results from the NBS
Certified Reference Standards


Material ID	Low Alloy Steel: NBS Certified Reference Standards			
	NBS 363		NBS 364	
	Certified	Measured	Certified	Measured
=====				
<u>Metals</u>	<u>Concentration in Weight Percent</u>			
Fe *	94.4	(matrix)	96.7	(matrix)
Co	0.048	0.0477	0.15	0.1574
Cu	0.10	0.097	0.249	N.A.
Cr	1.31	1.338	0.063	N.A.
Mn	0.30	0.304	0.144	N.A.
Mo	1.50	1.505	0.255	N.A.
Ni	0.028	0.029	0.49	N.A.
P	0.029	0.0326	0.01	N.A.
V	0.31	0.317	0.105	N.A.
Al	0.24	0.2383	0.008 t	0.0081
As	0.010	0.0118	0.052	0.0520
B	0.00078	0.00071	0.0106	0.01074
Nb	0.049	0.037	0.157	0.157
Sn	0.104	0.1040	0.0008	<0.0066
Ti	0.050	0.0566	0.24	0.2392
W	0.046	0.0680	0.10	0.1367
Zr	0.049	0.050	0.068	0.071
C	0.62	N.A.	0.87	N.A.
S	0.0068	N.A.	0.0250	0.0251
Si	0.74	N.A.	0.065	N.A.

Nitrogen	LECO Std #656		LECO Std #657	
	0.0193	0.196	0.0102	0.0104
	±0.0008		±0.0004	
=====				

* Matrix element calculated as difference for material balance. ()
Tentative value, certified ± 100% of value. t
N.A. - Not analyzed



a) Block 3541



b) Block 3573



c) Block 3514

Figure 5-1. Appearance of the Thermal Monitors in the Various Quartz Tubes. Melting Occurred in the One Inch Long Tubes (536°F)




Figure 5-2. Charpy V-Notch Impact Properties for the Maine Yankee Reactor Vessel Intermediate Shell Plate D-8406-1 (Longitudinal Orientation)




Figure 5-3. Charpy V-Notch Impact Properties for Maine Yankee Reactor Vessel Weld Metal




Figure 5-4. Charpy V-Notch Impact Properties for Maine Yankee Reactor Weld Heat Affected Zone Metal




Figure 5-5. Charpy V-Notch Impact Properties for the Maine Yankee Standard Reference Material (HSST - Plate 01)




Figure 5-6. Charpy V-Notch Impact Specimen Fracture Surfaces for the Maine Yankee Reactor Vessel Intermediate Shell Plate D-8406-1 (Longitudinal Orientation)



37K



31J




32L



32A



35D



32K



3A2



33M




37J



317



36C



312

Figure 5-7. Charpy Impact Specimen Fracture Surfaces for Maine Yankee Reactor Vessel Weld Metal



Figure 5-8. Charpy Impact Specimen Fracture Surfaces for Maine Yankee Reactor Vessel Weld Heat Affected Zone HAZ Metal





Figure 5-9. Charpy Impact Specimen Fracture Surfaces for Maine Yankee Standard Reference Material (HSST - Plate 01)


FIGURE 5-10

MEASURED 30 FT-LB TRANSITION TEMP.
SHIFT vs. FLUENCE

5-30



MEASURED UPPER SHELF ENERGY DECREASE vs. FLUENCE




5-31


FIGURE 5-12

MEASURED UPPER SHELF ENERGY

PERCENT DECREASE vs. FLUENCE

5-32





Code:

Open Points - Unirradiated

Closed Points - Irradiated to $1.25 \times 10^{19} \text{ n/cm}^2$





Figure 5-13. Tensile Properties for the Maine Yankee Reactor Vessel Intermediate Shell Plate D-8406-1 (Longitudinal Orientation)



Code:

Open Points - Unirradiated

Closed Points - Irradiated to $1.25 \times 10^{19} \text{ n/cm}^2$





Figure 5-14. Tensile Properties for Maine Yankee Reactor Vessel Weld Metal



Code:

Open Points - Unirradiated

Closed Points - Irradiated to 1.25×10^{19} n/cm²






Figure 5-15. Tensile Properties for Maine Yankee Reactor Vessel Weld Heat Affected Zone (HAZ) Metal




Specimen 1L4

74°F



Specimen 1KM


300°F



Specimen 1JL


550°

Figure 5-16. Fractured Tensile Specimens from the Maine Yankee Reactor Vessel Intermediate Shell Plate D-8406-1 (Longitudinal Orientation)




Specimen 3JM

74°F



Specimen 3J7


300°F



Specimen 3L4


550°F

Figure 5-17. Fractured Tensile Specimens from Maine Yankee Reactor Vessel Weld Metal




Specimen 4L2

74°F



Specimen 4KK

300°F



Specimen 4K1

550°F

Figure 5-18. Fractured Tensile Specimens from the Maine Yankee Reactor Vessel Weld Heat Affected Zone (HAZ) Metal





Figure 5-19. Engineering Stress-Strain Curves for the Maine Yankee Reactor Vessel Intermediate Shell Plate D-8406-1 Tension Specimens 1L4 and 1KM





Figure 5-20. Engineering Stress-Strain Curves for the Maine Yankee Reactor Vessel Intermediate Shell Plate D-8406-1 Tension Specimen 1JL and Weld Metal Tension Specimen 3JM





Figure 5-21. Engineering Stress-Strain Curves for the Maine Yankee Reactor Vessel Weld Metal Tension Specimens 3J7 and 3L4





Figure 5-22. Engineering Stress-Strain Curves for the Maine Yankee Reactor Vessel Weld Heat Affected Zone (HAZ) Metal Tension Specimens 4L2 and 4KK




Figure 5-23. Engineering Stress-Strain Curve for the Maine Yankee Reactor Vessel Weld Heat Affected Zone (HAZ) Metal Tension Specimen 4K1

SECTION 6.0
RADIATION ANALYSIS AND NEUTRON DOSIMETRY

6.1 Introduction

Knowledge of the neutron environment within the reactor pressure vessel and surveillance capsule geometry is required as an integral part of LWR reactor pressure vessel surveillance programs for two reasons. First, in order to interpret the neutron radiation-induced material property changes observed in the test specimens, the neutron environment (energy spectrum, flux, fluence) to which the test specimens were exposed must be known. Second, in order to relate the changes observed in the test specimens to the present and future condition of the reactor vessel, a relationship must be established between the neutron environment at various positions within the reactor vessel and that experienced by the test specimens. The former requirement is normally met by employing a combination of rigorous analytical techniques and measurements obtained with passive neutron flux monitors contained in each of the surveillance capsules. The latter information is derived solely from analysis.

The use of fast neutron fluence ($E > 1.0$ MeV) to correlate measured materials properties changes to the neutron exposure of the material for light water reactor applications has traditionally been accepted for development of damage trend curves as well as for the implementation of trend curve data to assess vessel condition. In recent years, however, it has been suggested that an exposure model that accounts for differences in neutron energy spectra between surveillance capsule locations and positions within the vessel wall could lead to an improvement in the uncertainties associated with damage trend curves as well as to a more accurate evaluation of damage gradients through the pressure vessel wall.

Because of this potential shift away from a threshold fluence toward an energy dependent damage function for data correlation, ASTM Standard Practice E853, "Analysis and Interpretation of Light Water Reactor Surveillance Results," recommends reporting displacements per iron atom

(dpa) along with fluence ($E > 1.0$ MeV) to provide a data base for future reference. The energy dependent dpa function to be used for this evaluation is specified in ASTM Standard Practice E693, "Characterizing Neutron Exposures in Ferritic Steels in Terms of Displacements per Atom." The application of the dpa parameter to the assessment of embrittlement gradients through the thickness of the pressure vessel wall has already been promulgated in Revision 2 to the Regulatory Guide 1.99, "Radiation Damage to Reactor Vessel Materials."

This section provides the results of the neutron dosimetry evaluations performed in conjunction with the analysis of test specimens contained in Capsule W-253. Fast neutron exposure parameters in terms of fast neutron fluence ($E > 1.0$ MeV), fast neutron fluence ($E > 0.1$ MeV), and iron atom displacements (dpa) are established for the capsule irradiation history. The analytical formalism relating the measured capsule exposure to the exposure of the vessel wall is described and used to project the integrated exposure of the vessel itself. Also uncertainties associated with the derived exposure parameters at the surveillance capsule and with the projected exposure of the pressure vessel are provided.

6.2 Discrete Ordinates Analysis

A plan view of the reactor geometry at the core midplane is shown in Figure 4-2. A plan view of Capsule W-253 is shown in Figure 6-1. In regard to the azimuthal locations of the surveillance capsules and vessel structures, it should be noted that positions; i.e. 253 degrees, are referenced to "pressure vessel 0.0" as indicated in the vessel design drawings. In performing neutron transport analyses, however, it is common practice to reference azimuthal 0.0 to an axis extending radially through the core flats. In the case of Maine Yankee, these two coordinate systems are displaced by 10 degrees. Thus, Capsule W-253 is located at 7 degrees relative to core 0.0. Likewise, vessel inner radius positions of 260, 275, 290, and 305 degrees relative to vessel 0.0 translate to 0, 15, 30, and 45 degrees in the core coordinate system.

From a neutron transport standpoint, the surveillance capsule structures are significant. They have a marked effect on both the distribution of neutron flux and the neutron energy spectrum in the water annulus between the neutron pad and the reactor vessel. In order to properly determine the neutron environment at the test specimen locations, the capsules themselves must be included in the analytical model.

In performing the fast neutron exposure evaluations for the surveillance capsules and reactor vessel, two distinct sets of transport calculations were available from prior analyses^[16]. The first, consisting of two computations in the conventional forward mode, was used primarily to obtain relative neutron energy distributions throughout the reactor geometry as well as to establish relative radial distributions of exposure parameters ($\phi(E > 1.0 \text{ MeV})$, $\phi(E > 0.1 \text{ MeV})$, and dpa) through the vessel wall. The neutron spectral information was required for the interpretation of neutron dosimetry withdrawn from the surveillance capsule as well as for the determination of exposure parameter ratios; i.e., $\text{dpa}/\phi(E > 1.0 \text{ MeV})$, within the pressure vessel geometry. The relative radial gradient information was required to permit the projection of measured exposure parameters to locations interior to the pressure vessel wall; i.e., the 1/4T, 1/2T, and 3/4T locations.

The second set of calculations consisted of a series of adjoint analyses relating the fast neutron flux ($E > 1.0 \text{ MeV}$) at surveillance capsule positions, and several azimuthal locations on the pressure vessel inner radius to neutron source distributions within the reactor core. The importance functions generated from these adjoint analyses provided the basis for all absolute exposure projections and comparison with measurement. These importance functions, when combined with cycle specific neutron source distributions, yielded absolute predictions of neutron exposure at the locations of interest for the first 11 cycles of irradiation; and established the means to perform similar predictions and dosimetry evaluations for all subsequent fuel cycles. It is important to note that the cycle specific neutron source distributions utilized in these analyses included not only spatial variations of fission rates within the reactor core; but, also accounted for the effects

of varying neutron yield per fission and fission spectrum introduced by the build-up of plutonium as the burnup of individual fuel assemblies increased.

The absolute cycle specific data from the adjoint evaluations together with relative neutron energy spectra and radial distribution information from the forward calculation provided the means to:

1. Evaluate neutron dosimetry obtained from surveillance capsule locations.
2. Extrapolate dosimetry results to key locations at the inner radius and through the thickness of the pressure vessel wall.
3. Enable a direct comparison of analytical prediction with measurement.
4. Establish a mechanism for projection of pressure vessel exposure as the design of each new fuel cycle evolves.

The forward transport calculation for the reactor model summarized in Fig. 4-2 and 6-1 was carried out in R, θ geometry using the DOT two-dimensional discrete ordinates code^[17] and the SAILOR cross-section library^[18]. The SAILOR library is a 47 group ENDFB-IV based data set produced specifically for light water reactor applications. In these analyses anisotropic scattering was treated with a P_3 expansion of the cross-sections and the angular discretization was modeled with an S_8 order of angular quadrature.

In regard to the geometric model used in the transport analysis, it should be noted that in performing the current capsule evaluation an explicit model of Capsule W-253 was not included in the geometric model. However, in the prior evaluations documented in reference 16, a model of Capsule W-263 was included. Since the forward transport results at the capsule location are used only to establish a relative energy distribution for use as an a priori guess in the spectrum adjustment procedure described later in this section, it was judged that the W-263 degree spectrum would be sufficient and that expenditure of additional resources to update the forward calculation was not warranted. Note that relative to the core 0.00 azimuthal position the two capsules are only 4

degrees apart; i. e., they are positioned at 3 and 7 degrees. Maine Yankee Atomic Power Company concurred with this judgement. Due to the proximity of the two capsules, the assumption of a similar spectrum is valid and is supported by the measured reaction rate ratios from the respective capsule dosimetry sets^[37].

In the analyses documented in reference 16, forward calculations were carried out for core designs representative of conventional out-in and low leakage fuel management. Plant specific core power distributions utilized in the forward analyses were based on a burnup weighted average of the cycles 1-6 core design for the first computation and on the cycle 8 fuel management for the second. The cycle 1-6 analysis was representative of reactor operation prior to the implementation of low leakage fuel management, while the cycle 8 calculation was typical of low leakage operation. Results of these two evaluations showed that the relative neutron spectra in the capsules and vessel wall are not significantly impacted by the implementation of low leakage core designs

All adjoint analyses were also carried out using an S_8 order of angular quadrature and the P_3 cross-section approximation from the SAILOR library. Adjoint source locations were chosen at several azimuthal locations along the pressure vessel inner radius as well as the geometric center of the surveillance capsule. Again, these calculations were run in R, θ geometry to provide neutron source distribution importance functions for the exposure parameter of interest; in this case, ϕ ($E > 1.0$ MeV). Having the importance functions and appropriate core source distributions, the response of interest could be calculated as:

$$R(r, \theta) = \int_r \int_{\theta} \int_E I(r, \theta, E) S(r, \theta, E) r dr d\theta dE$$

where: $R(r, \theta)$ = ϕ ($E > 1.0$ MeV) at radius r and azimuthal angle θ

$I(r, \theta, E)$ = Adjoint importance function at radius, r , azimuthal angle θ , and neutron source energy E .

$S(r, \theta, E)$ = Neutron source strength at core location r , θ and energy E .

Although the adjoint importance functions used in the Maine Yankee analysis were based on a response function defined by the threshold neutron flux ($E > 1.0$ MeV), prior calculations^[16] have shown that, while the implementation of low leakage loading patterns significantly impact the magnitude and the spatial distribution of the neutron field, changes in the relative neutron energy spectrum are of second order. Thus, for a given location the ratio of dpa/ϕ ($E > 1.0$ MeV) is insensitive to changing core source distributions. In the application of these adjoint importance functions to the Maine Yankee reactor, therefore, the iron displacement rates (dpa) and the neutron flux ($E > 0.1$ MeV) were computed on a cycle specific basis by using dpa/ϕ ($E > 1.0$ MeV) and ϕ ($E > 0.1$ MeV)/ ϕ ($E > 1.0$ MeV) ratios from the forward analysis in conjunction with the cycle specific ϕ ($E > 1.0$ MeV) solutions from the individual adjoint evaluations.

Again, with the forward analysis, an explicit adjoint library was not generated for the Capsule W-253 location. Rather, the Capsule W-263 library was used in conjunction with an azimuthal translation factor applied to the problem normalization to estimate the exposure at the center of Capsule W-253. This approach assumes that the relative neutron energy spectra at the center of the two capsules is the same and that the capsules are in close enough proximity that the ratio of the exposure rates at the capsule center is independent of core power distribution. In this case, considering core symmetry, the capsules are only 4 degrees apart in an area of the vessel that does not exhibit extreme azimuthal gradients in the observed exposure rates. Therefore, it was judged that using this method of calculation does not introduce significant uncertainty in the overall evaluation.

The reactor core power distribution and fission fractions by isotope used in the plant specific adjoint calculations were supplied by Maine Yankee Atomic Power Company^[36].

Selected results from the neutron transport analyses performed for the Maine Yankee reactor are provided in Tables 6-1 through 6-5. The data listed in

these tables establish the means for absolute comparisons of analysis and measurement for the capsule irradiation period and provide the means to correlate dosimetry results with the corresponding neutron exposure of the pressure vessel wall.

In Table 6-1, the calculated exposure parameters [ϕ ($E > 1.0$ MeV), $\phi(E > 0.1$ MeV), and dpa] are given at the geometric center of Capsule W-253. These plant specific data, based on the adjoint transport analysis, are meant to establish the absolute comparison of measurement with analysis. Similar data are given in Table 6-2 for the pressure vessel inner radius. Again, the three pertinent exposure parameters are listed for the cycle 1 through 11 plant specific power distributions. It is important to note that the data for the vessel inner radius were taken at the clad/base metal interface; and, thus, represent the maximum exposure levels of the vessel wall itself.

Radial gradient information for neutron flux ($E > 1.0$ MeV), neutron flux ($E > 0.1$ MeV), and iron atom displacement rate is given in Tables 6-3, 6-4, and 6-5, respectively. The data, obtained from the forward neutron transport calculation, are presented on a relative basis for each exposure parameter at several azimuthal locations. Exposure parameter distributions within the wall may be obtained by normalizing the calculated or projected exposure at the vessel inner radius to the gradient data given in Tables 6-3 through 6-5.

For example, the neutron flux ($E > 1.0$ MeV) at the 1/4T position on the 0° azimuth is given by:

$$\phi_{1/4T}(0^\circ) = \phi(221.67, 0^\circ) F(227.15, 0^\circ)$$

where: $\phi_{1/4T}(0^\circ)$ = Projected neutron flux at the 1/4T position on the 0° azimuth

$\phi(221.67, 0^\circ)$ = Projected or calculated neutron flux at the vessel inner radius on the 0° azimuth.

F (227.15, 0°)

= Relative radial distribution function from
Table 6-3.

Similar expressions apply for exposure parameters in terms of ϕ ($E > 0.1$ MeV) and dpa/sec.

6.3 Neutron Dosimetry

The passive neutron sensors included in the Maine Yankee surveillance program are listed in Table 6-6. Also given in Table 6-6 are the primary nuclear reactions and associated nuclear constants that were used in the evaluation of the neutron energy spectrum within the capsule and the subsequent determination of the various exposure parameters of interest [ϕ ($E > 1.0$ MeV), ϕ ($E > 0.1$ MeV), dpa].

The relative locations of the neutron sensors within the capsules are shown in Figure 6-1. The individual sensors were placed in holes drilled in the dosimeter blocks at several axial levels within the capsules. All sensors were positioned at the radial center of the dosimetry blocks.

The use of passive monitors such as those listed in Table 6-6 does not yield a direct measure of the energy dependent flux level at the point of interest. Rather, the activation or fission process is a measure of the integrated effect that the time- and energy-dependent neutron flux has on the target material over the course of the irradiation period. An accurate assessment of the average neutron flux level incident on the various monitors may be derived from the activation measurements only if the irradiation parameters are well known. In particular, the following variables are of interest:

- o The specific activity of each monitor.
- o The operating history of the reactor.
- o The energy response of the monitor.
- o The neutron energy spectrum at the monitor location.
- o The physical characteristics of the monitor.

The specific activity of each of the neutron monitors was determined using established ASTM procedures [19 through 32]. Following sample preparation and weighing, the activity of each monitor was determined by means of a lithium-drifted germanium, Ge(Li), gamma spectrometer.

In regard to the condition of the sensors removed from Capsule W-253, it is of interest to note that all of the uranium foils were oxidized and reduced to a powder form requiring dissolution and uranium separation to obtain accurate counting results. In addition, rapid oxidation of the titanium wires was observed upon removal from the capsule. In this case, the oxidation did not impair the ability to obtain measured specific activities. Also, in the case of Compartment 3541 the copper wire was fused with its cadmium jacket and could not be recovered for analysis.

The irradiation history of the Maine Yankee reactor during cycles 1 through 11 was obtained from NUREG-0020, "Licensed Operating Reactors Status Summary Report" for the applicable period and is given in Table 6-7. Measured and saturated reaction product specific activities as well as measured full power reaction rates are listed in Table 6-8. Reaction rate values were derived using the pertinent data from Tables 6-6 and 6-7. Due to its extremely short product half-life, no attempt was made to include reaction rates from the sulfur monitors in this evaluation.

Values of key fast neutron exposure parameters were derived from the measured reaction rates using the FERRET least squares adjustment code [33]. The FERRET approach used the measured reaction rate data and the calculated neutron energy spectrum at the center of the surveillance capsule as input and proceeded to adjust a priori (calculated) group fluxes to produce a best fit (in a least squares sense) to the reaction rate data. The exposure parameters along with associated uncertainties were then obtained from the adjusted spectra.

In the FERRET evaluations, a log normal least-squares algorithm weights both the a priori values and the measured data in accordance with the assigned uncertainties and correlations. In general, the measured values are linearly

related to the flux ϕ by some response matrix A:

$$f^{(s,\alpha)} = \sum_g A_{ig}^{(s)} \phi_g^{(\alpha)}$$

where i indexes the measured values belonging to a single data set s , g designates the energy group and α delineates spectra that may be simultaneously adjusted. For example,

$$R_i = \sum_g \sigma_{ig} \phi_g$$

relates a set of measured reaction rates R_i to a single spectrum ϕ_g by the multigroup cross section σ_{ig} . (In this case, FERRET also adjusts the cross-sections.) The lognormal approach automatically accounts for the physical constraint of positive fluxes, even with the large assigned uncertainties.

In the FERRET analysis of the dosimetry data, the continuous quantities (i.e., fluxes and cross-sections) were approximated in 53 groups. The calculated fluxes from the discrete ordinates analysis were expanded into the FERRET group structure using the SAND-II code [34]. This procedure was carried out by first expanding the a priori spectrum into the SAND-II 620 group structure using a SPLINE interpolation procedure for interpolation in regions where group boundaries do not coincide. The 620-point spectrum was then easily collapsed to the group scheme used in FERRET.

The cross-sections were also collapsed into the 53 energy-group structure using SAND II with calculated spectra (as expanded to 620 groups) as weighting functions. The cross sections were taken from the ENDF/B-V dosimetry file. Uncertainty estimates and 53 x 53 covariance matrices were constructed for each cross section. Correlations between cross sections were neglected due to data and code limitations, but are expected to be unimportant.

For each set of data or a priori values, the inverse of the corresponding relative covariance matrix M is used as a statistical weight. In some cases, as for the cross sections, a multigroup covariance matrix is used. More often, a simple parameterized form is used:

$$M_{gg'} = R_N^2 + R_g R_{g'} P_{gg'}$$

where R_N specifies an overall fractional normalization uncertainty (i.e., complete correlation) for the corresponding set of values. The fractional uncertainties R_g specify additional random uncertainties for group g that are correlated with a correlation matrix:

$$P_{gg'} = (1 - \theta) \delta_{gg'} + \theta \exp \left[\frac{-(g-g')^2}{2\delta^2} \right]$$

The first term specifies purely random uncertainties while the second term describes short-range correlations over a range δ (θ specifies the strength of the latter term).

For the a priori calculated fluxes, a short-range correlation of $\delta = 6$ groups was used. This choice implies that neighboring groups are strongly correlated when θ is close to 1. Strong long-range correlations (or anticorrelations) were justified based on information presented by R.E. Maerker^[35]. Maerker's results are closely duplicated when $\delta = 6$. For the integral reaction rate covariances, simple normalization and random uncertainties were combined as deduced from experimental uncertainties.

Results of the FERRET evaluation of Capsule W-253 dosimetry are given in Table 6-9. The data summarized in Table 6-9 indicated that the capsule received an integrated exposure of 1.25×10^{19} n/cm² ($E > 1.0$ MeV) with an associated 1σ uncertainty of $\pm 7\%$ in the derived fluence. Also reported are capsule exposures in terms of fluence ($E > 0.1$ MeV) and iron atom displacements (dpa). Summaries of the fit of the adjusted spectrum are provided in Table 6-10. In general, excellent results were achieved in the fits of the adjusted spectrum to the individual experimental reaction rates. The adjusted spectrum itself is tabulated in Table 6-11 for the FERRET 53 energy group structure.

A summary of the measured and calculated neutron exposure of Capsule W-253 is presented in Table 6-12. The agreement between calculation and measurement falls within $\pm 20\%$ for all fast neutron exposure parameters listed with the calculation underpredicting measurement in all cases.

Neutron exposure projections at the maximum fluence locations on the pressure vessel inner radius are given in Table 6-13. Projections are provided based on the cycle 8 core power distribution as well as for the cycle 10 fuel management design. The cycle 8 data represents a bounding low leakage pattern committed to by Maine Yankee Atomic Power Company while the cycle 10 results are representative of typical low leakage operation. Projected data are provided for periods up to 32 effective full power years of operation.

In developing these projections, the dosimetry from Capsule W-253 was included in an overall Maine Yankee measurement data base to provide a best estimate bias factor to be used in generating pressure vessel exposures. The development of this data base is described in detail in reference 37 and includes the use of surveillance capsule and reactor cavity dosimetry. Based on the use of this bias factor approach maximum fluence levels were computed by applying a factor of 1.22 to the analytical results.

In Table 6-14 estimated lead factors are listed for each of the remaining Maine Yankee surveillance capsules. For comparison purposes, values are provided for the cycles 1-6 non-low leakage core power distribution as well as for both the cycle 8 and cycle 10 low leakage core designs. The lead factors are defined as the ratio of the neutron flux at the center of the respective surveillance capsules to the maximum flux at the pressure vessel inner radius. These data may be used as a guide in establishing future withdrawal schedules for these capsules.

Relative to both the projected maximum vessel fluence and the capsule lead factors, it should be noted that the capsule results are representative of the core axial midplane; whereas, the maximum vessel exposure occurs at an axial elevation approximately 22 inches below core midplane. Adjustments for this axial effect were included for the vessel projections and the lead factors.




Figure 6-1. Plan View of a Wall Surveillance Capsule

TABLE 6-1

CALCULATED FAST NEUTRON EXPOSURE PARAMETERS
AT THE CENTER OF CAPSULE W-253

ϕ (E > 1.0 MeV) (n/cm²-sec)

CYCLES 1-6	3.23×10^{10}
CYCLE 7	2.86×10^{10}
CYCLE 8	2.19×10^{10}
CYCLE 9	2.15×10^{10}
CYCLE 10	1.69×10^{10}
CYCLE 11	1.85×10^{10}

ϕ (E > 0.1 MeV) (n/cm²-sec)

CYCLES 1-6	6.59×10^{10}
CYCLE 7	5.84×10^{10}
CYCLE 8	4.47×10^{10}
CYCLE 9	4.39×10^{10}
CYCLE 10	3.45×10^{10}
CYCLE 11	3.78×10^{10}

IRON ATOM DISPLACEMENT RATE (dpa/sec)

CYCLES 1-6	4.94×10^{-11}
CYCLE 7	4.38×10^{-11}
CYCLE 8	3.35×10^{-11}
CYCLE 9	3.29×10^{-11}
CYCLE 10	2.59×10^{-11}
CYCLE 11	2.83×10^{-11}

TABLE 6-2

CALCULATED FAST NEUTRON EXPOSURE PARAMETERS
AT THE PRESSURE VESSEL CLAD/BASE METAL INTERFACE

ϕ ($E > 1.0$ MeV) (n/cm²-sec)

	<u>260*</u>	<u>270*</u>
CYCLES 1-6	2.41×10^{10}	1.97×10^{10}
CYCLE 7	2.16×10^{10}	1.63×10^{10}
CYCLE 8	1.84×10^{10}	1.37×10^{10}
CYCLE 9	1.66×10^{10}	1.32×10^{10}
CYCLE 10	1.26×10^{10}	1.15×10^{10}
CYCLE 11	1.38×10^{10}	1.23×10^{10}

ϕ ($E > 0.1$ MeV) (n/cm²-sec)

	<u>260*</u>	<u>270*</u>
CYCLES 1-6	6.12×10^{10}	5.00×10^{10}
CYCLE 7	5.48×10^{10}	4.14×10^{10}
CYCLE 8	4.16×10^{10}	3.48×10^{10}
CYCLE 9	4.21×10^{10}	3.35×10^{10}
CYCLE 10	3.20×10^{10}	2.92×10^{10}
CYCLE 11	3.50×10^{10}	3.12×10^{10}

IRON ATOM DISPLACEMENT RATE (dpa/sec)

	<u>260*</u>	<u>270*</u>
CYCLES 1-6	3.86×10^{-11}	3.15×10^{-11}
CYCLE 7	3.46×10^{-11}	2.61×10^{-11}
CYCLE 8	2.62×10^{-11}	2.19×10^{-11}
CYCLE 9	2.63×10^{-11}	2.11×10^{-11}
CYCLE 10	2.02×10^{-11}	1.84×10^{-11}
CYCLE 11	2.21×10^{-11}	1.97×10^{-11}

TABLE 6-3

RELATIVE RADIAL DISTRIBUTIONS OF NEUTRON FLUX ($E > 1.0$ MeV)
WITHIN THE PRESSURE VESSEL WALL

Radius (cm)	Depth Into Vessel (in)	Relative Neutron Flux		
		260°	270°	280°
221.67 ⁽¹⁾	0.000	1.000	1.000	1.000
221.94	0.106	0.981	0.984	0.982
223.65	0.780	0.816	0.822	0.823
225.57	1.535	0.639	0.646	0.650
227.49	2.291	0.491	0.498	0.504
229.41	3.047	0.375	0.382	0.387
231.33	3.803	0.284	0.291	0.296
233.26	4.563	0.215	0.221	0.225
235.18	5.319	0.161	0.167	0.171
237.10	6.075	0.121	0.126	0.129
239.02	6.841	0.0899	0.0938	0.0965
240.94	7.587	0.0665	0.0695	0.0719
242.74	8.295	0.0485	0.0513	0.0537
243.58 ⁽²⁾	8.625	0.0406	0.0437	0.0473

NOTES: 1) Base Metal Inner Radius
2) Base Metal Outer Radius

TABLE 6-4

RELATIVE RADIAL DISTRIBUTIONS OF NEUTRON FLUX ($E > 0.1$ MeV)
WITHIN THE PRESSURE VESSEL WALL

Radius (cm)	Depth Into Vessel (in)	250°	270°	280°
221.67 ⁽¹⁾	0.000	1.000	1.000	1.000
221.94	0.106	0.981	0.984	0.982
223.65	0.780	0.816	0.822	0.823
225.57	1.535	0.639	0.646	0.650
227.49	2.291	0.491	0.498	0.504
229.41	3.047	0.375	0.382	0.387
231.33	3.803	0.284	0.291	0.296
233.26	4.563	0.215	0.221	0.225
235.18	5.319	0.161	0.167	0.171
237.10	6.075	0.121	0.126	0.129
239.02	6.841	0.0899	0.0938	0.0965
240.94	7.587	0.0665	0.0695	0.0719
242.74	8.295	0.0485	0.0513	0.0537
243.58 ⁽²⁾	8.625	0.0406	0.0437	0.0473

NOTES: 1) Base Metal Inner Radius
2) Base Metal Outer Radius

TABLE 6-5

RELATIVE RADIAL DISTRIBUTIONS OF IRON ATOM DISPLACEMENT
RATE (dpa/sec) WITHIN THE PRESSURE VESSEL WALL

Radius (cm)	Depth Into Vessel (in)	Depth		
		260°	270°	280°
221.67 ⁽¹⁾	0.000	1.000	1.000	1.000
221.94	0.106	0.988	0.985	0.985
223.65	0.780	0.865	0.869	0.870
225.57	1.535	0.726	0.733	0.736
227.49	2.291	0.611	0.617	0.620
229.41	3.047	0.512	0.519	0.525
231.33	3.803	0.429	0.436	0.442
233.26	4.563	0.357	0.367	0.373
235.18	5.319	0.298	0.307	0.314
237.10	6.075	0.246	0.255	0.263
239.02	6.841	0.201	0.210	0.217
240.94	7.587	0.160	0.169	0.177
242.74	8.295	0.125	0.134	0.142
243.58 ⁽²⁾	8.625	0.106	0.117	0.128

NOTES: 1) Base Metal Inner Radius
2) Base Metal Outer Radius

TABLE 6-6

NUCLEAR PARAMETERS FOR NEUTRON FLUX MONITORS

<u>Monitor Material</u>	<u>Reaction of Interest</u>	<u>Target Weight Fraction</u>	<u>Response Range</u>	<u>Product Half-Life</u>	<u>Fission Yield (%)</u>
Copper	$\text{Cu}^{63}(n,\alpha)\text{Co}^{60}$	0.6917	$E > 4.7 \text{ MeV}$	5.272 yrs	
Iron	$\text{Fe}^{54}(n,p)\text{Mn}^{54}$	0.0582	$E > 1.0 \text{ MeV}$	312.2 days	
Nickel	$\text{Ni}^{58}(n,p)\text{Co}^{58}$	0.6830	$E > 1.0 \text{ MeV}$	70.90 days	
Uranium-238*	$\text{U}^{238}(n,f)\text{Cs}^{137}$	1.0	$E > 0.4 \text{ MeV}$	30.12 yrs	5.99
Neptunium-237*	$\text{Np}^{237}(n,f)\text{Cs}^{137}$	1.0	$E > 0.08 \text{ MeV}$	30.12 yrs	6.50
Cobalt-Aluminum*	$\text{Co}^{59}(n,\beta)\text{Co}^{60}$	0.0015	$0.4\text{eV} > E > 0.015 \text{ MeV}$	5.272 yrs	
Cobalt-Aluminum	$\text{Co}^{59}(n,\beta)\text{Co}^{60}$	0.0015	$E > 0.015 \text{ MeV}$	5.272 yrs	

*Denotes that monitor is cadmium shielded.

TABLE 6-7

 IRRADIATION HISTORY OF NEUTRON SENSORS
 CONTAINED IN CAPSULE W-253

Irradiation Period	P_j (MW_t)	P_j $P_{Ref.}$	Irradiation Time (days)	Decay Time (days)
11/72	728	.270	23	6468
12/72	1341	.497	31	6437
1/73	1608	.595	31	6406
2/73	929	.344	28	6378
3/73	1023	.379	31	6347
4/73	1813	.672	30	6317
5/73	1597	.591	31	6286
6/73	1273	.472	30	6256
7/73	0	.000	31	6225
8/73	757	.280	31	6194
9/73	665	.246	30	6164
10/73	1490	.552	31	6133
11/73	1923	.712	30	6103
12/73	1727	.640	31	6072
1/74	1939	.718	31	6041
2/74	1818	.674	28	6013
3/74	1826	.676	31	5982
4/74	1851	.686	30	5952
5/74	1909	.707	31	5921
6/74	1772	.656	30	5891
7/74	0	.000	31	5860
8/74	0	.000	31	5829
9/74	0	.000	30	5799
10/74	1113	.412	31	5768
11/74	1717	.636	30	5738
12/74	1782	.660	31	5707
1/75	1414	.524	31	5676

TABLE 6-7 (continued)
IRRADIATION HISTORY OF NEUTRON SENSORS
CONTAINED IN CAPSULE W-253

Irradiation Period	P_j (MW _t)	P_j $P_{Ref.}$	Irradiation Time (days)	Decay Time (days)
2/75	1870	.692	28	5648
3/75	2048	.759	31	5617
4/75	2049	.759	30	5587
5/75	117	.044	31	5556
6/75	29	.011	30	5526
7/75	1426	.528	31	5495
8/75	2269	.840	31	5464
9/75	2341	.867	30	5434
10/75	2414	.894	31	5403
11/75	1858	.688	30	5373
12/75	2308	.855	31	5342
1/76	2339	.867	31	5311
2/76	2230	.826	29	5282
3/76	2225	.824	31	5251
4/76	2335	.865	30	5221
5/76	2255	.835	31	5190
6/76	2200	.815	30	5160
7/76	2238	.829	31	5129
8/76	2385	.883	31	5098
9/76	1274	.472	30	5068
10/76	2287	.847	31	5037
11/76	2414	.894	30	5007
12/76	2401	.889	31	4976
1/77	2298	.851	31	4945
2/77	2318	.859	28	4917
3/77	1973	.731	31	4886
4/77	382	.142	30	4856

TABLE 6-7 (continued)
IRRADIATION HISTORY OF NEUTRON SENSORS
CONTAINED IN CAPSULE W-253

Irradiation Period	P_j (MW_t)	P_j $P_{Ref.}$	Irradiation Time (days)	Decay Time (days)
5/77	0	.000	31	4825
6/77	1237	.458	30	4795
7/77	2405	.691	31	4764
8/77	2393	.886	31	4733
9/77	2414	.894	30	4703
10/77	2425	.898	31	4672
11/77	2412	.893	30	4642
12/77	2373	.879	31	4611
1/78	2415	.894	31	4580
2/78	2517	.932	28	4552
3/78	2395	.887	31	4521
4/78	2349	.870	30	4491
5/78	2442	.905	31	4460
6/78	2155	.798	30	4430
7/78	643	.238	31	4399
8/78	112	.042	31	4368
9/78	1042	.386	30	4338
10/78	2178	.807	31	4307
11/78	2467	.914	30	4277
12/78	2466	.913	31	4246
1/79	2389	.885	31	4215
2/79	2428	.899	28	4187
3/79	1019	.376	31	4156
4/79	0	.000	30	4126
5/79	0	.000	31	4095
6/79	1943	.719	30	4065
7/79	2522	.934	31	4034

TABLE 6-7 (continued)
 IRRADIATION HISTORY OF NEUTRON SENSORS
 CONTAINED IN CAPSULE W-253

Irradiation Period	P_j (MW_t)	$\frac{P_j}{P_{Ref.}}$	Irradiation Time (days)	Decay Time (days)
8/79	2498	.925	31	4003
9/79	21	.008	30	3973
10/79	2070	.767	31	3942
11/79	2444	.905	30	3912
12/79	2018	.748	31	3881
1/80	595	.220	31	3850
2/80	0	.000	29	3821
3/80	771	.286	31	3790
4/80	2416	.895	30	3760
5/80	1949	.722	31	3729
6/80	1454	.538	30	3699
7/80	2427	.899	31	3668
8/80	1690	.626	31	3637
9/80	1694	.627	30	3607
10/80	2535	.939	31	3576
11/80	2495	.924	30	3546
12/80	1263	.468	31	3515
1/81	2550	.944	31	3484
2/81	2541	.941	28	3456
3/81	2553	.946	31	3425
4/81	2551	.945	30	3395
5/81	619	.229	31	3364
6/81	0	.000	30	3334
7/81	482	.178	31	3303
8/81	2378	.881	31	3272
9/81	2402	.890	30	3242
10/81	2118	.784	31	3211

TABLE 6-7 (continued)
IRRADIATION HISTORY OF NEUTRON SENSORS
CONTAINED IN CAPSULE W-253

Irradiation Period	P_j (MW _t)	P_j <u>P_{Ref.}</u>	Irradiation Time (days)	Decay Time (days)
11/81	2392	.886	30	3181
12/81	2365	.876	31	3150
1/82	1712	.634	31	3119
2/82	2304	.853	28	3091
3/82	456	.169	31	3060
4/82	2490	.922	30	3030
5/82	2416	.895	31	2999
6/82	2439	.903	30	2969
7/82	2524	.935	31	2938
8/82	2264	.838	31	2907
9/82	1753	.649	30	2877
10/82	0	.000	31	2846
11/82	0	.000	30	2816
12/82	1078	.399	31	2785
1/83	1801	.667	31	2754
2/83	123	.046	28	2726
3/83	2025	.750	31	2695
4/83	2591	.960	30	2665
5/83	252	.093	31	2634
6/83	2595	.961	30	2604
7/83	2586	.958	31	2573
8/83	2502	.927	31	2542
9/83	2530	.937	30	2512
10/83	2591	.960	31	2481
11/83	1311	.485	30	2451
12/83	1631	.604	31	2420
1/84	2369	.877	31	2389

TABLE 6-7 (continued)
IRRADIATION HISTORY OF NEUTRON SENSORS
CONTAINED IN CAPSULE W-253

Irradiation Period	P_j (MW _t)	$\frac{P_j}{P_{Ref.}}$	Irradiation Time (days)	Decay Time (days)
2/84	2715	1.01	29	2360
3/84	2176	.806	31	2329
4/84	0	.000	30	2299
5/84	0	.000	31	2268
6/84	181	.067	30	2238
7/84	2503	.927	31	2207
8/84	2603	.964	31	2176
9/84	2600	.963	30	2146
10/84	2488	.921	31	2115
11/84	2024	.749	30	2085
12/84	2583	.957	31	2054
1/85	2422	.897	31	2023
2/85	2415	.895	28	1995
3/85	2443	.905	31	1964
4/85	2565	.950	30	1934
5/85	2276	.843	31	1903
6/85	2558	.948	30	1873
7/85	2221	.823	31	1842
8/85	1034	.383	31	1811
9/85	0	.000	30	1781
10/85	264	.098	31	1750
11/85	2161	.801	30	1720
12/85	2545	.943	31	1689
1/86	2418	.896	31	1658
2/86	1843	.683	28	1630
3/86	1577	.584	31	1599
4/86	2258	.836	30	1569

TABLE 6-7 (continued)
IRRADIATION HISTORY OF NEUTRON SENSORS
CONTAINED IN CAPSULE W-253

Irradiation Period	P_j (MW _t)	P_j <u>$P_{Ref.}$</u>	Irradiation Time (days)	Decay Time (days)
5/86	2504	.927	31	1538
6/86	2151	.797	30	1508
7/86	973	.361	31	1477
8/86	2465	.913	31	1446
9/86	2608	.966	30	1416
10/86	2518	.933	31	1385
11/86	2469	.915	30	1355
12/86	2582	.956	31	1324
1/87	2598	.962	31	1293
2/87	2360	.874	28	1265
3/87	1766	.654	31	1234
4/87	0	.000	30	1204
5/87	0	.000	31	1173
6/87	352	.130	30	1143
7/87	23	.009	31	1112
8/87	528	.196	31	1081
9/87	2585	.957	30	1051
10/87	2610	.966	31	1020
11/87	2608	.966	30	990
12/87	2592	.960	31	959
1/88	2515	.932	31	928
2/88	2589	.959	29	899
3/88	2628	.973	31	868
4/88	2620	.971	30	838
5/88	2613	.968	31	807
6/88	2598	.962	30	777
7/88	2620	.971	31	746

TABLE 6-7 (continued)
IRRADIATION HISTORY OF NEUTRON SENSORS
CONTAINED IN CAPSULE W-253

Irradiation Period	P_j (MW_t)	$\frac{P_j}{P_{Ref.}}$	Irradiation Time (days)	Decay Time (days)
8/88	1516	.562	31	715
9/88	1956	.724	30	685
10/88	905	.335	31	654
11/88	0	. 0	30	624
12/88	13	.005	31	593
1/89	2442	.905	31	562
2/89	1795	.665	28	534
3/89	2628	.973	31	503
4/89	2548	.944	30	473
5/89	2629	.974	31	442
6/89	2611	.967	30	412
7/89	2608	.966	31	381
8/89	2614	.968	31	350
9/89	2554	.946	30	320
10/89	2134	.790	31	289
11/89	1713	.635	30	259
12/89	2615	.969	31	228
1/90	2585	.957	31	197
2/90	2565	.950	28	169
3/90	2548	.944	31	138
4/90	2023	.749	7	131

NOTE: Reference Power = 2700 MW_t

TABLE 6-8
MEASURED SENSOR ACTIVITIES AND REACTION RATES

<u>Monitor and Axial Location</u>	<u>Measured Activity (dis/sec-gm)</u>	<u>Saturated Activity (dis/sec-gm)</u>	<u>Reaction Rate (RPS/NUCLEUS)</u>
Cu-63 (n,α) Co-60			
COMP 3514	1.49 x 10 ⁵	2.78 x 10 ⁵	
COMP 3541	Sensor was fused with Cd cover		
COMP 3573	1.39 x 10 ⁵	2.60 x 10 ⁵	
Average	1.44 x 10 ⁵	2.69 x 10 ⁵	4.10 x 10 ⁻¹⁷
Ti-46 (n,p) Sc-46			
COMP 3514	1.42 x 10 ⁵	6.55 x 10 ⁵	
COMP 3541	1.25 x 10 ⁵	5.76 x 10 ⁵	
COMP 3573	1.30 x 10 ⁵	5.99 x 10 ⁵	
Average	1.32 x 10 ⁵	6.10 x 10 ⁵	5.88 x 10 ⁻¹⁶
Fe-54 (n,p) Mn-54			
COMP 3514	9.54 x 10 ⁵	2.20 x 10 ⁶	
COMP 3541	8.28 x 10 ⁵	1.92 x 10 ⁶	
COMP 3573	8.55 x 10 ⁵	1.98 x 10 ⁶	
Average	8.79 x 10 ⁵	2.03 x 10 ⁶	3.24 x 10 ⁻¹⁵
Ni-58 (n,p) Co-58			
COMP 3514	5.98 x 10 ⁶	3.34 x 10 ⁷	
COMP 3541	5.02 x 10 ⁶	2.80 x 10 ⁷	
COMP 3573	5.38 x 10 ⁶	3.00 x 10 ⁷	
Average	5.46 x 10 ⁶	3.05 x 10 ⁷	4.35 x 10 ⁻¹⁵

TABLE 6-8
MEASURED SENSOR ACTIVITIES AND REACTION RATES - cont'd

<u>Monitor and Axial Location</u>	<u>Measured Activity (dis/sec-gm)</u>	<u>Saturated Activity (dis/sec-gm)</u>	<u>Reaction Rate (RPS/NUCLEUS)</u>
U-238 (n,f) Cs-137 (Cd)			
COMP 3514	5.88×10^5	2.71×10^6	
COMP 3541	5.59×10^5	2.58×10^6	
COMP 3573	5.73×10^5	2.64×10^6	
Average	5.73×10^5	2.64×10^6	1.76×10^{-14}
Co-59 (n, β) Co-60			
COMP 3514	3.59×10^7	6.71×10^7	
COMP 3541	4.03×10^7	7.53×10^7	
COMP 3573	2.70×10^7	5.04×10^7	
Average	3.44×10^7	6.42×10^7	4.19×10^{-12}
Co-59 (n, β) Co-60 (Cd)			
COMP 3514	5.12×10^6	9.56×10^6	
COMP 3541	5.34×10^6	9.97×10^6	
COMP 3573	4.97×10^6	9.28×10^6	
Average	5.14×10^6	9.61×10^6	6.27×10^{-12}

TABLE 6-9

SUMMARY OF NEUTRON DOSIMETRY RESULTS

<u>TIME AVERAGED EXPOSURE RATES</u>		
ϕ (E > 1.0 MeV) (n/cm ² -sec)	3.41×10^{10}	$\pm 7\%$
ϕ (E > 0.1 MeV) (n/cm ² -sec)	7.09×10^{10}	$\pm 15\%$
dpa/sec	4.96×10^{-11}	$\pm 8\%$
ϕ (E < 0.414 eV) (n/cm ² -sec)	1.43×10^{11}	$\pm 13\%$
<u>INTEGRATED CAPSULE EXPOSURE</u>		
Φ (E > 1.0 MeV) (n/cm ²)	1.25×10^{19}	$\pm 7\%$
Φ (E > 0.1 MeV) (n/cm ²)	2.61×10^{19}	$\pm 15\%$
dpa	1.82×10^{-2}	$\pm 8\%$
Φ (E < 0.414 eV) (n/cm ²)	5.26×10^{19}	$\pm 13\%$

NOTE: Total Irradiation Time = 11.7 EFPY

TABLE 6-10

COMPARISON OF MEASURED AND FERRET CALCULATED
REACTION RATES AT THE SURVEILLANCE CAPSULE CENTER

<u>Reaction</u>	<u>Measured</u>	<u>Adjusted Calculation</u>	<u>C/M</u>
Cu-63 (n, α) Co-60	4.10×10^{-17}	4.10×10^{-17}	1.00
Ti-46 (n,p) Sc-46	5.88×10^{-16}	5.86×10^{-16}	1.00
Fe-54 (n,p) Mn-54	3.24×10^{-15}	3.27×10^{-15}	1.01
Ni-58 (n,p) Co-58	4.35×10^{-15}	4.34×10^{-15}	1.00
U-238 (n,f) Cs-137 (Cd)	1.47×10^{-14}	1.47×10^{-14}	1.00
Co-59 (n, β) Cu-60 (Cd)	4.19×10^{-12}	4.18×10^{-12}	1.00
Co-59 (n, β) Co-60	6.27×10^{-13}	6.26×10^{-13}	1.00

TABLE 6-11
ADJUSTED NEUTRON ENERGY SPECTRUM AT
THE SURVEILLANCE CAPSULE CENTER

Group	Energy (Mev)	Adjusted Flux (n/cm ² -sec)	Group	Energy (Mev)	Adjusted Flux (n/cm ² -sec)
1	1.73x10 ¹	4.29x10 ⁶	28	9.12x10 ⁻³	3.55x10 ⁹
2	1.49x10 ¹	1.02x10 ⁷	29	5.53x10 ⁻³	3.68x10 ⁹
3	1.35x10 ¹	4.41x10 ⁷	30	3.36x10 ⁻³	1.22x10 ⁹
4	1.16x10 ¹	1.06x10 ⁸	31	2.84x10 ⁻³	1.22x10 ⁹
5	1.00x10 ¹	2.46x10 ⁸	32	2.40x10 ⁻³	1.23x10 ⁹
6	8.61x10 ⁰	4.23x10 ⁸	33	2.04x10 ⁻³	3.72x10 ⁹
7	7.41x10 ⁰	9.91x10 ⁸	34	1.23x10 ⁻³	3.76x10 ⁹
8	6.07x10 ⁰	1.36x10 ⁹	35	7.49x10 ⁻⁴	3.83x10 ⁹
9	4.97x10 ⁰	2.47x10 ⁹	36	4.54x10 ⁻⁴	3.90x10 ⁹
10	3.68x10 ⁰	2.58x10 ⁹	37	2.75x10 ⁻⁴	4.01x10 ⁹
11	2.87x10 ⁰	4.61x10 ⁹	38	1.67x10 ⁻⁴	4.48x10 ⁹
12	2.23x10 ⁰	1.02x10 ¹⁰	39	1.01x10 ⁻⁴	4.25x10 ⁹
13	1.74x10 ⁰	5.00x10 ⁹	40	6.14x10 ⁻⁵	4.25x10 ⁹
14	1.35x10 ⁰	4.01x10 ⁹	41	3.73x10 ⁻⁵	4.25x10 ⁹
15	1.11x10 ⁰	5.91x10 ⁹	42	2.26x10 ⁻⁵	4.23x10 ⁹
16	8.21x10 ⁻¹	5.76x10 ⁹	43	1.37x10 ⁻⁵	4.20x10 ⁹
17	6.39x10 ⁻¹	5.32x10 ⁹	44	8.32x10 ⁻⁶	4.20x10 ⁹
18	4.98x10 ⁻¹	3.82x10 ⁹	45	5.04x10 ⁻⁶	4.20x10 ⁹
19	3.88x10 ⁻¹	4.35x10 ⁹	46	3.06x10 ⁻⁶	4.20x10 ⁹
20	3.02x10 ⁻¹	6.82x10 ⁹	47	1.86x10 ⁻⁶	4.14x10 ⁹
21	1.83x10 ⁻¹	5.81x10 ⁹	48	1.13x10 ⁻⁶	4.06x10 ⁹
22	1.11x10 ⁻¹	4.92x10 ⁹	49	6.83x10 ⁻⁷	4.37x10 ⁹
23	6.74x10 ⁻²	4.24x10 ⁹	50	4.14x10 ⁻⁷	5.20x10 ⁹
24	4.09x10 ⁻²	3.42x10 ⁹	51	2.51x10 ⁻⁷	1.71x10 ¹⁰
25	2.55x10 ⁻²	2.08x10 ⁹	52	1.52x10 ⁻⁷	3.22x10 ¹⁰
26	1.99x10 ⁻²	1.98x10 ⁹	53	9.24x10 ⁻⁸	8.82x10 ¹⁰
27	1.50x10 ⁻²	3.42x10 ⁹			

NOTE: Tabulated energy levels represent the upper energy of each group.

TABLE 6-12

COMPARISON OF CALCULATED AND MEASURED
EXPOSURE LEVELS FOR CAPSULE W-253

	<u>Calculated</u>	<u>Measured</u>	<u>C/M</u>
$\Phi(E > 1.0 \text{ MeV}) \text{ (n/cm}^2\text{)}$	1.01×10^{19}	1.25×10^{19}	0.81
$\Phi(E > 0.1 \text{ MeV}) \text{ (n/cm}^2\text{)}$	2.06×10^{19}	2.61×10^{19}	0.79
dpa	1.54×10^{-2}	1.82×10^{-2}	0.85

TABLE 6-13

NEUTRON EXPOSURE PROJECTIONS AT KEY LOCATIONS
ON THE PRESSURE VESSEL CLAD/BASE METAL INTERFACE FOR MAINE YANKEE

$\phi(E > 1.0 \text{ MeV}) \text{ (n/cm}^2\text{)}$

OPERATING TIME (EFPY)	CYCLE 8 PROJECTION		CYCLE 10 PROJECTION	
	260 DEG	270 DEG	260 DEG	270 DEG
11.7	9.20×10^{18}	7.57×10^{18}	9.20×10^{18}	7.57×10^{18}
15.0	1.13×10^{19}	9.31×10^{18}	1.08×10^{19}	9.03×10^{18}
20.0	1.45×10^{19}	1.19×10^{19}	1.32×10^{19}	1.12×10^{19}
25.0	1.77×10^{19}	1.45×10^{19}	1.56×10^{19}	1.34×10^{19}
30.0	2.09×10^{19}	1.71×10^{19}	1.80×10^{19}	1.56×10^{19}
32.0	2.22×10^{19}	1.82×10^{19}	1.90×10^{19}	1.65×10^{19}

TABLE 6-14

UPDATED LEAD FACTORS FOR MAINE YANKEE
WALL SURVEILLANCE CAPSULES

<u>CAPSULE</u>	<u>Lead Factor</u>			
	<u>CYCLES</u> <u>1-11</u>	<u>CYCLES</u> <u>1-6</u>	<u>CYCLE</u> <u>8</u>	<u>CYCLE</u> <u>10</u>
W-83	1.451	1.454	1.446	1.456
W-263		Previously Withdrawn		
W-353	1.451	1.454	1.446	1.456
W-253	1.341	Current Evaluation		
W-343	1.341	1.343	1.336	1.345
W-160	1.220	1.223	1.216	1.224

SECTION 7.0
SURVEILLANCE CAPSULE REMOVAL SCHEDULE

The following removal schedule meets ASTM E185-82 and is suggested for future capsules to be removed from the Maine Yankee reactor vessel:

Capsule Location (deg.)	Capsule Lead Factor	Capsule Removal EFPY	Estimated Fluence (n/cm ²)
A-25	Withdrawn	-----	1.76 x 10 ¹⁹ (a)
A-35	Withdrawn	-----	6.53 x 10 ¹⁹
W-263	Withdrawn	4.58	0.572 x 10 ¹⁹
W-253 (b)	1.34	11.65	1.25 x 10 ¹⁹ (c)
W-353	1.45 (d)	22.0	2.2 x 10 ¹⁹ (e)
W-343	1.34 (d)	32.0 (EOL)	2.98 x 10 ¹⁹ (f)
W-83	1.45 (d)	Standby	- - - -
W-160	1.22 (d)	Standby	- - - -
W-263 (replacement capsule)		Standby	- - - -

-
- (a) Approximate 15 EFPY fluence
 - (b) Current evaluation
 - (c) Approximate fluence at 1/4 thickness reactor vessel wall at end of life (32 EFPY)
 - (d) Estimate based on azimuthal distribution using cycle 8 radial power distribution
 - (e) Approximate fluence at reactor vessel clad/base metal interface at end of life (32 EFPY)
 - (f) Fluence not less than once or greater than twice the peak end of life (32 EFPY) clad/base metal interface fluence

SECTION 8.0

REFERENCES

1. Shekherd, J.W., and Wullaert, R.A., "Unirradiated Mechanical Properties of Maine Yankee Nuclear Pressure Vessel Materials", CR 75-269, February 1, 1975.
2. Smith, R.W., "Analysis of the Maine Yankee First Accelerated Surveillance Capsule", YAEC-1083, Yankee Atomic Electric Company, October 18, 1975.
3. Wullaert, R.A. and Shekherd, J.W., "Evaluation of the First Maine Yankee Accelerated Surveillance Capsule", CR 75-317, Effects Technology, Inc., August 15, 1975.
4. Yanicho, Anderson, Shogan and Lott, "Analysis of the Maine Yankee Reactor Vessel Second Accelerated Surveillance Capsule", WCAP-9875, March 1981.
5. Perrin, Fromm, Farmelo, Denning and Jung, "Maine Yankee Nuclear Plant Reactor Pressure Vessel Surveillance Program: Capsule 263", BCL-585-21, December 12, 1980.
6. Code of Federal Regulations, 10CFR50, Appendix G, "Fracture Toughness Requirements", and Appendix H, "Reactor Vessel Material Surveillance Program Requirements," U.S. Nuclear Regulatory Commission, Washington, D.C.
7. Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials", U.S. Nuclear Regulatory Commission, February, 1986.
8. Section III of the ASME Boiler and Pressure Vessel Code, Appendix G, "Protection Against Nonductile Failure."
9. ASTM F208, "Standard Test Method for Conducting Drop-Weight Test to Determine Nil-Ductility Transition Temperature of Ferritic Steels."

10. ASTM E185-82, "Conducting Surveillance Tests for Light-Water Cooled Nuclear Power Reactor Vessels, E706 (IF)."
11. ASTM E23-88, "Standard Test Methods for Notched Bar Impact Testing of Metallic Materials."
12. ASTM A370-88, "Standard Test Methods and Definitions for Mechanical Testing of Steel Products."
13. ASTM E8-89b, "Standard Test Methods of Tension Testing of Metallic Materials."
14. ASTM E21-79(1988), "Standard Practice for Elevated Temperature Tension Tests of Metallic Materials."
15. ASTM E83-85, "Standard Practice for Verification and Classification of Extensometers."
16. Anderson, S. L. and Lippincott, E. P., "Summary of Fast Neutron Exposure Evaluations for the Maine Yankee Reactor Pressure Vessel", WCAP-11335, November 1986.
17. R. G. Soltesz, R. K. Disney, J. Jedruch, and S. L. Ziegler, "Nuclear Rocket Shielding Methods, Modification, Updating and Input Data Preparation. Vol. 5--Two-Dimensional Discrete Ordinates Transport Technique", WANL-PR(LL)-034, Vol. 5, August 1970.
18. "ORNL RSIC Data Library Collection DLC-76 SAILOR Coupled Self-Shielded, 47 Neutron, 20 Gamma-Ray, P3, Cross Section Library for Light Water Reactors".

19. ASTM Designation E482-82, "Standard Guide for Application of Neutron Transport Methods for Reactor Vessel Surveillance", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
20. ASTM Designation E560-77, "Standard Recommended Practice for Extrapolating Reactor Vessel Surveillance Dosimetry Results", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
21. ASTM Designation E693-79, "Standard Practice for Characterizing Neutron Exposures in Ferritic Steels in Terms of Displacements per Atom (dpa)", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
22. ASTM Designation E706-81a, "Standard Master Matrix for Light-Water Reactor Pressure Vessel Surveillance Standard", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
23. ASTM Designation E853-84, "Standard Practice for Analysis and Interpretation of Light-Water Reactor Surveillance Results", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
24. ASTM Designation E261-77, "Standard Method for Determining Neutron Flux, Fluence, and Spectra by Radioactivation Techniques", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
25. ASTM Designation E262-77, "Standard Method for Measuring Thermal Neutron Flux by Radioactivation Techniques", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.

26. ASTM Designation E263-82, "Standard Method for Determining Fast-Neutron Flux Density by Radioactivation of Iron", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
27. ASTM Designation E264-82, "Standard Method for Determining Fast-Neutron Flux Density by Radioactivation of Nickel", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
28. ASTM Designation E481-78, "Standard Method for Measuring Neutron-Flux Density by Radioactivation of Cobalt and Silver", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
29. ASTM Designation E523-82, "Standard Method for Determining Fast-Neutron Flux Density by Radioactivation of Copper", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
30. ASTM Designation E704-84, "Standard Method for Measuring Reaction Rates by Radioactivation of Uranium-238", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
31. ASTM Designation E705-79, "Standard Method for Measuring Fast-Neutron Flux Density by Radioactivation of Neptunium-237", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
32. ASTM Designation E1005-84, "Standard Method for Application and Analysis of Radiometric Monitors for Reactor Vessel Surveillance", in ASTM Standards, Section 12, American Society for Testing and Materials, Philadelphia, PA, 1984.
33. F. A. Schmittroth, FERRET Data Analysis Core, HEDL-TME 79-40, Hanford Engineering Development Laboratory, Richland, WA, September 1979.

34. W. N. McElroy, S. Berg and T. Crocket, A Computer-Automated Iterative Method of Neutron Flux Spectra Determined by Foil Activation, AFWL-TR-7-41, Vol. I-IV, Air Force Weapons Laboratory, Kirkland AFB, NM, July 1967.
35. EPRI-NP-2188, "Development and Demonstration of an Advanced Methodology for LWR Dosimetry Applications", R. E. Maerker, et al., 1981.
36. Maine Yankee Atomic Power Company Letters # HFJ-86-10, # HFJ-86-21, and # HFJ-90-038 to Westinghouse Electric Corporation, 03/20/86, 05/07/86, and 09/24/90, respectively.
37. S. L. Anderson, "Summary of fast Neutron Exposure Evaluations for the Maine Yankee Reactor Pressure Vessel Through Cycle 11", WCAP-11335, Revision 1, March 1991.
38. FSD-RSA-83/1812, "Analysis of Fast Neutron Flux Levels for the Maine Yankee Reactor Pressure Vessel, Revision 1", Letter from S. L. Anderson (Westinghouse) to Howard Jones (Maine Yankee), Dated January 3, 1984.
39. HFJ-91-13, "Materials Testing of Irradiated Surveillance Capsule Specimens PO 58404", letter from H. F. Jones (Maine Yankee) to Ed Terek (Westinghouse), Dated March 14, 1991.

APPENDIX A

Load-Time Records for Charpy Specimen Tests

A-1




Figure A-1. Idealized Load-Time Record




Figure A-2. Load-time record for Specimen 12T

A-3




Figure A-3. Load-time record for Specimen 13E




Figure A-4. Load-time record for Specimen 121




Figure A-5. Load-time record for Specimen 15M




Figure A-6. Load-time record for Specimen 124




Figure A-7. Load-time record for Specimen 12C

A-8




Figure A-8. Load-time record for Specimen 126




Figure A-9. Load-time record for Specimen 12M

A-10




Figure A-10. Load-time record for Specimen 12P




Figure A-11. Load-time record for Specimen 12D

A-12




Figure A-12. Load-time record for Specimen 12U




Figure A-13. Load-time record for Specimen 13K




Figure A-14. Load-time record for Specimen 31J




Figure A-15. Load-time record for Specimen 32L




Figure A-17. Load-time record for Specimen 35D

A-18




Figure A-18. Load-time record for Specimen 32K




Figure A-19. Load-time record for Specimen 3A2




Figure A-20. Load-time record for Specimen 33M




Figure A-21. Load-time record for Specimen 37J




Figure A-22. Load-time record for Specimen 317




Figure A-23. Load-time record for Specimen 36C




Figure A-24. Load-time record for Specimen 312




Figure A-25. Load-time record for Specimen 47Y




Figure A-26. Load-time record for Specimen 43J




Figure A-27. Load-time record for Specimen 433




Figure A-28. Load-time record for Specimen 47C




Figure A-29. Load-time record for Specimen 47J




Figure A-30. Load-time record for Specimen 471




Figure A-31. Load-time record for Specimen 438

A-32




Figure A-32. Load-time record for Specimen 46Y

A-33




Figure A-33. Load-time record for Specimen 43K

A-34




Figure A-34. Load-time record for Specimen 46U




Figure A-35. Load-time record for Specimen 473

A-36




Figure A-36. Load-time record for Specimen 61E




Figure A-37. Load-time record for Specimen 614




Figure A-38. Load-time record for Specimen 61C




Figure A-39. Load-time record for Specimen 6IM




Figure A-40. Load-time record for Specimen 627




Figure A-41. Load-time record for Specimen 62A




Figure A-42. Load-time record for Specimen 61A




Figure A-43. Load-time record for Specimen 61D




Figure A-44. Load-time record for Specimen 61T

A-45




Figure A-45. Load-time record for Specimen 6IU

A-46





Figure A-46. Load-time record for Specimen 61J



APPENDIX B

Equipment Calibration Data

Report & Certificate of Verification

C&M COLLINS CALIBRATION SERVICE

THIS IS TO CERTIFY that the following described testing machine has been calibrated by C&M CALIBRATION and the loading range(s) shown below found to be within a maximum tolerance of 1%.

MACHINE INSTRON 3481 TYPE LOAD CELL TENSION
 LOCATION WESTINGHOUSE ELECTRICAL CORP. CAPACITY 20000 lbs
1310 BULLARD RD PITTSBURGH PA SERIAL NO. 166

DATE OF VERIFICATION MAY 9 1990

Method of verification and below recorded data is in accordance with A.S.T.M. E-4 23A. The testing device(s) used for this calibration have certifications traceable to the National Institute of Standards Technology.

Machine Readings Pounds Newtons Kilograms Readings temperature corrected for 72.4 °F

MACHINE READING	CALIBRATION DEVICE READING	MACHINE ERROR		C.D. NO	MACHINE READING	CALIBRATION DEVICE READING	MACHINE ERROR		C.D. NO
		lbs	%				lbs	%	
50	50.15	-15	.30	1	200	200.29	-29	.14	2
100	100.30	-30	.30	1	400	400.43	-43	.11	2
200	200.11	-11	.06	1	800	802.96	-296	.37	2
300	300.32	-32	.11	2	1200	1205.2	-5.2	.43	2
400	399.98	+02	.01	2	1600	1606.1	-6.1	.38	2
500	499.87	+13	.03	2	2000	2009.2	-9.2	.46	3
100	100.59	-59	.59	1	500	503.43	-3.43	.69	2
200	201.11	-1.11	.55	1	1000	1006.7	-6.7	.67	2
400	403.70	-3.70	.67	2	2000	2014.7	-14.7	.73	3
600	603.39	-3.39	.56	2	3000	3020.9	-20.9	.70	3
800	804.52	-4.52	.56	2	4000	4027.1	-27.1	.68	3
1000	1006.2	-6.2	.62	2	5000	5033.2	-33.2	.66	3

CALIBRATION APPARATUS - Morehouse Proving Rings, Stainsense load cells & Troemner Dead Weights. Verifications traceable to the National Institute of Standards Technology, in accordance with A.S.T.M. latest specifications.

C.D. CODE	SERIAL NO.	LOADING RANGE CLASS A VALUE	CALIB. DATE	NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY LAB NO.		TEMP. OF C.D.
1	4758	25-200 lbs	5-27-88	66 / 156007		73
2	4757	240-2K lbs	5-27-88	737 / 229759		73
3	4755	1708-20K lbs	3-21-89	737.229759	73207 / 241080	73
4						
5						

MACHINE RANGE	LOADING RANGE
0 - 500 lbs	50 - 500 lbs
0 - 1000 lbs	100 - 1000 lbs
0 - 2000 lbs	200 - 2000 lbs
0 - 5000 lbs	500 - 5000 lbs

Primary Load Indicating Device

INSTRON CHART RECORDER

C & M COLLINS CALIBRATION SERVICE
 230 Haymont Dr., Box 149, Gibsonia, PA 15044
 (412) 443-7631

By: R. Butcher
 (SERVICE ENGINEER)

Witnessed By: _____

Report & Certificate of Verification

C&M COLLINS CALIBRATION SERVICE

THIS IS TO CERTIFY that the following described testing machine has been calibrated by C&M CALIBRATION and the loading range(s) shown below found to be within a maximum tolerance of 1%.

MACHINE INSIRON 3481 TYPE LOAD CELL TENSION

LOCATION WESTINGHOUSE ELECTRIC CORP. CAPACITY 20000 lbs

1310 BURLAIT RD P. 775 BURGESS PA. SERIAL NO. 166

DATE OF VERIFICATION MAY 9 1990

Method of verification and below recorded data is in accordance with A.S.T.M. E-4 33A. The testing device(s) used for this calibration have certifications traceable to the National Institute of Standards Technology.

Machine Readings Pounds Newtons Kilograms Readings temperature corrected for 73.4 °F.

MACHINE READING	CALIBRATION DEVICE READING	MACHINE ERROR		C.D. NO.	MACHINE READING	CALIBRATION DEVICE READING	MACHINE ERROR		C.D. NO.
			%					%	
1000	1007.2	-7.2	.72	1					
2000	2015.2	-15.2	.76	2					
4000	4029.7	-29.7	.74	2					
6000	6036.1	-36.1	.60	2					
8000	8049.1	-49.1	.61	2					
10000	10059.	-59.	.59	2					
3000	1997.2	+2.8	.14	2					
4000	3999.7	+3.	.01	2					
8000	8047.0	-47.0	.59	2					
12000	12047.	-47.	.39	2					
14000	14096.	-96.	.68	2					
16000	16117.	-117.	.73	2					

CALIBRATION APPARATUS - Morehouse Proving Rings, Stainsense load cells & Troemner Dead Weights. Verifications traceable to the National Institute of Standards Technology, in accordance with A.S.T.M. latest specifications.

O.D. CODE	SERIAL NO.	LOADING RANGE CLASS VALUE	CALIB. DATE	NATIONAL INSTITUTE OF STANDARDS TECHNOLOGY LAB NO.	TEMP. OF C.D.
1	4757	240-2K lbs	5-27-88	737 / 229759	73
2	4755	1808-20K lbs	3-21-89	737-229759	73
3				732.07 / 241080	
4					
5					

MACHINE RANGE	LOADING RANGE
0-10000 lbs	1000-10000 lbs
0-20000 lbs	2000-16000 lbs

Primary Load Indicating Device

INSIRON CHART RECORDER

C & M COLLINS CALIBRATION SERVICE
230 Haymont Dr., Box 149, Gibsonia, PA 15044
(412) 443-7631

By: R. But Collins
(SERVICE ENGINEER)

Witnessed By _____

WESTINGHOUSE SCIENCE & TECHNOLOGY CENTER
CALIBRATION RECORD

DATE: 6/1/90

INSTRUMENT BEING CALIBRATED: Tinius-Olsen Mod. 74, Ser. # 123159 Impact machine

LOCATION: Bldg. 302A low level cell

OPERATOR: L. M. Thomas

CALIBRATION METHOD: NIST standards per ASTM E23-86

Replace Watertown Standards

RESULTS:

Series	Average Value		Expected Energy Range
	Dial	Computer	
LL22	11.6	11.8	11-15 ft-lb
SRM 2092			
WM17	70.6	71.9	66-78 ft-lb
SRM 2096			

CALIBRATION ACCEPTABLE X NOT ACCEPTABLE

COMMENTS:

APPROVAL: _____

R. P. Shogan

Supervisor, Nuclear Services and Component Analysis

6/1/90
Date



National Institute of Standards & Technology

Certificate

Standard Reference Materials 2092 & 2096

Certified Low-Energy and High-Energy Samples for Charpy V-Notch Test¹ Machines

Standard Reference Materials (SRM's) 2092 and 2096 are intended primarily for the certification of Charpy V-Notch testing machines in accordance with ASTM Standard E-23. Each SRM consists of five 10 x 10 x 10 mm bars of 4340 alloy steel. The bars were fabricated from vacuum melted, vacuum arc remelted steel. The bars were cut to finished lengths, machined, and heat treated in SRM "lots" of 1200 bars.

A random sampling of bars was taken from each SRM lot and tested by a number of Charpy V-Notch test machines at NIST's Boulder, Colorado laboratory. These machines were chosen to represent the wide variety of Charpy V-Notch testing machines available in today's market. The data were statistically evaluated to assure the quality of the lot and a certified energy value for the lot was derived. Below is a table of hardness and energy ranges for SRM 2092 (Low Energy) and SRM 2096 (High Energy).

SRM No.	Hardness Range	Energy Range		
	(HRC)	(ft.-lbs)	(J)	(m-Kg)
2092	45 ± 1	11-15	15-20	1.5-2.1
2096	32 ± 1	66-78	90-106	9.1-10.8

Note: Each bar is identified by a Series number (two letters followed by two digits) identifying the lot from which the bar came and an identification number (three or four digits) representing the location of the bar within the lot. These numbers are stamped on one end of each bar.

Use:

Prior to testing a Charpy V-Notch testing machine, the machine should be checked to assure compliance with sections 4 and 5 of ASTM Standard E-23. Specimens are to be tested at -40°F (-40°C) and in accordance with the testing procedures of Sections 11.2.1 and 11.2.3.1 of E-23. An accurate machine will produce values within 1.0 ft-lb or 5 percent of the certified energy value, whichever is greater.

Notice to User:

- The five specimens in both SRM 2092 and SRM 2096 (a total of ten specimens) must be tested for certification in accordance with ASTM Standard E-23.
- Each SRM must consist of samples with identical Series numbers.

Because the source(s) of erroneous energy values at one energy level may not be the same at different energy levels, calibration or correction curves should not be used.

Gaithersburg, MD 20899
March 26, 1990
(Revision of certificates
dated 8-31-89 & 12-20-89)

William P. Reed, Acting Chief
Standard Reference Materials Program

(over)

Certification of Machine:

The National Institute of Standards and Technology (NIST) will issue a report of its findings to your facility upon receipt of the fractured specimens and completed questionnaire. If your machine produces acceptable values, this report will certify the conformance of your machine. If your machine produces values outside the allowable tolerance of the certified energy values, this report will suggest changes in machine design, repair or replacement of machine parts, changes in testing techniques, etc. Fractured specimens and completed questionnaires should be returned to Charpy Program Coordinator, NIST Code 430, 325 Broadway, Boulder CO 80303. A plastic, self-locking bag is provided for the return of broken specimens. Tape broken pieces together as described in the wrapping instructions (last page of the questionnaire).

The certification you will receive is valid for one year from the date of the test.

If your machine is moved or undergoes any major repairs or adjustments, the current certification becomes invalid and the machine must be recertified. Removal of the pendulum, replacement of the anvils or adjustment of the height of drop are examples of such major repairs or adjustments. If a specimen requires over 80 percent of the machine capacity to fracture, the machine should be checked to assure that the pendulum is straight, the anvils or striker have not been damaged and that all bolts are still tight.

General Information:

Shipping charges for the return of broken specimens are the responsibility of the customer. The mailing label which is provided must be used to expedite shipping and, for overseas shipments, clearance by U.S. Customs.

Note to International Customers: Overseas shipments should be sent by airmail so that after the packages have been cleared by U.S. Customs, they will be forwarded directly to NIST-Boulder. If more rapid shipment is necessary, choose an overnight delivery service that will handle U.S. Customs clearance and will deliver directly to NIST-Boulder. Unless you assure delivery, airfreight packages may be returned to the customer by U.S. Customs instead of being forwarded to NIST-Boulder.

This SRM is anticipated to have an indefinite shelf life under normal storage conditions. The SRM is coated with oil, wrapped in a corrosion inhibiting paper, and sealed in a plastic envelope. We recommend that the SRM be retained in this package to protect it from moisture until it is used. The protective oil coating should be wiped from the SRM just prior to testing.

The overall direction and coordination of the technical measurements leading to certification of test specimens and machines, evaluation of test results and issuance of the report on machine conformance are under the direction of D. A. Shepherd, Materials Reliability Division, NIST. Questions concerning any of the above should be directed to D.A. Shepherd, Telephone: (303) 497-3211, Telefax: (303) 497-5030.

Technical and support aspects concerning the preparation, certification of the material and issuance of these Standard Reference Materials were coordinated through the Standard Reference Materials Program by J. Falco and R.L. McKenzie.

dynatup**General Research Corp.**

A GPC International Company

111 CASTILIAN DRIVE
SANTA BARBARA, CA 93117-3093
TELEPHONE (805) 685-2772
TELEFAX (805) 685-9638ALUMINUM CHARPY CALIBRATION SPECIMENS

These calibration specimens allow the dynamic calibration of the tup and data system to be checked. To perform a check, compare the average measured maximum load for a group of at least five calibration specimens to the reference maximum load listed below. Variations from the reference value that exceed the listed tolerance indicate a calibration problem. Note that energy values will vary significantly. These specimens cannot be used for energy calibration. For equipment requiring energy calibration, Watertown Arsenal (AMMRC) specimens must be used.

These standard dimension Charpy specimens (ASTM Method E23) are prepared from aluminum alloy bar. Each specimen is identified with a scribed number. The material is slightly strain rate sensitive. For this reason, the average maximum load value for a minimum of five specimens will vary with impact velocity.

Maximum Load		Tolerance	Velocity	
lb	(kn)	Percent	ft/s	(m/s)
1845	(8.206)	4.0%	11.0	(3.353)
1846	(8.211)	4.0%	17.0	(5.182)

The instrumentation response time (TR) should be approximately 80 micro-seconds. Smaller TR values will result in higher maximum load values. When using the DYNATUP Model 730-I or 600 series data systems, the test time, filtering and smoothing must be set as follows to achieve the correct TR value.

Model Number	Test Time	Filter No.	Smoothing (2m+1 data pts)
<u>730-I or 830-I</u>			
1024 data pts (Normal)	10 ms	1	m = 4
2048 data pts	10 ms	1	m = 8
<u>600 Series</u>			
All Systems	10 ms	1	m = 8

Note:

While all standard scientific precautions are followed in the production of these specimens, they are not manufactured in accordance with specifications written by the NRC, ASTM, etc. For applications requiring equipment to be calibrated to any particular specification, use of these specimens may not be accepted.

These 100 ea. specimens are from Lot No. B 6/90

Shipping Date: 6-26-90
An Equal Opportunity Employer