

APPENDIX

U.S. NUCLEAR REGULATORY COMMISSION  
REGION IV

NRC Inspection Report: 50-285/91-07

Operating License: DPR-40

Docket: 50-285

Licensee: Omaha Public Power District (OPPD)  
444 South 16th Street Mall  
Mail Stop 8E/EP4  
Omaha, Nebraska 68102-2247

Facility Name: Fort Calhoun Station (FCS)

Inspection At: FCS Site, Blair, Nebraska

Inspection Conducted: April 15-19, 1991

Inspectors:

*J. B. Nicholas*  
J. B. Nicholas, Senior Radiation Specialist  
Radiological Protection and Emergency  
Preparedness Section

5/20/91  
Date

*L. Wilborn*  
L. Wilborn, Radiation Specialist, Radiological  
Protection and Emergency Preparedness Section

5/20/91  
Date

*A. D. Gaines*  
A. D. Gaines, Radiation Specialist  
Radiological Protection and Emergency  
Preparedness Section

5/20/91  
Date

Approved:

*Blaine Murray*  
Blaine Murray, Chief, Radiological Protection  
and Emergency Preparedness Section

5/20/91  
Date

## Inspection Summary

Inspection Conducted April 15-19, 1991 (Report 50-285/91-07)

Areas Inspected: Routine, announced inspection of the licensee's water chemistry and radiochemistry programs including water chemistry and radiochemistry confirmatory measurements.

Results: The inspectors determined that the licensee had developed and implemented a water chemistry program and radiochemistry program based on regulatory and industry guidelines. The water chemistry and radiochemistry programs were being conducted in accordance with Technical Specification (TS) requirements. The licensee's chemistry staff had experienced a personnel turnover of approximately 30 percent over the past 22 months. Quality Assurance (QA) surveillances and audit had been performed as required and were technically comprehensive. The results of the water chemistry confirmatory measurements from the secondary chemistry laboratory indicated 90 percent agreement with the NRC's results and the radiochemistry laboratory results were in 83 percent agreement. The licensee's performance showed approximately the same performance as the 92 percent agreement and 80 percent agreement as reported for the two laboratories, respectively, during the previous NRC inspection of this area conducted in June 1989. The licensee's radiological confirmatory measurements results were in 98 percent agreement with the NRC's results. This showed a performance equivalent to the 98 percent agreement achieved during the NRC inspection of this area in June 1989.

Within the areas inspected, no violations or deviations were identified. One unresolved item and three open items which were previously identified were closed.

## DETAILS

### 1. Persons Contacted

#### OPPD

- \*W. C. Jones, Senior Vice President, OPPD
- \*T. L. Patterson, Manager, FCS
- R. C. Beck, Chemistry Laboratory Specialist
- A. D. Bilau, Supervisor, Radwaste
- J. B. Biggs, Chemist
- \*F. F. Franco, Manager, Radiological Services
- A. F. Friebe, Chemistry, Technician
- \*J. K. Gasper, Manager, Training
- J. M. Glantz, Chemist, Radiological Services
- \*R. L. Jaworski, Manager, Station Engineering
- J. G. Krist, Environmental Scientist, Radiological Services
- \*L. T. Kusek, Manager, Nuclear Safety Review
- \*W. W. Orr, Manager, QA/Quality Control (QC)
- B. A. Schmidt, Supervisor, Secondary Chemistry
- \*L. D. Sills, QA Auditor
- \*C. F. Simmons, Station Licensing Engineer
- \*F. K. Smith, Supervisor, Chemistry
- \*D. E. Spires, QA Auditor
- \*T. G. Therkildsen, Acting Manager, Licensing and Industry Affairs

#### NRC

- \*R. P. Mullikin, Senior Resident Inspector, FCS

\*Denotes those present during the exit interview on April 19, 1991.

### 2. Followup on Previously Identified Inspection Findings (92701)

(Closed) Unresolved Item (285/9011-01): Failure to Complete All Identified Training for the Radwaste Staff - This unresolved item was identified in NRC Inspection Report 50-285/90-11 and involved radwaste personnel who had not completed training covering all the objectives in Lesson Plans 19-23-18, "Shipment and Receipt of Radioactive Material," and 19-24-35, "Shipment/Receipt Surveys." During this inspection, the inspectors verified that the licensee had provided formal training commensurate with radwaste personnel job assignments. The licensee provided radiation protection fundamentals training for junior radwaste technicians starting in July 1990. A radioactive material shipping and packing workshop course and site-specific training were provided in December 1990 for the senior radiation protection technicians, as well as the radwaste operations coordinator, contamination control coordinator, and the radioactive waste operations supervisor. The junior radwaste technicians attended the site-specific training. The inspectors verified that no licensee personnel had performed activities in this area without the appropriate training. The licensee's actions were adequate to close this unresolved item.

(Closed) Open Item (285/9041-01): Radioactive Waste Material Shipment Dose Rates - This open item was identified in NRC Inspection Report 50-285/90-41 and involved revising radwaste procedures to include the corrective actions outlined in the licensee's response to a violation of the state of Washington's Administrative Code and U.S. Ecology, Inc.'s Radioactive Materials License WN-ID19-2. The violation resulted from a discrepancy between the licensee's external radiation reading on Drum 90-CT-0383 in a radwaste shipment on April 5, 1990, and the burial site's external radiation reading on that drum during a receipt inspection of the shipment on April 9, 1990. The inspectors verified that the changes to Procedures RP-401 and RW-312 and Forms FC-RW-201-1 and FC-RW-304-2 incorporated those corrective actions committed to by the licensee in its response to the state of Washington. The licensee's procedural changes were adequate to close this open item.

(Closed) Open Item (285/9041-02): QA Radiological Effluent Surveillance Program - This open item was identified in NRC Inspection Report 50-285/90-41 and involved the lack of semiannual QA surveillances of liquid and gaseous radiological effluent releases performed in years previous to 1989. The inspectors reviewed the licensee's QA surveillance schedules for 1990 and 1991 and noted that Surveillance B-1, "Radioactive Effluent Release Summary Report," was scheduled semiannually for June and December. The licensee's actions were adequate to close this open item.

(Closed) Open Item (285/9041-03): Chemistry Section Radioactive Effluent Dose Calculations - This open item was identified in NRC Inspection Report 50-285/90-41 and involved the licensee altering the monitor tank radionuclide input listing and not changing the data input table to correspond to the radionuclide input listing for the licensee's computer code written by the licensee to determine compliance with the TS requirements. The results of this computer software modification caused the input data for several radionuclides to be out-of-order and not correspond with the correct radionuclide listed in the computer code, thus causing erroneous dose results. The inspectors determined that the licensee had modified the data input table to properly correspond to the radionuclide input listing. The inspectors verified that the chemistry section software computed doses for radioactive liquid effluents were in accordance with the Offsite Dose Calculation Manual equations and table values and were in agreement with the NRC's computed doses for the adult total body and the adult critical organ (liver). The licensee's actions were adequate to close this open item.

(Open) Open Item (285/9041-04): Radiological Services Group Radioactive Dose Calculations - This open item was identified in NRC Inspection Report 50-285/90-41 and involved differences in the calculated dose results between the licensee's radiological services group and the NRC for the various age groups and critical organs resulting from radioactive liquid and gaseous effluents. The inspectors determined that the licensee had completed their study and research of the computer code, LADTAP, and had made the necessary corrections to the dose factor library so that it conformed with the dose factor tables in Regulatory Guide 1.109, Revision 1. The inspectors performed additional confirmatory dose

calculations with the licensee and verified that all calculated doses resulting from radioactive liquid effluents compared exactly between the licensee and the NRC for all age groups (adult, teen, child, and infant) and for all critical organs (liver, thyroid, kidney, lung, gastro-intestine, and total body). The licensee's actions were satisfactory to close the radioactive liquid effluent dose calculation portion of the open item.

The licensee was continuing their study, research, and investigations into the computer code, GASPAR, for calculating doses resulting from radioactive effluent airborne iodine and particulates. The licensee's original calculated doses for ingestion pathways including cow meat, cow milk, and vegetation indicated that the licensee's dose results were nonconservative when compared to the NRC's calculated doses. The licensee had established an action plan and schedule for researching and correcting their GASPAR computer code so that their calculated dose results from airborne iodine and particulates will compare with the NRC's calculated doses. The licensee indicated that their action plan was on schedule and would be completed by their proposed completion date of July 31, 1991. The gaseous effluent portion of this open item will remain open pending further review by the inspectors.

3. Organization and Management Controls (84750)

The inspectors reviewed the licensee's organization and staffing of the FCS chemistry section to determine agreement with commitments in Chapter 12 of the Updated Safety Analysis Report (USAR) and compliance with the requirements of TS 5.2.

The inspectors reviewed the organization structure of the FCS chemistry section and verified it to be as described in the USAR and TS. Since the previous NRC inspection of the licensee's chemistry program conducted in June 1989, the licensee had made one supervisory organizational change and had added six new chemistry technicians. A supervisory position responsible for hazardous materials had been established. At the time of the inspection, the FCS chemistry staff was composed of a chemistry supervisor, four assistant chemistry supervisors, seven chemists and laboratory assistants, six shift-qualified chemistry technicians, four contractor staff chemists, and five chemistry technicians in training. There were two vacancies in the chemistry technical staff which were not presently filled. The four assistant chemistry supervisors report directly to the chemistry supervisor. Each of these assistant chemistry supervisors were responsible for a specific chemistry area (i.e., secondary chemistry, radiochemistry, laboratories, and hazardous materials). The chemistry technical staff personnel were assigned to work in the various chemistry areas and reported to their respective assistant chemistry supervisor. The inspectors were informed that as the five new chemistry technicians complete their shift-qualification training, they will replace three of the contractor chemistry technical staff and fill the two technician vacancies. The fourth contractor position will not

remain authorized. This will completely fill the 19 authorized chemistry section technical staff positions with OPPD personnel.

Since the previous NRC chemistry inspection in June 1989, the FCS chemistry section had experienced a personnel turnover of approximately 30 percent. This personnel turnover was identical to the chemistry section personnel turnover experienced during the 12 months prior to June 1989 which indicated a reduction in chemistry staff turnover at that time. This is a positive indication of chemistry staff stability.

No violations or deviations were identified.

4. Training and Qualifications (84750)

The inspectors reviewed the licensee's continuing training and qualification program for FCS chemistry section personnel to determine agreement with commitments in Chapter 12 of the USAR and compliance with the requirements in TS 5.3 and 5.4.

The inspectors reviewed the experience, educational backgrounds, and qualifications of the present chemistry staff and determined that all met the ANSI 18.1-1971 qualification requirements and qualifications specified in the USAR and TS except for the five new staff members, who were currently in training. It was determined that the licensee had an adequately qualified chemistry staff.

The inspectors reviewed: (1) the chemistry staff training records for shift qualification, (2) the requalification and continuing training program, (3) the postaccident sampling system operator requalification training, (4) the initial chemistry training program including the use of performance evaluation checklists for documentation of on-the-job training (OJT) leading to shift qualification, and (5) the chemistry instructors' training and certifications. The initial and continuing chemistry training programs and training calendar for 1991 appeared satisfactory. The inspectors determined that the licensee's training program for the FCS chemistry staff was being implemented in accordance with the FCS chemistry training procedures. The chemistry OJT for the new chemistry technicians was being completed as rapidly as time and routine chemistry activities would permit.

No violations or deviations were identified.

5. QA Program (84750)

The inspectors reviewed the licensee's QA surveillance and audit programs regarding water chemistry and radiochemistry activities to determine agreement with commitments in Chapter 12 of the USAR and compliance with the requirements in TS 5.5.2.8.

The inspectors reviewed the licensee's audit and surveillance schedules for 1990 and 1991 and the qualifications of the QA auditors. Audit and



surveillance reports generated from QA activities during the period January 1989 through April 1991 in the area of chemistry were reviewed for scope and depth to ensure thoroughness of the chemistry program evaluation and timely followup of identified deficiencies. The inspectors determined that the surveillances, audit plan, and audit checklist were comprehensive. The inspectors determined that the QA surveillances and audit of the chemistry program were performed in accordance with FCS procedures and schedules and by qualified auditors who were experienced in nuclear power facility chemistry activities.

No violations or deviations were identified.

6. Confirmatory Measurements for Chemistry Analysis (84750)

The inspectors reviewed the licensee's water chemistry analysis program by performing water chemistry confirmatory measurements to determine agreement with the commitments in Chapter 4 of the USAR and compliance with TS 2.1.5, 2.2, 5.8, and 5.13.

The inspectors reviewed selected water chemistry procedures revised since the previous NRC chemistry inspection conducted in June 1989 and determined that the licensee had implemented sufficient programmatic procedures to meet the commitments of the USAR and TS requirements.

During the inspection, the inspectors provided standard chemical solutions to the licensee for confirmatory measurement analyses. The standards were analyzed by the licensee in both the secondary chemistry laboratory and the radiochemistry laboratory using routine analytical methods and equipment. The results of the measurement comparisons are summarized in Attachments 1, 2, and 3 of this report. The licensee's analytical results from the secondary chemistry laboratory indicated 90 percent agreement with the Brookhaven National Laboratory (BNL) results. This was approximately the same performance in the secondary chemistry laboratory as the 92 percent agreement reported during the previous NRC inspection conducted in June 1989. The licensee's analytical results from the radiochemistry laboratory indicated 83 percent agreement with the BNL results. The licensee's performance in the radiochemistry laboratory showed a slight improvement over the 80 percent agreement reported in the previous NRC inspection conducted in June 1989.

No violations or deviations were identified.

7. Confirmatory Measurements for Radiochemistry Analysis (84750)

The inspectors reviewed the licensee's radiochemical analysis program by performing radiochemistry confirmatory measurements to determine agreement with the commitments in Chapter 4 of the USAR and compliance with TS 2.1, 2.9.1, 2.20, 3.2, 3.12, 5.8, and 5.15.

The inspectors reviewed selected radiochemistry procedures revised since the previous NRC chemistry inspection conducted in June 1989 and

determined that the licensee had implemented sufficient radioanalytical procedures to meet the commitments of the USAR and TS requirements.

During the inspection, radiochemistry confirmatory measurements were performed on standards and split samples by the licensee and the inspectors in the Region IV mobile laboratory on site. The standards and samples were analyzed by the licensee using routine methods and equipment. The results of the measurements comparisons are summarized in Attachments 1 and 5 of this report. The licensee's analytical results from the radiochemistry counting room indicated 98 percent agreement with the NRC's mobile laboratory analytical results. These radiochemistry confirmatory measurement results were equivalent to the high quality performance of 98 percent agreement reported during the previous NRC chemistry confirmatory measurements inspection conducted in June 1989.

No violations or deviations were identified.

8. Exit Meeting (30703)

The inspectors met with the NRC senior resident inspector and the licensee representatives identified in paragraph 1 of this report at the conclusion of the inspection on April 19, 1991. The inspectors summarized the scope and findings of the inspection and discussed the results of the water chemistry and radiochemistry confirmatory measurements as presented in the report. The licensee did not identify as proprietary any of the materials provided to, or reviewed by, the inspectors during the inspection.





















## 4. Boron Analysis (400-2500 ppm) Manitol Titration

Sample	FCS Results (ppm)	NRC Results (ppm)	Comparison Decision
88D	502	513	Qual. Agree.
88E	751	748	Agreement
88F	2499	2550	Agreement
Retest - prepared new BNL boron standard dilution, prepared new boron calibration standard, recalibrated the titrator, and performed retest analysis			
88D	505	513	Agreement

## 5. Iron Analysis (3-50 ppm) Flame Atomic Absorption

Sample	FCS Results (ppm)	NRC Results (ppm)	Comparison Decision
88G	3.81	3.96	Agreement
88H	17.80	19.60	Agreement
88I	26.30	29.00	Agreement

## 6. Copper Analysis (3-50 ppm) Flame Atomic Absorption

Sample	FCS Results (ppm)	NRC Results (ppm)	Comparison Decision
88G	3.86	3.98	Agreement
88H	20.21	20.25	Agreement
88I	30.80	29.75	Agreement

## 7. Nickel Analysis (3-50 ppm) Flame Atomic Absorption

Sample	FCS Results (ppm)	NRC Results (ppm)	Comparison Decision
88G	4.10	4.06	Agreement
88H	18.50	20.15	Qual. Agree.
88I	26.30	30.50	Disagreement

## 8. Chromium Analysis (3-50 ppm) Flame Atomic Absorption

Sample	FCS Results (ppm)	NRC Results (ppm)	Comparison Decision
88G	3.94	4.00	Agreement
88H	18.65	20.20	Agreement
88I	27.10	30.00	Agreement

## 9. Lithium Analysis (2-50 ppm) Flame Atomic Absorption

Sample	FCS Results (ppm)	NRC Results (ppm)	Comparison Decision
87J	2.03	1.97	Agreement
87K	3.17	3.00	Agreement
88L	4.25	3.95	Agreement

## 10. Ammonia Analysis (20-3000 ppb) Spectroscopy

Sample	FCS Results (ppb)	NRC Results (ppb)	Comparison Decision
88M	49.00	51.00	Agreement
88N	144.00	155.00	Agreement
88O	513.00	500.00	Agreement

## 11. Hydrazine Analysis (10-600 ppb) Spectroscopy

Sample	FCS Results (ppb)	NRC Results (ppb)	Comparison Decision
88P	19.30	20.40	Agreement
88Q	39.90	42.30	Agreement
88R	159.30	164.80	Agreement

## 12. Silica Analysis (10-2000 ppb) Spectroscopy

Sample	FCS Results (ppb)	NRC Results (ppb)	Comparison Decision
87S	49.00	52.00	Agreement
86T	101.00	109.00	Agreement
87U	285.00	314.00	Qual. Agree.

## ATTACHMENT 3

4

## 13. Postaccident Sample Matrix Analysis Ion Chromatograph

Analysis	FCS Results (ppm)	NRC Results (ppm)	Comparison Decision
Chloride	12.40	11.30	Agreement
Boron	2020.00	2060.00	Agreement





## ATTACHMENT 4

2

Ampule	Analyte	Agreement Range	Qualified Agreement Range
88M	NH <sub>3</sub>	46.00 - 56.00	44.00 - 59.00
88N	NH <sub>3</sub>	140.00 - 170.00	132.00 - 178.00
88O	NH <sub>3</sub>	452.00 - 548.00	428.00 - 572.00
88P	N <sub>2</sub> H <sub>4</sub>	18.80 - 22.00	18.00 - 22.80
88Q	N <sub>2</sub> H <sub>4</sub>	39.00 - 45.80	37.40 - 47.20
88R	N <sub>2</sub> H <sub>4</sub>	155.80 - 181.80	149.20 - 188.40
87S	SiO <sub>2</sub>	47.40 - 56.60	45.10 - 58.90
86T	SiO <sub>2</sub>	100.00 - 120.00	95.00 - 125.00
87U	SiO <sub>2</sub>	300.00 - 360.00	284.00 - 376.00

The ranges for the data in Attachment 3 is as follows:

Ampule	Analyte	Agreement Range	Qualified Agreement Range
88A	F	21.00 - 27.00	20.00 - 28.00
	Cl	28.00 - 32.00	27.00 - 33.00
	SO <sub>4</sub>	17.00 - 21.00	16.00 - 22.00
88B	F	42.00 - 54.00	40.00 - 56.00
	Cl	57.00 - 67.00	55.00 - 69.00
	SO <sub>4</sub>	34.00 - 42.00	33.00 - 43.00
88C	F	65.00 - 83.00	61.00 - 87.00
	Cl	88.00 - 102.00	85.00 - 105.00
	SO <sub>4</sub>	54.00 - 66.00	52.00 - 68.00
88D	B	504 - 526	499 - 532
88E	B	732 - 764	724 - 772
88F	B	2495 - 2605	2469 - 2632



# ATTACHMENT 5

## Radiological Confirmatory Measurement Results

### Fort Calhoun Station

NRC Inspection Report: 50-285/91-07

#### 1. NRC Air Particulate Filter Standard (34118-109) (Standardized: 08:00, CDT, April 15, 1991)

The standard was analyzed by the licensee using their Canberra Series-80 and Series-90 analytical systems in their radiochemistry counting room and the isotopic results from the two systems's analyses are reported in that order in the following table.

Nuclide	FCS Results (uCi/sample)	NRC Results (uCi/sample)	FCS/NRC Ratio	Comparison Decision
Co-57	8.110±0.280E-3	7.717±0.081E-3	1.05	Agreement
	8.630±0.400E-3		1.12	Agreement
Ce-139	3.750±0.190E-3	3.330±0.073E-3	1.13	Agreement
	3.830±0.200E-3		1.15	Agreement
Sn-113	4.960±0.260E-3	4.720±0.148E-3	1.05	Agreement
	4.940±0.200E-3		1.05	Agreement
Cs-137	7.320±0.200E-2	6.852±0.032E-2	1.07	Agreement
	7.370±0.260E-2		1.08	Agreement
Y-88	6.850±0.290E-3	6.325±0.212E-3	1.08	Agreement
	6.660±0.250E-3		1.05	Agreement
Co-60	7.160±0.190E-2	6.671±0.039E-2	1.07	Agreement
	7.070±0.210E-2		1.06	Agreement

2. FCS Air Particulate Filter Standard (38210-22)  
 (Standardized: 11:00, <sup>137</sup>Cs, January 1, 1991)

The standard was analyzed by the licensee using their Canberra Series-80 and Series-90 analytical systems in their radiochemistry counting room and the isotopic results from the two systems's analyses are reported in that order in the following table.

Nuclide	FCS Results (uCi/sample)	NRC Results (uCi/sample)	FCS/NRC Ratio	Comparison Decision
Co-57	2.600±0.090E-2	2.355±0.016E-2	1.10	Agreement
	2.740±0.120E-2		1.16	Agreement
Ce-139	4.170±0.190E-2	3.638±0.023E-2	1.15	Agreement
	4.050±0.200E-2		1.11	Agreement
Hg-203	6.560±0.310E-2	5.716±0.066E-2	1.15	Agreement
	6.400±0.280E-2		1.12	Agreement
Sn-113	8.360±0.350E-2	7.829±0.050E-2	1.07	Agreement
	8.550±0.280E-2		1.09	Agreement
Cs-137	6.420±0.170E-2	5.865±0.033E-2	1.09	Agreement
	6.480±0.230E-2		1.10	Agreement
Y-88	1.380±0.040E-1	1.287±0.008E-1	1.07	Agreement
	1.380±0.040E-1		1.07	Agreement
Co-60	7.000±0.180E-2	6.472±0.066E-2	1.08	Agreement
	6.930±0.210E-2		1.07	Agreement

3. NRC CESCO Charcoal Cartridge Standard (34119-109)  
 (Standardized: 08:00, CDT, April 15, 1991)

The standard was analyzed by the licensee using their Canberra Series-80 and Series-90 analytical systems in their radiochemistry counting room and the isotopic results from the two systems's analyses are reported in that order in the following table.

Nuclide	FCS Results ( $\mu\text{Ci/sample}$ )	NRC Results ( $\mu\text{Ci/sample}$ )	FCS/NRC Ratio	Comparison Decision
Co-57	1.150 $\pm$ 0.038E-2	1.045 $\pm$ 0.010E-2	1.10	Agreement
	1.160 $\pm$ 0.054E-2		1.11	Agreement
Ce-139	5.350 $\pm$ 0.253E-3	4.529 $\pm$ 0.088E-3	1.18	Agreement
	4.910 $\pm$ 0.256E-3		1.08	Agreement
Sn-113	6.630 $\pm$ 0.312E-3	6.213 $\pm$ 0.168E-3	1.07	Agreement
	6.170 $\pm$ 0.294E-3		0.99	Agreement
Ca-137	10.10 $\pm$ 0.265E-2	8.720 $\pm$ 0.039E-2	1.16	Agreement
	9.450 $\pm$ 0.273E-2		1.08	Agreement
Y-88	9.060 $\pm$ 0.326E-3	8.213 $\pm$ 0.231E-3	1.10	Agreement
	8.760 $\pm$ 0.299E-3		1.07	Agreement
Co-60	9.480 $\pm$ 0.244E-2	8.338 $\pm$ 0.043E-2	1.14	Agreement
	9.180 $\pm$ 0.251E-2		1.10	Agreement

4. FCS TKDA 2 Charcoal Cartridge Standard (38207A-22)  
(Standardized: 11:00, GST, January 1, 1991)

The standard was analyzed by the licensee using their Canberra Series-80 and Series-90 analytical systems in their radiochemistry counting room and the isotopic results from the two systems's analyses are reported in that order in the following table.

Nuclide	FCS Results (uCi/sample)	NRC Results (uCi/sample)	FCS/NRC Ratio	Comparison Decision
Co-57	2.790±0.090E-2	2.591±0.019E-2	1.08	Agreement
	2.800±0.130E-2		1.08	Agreement
Ce-139	4.460±0.200E-2	3.972±0.027E-2	1.12	Agreement
	4.190±0.220E-2		1.05	Agreement
Hg-203	6.960±0.320E-2	6.813±0.071E-2	1.20	Agreement
	6.550±0.330E-2		1.13	Agreement
Sn-113	8.950±0.370E-2	8.250±0.058E-2	1.08	Agreement
	8.230±0.370E-2		1.00	Agreement
Cs-137	6.930±0.180E-2	6.240±0.037E-2	1.11	Agreement
	6.480±0.190E-2		1.04	Agreement
Y-88	1.470±0.040E-1	1.354±0.008E-1	1.09	Agreement
	1.400±0.040E-1		1.03	Agreement
Co-60	7.440±0.190E-2	6.768±0.041E-2	1.10	Agreement
	7.130±0.200E-2		1.05	Agreement



5. Waste Liquid Holding Tank "C" Sample  
(Sampled: 13:53, CDT, April 10, 1989)

The sample was analyzed by the licensee using their Canberra Series-80 and Series-90 analytical systems in their radiochemistry counting room and the isotopic results from the two systems' analyses are reported in that order in the following table.

Nuclide	FCS Results (uCi/ml)	NRC Results (uCi/ml)	FCS/NRC Ratio	Comparison Decision
Mn-54	3.140±0.110E-5	3.161±0.058E-5	0.99	Agreement
	3.110±0.110E-5		0.98	Agreement
Co-58	2.100±0.060E-4	2.102±0.011E-4	1.00	Agreement
	2.080±0.060E-4		0.99	Agreement
Co-60	1.740±0.070E-5	1.905±0.045E-5	0.91	Agreement
	1.770±0.080E-5		0.93	Agreement
Sb-125	1.550±0.320E-5	2.026±0.019E-5	0.76	Disagreement
	1.750±0.220E-5		0.86	Agreement
I-131	2.230±1.020E-6	3.654±0.635E-6	0.61	Agreement
	3.350±0.690E-6		0.92	Agreement
Cs-134	4.280±0.110E-4	4.155±0.016E-4	1.03	Agreement
	4.270±0.130E-4		1.03	Agreement
Cs-137	7.190±0.190E-4	7.207±0.020E-4	1.00	Agreement
	7.200±0.260E-4		1.00	Agreement

6. Reactor Coolant Gas Sample  
(Sampled: 17:15, CDT, April 16, 1991)

The sample was analyzed by the licensee using their Canberra Series-80 and Series-90 analytical systems in their radiochemistry counting room and the isotopic results from the two systems's analyses are reported in that order in the following table.

Isotope	FCS Results (uCi/cc)	NRC Results (uCi/cc)	FCS/NRC Ratio	Comparison Decision
Ar-41	4.020±0.280E-3	4.142±0.137E-3	0.97	Agreement
	4.280±0.260E-3		1.03	Agreement
Kr-85m	1.360±0.050E-2	1.445±0.013E-2	0.94	Agreement
	1.350±0.050E-2		0.93	Agreement
Kr-87	2.600±0.110E-2	2.602±0.029E-2	0.92	Agreement
	2.490±0.110E-2		0.89	Agreement
Kr-88	3.300±0.240E-2	3.300±0.038E-2	1.00	Agreement
	3.130±0.230E-2		0.94	Agreement
Xe-133m	4.760±0.800E-3	5.467±0.570E-3	0.87	Agreement
	4.190±0.660E-3		0.77	Agreement
Xe-133	1.880±0.070E-1	1.674±0.005E-1	1.12	Agreement
	1.690±0.060E-1		1.01	Agreement
Xe-135a	8.260±0.310E-2	9.414±0.197E-2	0.88	Agreement
	7.920±0.350E-2		0.84	Agreement
Xe-135	1.120±0.100E-1	1.141±0.002E-1	0.98	Agreement
	1.050±0.090E-1		1.05	Agreement
Xe-138	1.140±0.070E-1	1.137±0.073E-1	1.00	Agreement
	0.980±0.080E-1		0.86	Agreement

7. Reactor Coolant Liquid Sample  
(Sampled: 17:15, CDT, April 16, 1991)

The sample was analyzed by the licensee using their Canberra Series-80 and Series-90 analytical systems in their radiochemistry counting room and the isotopic results from the two systems analyses are reported in that order in the following table.

Nuclide	FCS Results ( $\mu\text{Ci/ml}$ )	NRC Results ( $\mu\text{Ci/ml}$ )	FCS/NRC Ratio	Comparison Decision
I-131	4.360 $\pm$ 0.340E-3	3.675 $\pm$ 0.105E-3	1.19	Agreement
	3.640 $\pm$ 0.220E-3		0.99	Agreement
I-132	3.970 $\pm$ 0.290E-2	5.826 $\pm$ 0.029E-2	0.68	Disagreement
	5.320 $\pm$ 0.250E-2		0.91	Agreement
I-133	3.820 $\pm$ 0.130E-2	3.685 $\pm$ 0.015E-2	1.04	Agreement
	3.910 $\pm$ 0.150E-2		1.06	Agreement
I-134	9.470 $\pm$ 0.280E-2	9.936 $\pm$ 0.092E-2	0.95	Agreement
	9.900 $\pm$ 0.310E-2		1.00	Agreement
I-135	6.770 $\pm$ 0.240E-2	6.579 $\pm$ 0.056E-2	1.03	Agreement
	6.550 $\pm$ 0.240E-2		1.00	Agreement
Cs-134	3.650 $\pm$ 0.360E-3	3.909 $\pm$ 0.098E-3	0.93	Agreement
	3.580 $\pm$ 0.260E-3		0.92	Agreement
Cs-137	5.110 $\pm$ 0.280E-3	4.604 $\pm$ 0.102E-3	1.11	Agreement
	4.910 $\pm$ 0.450E-3		1.07	Agreement
Cs-138	1.260 $\pm$ 0.050E-1	1.300 $\pm$ 0.015E-1	0.97	Agreement
	1.240 $\pm$ 0.050E-1		0.95	Agreement

## ATTACHMENT 5

8

8. Containment Atmosphere Sample (RM-050)  
(Sampled: 12:42, CST, April 16, 1991)

The sample was analyzed by the licensee using their Canberra Series-80 and Series-90 analytical systems in their radiochemistry counting room and the isotopic results from the two systems's analyses are reported in that order in the following table.

Nuclide	FCS Results (uCi/cc)	NRC Results (uCi/cc)	FCS/NRC Ratio	Comparison Decision
Ar-41	3.330±0.180E-6	3.250±0.104E-6	1.02	Agreement
	3.390±0.190E-6		1.04	Agreement
Xe-131m	2.700±0.600E-6	2.451±0.409E-6	1.10	Agreement
	1.890±0.440E-6		0.77	Agreement
Xe-133m	1.280±0.230E-6	1.546±0.141E-6	0.83	Agreement
	1.260±0.150E-6		0.82	Agreement
Xe-133	1.420±0.050E-4	1.259±0.004E-4	1.13	Agreement
	1.300±0.050E-4		1.03	Agreement
Xe-135	2.980±0.270E-6	2.728±0.041E-6	1.09	Agreement
	2.720±0.140E-6		1.00	Agreement

## ATTACHMENT 2

### CRITERIA FOR COMPARING RADIOCHEMISTRY ANALYTICAL MEASUREMENTS

The following are the criteria used in comparing the results of capability tests and verification measurements. The criteria are based on an empirical relationship established through prior experience and this program's analytical requirements.

In these criteria, the judgement limits vary in relation to the comparison of the resolution.

$$\text{Resolution} = \frac{\text{NRC VALUE}}{\text{NRC UNCERTAINTY}}$$

$$\text{Ratio} = \frac{\text{LICENSEE VALUE}}{\text{NRC VALUE}}$$

Comparisons are made by first determining the resolution and then reading across the same line to the corresponding ratio. The following table shows the acceptance values.

RESOLUTION	AGREEMENT RATIO
<4	0.40 - 2.50
4 - 7	0.50 - 2.00
8 - 15	0.60 - 1.66
16 - 50	0.75 - 1.33
51 - 200	0.80 - 1.25
>200	0.85 - 1.18

The above criteria are applied to the following analyses:

- (1) Gamma Spectrometry
- (2) Tritium in liquid samples
- (3) Iodine on adsorbents
- (4) <sup>89</sup>Sr and <sup>90</sup>Sr determinations
- (5) Gross Beta where samples are counted on the same date using the same reference nuclide.