

SIEMENS

RECEIVED
NRC
RIV WCFO

94 SEP -7 AM 10:44

DMB

August 30, 1994
LJM:94:0111

Washington State Department of Ecology
Attention: Mr. Kim H. Sherwood
Water Quality Division
106 S. 6th Avenue
Yakima, WA 98902-3387


Dear Mr. Sherwood:

WASTE LIQUID EFFLUENT REPORT
July 1994

Measurements of liquid waste discharges from the Siemens Power Corporation facility to the Richland Municipal Sewerage System are reported herein. Discharges were in full compliance with limits specified in the Siemens State Waste Discharge Permit (Permit ST3919). A pH measurement of 10.4 on July 27, 1994, exceeded the City of Richland's pretreatment pH limit of 10.0. The cause was a process upset at the Ammonia Recovery Facility that sent high pH bottoms to Lagoon 5A. The City of Richland was notified. Lagoon 5A sewerage was halted, then resumed on July 31 at reduced rates.

Waste discharge records are maintained by Siemens and are available for review at your convenience.

Very truly yours,



L. J. Maas, Manager
Regulatory Compliance

/jaw

Attachment

- c: S. R. Arlt - Water & Waste Utilities Director, City of Richland
- L. J. Callan - Administrator, NRC Region IV
- C. A. Hooker - NRC, Region IV
- M. L. St. Martin - City of Richland

130068

Siemens Power Corporation

Nuclear Division - Engineering and Manufacturing Facility

2101 Horn Rapids Road, PO Box 130 Richland, WA 99352-0130

Tel: (509) 375-8100

Fax: (509) 375-8402

9412130257 940830
PDR ADDOCK 07001257
C PDR

JE 23
VERON