

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

LICENSEE CODE M I D C C 1 LICENSE NUMBER 2 0 0 - 0 0 0 0 0 0 - 0 0 0 LICENSE TYPE 3 4 1 1 1 1 CAT 58 4

CON'T
REPORT SOURCE 1 DOCKET NUMBER 6 0 5 0 0 0 3 1 5 7 EVENT DATE 0 6 2 4 8 3 REPORT DATE 0 7 2 0 8 3

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 DURING NORMAL PLANT OPERATION, A SECURITY OFFICER FOUND THE CO₂ SWITCH FOR THE

0 3 UNIT 1 CD DIESEL GENERATOR ROOM IN THE ISOLATE POSITION WITH NO ONE IN THE ROOM.

0 4 THIS IS NON-CONSERVATIVE WITH RESPECT TO THE REQUIREMENTS OF T.S.3.7.9.3. THE

0 5 CONDITION EXISTED FOR TWELVE (12) MINUTES. THE FIRE DETECTION SYSTEM WAS OPERABLE

0 6 DURING THIS PERIOD. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. PREVIOUS OCCUR-

0 7 RENCES WERE REPORTED VIA RO NOS. (UNIT 2):316/82-054,062,074,076,084,83-022,028&034.

0 8 AND (UNIT 1):315/82-037,044,045,049,068,081,082,108&83-048.

SYSTEM CODE A B CAUSE CODE A CAUSE SUBCODE X COMPONENT CODE Z Z Z Z Z Z COMP SUBCODE Z VALVE SUBCODE Z

LER-RO REPORT NUMBER 17 EVENT YEAR 8 3 SEQUENTIAL REPORT NO. 0 6 0 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0

ACTION TAKEN H FUTURE ACTION Z EFFECT ON PLANT Z SHUTDOWN METHOD Z HOURS 0 0 0 0 ATTACHMENT SUBMITTED N NPD-4 FORM SUB N PRIME COMP SUPPLIER Z COMPONENT MANUFACTURER Z 9 9 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 THE PRIMARY CAUSE OF THE EVENT WAS A PERSONNEL ERROR. A CONTRACTOR CRAFT EMPLOYEE

1 1 EXITED THE AREA WITHOUT RETURNING CO₂ SYSTEM TO NORMAL, FOR OPERATION. TO INCREASE

1 2 AWARENESS OF THE FIRE PROTECTION SYSTEM REQUIREMENTS, A PERSONAL CONFERENCE AND A

1 3 REVIEW OF THE INDIVIDUALS RESPONSIBILITY REGARDING FIRE PROTECTION SYSTEMS WERE

1 4 HELD.

FACILITY STATUS E % POWER 1 0 0 OTHER STATUS N/A METHOD OF DISCOVERY B DISCOVERY DESCRIPTION SECURITY OFFICER OBSERVATION

ACTIVITY RELEASED OF RELEASE Z CONTENT Z AMOUNT OF ACTIVITY N/A LOCATION OF RELEASE N/A

PERSONNEL EXPOSURES NUMBER 0 0 0 TYPE Z DESCRIPTION N/A

PERSONNEL INJURIES NUMBER 0 0 0 DESCRIPTION N/A

LOSS OF OR DAMAGE TO FACILITY TYPE Z DESCRIPTION N/A

PUBLICITY DESCRIPTION N/A

ISSUED N

8308040364 830720
PDR ADOCK 05000315
S PDR

NAME OF PREPARER L. W. CASTLE PHONE (616) 465-5901

NRC USE ONLY

GPO 91-7-926