

PRESSURIZED  
SECONDARY LOOP RELEASES OF LIGHT WATER REACTORS IN NORMAL OPERATION  
AND  
IN SELECTED BREAKDOWNS

Providing of computer program SEKEM: - Sensitivity analysis of  
secondary loop releases - Release calculation in the case of  
failure of steam generator tubes and the assessments of  
results

IFEU - INSTITUTE OF ENERGY AND ENVIRONMENTAL RESEARCH  
HEIDELBERG , R.A.

The report was sponsored by the Federal Ministry for  
Research and Technology

Sponsorship number : 150 426

**XA** Copy Has Been Sent to PDR

IFEU - REPORT No.16

1982

XA

8205740143

IFEU - INSTITUTE FOR ENERGY AND ENVIRONMENTAL RESEARCH  
HEIDELBERG, R.A.

SECONDARY LOOP RELEASES OF LIGHT WATER PRESSURE<sup>12ED</sup> REACTORS  
Sponsorship number: 150 426

The Study was prepared under the auspices of the Association  
for Reactor Safety (GRS) in the Institute for Energy and  
Environmental Research Heidelberg R.A.

Quarterly Interim Reports were published by the  
Association for Reactor Safety

The work on which this report is based was promoted with  
the funds provided by the Federal Minister for Research and Technology  
(sponsorship number 150 426).

However, the author alone is responsible for the  
contents [of this study]

SECONDARY LOOP RELEASES OF LIGHT WATER PRESSURE <sup>12ED</sup> REACTORS

Project head : Dr.R.Ratka

Responsible Authors : Dr. T.Koc̄

T.Kaplan

Dr.R.Ratka

-----

The following persons have cooperated in individual  
problems : H.P.Bittner, S.Etemad, R.Franke, G.Kirchner,  
M.S. Scheld-Grüning, D.Stein, T.Zapf, B.Vey

Special . acknowledgment is due to Dr.P.Rentrop and Dr.P.Lory  
From the Technological University Munich

## 1. INTRODUCTION

The present study aims at developing a computer program for the determination of radioactivity in the secondary loop and the radioactivity release in the turbine hall. Secondary loop releases have not been until now measured technologically and are the consequence of heat exchanger tube leakage in a steam generator. In Germany steam generator leakages have already occurred in 1971, in nuclear power plants in Obrigheim, and during the preparation of this study there were leakages in nuclear power plant in Biblis and Stade. In the Ginna reactor, in the United States, massive steam generator leakages occurred, so much so that the secondary side relief valves had to be opened and radioactivity was released into the environment.

The program is tested with the aid of sensitivity analysis and the influence of the following parameters compared with the release rates :

primary loop activity, steam generator heating tube leakage, radioactive decay constant, steam release rates from the high pressure side and from the feed-water degassing, residue humidification, (for instance, in the steam generator), elutriation rates per steam generator, decontamination factors in the elutriation demineralization plant as well as phase distribution factors in high and low pressure areas.

In addition, load changes and radioactivity spikes will be investigated. During the sensitivity analysis the influence of various parameters on release pathways, so far not recognized, will be investigated.

It is planned to carry out realistic computation of the

plant leakage in a steam generator. In this matter special attention will be paid to what degree the officially fixed maximum J-131 fresh steam concentration shall be adhered to, and also what going above these values would mean. In addition, the releases should be assessed by emission calculations. In particular, we are going to find out whether other nuclides, in addition to iodine-131 are relevant in secondary loop releases.

The functioning capacity of the K-16-signal, especially the connection between the response time and the reactor power will also be investigated.

The single fault criterion will be applied to a coolant-loss disturbance caused by steam generator tube failure. It will be investigated whether the perturbations which result from tube failure were considered in the accidents discussed, and what were the consequences of them. With the aid of the computer program the release of these breakdowns will be calculated.

---

## Introduction

Voluminous documentation studies show that secondary systems of the German nuclear power plants with pressure water reactors are comparable in their essential component parts. See (1), p.61, diagram 3 2.8., principal circuit diagram of the main heat removal system; (2) diagram 8, outline; (3), diagram 6, water steam loop; (4) especially page 12; (5) especially p.32 diagram 1, also 3,3 or 4; loop installations in principle are built in a similar way, so that in release calculations for the turbine hall in general only vary with mass flows and the varying efficiency of the elutration demineralization plants are taken into account.

See (6),(7),(8),(9) and (10).

In the investigation of the individual components, the research was based on the standard work by Karl Schröder (11).

In the scenario or models development, direct contact with the managers in addition to the study of the literature was essential, and also the examination of internal documents of the nuclear power plant at Neckerwestheim as well as on-the-spot inspection and discussions at the nuclear power plant in Grafenrheinfeld, at Biblis A and B.

As a reference was chosen the npp Biblis Block B (See (12) p.35) although in earlier power plants some components are not correspondingly designed. Biblis B, however, has the advantage of corresponding to the plants in construction or planned ( construction line 8) so that the computer program developed by us is applicable to them.

In the following pages we deal in detail with the scenario used in the study of the secondary loop of the light water reactors. In it we discuss the system-oriented as well as the operational technical marginal conditions. Then follows a discussion about the nuclide transport in SK determined magnitudes - which are the introductory parameters important for the computer program.

For the nuclide distribution a mathematical formula is deduced for local and nuclide specific distribution factors. At the end of this chapter a section will be devoted for the difficulties in information obtainement.

## 2.1. Scenario of the secondary loop of light water pressure<sup>120 d</sup> reactors

1. On the one hand, it must reproduce the main structure and function of the secondary loop in a simplified and summarized way, without falsifying or omitting the essential characteristics of the system in its functional context.
2. *On the other hand,* The scenario must make the mathematical formulation of the functional system possible.

The secondary loop scenario is also the result of a system analysis. It must contain the essential transport<sup>t</sup> pathways for nuclides and especially the release pathways.


### 2.1.1 Structure and function of the pressure<sup>120 d</sup> water reactors

The description of the secondary loops - also called feedwater steam loop - is placed at the outset for the completion of the structural explanation and the way of operation of the nuclear power plant, with pressure water reactor.

The structure and method of operation of a nuclear power plant with pressure water reactor is illustrated by the simplified operation diagram 2.1.1. We see there three loops :

1. Primary loop : which is an essentially closed heat-transfer circuit in which the heat produced in the reactor core is transferred by the main coolant pump 4 from the reactor pressure vessel 3 via the steam generator 2 (At most 2 to 4 steam generators per reactor block) to the secondary loop.
2. Secondary loop : the feed water heat-transfer circuit largely corresponds to the conventional power plants. The feed water is pumped through it by the main feed water pump into the steam generator, where it is evaporated by the heat from the reactor loop. The generated steam drives the turbine installation consisting of a high pressure turbine and three parallel low pressure turbines, and these in turn drive generator 6. The steam exiting from the turbines is condensed in condenser 7 by release of its heat to a coolant medium, and the loop is completed. Arrow 10 shows that during the operation steam leakages continuously occur through the turbine wall roof.
3. Tertiary loop : The main heat-transfer circuit is used to transfer heat from the condenser. During this operation, water is pumped by the main coolant pump through the condenser which releases about 2/3 of the heat produced in the reactor core, to be discharged, as the case may be, directly into a river, into the sea or through the cooling towers into the atmosphere.

Chart 2.1.1 Symbolic Circuit of a Nuclear Plant with Pressure Water Reactor




- |                         |   |
|-------------------------|---|
| 1. Reactor core         | 6 Generator                             |
| 2 Steam generator       | 7 Condenser                             |
| 3 Reactor pressure tank | 8 Main feed water pump                  |
| 4. Primary coolant pump | 9 Main cooling water pump               |
| 5 Turbine               | 10 Steam releases from the turbine hall |

The generation of electric power from heat in nuclear power plants occurs in principle in the same way as in other thermal power plants. The difference consists in the heat production through the process of nuclear fission. Since during this operation several hundred radioactive isotopes are produced which because of their radiation could cause possible injuries, and constitute a risk for living organisms, special precautions must be taken to minimize the release of radioactive materials into the power plant environment. Radioactive releases cannot be completely eliminated even during normal undisturbed operation.

## 2.1.2 Structure and Function of the Secondary Loop

Structure and function of the secondary loop are represented in a simplified form in the basic circuit diagram No.2.1.2



- |   |  |
|---|--|
| 1 Steam generator                                       | 10 Condenser                             |
| 2 Pressurizer   | 11 Discharge for condenser cooling water |
| 3 Pressurizer emergency relief valve and blow-off valve | 12 Inlet for condenser; cooling water    |
| 4 Feed water container                                  | 13 Turbine                               |
| 5 Main feed water                                       | 14 Steam bypass equipment                |
| 6 Emergency feed water system                           | 15 Main steam valve                      |
| 7 Hydrogen recombination tank                           | 16 Turbine safety regulator valve        |
| 8 Main condensate flow                                  | 17 Steam safety valve and blow-off valve |
| 9 Condenser cooling system                              | 18 Steam emissions from the turbine hall |

Chart 2.1.2 : Basic circuit diagram of the reactor heat-transfer circuit and the feed water steam circuit

The function of the steam and feed water systems is the transfer of nuclear heat and its thermokinetic transformation into electricity.

The important operational elements are the steam generators, turbine and electric generators and the steam condenser.

As we have already sketched in brief, the fresh steam generated in the steam generators leaves the safety tank through the fresh steam piping provided with relief and safety valves, and flows through the turbine valves to drive the turbine unit. The steam from this operation is condensed in the condensers, the condensate flow is collected in the condensate tank and returned by the main condensate pumps through some prewarming steps into the feed water tank, and from there is pumped by the main feed water pumps back into the steam generator. During this time the steam for the prewarming of the condensate is tapped at various turbine stages in the way convenient to all thermal power plants.

The complete technological representation of the secondary loop is within the circuit diagrams :

1. reactor heat-transfer circuit
2. main feed water system
3. emergency feed water system
4. hydrogen recombination system
5. steam piping system.

Each of these circuit diagrams comprises about 6 - to 8 DIN A pages (See German Reactor Safety Study, Bibliography No.15) with several hundred components.

It is not meaningful for determination of releases from the secondary loop to go into great detail about its parts or their technological aspects. As the following section shows, it is possible to keep the number of components sufficiently small for comprehension (treatment) in a scenario.

### 2.1.3 Development of the working model

The permanent study serves the following general purpose : the computation on the basis of the primary loop radioactivity of any radio nuclide as well as of the steam generator leakage, the specific radioactivity of this nuclide, the radioactivity flow between two connected sites as well as the releases resulting from them from the secondary loop at any time and at any place of the secondary loop.

The following restricted function is relevant to the model development within the system analysis :

On the basis of the primary loop activity of any radio nuclide as well as of the steam generator in a state of equilibrium and for a determined operating transient, the computation has to be undertaken of the specific radioactivity of this nuclide for relevant sites and for releases from the secondary loop.

The task of model development consists in presenting a model which can exactly simulate continuous space/time distribution of any radio nuclide in the secondary loop. With regard to time distribution, steady state activities and in special cases time-dependent transient conditions must be taken into consideration .

With respect to space distribution an appropriate selection of sites in the feed water steam system must be made.

Further, it must be determined which magnitudes for the nuclide transport are essential in the secondary loop.

Within the framework of model development the following nuclide specific and non-nuclide specific determination magnitudes are taken at the start :

### 1. Specific primary loop radioactivity and steam generator leakage

The specific primary loop radioactivity is specific to nuclides, the steam generator leakages are not. These two magnitudes go into the radioactivity computation in a linear way. The present marginal and initial conditions, which affect the height, but not the space and time distribution of the specific nuclide activity.

### 2. Mass flows and steam emissions

Mass flows and steam releases are not specific to nuclides. The radio nuclides carried through the steam generator leakage into the secondary loop are carried with water or steam; they are distributed according to the mass flows of water and steam phases among other things. This is expressed by the fact, that for each radio nuclide, specific activity, thus the number of decays per time unit and mass unit (most in Ci/t) is computed in each relevant considered site of the SK.

### 3. Phase distribution factor alpha or decontamination factor & DF

Factors alpha and DF are specific in nuclides and indicate in what quantity a radio nuclide remains in the transition phase of evaporation or condensation in a fluid or in gaseous phase. Thus, for instance, a nuclide which is ionized in an evaporation process will mostly remain in fluid phase. Factors alpha and DF depend on the chemical and physical properties of the considered nuclide, as well as on technically indicated magnitudes of pressure, temperature, steam humidity, pH-values, etc.

A detailed description of the magnitudes determining nuclide transport will be found in sections 2.2 a or 2.5 of the system analysis.

Since the model development is closely connected with mathematical formulation, mathematical description or solution statements let us consider the computer program here before chapter 3.

The following basic physical assumptions determine the mathematical treatment :

1. The mass conservation law or continuity equation applies for the mass flow or mass current density.
2. In the SK-System (model) there are no other sources for radio nuclides outside the steam generator leakages, given by the leakage rate in the steam generator and in the primary loop concentration of specific nuclides.
3. For each site in SK the radioactivity can be estimated from the technically given mass flows by linear differential equation. The radioactivity distribution for all parts flows as the solution of differential equation systems [DE-Systems].  
The number of places to be taken into account determines directly the extent of the DE-System and the expenditure for its solving.

The following places have been selected as indicated above and will be explained shortly (See diagram 2.1.3 and diagram 2.1.4).

1. DE - leaking
2. De - leakproof
3. FD fresh steam
4. High pressure turbine
5. Water separator or trap/ intermediate superheater
6. Low pressure turbine
7. Condenser
8. Hot well
9. Feed water tank
10. The blow-down flash tank (elutration stress-reliever)
11. Elutration demineralization (elutrat on demineralization)
12. Sump
13. Atmosphere

With regard to 1 and 2 :

the steam generators play<sup>2</sup> central role from

two points of view : on the one hand, the steam generators are the site in which radio activity is introduced from the primary loop into the SX. On the other hand, according to the element and the chemical form in which it is found, the increase in the activity in the fluid phase occurs in the evaporation process. Here the pressure, temperature and the residual humidity are of decisive importance.

This phenomenon, which rests on high differences in solubility of substances in water or steam, will be described in terms of the aforementioned phase distribution and decontamination factors. (See section 2.2 and 2.5 ).

✓ We proceed from the assumption that a steam generator leakage does not occur simultaneously in all steam generators. Thus, in practice so far there have been one, at the most two, steam generator leakages among the four steam generators to be found in the reactor. The scenario must assume exactly two sites of steam generators, of which one is intact and the other represents a steam generator with heat exchanges tube leakages.

With respect to 3 : the fresh steam generated in the steam generator is dried and distributed in an extensive piping system. The practice of introducing fresh steam into a stage is based on the consideration that the fresh steam tubes of steam generator connect into a gath ring line before its entry into the turbine which will influence the radioactivity distribution. Further, some of the already collected fresh steam will be diverted and conveyed for the purposes of pre-heating into the 5th stage, bypassing the turbine, into the water separator and into the intermediate superheater,

and from there into the feed water tank. This is important because of its feed water degassing device for the release computation.

With respect to 4 :

The high pressure turbine should be seen as a relevant site because, on the one hand, it constitutes a mass flow distribution junction with direct inflow into the feed water tank thanks to its numerous taps which we have indicated, and, on the other hand, it changes the magnitudes of pressures, temperature, steam quantity and residual humidity relevant for the phase distribution factors.

With respect to 5 :

As with the high pressure turbine, so also the water separator/and intermediate superheater represent mass flow branching, which influences radioactivity flows over factor alpha with direct inflow into the SW tank. Pressure, temperature and humidity contents of the fresh steam are also influenced by these components.

With regard to 6 : see 4

With regard to 7 :

the condenser is an operational and safety technical power plant component because it fulfills a relevant function of heat removal, for instance, during a reactor "scram" or a turbine trip-out and operates through the bypass station. Further, it constitutes a linkage of the tertiary loop with the main water loop.

Condenser leakages decisively influence tubes of the steam generator. Finally, an essential release pathway for noble gases exits from SK through condenser absorption.

With respect to 8 :

the hot well represents the central point of the mass flow. Here the mass flows collect from the 1 elutriation (blow-down)

demineralization, low pressure turbine taps and condensate, and flow from the hot well into the feed water tank. In the hot well, the hydrogen recombination is in addition resupplied as a make up for the water and steam losses.

With respect to 9 :

A direct release pathway goes through the feed water degassing into the atmosphere. The feed water tank in addition is a mass flow junction point, with a direct line to the steam generators.

With respect to 10 :

The blow-down flash tank serves the pressure and temperature change of the steam generator water to the values required for the blow down flash tank installation. During the depressurization the water in the steam generator is generated, which is directly conveyed into the feed water tank. This mass flow is decisive in the radioactivity of the feed water tank and for its release.

With respect to 11 :

The elutriation demineralization serves to hold-back nuclides in a crystallized state.

With respect to 12 and 13 :

The sump and atmosphere represent receiving phases for the water and steam.

The model optimization described above takes into account in brief the following marginal conditions :


- the degree of specification in the description of the reactor technique
- determinant magnitude of the radio nuclide transportation
- mathematical formulation statement
- problem adopted EDV optimization (location, computation, time, etc.)

2.1.4 . Computation of Radio Nuclide Emissions for the Secondary Loop

The result of the scenario development is shown in diagram 2.1.3. As the mass flows are shown, the component relevant for the determining of mass flows and <sup>to</sup>wiring system <sup>is</sup> are included. The scenario of the secondary loop for the computer program is derived from diagram 2.1.3 and shown in diagram 2.1.4.

It becomes evident when we compare diagram 2.1.3 and 4 that the regulation and safety technical components such as tension valves, shut-off valves, safety accessories are omitted or summarized. Parallel piping in diagram 2.1.4 is either omitted - because it is of no importance for nuclide transport - or summarized.


Three release pathways have a special importance for the releases into the atmosphere, two of them take place not through the ventilation chimney :

1. The main leakage point at high pressure points, from which even in normal operation, emissions are released are indicated by the following brackets . Individually, the emission points are to be understood to include the following components : high pressure sump hole release, with its standing vent into the turbine hall roof and leakages from various waterproofings and glands.

2. Emissions from the feed water degassing. For reasons of water chemistry the feed water must be freed as much as possible from dissolved corrosive gases such as oxygen and carbon dioxide. The gases are released through <sup>the</sup>turbine hall roof with water steam as the carrier gas (without smoke cooler/ waste vapor condenser)

In this case it is important that, about only half of the mass flows which are diverted for the purpose of demineralization from steam generators, reaches the demineralization installation.






Places in computer program

- |  |   |
|--|---|
| 1 DE - leaking   | 8 Hot well  |
| 2 De - leakproof                                       | 9 Feed water tank   |
| 3 FD - fresh steam                                     | 10 The blow-down flash tank<br>(elutration stress-reliever) |
| 4 High pressure turbine                                | 11 Elutration demineralization                              |
| 5 Water separator or trap/<br>intermediate superheater | 12 Sump   |
| 6 Low pressure turbine                                 | 13 Atmosphere   |
| 7 Condenser  |   |

SWE - Feed water degassing  
 KE - condenser evacuation

Diagram 2.1.4 : Model of the Secondary loop  
 for the Computer Program




- 1 Steam generator
- 2 Stress relief of the elutration demineralization
- 3 Cooler of the elutration demineralization
- 4 Cleaning system of the elutration demineralization
- 5 Hot well
- 6 Condenser
- 7 Feed water tank
- 8 Release pathway : feed water degassing into the atmosphere

IFEU  
 Institut für Energie- und  
 Umweltforschung Heidelberg a.V.  
 Im Sand 5  
 D-6900 HEIDELBERG

Diagram : Elutration demineralization  
 2.1.5. in a steam generator

- IFEU  
 Institut für Energie- und  
 Umweltschutz Heidelberg a.V.  
 Im Sand 5  
 D-6900 HEIDELBERG

Diagram 2.1.6  
 Explanation diagram for radioactivity  
 in the systems  
 according to the bibliographical entry:



The other half of this mass flow reaches the feed tank unfiltered. In cases of steam generator leakage, radioactivity goes directly into the environment through this pathway via the feed water degassing (See diagram 2.1.5.).

### 3. Releases from the condenser absorption.

Noble gases under pressure are released through the hot vent.

### 2.1.5. Theoretical Comparison of the SK Model with the Secondary Loop Model of the Union of Nuclear Power Plants (KWU)

At the completion of the system analysis we must briefly examine the SK Model use by the Union of the Nuclear Power Plants (KWU). [13]. The theoretical comparison is informative on the one hand, because the KWU-Model found acceptance in the evaluation of nuclear power plants within the legal licencing procedure, on the other hand, because the comparison illuminates the importance of the system analysis. It is evident that a model, in principle, cannot take the release pathways more into consideration of all the relevant system magnitudes - in this case the transport of nuclides including release pathways the derived model cannot completely comprehend fragmentary releases.

The KWU diagram for the computation of radioactive flows in the secondary loop is represented in diagram 2.1.6.

A detailed comparison reveals :

1. The KWU - Model has no feed water tank, but rather a condenser, and hence no feed water degassing. As a consequence all of the live steam goes into the condenser through turbines which must lead to the overestimation of those releases, which exit through the roof stack and thus in a "controlled" way.

\* them can be included within the framework of the system analysis. This means, that without a complete consideration

Translation (German)

6. COMPUTATIONS OF RELEASES AND EVALUATION IN BREAKDOWNS CAUSED  
BY BURST TUBES IN STEAM GENERATORS

Introduction

The bursting of ~~the~~ tubes in steam generators must under certain marginal conditions be ~~evaluated~~<sup>evaluated</sup> as a breakdown caused by the loss of coolant.

According to the number of ~~the~~<sup>tube</sup> breakdowns in steam generators, we may ~~differentiate~~<sup>differentiate</sup> between minimal and small breakdowns caused by the loss of

coolants. As a result of ~~the~~<sup>tube</sup> breakdowns in steam generators, ~~the~~<sup>the</sup> ~~secondary loop is infiltrated by~~<sup>secondary loop is infiltrated by</sup> ~~primary coolants~~<sup>primary coolants</sup> ~~which part is released~~<sup>of</sup> into the environment in certain breakdown sequences.

In Section 2.4 it was pointed out that ~~breakdowns~~<sup>tube</sup> in steam generators may also occur in steam generators used in the Federal

Republic of Germany and must be taken into consideration in ~~the~~<sup>of</sup> evaluations.

The viewpoint that ~~constructions and materials used in the Federal~~<sup>tube breakdowns in steam generators will not occur</sup>

Republic of Germany ~~can no longer be maintained.~~<sup>can no longer be maintained.</sup>

The <sup>leak</sup> at the Robert F. Ginna (U.S.) pressurized water reactor (1)

at the beginning of February 1982 shows, in agreement with our results, that

the breakdown of ~~the~~ tubes in steam generators must not only be viewed in

connection with <sup>the</sup> bursting of the feed water line and <sup>the</sup>

~~live-steam~~ line. In the case of the Ginna reactor, secondary discharge

valves opened a few minutes after the bursting of ~~the~~ <sup>the</sup> tube in a steam generator:

as a result of which ~~the~~ radioactive particles were released <sup>into the environment</sup>.

In order to minimize <sup>such releases,</sup> ~~the~~ the primary ~~the~~ discharge valve

was opened a few times and closed again - after it was opened for the fifth

time, the valve failed and remained in a "partially open" position. Luckily,

33 hours after the <sup>breakdown</sup> ~~the~~ reactor was brought under control by a

cold shutdown.

225

After Harrisburg, this <sup>breakdown</sup> ~~the~~ points again to the weak point caused

by "valve failure."

In the following chapter <sup>breakdown sequences</sup> ~~the~~ caused by ruptured ~~the~~ tubes in

steam generators will be discussed qualitatively and ~~the~~ quantitatively <sup>as</sup>

well as the application of the concepts of individual error# (2,3). It shows

that in accordance with the regulations on ~~xxx~~ radiation protection, the admissible ~~xxxx~~ <sup>admission</sup> cut-off values have <sup>considerably</sup> been exceeded in <sup>breakdown</sup> ~~xxxx~~

In addition, there <sup>is</sup> ~~is~~ a critical discussion <sup>of the studies of breakdown</sup> ~~of breakdown~~ <sup>carried out</sup> by the Baden Technical Control Board (4).

6.1 Application of the Individual Error Concept in ~~xxxxxxx~~ Coolant Loss Accidents Caused by Burst Tubes in Steam Generators

In the safety regulations for <sup>nuclear</sup> ~~atomic~~ plants (2) and ~~the~~ principles of the application of the individual error criterion (3), the Federal Minister of the Interior has established that <sup>an individual error must be assumed in</sup> ~~xxxx~~ post heat ~~xxxx~~ discharges after loss of coolants.

The exact wording is:

Safety Criteria for <sup>nuclear</sup> ~~atomic~~ Plants,

Section 4, Criterion 4.3:

" Post heat discharge after coolant losses:  
A reliable and redundant system for the emergency cooling (emergency

cooling system) of the reactor core in <sup>coolant</sup> losses ~~xxxx~~ must be available <sup>and operate</sup> in such a manner that <sup>with regard to</sup> ~~xxxx~~ sizes ~~xxxx~~ locations of ~~xxxx~~ rupture <sup>d</sup> points, working conditions and transients in the reactor cooling system

225

1. the emergency cooling system will <sup>safely perform</sup> ~~be~~ ~~also~~ during maintenance work and ~~be~~ simultaneous <sup>occurrence</sup> ~~of~~ of an individual error in the system.
2. the specified cut-off values ~~be~~ for ~~the~~ fuel elements, <sup>installed core</sup> ~~be~~ equipment and safety <sup>be</sup> not exceeded.
3. <sup>the</sup> chemical reactions be limited to a degree ~~be~~ absolutely safe from the technical point of view.

226

In the interpretations <sup>of</sup> the safety criteria for <sup>nuclear</sup> ~~the~~ plants which have the same significance and binding character as the safety criteria <sup>themselves</sup>, the application of the individual error criteria is specified as follows under Point (1) which states verbatim:

"The individual error is considered to be an accidental error which must not be equated with an error that occurred as a result of the operational requirements or <sup>of an</sup> ~~additional~~ <sup>error in the safety installations.</sup> ~~error~~. An error exists if part of the system <sup>3)</sup> of the safety installations does not ~~perform its~~ function properly during operation. A possible ~~error~~ <sup>resulting in an</sup> false operation ~~is~~ error in the

safety installations must be equated with an individual error.

Generally reasons for <sup>an assumed</sup> ~~error~~ must not be given."

3) The term "part of the system" covers all the parts of the <sup>operational</sup> ~~system~~ unit itself and <sup>the</sup> ~~the~~ supply, adjustment and auxiliary <sup>and if necessary, redundant</sup> installations ~~that are necessary~~ for ~~its~~ safe operation.

If the breakdown of a ~~the~~ tube in a steam generator is ~~not~~ considered <sup>to be</sup> the cause of a coolant ~~loss~~ loss, we must regard as an individual error, for instance, the failure of a secondary ~~the~~ discharge valve (failure to close after it has been opened) in post heat discharges.

There are <sup>good</sup> ~~some~~ reasons (for instance, <sup>the</sup> resulting effect of a two-phase flow) ~~the failure of~~ ruptured <sup>tubes</sup> in steam generators may cause breakdowns.

This <sup>leads to</sup> ~~leads to~~ the following ~~breakdown~~ breakdown sequence:

As a result of the bursting of a tube in the steam generator, an excessive quantity of primary coolant enters the secondary loop and <sup>increases</sup> ~~increases~~ the pressure there as a result of which the discharge valve ~~will not~~ responds.

The discharge valve of a defective steam generator breaks down in <sup>the</sup> a position of "open" or "partially open" ~~position~~ (individual error).

This leads to the release of radioactive substances in ~~the~~ <sup>to the</sup> environment.

~~Breakdown Sequence~~

~~The Breakdown Sequence~~ The Breakdown Sequence

- Breakdown of a ~~the~~ tube in a steam generator (triggering process)
- Response of the secondary ~~the~~ discharge valve of the defective steam generator.
- Breakdown of the secondary ~~the~~ discharge valve in ~~a~~ a position of "open" or "partially open." (Individual error)

results from the application of the individual error criteria to the post heat discharge in coolant losses; ~~the first two~~ <sup>accidents</sup>

~~actually~~ happened at Ginna, U.S.

A <sup>more</sup> detailed description of the ~~breakdown sequence~~ <sup>breakdown sequence</sup> as well as the ~~computations~~ <sup>computations</sup>

~~of releases~~ under different marginal conditions and their <sup>of</sup> valuation will be given ~~below~~ below:

6.2. Description of the ~~Breakdown~~ Breakdown Sequence

As a result of the breakdown of 10 ~~tubes~~ tubes in the steam generator, the main coolant infiltrates the secondary loop. <sup>This leads after</sup> ~~approximately~~ approximately 10 seconds ~~to~~ to the rapid shutdown of the reactor by signal 'N16>max' and <sup>after another</sup> 15 seconds ~~to~~ to the delayed quick shutdown of the turbine.

At this point, that is approximately 25 seconds after the beginning of the ~~breakdown~~ <sup>breakdown</sup>, the ~~pressure~~ pressure ~~has~~ <sup>increased</sup> to ~~a degree~~ <sup>such</sup> a degree ~~that activates~~ the discharge valve, ~~which~~

In accordance with the individual error ~~criteria~~ <sup>criteria</sup> ~~and~~ ~~occasions~~ the breakdown of the discharge valve is ~~assigned due to~~ <sup>is assigned due to</sup> its ~~position~~ "open" or "partially open" <sup>position</sup>.

~~Three~~ <sup>Three</sup> further scenarios are established for the continued ~~sequence~~ <sup>sequence</sup> of ~~breakdowns~~ breakdowns. ~~J 131~~ <sup>J 131</sup> ~~is~~ <sup>is</sup> chosen as a guiding nuclide. ~~As a result of the~~ <sup>As a result of the</sup>

~~transient and spiking~~ <sup>transient and spiking</sup> ~~factors~~ <sup>factors</sup> the interpretation ~~activity~~ <sup>radio</sup> activity was ~~established~~ <sup>established</sup> between 25 and 100 s.

Establishment of the Marginal Conditions Applicable to All Scenarios

- Only the <sup>radio</sup> activity release during the first 30 minutes after the ~~accident~~ <sup>beginning of</sup> accident was computed. This period of time is not ~~conservative~~ <sup>considered to be</sup> conservative since ~~subsequent~~ <sup>subsequent</sup> releases ~~are~~ <sup>are</sup> not considered.

228

-8-

may occur.

- About 1 minute after the beginning of the accident (it may differ according to the scenarios) the main coolant pumps are shut off by the signal "pressurizer water level < min". Since the signal "primary pressure < min" has responded (?), the flow into the loop begins through the safety feed-in pumps. In this connection, only two (out of four) feed-in pumps <sup>have been</sup> ~~are~~ considered.

This is not <sup>an</sup> absolutely ~~a~~ conservative assumption, since after consideration of the 3 or 4 high pressure feed-in pumps, the main coolant leakage <sup>increases</sup> ~~is~~ in the secondary part of the defective steam generator.

- During the first 25 seconds after the beginning of the accident, steam <sup>releases</sup> ~~is~~ from the high-pressure part of 1 kg/sec and ~~the~~ the feed water degasification of 0.5 kg/sec <sup>are</sup> ~~is~~ assumed.

229

- For the purpose of determining the <sup>radio</sup> activity discharge through the discharge ~~from~~ valves <sup>into the environment</sup> ~~only~~ only the primary coolant quantity discharged from the discharge valve of the defective steam generator <sup>has been</sup> considered.

During the first ~~minute~~ 20 seconds after the beginning of the <sup>breakdown</sup> ~~breakdown~~

the ~~total~~ average primary coolant leakage into the secondary loop (<sup>in the</sup> ~~is~~)

229

9-

following to be called primary coolant leakage) <sup>is</sup> approximately 310 kg/sec.

The primary coolant leakage ~~is~~ <sup>drops</sup> to 280 kg/sec from 20 ~~to~~ to 25 seconds.   
 Afterwards the leakage quantities <sup>will</sup> vary according to the scenario.

Marginal Conditions <sup>in</sup> Scenario 1

A spiking factor of 25 for J 131 <sup>is</sup> assumed.

0 - 25 sec after the beginning of the breakdown

- average residual moisture in the steam generator 30%

25 - 300 sec after the beginning of the breakdown

- average residual moisture in the steam generator 20%
- primary coolant leakage dropped from 280 kg/sec to 80 kg/sec

- ~~release~~ <sup>release</sup> of steam from the defective discharge valve (in "partially open" position) of the steam generator ~~and its burst~~

~~the~~ tubes (called steam <sup>release</sup> ~~below~~) is on the average 120 kg/sec

300 - 1800 sec after the beginning of the breakdown

- average residual moisture in the steam generator 5%
- primary coolant leakage <sup>drops</sup> ~~and~~ averages 40 kg/sec
- steam <sup>release drops</sup> ~~and~~ averages 20 kg/sec

Marginal Conditions <sup>in</sup> ~~Scenario~~ Scenario 3

A spiking factor of 50 for J 131 <sup>is</sup> ~~is~~ assumed.

0 - 25 sec after beginning of breakdown

- average residual moisture in steam generator 30%

25 - 100 sec after beginning of breakdown 20%

- average residual moisture in steam generator 20%
- primary coolant leakage drops from 280 kg/sec to 140 kg/sec
- average steam <sup>release</sup> ~~release~~ 150 kg/sec

100 - 1 800 sec after beginning of breakdown

- average residual moisture in steam generator 10%
- primary coolant leakage drops and averages 70 kg/sec
- steam <sup>release</sup> ~~release~~ drops and averages 50 kg/sec

Marginal Conditions <sup>in</sup> ~~Scenario~~ Scenario 3

A spiking factor of 100 for J 131 <sup>is</sup> ~~is~~ assumed.

0 - 25 sec after beginning of breakdown

- average residual moisture in steam generator 30%

25 - 1 800 <sup>sec</sup> after beginning of breakdown

- average residual moisture in steam generator 20%
- primary coolant leakage drops and averages 140 kg/sec
- steam ~~leakage~~ <sup>release</sup> averages 250 kg/sec  
in ~~more~~ <sup>greater</sup> detail

It would be desirable to examine (the above and additional scenarios by means of ~~the~~ further studies and possibly with the aid of measuring programs.

In this connection, it would be especially important to ~~ascertain~~ <sup>ascertain</sup> how many ~~the~~ <sup>the</sup> tubes in steam ~~generator~~ <sup>generator</sup> (with discharge valve ~~closed~~ in "C

position would have to breakdown to bring about a ~~meltdown~~ <sup>meltdown</sup> accident in the

In such a case a portion of the core equipment might be released ~~into the environment~~ <sup>into the environment</sup>

as a result of which the ~~releases~~ <sup>releases</sup> in the above-mentioned scenarios would multiply.

231


6.3 Computation of the J 131 ~~Releases~~ and Their Evaluation  
with Program SEKEM 4

The ~~radioactive~~ <sup>radio</sup> releases were calculated under the marginal conditions indicated.

In the following Table 6.3.1, the ~~releases~~ <sup>releases</sup> and the ~~release~~ <sup>release</sup> rates during the individual periods have been described ~~in~~ <sup>in</sup> Scenario 2 (to be as an example). The ~~releases~~ <sup>releases</sup> refer to the periods indicated.

1 131

LAK 9.9780E-071/5



O Source strength (C/s)  
 Δ ~~Release~~ rate (C/s)  
 + ~~Release~~ (C)


IFLU  
 Institute for  
 Energy and  
 Environmental  
 Research  
 Im Sand 5  
 6900 Heidelberg

Table 6.3.1

~~Releases~~ or ~~release~~ rates <sup>is a result</sup> of the  
 breakdown according to Scenario 2.  
 The source strength represents, as  
 indicated, the product of time-dependent  
 primary concentration and time-dependent  
 leakage rate.

I 131


LRM = 9.9780E-071/5



○ Source strength (Ci/s)  
 ▲ Release rate (Ci/s)  
 + Release (Ci)

I 131

LRM = 9.9780E-071/5



▲ Release rate (Ci/s)  
 + Release (Ci)

IFEU  
 Institute for  
 Energy and  
 Environmental  
 Im Sand  
 6900 Heidelberg

Table 6.3.1

*Releases* or *release* rates *as a result* of the breakdown according to Scenario 2. As indicated the source strength represents the product of time-dependent primary concentration and time-dependent leakage rate.

233

In the following table the J 131 ~~release~~ <sup>releases</sup> of the individual scenarios during the first 30 minutes after the beginning of the breakdown have been listed.

In addition, the inhalation dose (only J 131) for adults and the thyroid gland of unborn children (fetuses) have been indicated under breakdown conditions.

Breakdown scenarios	J-131 <del>release</del> <sup>releases</sup> in 30 min	Inhalation dose for adults [rem]	Dose for fetal thyroid gland [rem]
Scenario 1	185	12	31 - 250
Scenario 2	830	54	140 - 1,100
Scenario 3	14400	940	2400 - 19800
<p>Table 6.3.1 <del>Release</del> <sup>Release</sup> from J-131 in (Ci) and inhalation dose [rem]            Breakdown limit: 15 [rem]            Breakdown <del>source</del> <sup>source</sup>: burst tube in steam generator and discharge valve breakdown in "open" or "partially open" position.</p>			

The table shows that already ~~by~~ <sup>through</sup> inhalation the breakdown limit of 15 rem for unborn children (fetuses) <sup>has been</sup> ~~is~~ exceeded in all cases and for adults in scenarios 2 and 3.

In scenario 2, the limit for adults exceeds around factor 3.6 and in scenario 3 around factor 60.

The load of all other ~~released nuclides~~ <sup>released nuclides</sup> must still be added to the above.

~~We proceeded~~ <sup>We proceeded</sup> from the ~~assumption~~ <sup>assumption</sup> that in the event of such breakdowns the consumption of food from the contaminated regions ~~will be prohibited~~ <sup>will most likely</sup> ~~by~~

the authorities.

For this reason <sup>only</sup> the inhalation dose of the ~~released~~ <sup>released</sup> J 131 was calculated.

If ingestion loads were included, the dose values would ~~be~~ be much higher.

Calculation of the Breakdown Dose

The inhalation dose D under breakdown conditions is calculated as follows:

$$D = A \cdot X \cdot V \cdot D/Q_i$$

with A = released radioactive nuclide quantity [Ci]

X = short-time propagation factor [s/m<sup>3</sup>]

V = breathing rate [m<sup>3</sup>/Ci]

D/Q<sub>i</sub> = inhalation factor [rem/Ci]

239

The following values were used:

- The released J 131 <sup>radio</sup> activities for the individual scenarios are listed in Table 6.3.1

- The Technical Control Board Hannover indicates a value of  $2 \times 10^{-4}$  (s/m<sup>3</sup>) ~~at~~ at a distance of 150 m ~~rs~~ <sup>turbine hall</sup> short-time propagation factor for ~~release~~ from the ~~release~~ (6). In this connection, the upward pressure of the ~~release~~ activity cloud caused by the ~~release~~ large quantities of superheated steam <sup>that were simultaneously released</sup> has already been taken into consideration.

- <sup>As</sup> ~~the~~ inhalation rate the value for adults of  $20 \text{ m}^3/\text{d}$  ( $\hat{=} 2,31 \cdot 10^{-4} \text{ m}^3/\text{s}$ ) was obtained from (7).

- <sup>Also</sup> ~~the~~ same source <sup>Furnished</sup> the employed inhalation dose factor for the thyroid gland (J 131) of  $1,4 \cdot 10^6$  rem/Ci.

As exhaustively explained by Steinhilber-Schwab and Franke (8), the ~~thyroid gland~~ <sup>thyroid gland</sup> represents the "most unfavorable <sup>area</sup> of action via the load path.

In Table 6.3.2, the ratio between the fetal thyroid gland and the reference value according to (7) has been represented.


Accordingly, the fetal thyroid gland dose is higher than the reference value <sup>around factor 2.6 to 21.</sup>

	Dose factor (BMI 1979) (in mrem/pCi)	Inhalation rate	Dose in Jod 131 in air concentra- tions of 1 pCi/m <sup>3</sup> 9in mrem/d)	relative thyroid gland dose, adults (BMI) = 1
Adults	$1.4 \times 10^{-3}$	20 m <sup>3</sup> /6	$2.8 \times 10^{-2}$	
Children	$1.2 \times 10^{-2}$	2 m <sup>3</sup> /6 (in position of rest (ICRP 23)	$2.4 \times 10^{-2}$	0.85
		6 m <sup>3</sup> /d (in activity ICRP 23)	$7.2 \times 10^{-2}$	2.6
Fetuses	J 131 concen- tration in fetal thyroid gland 2 - 12 times of that of adults according to BMI (1979)	27m <sup>3</sup> /d (in easy activity ICRP 23)	$7.5 \times 10^{-2}$ bis $4.5 \times 10^{-1}$	2.6 - 16
		36 m <sup>3</sup> /d (in increased activity ICRP	$1.0 \times 10^{-1}$ bis $6 \times 10^{-1}$	3.5 - 21

Table 6.3.2. Comparison of the J - 131 inhalation dose of adults, small children and fetuses (according to Lit. (8))

IFEU  
Institute for  
Energy and Envi-  
ronmental Research  
Im Sand  
6900 Heidelberg





- 1. Reactor pressure container
- 2. Steam generator
- 3. Safety container
- 4. Reinforced concrete casing
- 5. Live-steam line
- 6. Feed water line
- 7. Discharge valves (Live steam safety valves and discharge exhaust valves).
- o Activity

IFEU

Institute for  
 Energy and Environ-  
 mental Research  
 Im Sand 5  
 6900 Heidelberg

Table 6.3.2. Release of <sup>radio</sup>activity ~~by~~ <sup>by</sup>  
 bypassing all safety barriers  
~~caused~~ <sup>caused</sup> of breakdown: Breakdown  
 of ~~the~~ tubes in steam generator-  
 Exhaust valve in "open" position

6.4. A Critical Examination of the Breakdown Studies Carried out by the  
Baden Technical Control Board

In <sup>its</sup> ~~the~~ examination "Release of <sup>Radio</sup> Activities in ~~Atomic~~ Atomic Plants Breakdowns with LWR [meaning of abbreviation unknown] Via the Exhaust Path Within the Framework of a Guideline to ~~Paragraph~~ Paragraph 3, Article 28 (as of December 14, 1979)" the Baden Technical Control Board likewise considered breakdowns with secondary releases <sup>through</sup> roof of <sup>lubrication</sup> hall. For this purpose the KKP II (Philippsburg, Baden) installation now under construction <sup>has</sup> served for the examination of the KWU-pressurized water line.

From the list of the breakdowns discussed in the above examination <sup>interesting</sup> two breakdowns are discussed in <sup>greater</sup> detail in connection with the above-mentioned examination. They are:

1. Breakdown of a live-steam line outside of the safety container coinciding with the breakdown of 10 tubes in the steam generator.
2. Breakdown in the feed water system outside of the safety container coinciding with the breakdown of a tube in the steam generator.

<sup>No opportunity</sup> ~~to~~ <sup>for the</sup> ~~review~~ review the KWU programs modified by the Baden Technical Control Board and the system analysis based on them. For this reason the correctness of the calculation programs and computer

237

plots with regard to the algorithm and also the system analysis must be assumed a priori.

Therefore consideration may be given to the ~~sequence~~<sup>sequence</sup> of ~~breakdowns~~ only ~~as far as~~<sup>those</sup> criteria are concerned ~~that are~~<sup>that are</sup> particularly relevant to ~~release~~<sup>release</sup>. Special attention should also be given here to ~~radio~~<sup>radio</sup> activity ~~in~~<sup>in</sup> production data.

6.4.1. Breakdown 1 - Bursting of a live-steam line outside of the

safety container coinciding with the breakdown of 10 ~~tubes~~ tubes in the steam generator.

The Technical Control Board computes the ~~total~~ quantity of activity ~~released~~ <sup>in</sup> 30 minutes as a result of a breakdown in the live-steam line coinciding with the breakdown (10 ~~tubes~~ tubes) in the steam generator at the beginning of the breakdown in the live-steam line leakage and, subsequent via the discharge valves of the steam generator via the turbine hall.

238

The breakdown has not been chosen conservatively since only a breakdown of 10 ~~tubes~~ tubes in the steam generator has been assumed. Altogether <sup>there are</sup> more than 4,000 U-shaped ~~tubes~~ tubes in a steam generator. According to our findings in transients the breakdown of at least 20 ~~tubes~~ tubes should be assumed ~~in~~.

The ~~release~~ <sup>release</sup> results from the primary cooling water released into the environment and its specific activity.

In its computations, the Technical Control Board proceeds from a release of primary ~~coolant~~ coolant of 191.63 kg with a specific <sup>radic</sup> activity of 21.6 Ci/t with a Jod-131-share of 0.92 Ci/t.

Both specifications must be challenged.

1. The primary coolant release of approximately 200 kg is too low ~~by~~ <sup>by factor</sup> 27 as it ~~is~~ <sup>can</sup> be recalculated from the Technical Control Board's own data and assumptions. <sup>In addition</sup> a correction of the untenable assumptions about the ~~residual~~ residual moisture in the steam generator has not been made.

2. the specific activity of the primary coolant of 21.6 Ci/t indicated by the Technical Control Board is ~~at least~~ <sup>around</sup> too low at least ~~3~~ factor 4.6 in ~~maximum~~ average spikes and 19.3 in maximal spikes.

This specific activity of the primary cooling water may already be exceeded over short periods in normal operation as a result of load changes (small transients). This spiking effect grows with the size of the transients.

A maximal <sup>transgression</sup> ~~of~~ of the interpretation activities is, therefore, to be expected particularly in ~~the~~ assumed breakdown conditions with large pressure transients. Therefore, the spiking factors must be <sup>added [?]</sup> to the ~~interpretation activities~~

238

-23-

interpretation activities (see Section 2.3.1.2.).

239

In addition to the ~~spike~~ spike criterion, consideration must be given to the fact that ~~the~~ Tables 3.22 and 3.23 of the Technical Control Board which all computations of the activity release refer, <sup>do not include</sup> ~~all~~ all relevant nuclear ~~and~~ and that the data ~~always~~ always exclude ~~tritium~~ tritium activities.

In connection with the breakdown discussed here - breakdown ~~in~~ in the live-steam line coinciding with <sup>the</sup> bursting of ~~the~~ tubes in the steam generator it is suggested ~~to~~ that we examine here this breakdown <sup>and the</sup> ~~additional~~ additional breakdown of a discharge valve in "open" or "partially open" position in agreement with the individual error criteria.

By doing so, we would have to consider the breakdown of the ~~the~~ tube as an error resulting from the bursting of the live-steam line. In this breakdown significantly higher <sup>releases</sup> ~~releases~~ may be expected as a result of the breakdown of the discharge valve.

6.4.2. Breakdown 2- Breakdown in the Feed Water System Coinciding with

the Breakdown of a ~~the~~ Tube in the Steam Generator

After the breakdown of the feed water line at the lowest point of the feed water system, its contents empties together with the live-steam

239

-24-

portion into the roof of the ~~generator~~ <sup>turbine hall</sup> (altogether 730 t) during which time part of it evaporizes (approx 170 tons) and <sup>'s</sup> released into the environment via the roof of the ~~generator~~ <sup>turbine hall</sup>.

88 kg of water with primary activity ~~infiltrates~~ <sup>infiltrates</sup> the feeder via the ~~generator~~ <sup>turbine</sup> ~~hall~~ sump system. ~~According~~ <sup>According</sup> to the Technical Control Board these 88 kg ~~infiltrates~~ <sup>infiltrates</sup> with the live steam ~~leakage~~ <sup>leakage</sup> the feed water container via the condens~~er~~ <sup>er</sup> by the time the turbine is shut down (30 sec).

In this connection the following may be stated:

1.. The ~~response~~ <sup>breakdown</sup> sequence contains a few ~~conservative~~ <sup>conservative</sup> assumptions:

Only one ~~single~~ <sup>single</sup> tube breakdown has been assumed.

Already at the burst of ~~2~~ <sup>2</sup> tubes ~~the~~ <sup>the</sup> response pressure of the discharge valves (86 bar for KKP II) would be exceeded and a significant additional release would result (see breakdown 1 - breakdown of the live steam line).

As described in Section 2.4, a sudden breakdown of ~~2~~ tubes in the steam generator must be ~~assured~~ <sup>assured</sup> and ~~assumed~~ <sup>assumed</sup>, in particular, ~~assumed~~ <sup>assumed</sup>.

~~the~~ <sup>the</sup> breakdown of at least 10 ~~tubes~~ <sup>tubes</sup>.

in transient's subject to breakdowns. In addition, we ~~must further~~ <sup>must further</sup> assume t

not all ~~2~~ tube leakages occur in one steam generator.

240

Handwritten scribbles and lines at the bottom left corner.

240

2. The computation of the activity release is contradictory.

2.1 It is assumed that 88 kg <sup>of</sup> ~~primary~~ primary water are released through the feed water leakage and that ~~A~~ part of it evaporizes together with the 170 t and <sup>is</sup> released through the roof.

If we proceed from the <sup>s</sup> ~~assumption~~ assumption that the 88 kg must be equally distributed ~~over~~ <sup>over</sup> the 730 t of the total water leakage, 20.5

<sup>of</sup> kg primary water would have to evaporize with it. In this connection, it is assumed ~~that~~ <sup>that</sup> ~~evaporization~~ <sup>evaporization</sup> quantity <sup>of 170t</sup> has been correctly

computed. The Technical Control Board did not take into consideration

the activity adequate for this primary coolant quantity of at least

2.1 Ci in average and 8.5 Ci in <sup>maximum</sup> ~~spikes~~ spikes.

2.2. The formula used for the computation of the live-steam <sup>radio</sup> activity

in operational leakages is not sufficient. The formula does not

consider the <sup>radio</sup> activity return flow from the feed water container

into the steam generator (as shown in Chapter 4 - sensitivity

analysis.- this <sup>radio</sup> ~~return~~ flow is primarily for the-live steam concentration).

2.3 The <sup>radio</sup> activities indicated in Table 3.22 show discrepancies in the:

240

values ~~are~~ calculated from the formula indicated. A comparison <sup>between</sup> ~~of~~ the live steam values with the data in Table 3.23 <sup>"specific nuclide activity"</sup> ~~is made in the same manner as~~

in steam generator water" indicates that the Technical Control Board, ~~on~~ <sup>the basis of</sup> ~~the~~ <sup>has consistently</sup> ~~employed~~ excessive high ~~decontamination~~ decontamination factors which results in an un<sup>der</sup>evaluation of

the ~~release~~ release.

Concludingly, it <sup>is</sup> ~~may~~ be stated that the <sup>sequences of</sup> ~~breakdown sequence~~ <sup>in</sup> both

examples examined <sup>are</sup> ~~is~~ not conservative in many points which leads to an under evaluation of the ~~releases~~ <sup>releases</sup>. This applies, in particular to the number of

~~burst~~ tubes in steam generators and the primary <sup>loop</sup> ~~loop~~ activities.

If the abovementioned factors are taken into consideration, the breakdown li may be exceeded by J-131.

241

742

6.5 ~~Annex~~ Bibliography

- (1) Newsweek, February 8, 1982 PP 43: "Again a Nuclear Mishap."
- (2) - Announcement of Safety Criteria for ~~Atomic~~ <sup>Nuclear</sup> Plants of October 21, 1977.  
Federal Minister of the Interior - RS16 - 513301-1/9
- (3) Interpretations of the Safety Criteria for ~~Atomic~~ <sup>Nuclear</sup> Plants,  
Announcement <sup>by</sup> ~~of~~ the Minister of the Interior of October 26, 1978  
- October 26, 1978 RS16 - 513301-4/1
- (4) Technical Control Board Baden: "Activity Release in ~~Atomic~~ <sup>Nuclear</sup> Plant  
Mishaps with LWR via the Exhaust Path within the Framework of a Guideline  
to Paragraph 3 Article 28 StrlSchV" as of December 14, 1979.
- (5) The Effects of Serious Accidents in Regeneration Plants and ~~Atomic~~ <sup>Nuclear</sup>  
Plants.
- (6) Technical Control Board Hannover, An Opinion about the Safety of the  
Grohnde ~~Atomic~~ <sup>Nuclear</sup> Plant, SOG 1, "Radiation Exposition Through ~~Atomic~~ <sup>Release</sup>  
of Radioactive Particles with the Exhaust from the Grohnde ~~Atomic~~ <sup>Nuclear</sup> Plant  
in Special Test Points," Hannover, November 1977.
- (7) The Minister of the Interior, "General Computation Basis for ~~Atomic~~ <sup>Nuclear</sup> Radio

242

Exposures  
~~Deposition~~ in Radioactive Leakages with the Exhaust and in Surface  
Waters," Joint Journal 1979.

(8) B. Steinhilber-Schwab, B. Franke, IFEU - Institute for Energy and  
Environmental Research, Heidelberg, Inc.

"Load Paths and Selected Examples," Lecture at the Radioecology<sup>ical</sup>

Symposium of the Study Group for Environmental Issues, Inc. and the  
Federal Public Health Office, University of Stuttgart, October ~~1980~~

15 and 16, 1981.

7. CONCLUDING REMARKS

7.1 Consequences <sup>Derived</sup> from the Results of the Study

The ~~error~~ <sup>of releases</sup> computations in operational leakages in steam generator ~~and breakdowns~~ <sup>of tubes</sup> in steam generators show that the primary ~~concentrations~~ <sup>Loop</sup> represent central input parameters,

In order to minimize in normal operation the risks connected with an

increase of the primary ~~activities~~ <sup>Loop radio</sup> activities, we propose to expand ~~the primary circuit~~ <sup>in terms of</sup>

the primary circuit the reactor protective system by ~~measuring device~~ <sup>radio</sup>

measuring device <sup>for the purpose of continuously monitoring</sup> the activity concentrations of some guiding nuclides.

After exceeding a <sup>critical</sup> limit ~~the reactor should shut off automatically~~

(see Lit. (5) and (1)). In (1) Osetek and others present a special

$\gamma$ - spectrometer with which the fission productivity of the primary coolant

~~can be~~ <sup>can</sup> be measured continuously

The ~~breakdowns~~ <sup>burst</sup> of the ~~hot~~ tubes in the ~~generator~~ <sup>steam</sup> generator ~~examination~~ <sup>after</sup>

show that the corresponding secondary ~~emissions~~ <sup>releases</sup> have so far been entirely

underevaluated:

If, <sup>by applying</sup> ~~the individual error criteria~~ <sup>to</sup> a burst ~~with~~

243

tube in a steam generator, an additional breakdown of the secondary discharge valve in an "open" or "partially open" position is taken into consideration, the computations show an transgression of the breakdown limit through inhalation already for Jod-131 by the factor 60 in the case of adults.

These results relate to the statement made in the "German Study of Risk"

(3):

controlled

" A leak in the pressure holder or the steam generator itself is ~~uncontrolled~~ by the safety systems just as a leak in the primary ~~coolant~~ <sup>coolant</sup> line."


This statement does not apply ~~to~~ to the breakdown described above which, in ~~the~~ application of the individual error system, we propose to include as an interpretation breakdown in the series of the breakdowns to be considered within the framework of a guideline to Paragraph 3, Article 28 of the StrSchV since a spontaneous breakdown of ~~the~~ tubes in the steam generator may not be excluded even without large transients (see the ~~fact~~ <sup>mishap</sup> at GINNA, U.S. in February 1982).

244

In connection with ~~the~~ <sup>the</sup> burst ~~in~~ <sup>etc</sup> tube in steam generator

and breakdown of the secondary discharge valve in "open" position ~~is~~ <sup>an</sup>

a ~~core meltdown~~ <sup>core meltdown</sup> accident as a result of ~~the~~ coolant loss cannot be excluded.



244 31-  
This would result in the release of part of the nuclear ~~equipment~~ <sup>equipment</sup> via the secondary discharge valve. ~~The~~ <sup>^</sup> effect ~~it~~ <sup>it</sup> may have on the environment has already been examined by the Institute for Reactor Safety (IRS) (2).

In order to minimize the catastrophic consequences of such a breakdown (the term "breakdown" has been purposely chosen since the ~~breakdowns~~ <sup>sequence of</sup> ~~breakdowns~~ <sup>sequence of</sup> results from the application of the individual error criteria to the ~~breakdowns~~ coolant loss breakdowns), we propose ~~to~~ <sup>to</sup> build ~~the~~ <sup>the</sup> a containment for the purpose of preventing corresponding releases from the secondary discharge valve from ~~infiltrating~~ <sup>infiltrating</sup> the environment. In this connection, we also wish to mention ~~the construction~~ <sup>the construction</sup> of a subterranean safety tunnel through which the exhaust valves ~~will~~ <sup>will</sup> release steam (4).

In addition, the following consequences should be drawn from the results of the study:

- The air conditioning ~~in~~ <sup>system</sup> the switch plant for the control room, etc. net is air humidity (ca. 160 kg/h) from the auxiliary steam system. The auxiliary steam system, however, will in accordance with the operational condition of the power plant ~~be~~ <sup>be</sup> supplied either ~~by~~ <sup>by</sup> the high pressure tap system, the ~~live~~ live steam system or ~~the~~ the auxiliary steam generator

system. This should be changed immediately since in the event of a ~~burst~~ tube <sup>burst</sup> in the steam generator the <sup>radio</sup> activity ~~that infiltrated~~ to the live steam is distributed over the air conditioning system.

The shut-off limit of the N-16 signal should be coupled to the reactor output since in a 50% output <sup>as compared</sup> ~~to~~ to a 100% output the steam generator output <sup>might</sup> ~~be~~ be approximately twice as high ~~before~~ prior to the N-16 quick shut-off's response.

- Particularly, in the steam generator, a direct steam transport should be taken into consideration in most nuclides ~~and~~ in addition to the residual moisture transport since both ~~the~~ live steam <sup>radio</sup> activity and also ~~releases~~ might be undervaluated.

- ~~Compliance~~ <sup>maximum</sup> Compliance with the ~~live steam~~ <sup>for J-131</sup> live steam concentration as established by the ~~competent~~ authorities ~~should~~ ~~be~~ <sup>by</sup> continuous <sup>be measured.</sup> ~~measured~~ ~~otherwise~~ a transgression might occur.

- ~~Measurements~~ <sup>Turbine hall releases</sup> ~~should~~ <sup>monitored</sup> be ~~monitored~~ by measuring instruments.

As long as this is not the case, repeated ~~measurements~~ <sup>+</sup> differences between ~~measurements~~ <sup>releases</sup> of ~~activity~~ and immission <sup>quantities similar to</sup> of those that ~~happen~~ <sup>happen</sup>.

245

33-

in in Obrigheim ~~cannot be~~ <sup>unmeasured</sup> excluded since ~~activity~~ activity

~~releases~~ releases may occur.

246

7.2. <sup>Bibliography</sup> ~~related~~ to 7.

- (1) Osceck, D.J. Coates, R.A., Johnson, L.O., Killian, E.W., King, J.J.,

"The Power Burst Facility Fission Product Detection System."

NRC Instrumentation Review Group Meeting July 1979

- (2) The Effects of Serious Accidents in WAA's and AKW's. Reprint and

Interpretation of two confidential studies by the Institute for

Reactor Safety of August and November 1976.

BBU January 1977

- (3) Association for Reactor Safety,

"German Study of Risk <sup>in</sup> Atomic Plants," Technical Volume 7,

Page 36, Technical Control Board Publishing House, Rhineland 1980

- (4) Akesson, B.A., Bergman, S.G.A., Sagefors, K.I., WP-Cave - A New

Concept for Underground High-level Nuclear Waste ~~Res~~ Repository,

Subsurface Space, Rockstore 80, Volume 2, Pergamon Press, 1980.

- (5) Jakobi, S. Trudowsky, K. Monitoring of Casings in Fuel Elements of

Nuclear Reactors, KfK 1452, October 1971.

2. The KWU Model does not assume any elutriation demineralization release, and hence suppresses essential radioactivity contributing to a direct unfiltered release through the roof of the turbine hall.

3. The KWU Model assumes that the only direct release pathway is by a blow-off through the safety valve. It does not take into account releases from the high pressure part of the secondary loop. Both assumptions lead to a considerable understatement of the direct and unfiltered releases through the roof stack in normal operation (no blow-off).

4. The diagram suggests leakages into the turbine hall (with the exception of the blow-off through the safety valves). In contradiction to this is the assumption made on the completely false premisses in the text that although iodine-131 is released through the roof of the turbine hall (and as well as through the sewage), the N-16-scrum limits the concentration of iodine -131 in live steam to the values decreed by the Federal Minister for the Interior. This point will be further discussed in the chapter on the steam generator leakages.

We can briefly say, that the KWU Model must lead to a strong underestimation of real releases.

Translated by Casimir Petraitis  
Congressional Research Service  
Language Services