

APPENDIX A

NOTICE OF VIOLATION

Virginia Electric and Power Company
North Anna 1 and 2

Docket Nos. 50-338 & 50-339
License Nos. NPF-4 & NPF-7

As a result of the inspection conducted on September 13-17, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified.

Technical Specification 3.4.8 requires that a special report be prepared and submitted to the Commission whenever the specific activity of the primary coolant is greater than one microcurie per gram Dose Equivalent I-131.

Contrary to the above, a special report was not prepared nor submitted to the Commission when the specific activity of the Unit 1 primary coolant exceeded one microcurie per gram and remained over this limit for 12 hours on January 23, 1982. The specific activity peaked at 1.80 microcuries per gram.

This is a Severity Level V Violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Date: October 5, 1982