

January 5, 1995

Mr. Roger O. Anderson, Director  
Licensing and Management Issues  
Northern States Power Company  
414 Nicollet Mall  
Minneapolis, Minnesota 55401


SUBJECT: PRAIRIE ISLAND NUCLEAR GENERATING PLANT, UNIT NOS. 1 AND 2 -  
ISSUANCE OF AMENDMENTS RE: EMERGENCY DIESEL GENERATOR TESTING  
REQUIREMENTS (TAC NOS. M90564 AND M90565)

Dear Mr. Anderson:

The Commission has issued the enclosed Amendment No. 113 to Facility Operating License No. DPR-42 and Amendment No. 106 to the Facility Operating License No. DPR-60 for the Prairie Island Nuclear Generating Plant, Unit Nos. 1 and 2. The amendments consist of changes to the Technical Specifications in response to your application dated October 3, 1994, as supplemented November 30, 1994,

The amendments revise Prairie Island Nuclear Generating Plant Technical Specification 4.6, "Periodic Testing of Emergency Power Systems." Specifically, the amendments modify the emergency diesel generator (EDG) 24-hour load test requirements to provide an indicated load range of 103-110 percent of the continuous rating. The amendments also rephrase various EDG test requirements to provide clarity and delete the requirement to verify that the auto-connected loads for the Unit 1 and Unit 2 EDGs do not exceed 3,000 kilowatts and 5,100 kilowatts, respectively.

A copy of our related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.




Sincerely,  
  
Sheri R. Peterson, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

- Enclosures: 1. Amendment No. 113 to DPR-42  
2. Amendment No. 106 to DPR-60  
3. Safety Evaluation

cc w/encl: See next page

DOCUMENT NAME: G:\WPDOCS\PRAIRIE\PI90564.AMD \*See Previous Concurrence

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure  
"N" = No copy

OFFICE	LA:PD31	<input checked="" type="checkbox"/> E	PM:PD31	OGC*	D:PD31
NAME	CJamerson 		SPeterson 	CABarth	JHannon 
DATE	1/4/95		1/5/95	12/30/94	1/5/95

OFFICIAL RECORD COPY

9501100244 950105  
PDR ADOCK 05000282  
P PDR



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

January 5, 1995

Mr. Roger O. Anderson, Director  
Licensing and Management Issues  
Northern States Power Company  
414 Nicollet Mall  
Minneapolis, Minnesota 55401

SUBJECT: PRAIRIE ISLAND NUCLEAR GENERATING PLANT, UNIT NOS. 1 AND 2 -  
ISSUANCE OF AMENDMENTS RE: EMERGENCY DIESEL GENERATOR TESTING  
REQUIREMENTS (TAC NOS. M90564 AND M90565)

Dear Mr. Anderson:

The Commission has issued the enclosed Amendment No. 113 to Facility Operating License No. DPR-42 and Amendment No. 106 to the Facility Operating License No. DPR-60 for the Prairie Island Nuclear Generating Plant, Unit Nos. 1 and 2. The amendments consist of changes to the Technical Specifications in response to your application dated October 3, 1994, as supplemented November 30, 1994,

The amendments revise Prairie Island Nuclear Generating Plant Technical Specification 4.6, "Periodic Testing of Emergency Power Systems." Specifically, the amendments modify the emergency diesel generator (EDG) 24-hour load test requirements to provide an indicated load range of 103-110 percent of the continuous rating. The amendments also rephrase various EDG test requirements to provide clarity and delete the requirement to verify that the auto-connected loads for the Unit 1 and Unit 2 EDGs do not exceed 3,000 kilowatts and 5,100 kilowatts, respectively.

A copy of our related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Sheri R. Peterson, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III/IV  
Office of Nuclear Reactor Regulation

Docket Nos. 50-282 and 50-306

Enclosures: 1. Amendment No. 113 to DPR-42  
2. Amendment No. 106 to DPR-60  
3. Safety Evaluation

cc w/encl: See next page

NRC FILE CENTER COPY

090031

DF01

DATED: January 5, 1995

AMENDMENT NO. 113 TO FACILITY OPERATING LICENSE NO. DPR-42-PRAIRIE ISLAND - UNIT 1  
AMENDMENT NO. 106 TO FACILITY OPERATING LICENSE NO. DPR-60-PRAIRIE ISLAND - UNIT 2

**Docket File**

PUBLIC  
PDIII-1 Reading  
J. Roe  
J. Hannon  
C. Jamerson  
S. Peterson (2)  
C. Berlinger  
M. Pratt  
D. Thatcher  
OGC  
G. Hill, IRM (4)  
C. Grimes, DOPS/OTSB, O-11F23  
ACRS (4)  
OPA  
OC/LFDCB  
W. Kropp, RIII  
SEDB

cc: Plant Service list

Mr. Roger O. Anderson, Director  
Northern States Power Company

Prairie Island Nuclear Generating  
Plant

cc:

J. E. Silberg, Esquire  
Shaw, Pittman, Potts and Trowbridge  
2300 N Street, N. W.  
Washington DC 20037

Site General Manager  
Prairie Island Nuclear Generating  
Plant  
Northern States Power Company  
1717 Wakonade Drive East  
Welch, Minnesota 55089

Adonis A. Neblett  
Assistant Attorney General  
Office of Attorney General  
455 Minnesota Street  
Suite 900  
St. Paul, Minnesota 55101-2127

U.S. Nuclear Regulatory Commission  
Resident Inspector Office  
1719 Wakonade Drive East  
Welch, Minnesota 55089-9642

Regional Administrator, Region III  
U.S. Nuclear Regulatory Commission  
801 Warrenville Road  
Lisle, Illinois 60532-4351

Mr. Jeff Cole, Auditor/Treasurer  
Goodhue County Courthouse  
Box 408  
Red Wing, Minnesota 55066-0408

Kris Sanda, Commissioner  
Department of Public Service  
121 Seventh Place East  
Suite 200  
St. Paul, Minnesota 55101-2145

Site Licensing  
Prairie Island Nuclear Generating  
Plant  
Northern States Power Company  
1717 Wakonade Drive East  
Welch, Minnesota 55089