

Point Beach Nuclear Plant 6610 Nuclear Rd., Two Rivers, WI 54241

(414) 755-2321

PBL 95-0005

January 6, 1995

Document Control Desk U. S. NUCLEAR REGULATORY COMMISSION Mail Station P1-137 Washington, DC 20555

Gentlemen:

DOCKETS 50-266 AND 50-301 MONTHLY OPERATING REPORTS POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Attached are monthly operating reports for Units 1 and 2 of the Point Beach Nuclear Plant for the calendar month of December, 1994.

Sincerely,

G. J. Makfield PBNP Manager

djs

Attachments

cc: L. L. Smith, PSCW

NRC Regional Administrator, Region III

NRC Resident Inspector

110000

9501110478 941231 PDR ADDCK 05000266 PDR Mert!

#### OPERATING DATA REPORT

DOCKET NO. 50-266

DATE: 01/04/95

COMPLETED BY: M. B. Koudelka

TELEPHONE: 414 755-6480

### OPERATING STATUS

1. UNIT NAME: POINT BEACH NUCLEAR PLANT - UNIT 1 . NOTES

2. REPORTING PERIOD: December - 1994

3. LICENSED THERMAL POWER (MWT): 1518.5

4. NAMEPLATE RATING (GROSS MWE): 523.8

5. DESIGN ELECTRICAL RATING (NET MWE): 497.0

6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 509.0 .

8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:

NA

NA

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE): NA

10. REASONS FOR RESTRICTIONS, (IF ANY):

		THIS MONTH	YEAR TO DATE	CUMULATIVE
7.7	HOURS IN REPORTING PERIOD	744.0	8,760.0	211,728.0
	NUMBER OF HOURS REACTOR WAS CRITICAL	730.1	8,120.7	176,839.6
	REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	667.3
	HOURS GENERATOR ON LINE	730.1	8,072.2	173,712.4
	UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	846.9
		1,096,432	12,063,227	245,544,997
	GROSS THERMAL ENERGY GENERATED (MWH)	371,760	4,084,520	82,938,650
	GROSS ELECTRICAL ENERGY GENERATED	356,154	3,905,061	79,060,651
	NET ELECTRICAL ENERGY GENERATED (MWH)	98.1%	92.1%	82.0%
	UNIT SERVICE FACTOR	98.1%	92.1%	82.4%
	UNIT AVAILABILITY FACTOR	98.7%	91.9%	76.6%
	UNIT CAPACITY FACTOR (USING MDC NET)	96.3%	89.7%	75.1%
	UNIT CAPACITY FACTOR (USING DER NET)	0.0%	0.0%	1.5%
23.	UNIT FORCED OUTAGE RATE			

24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):
Refueling, 03/11/95, 36 days

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:

NA

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC LETTER DATED SEPTEMBER 22, 1977

# UNIT SHUTDOWNS AND POWER REDUCTIONS

# REPORT MONTH DECEMBER - 1994

Docket No. Unit Name Date

50-266 Point Beach, Unit 1

January 5, 1995 M. B. Koudelka

Completed By M. B. Koudelka Telephone No. 414/755-6480

No.	Date	Type <sup>1</sup>	Duration (Hours)	Peason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report No.	System Code <sup>4</sup>	Component Code <sup>5</sup>	10 Pievelli Recollence	
4	12-31	5	13.9	В	5	NA	СВ	нтехсн	Furmanite repair performed on a leaking lower steam generator handhole.	

F: Forced S: Scheduled 2Reason:

A - Equipment Failure (explain)

B - Maintenance or Testing

C - Refueling

D - Regulatory Restriction

E - Operator Training & Licensing Exam

F - Administrative

G - Operational Error (explain)

H - Other (explain)

3Method:

1 - Manual

2 - Manual Scram

3 - Automatic Scram

4 - Continuation of Previous Shutdown

5 - Reduced Load

( - Other (explain)

<sup>4</sup>Exhibit G - Instructions for preparation of data entry sheets LER file (NUREG-0161)

5Exhibit I - Same Source

### AVERAGE DAILY UNIT POWER LEVEL

MONTH DECEMBER - 1994

DATE January 5, 1995

50-266

Point Beach, Unit 1

M. B. Koudelka

DOCKET NO.

UNIT NAME

COMPLETED BY

TELEPHONE (414) 755-6480

DAY	AVERAGE DAILY POWER LEVEL MWe NET	DAY	AVERAGE DAILY POWER LEVEL MWe NET	DAY	AVERAGE DAILY POWER LEVEL MWe NET
1	494	11	494	21	496
2	494	12	493	22	496
3	494	13	493	23	496
4	483	14	494	24	495
5	494	15	496	25	465
6	493	16	495	26	494
7	494	17	494	27	495
8	494	18	497	28	495
9	493	19	495	29	494
10	493	20	496	30	488
				31	52

DOCKET NO. 50-266

UNIT NAME Point Beach Unit 1
DATE January 5, 1995
COMPLETED BY M. B. Koudelka
TELEPHONE 414/755-6480

Unit 1 operated at an average of 479 MWe net for the report period.

## Safety-related maintenance included:

- 1B04 400 V safeguards load center cable ZB1B17BH lugged and meggared.
- 1B52-10B power to P35A electric fire pump amptector retrofit upgrade.
- 3. CO2 main control board new jumper wire installed.
- 4. C22 battery room HVAC control panel light socket and bearing replacements.
- 5. D07 D05 dc station battery charger adjusted and rewired.
- G02 emergency diesel generator air inlet louvers inspected and filed.
- 7. 1N46 power range comparator channel deviation alarm adjusted.
- 8. 1P2A charging pump packing replaced.
- 9. P32C service water pump packing adjusted.
- 10. P32E service water pump packing repaired.
- 11. P38B auxiliary feedwater motor-driven pump oil sampled, pump inspected and cleaned.
- 12. PI-3909 P70B fuel oil transfer pump discharge pressure indicator snubber replacement.
- 13. 1PT-940 T34A safety injection accumulator pressure transmitter high pressure alarm adjusted.
- 14. 1SI-8253 T13 refueling water storage tank outlet to P15A&B safety injection pump valve inspected and cleaned.
- 15. 1SI-826A&P P15A&B safety injection pump suction from boric acid storage tank series and parallel isolation valves inspected and cleaned.

- 16. 1SI-870A P14A containment spray pump suction from T13 refueling water storage tank valve inspected and cleaned.
- 17. SW-658 HX-13A&B spent fuel pool heat exchanger return drain cleaned and rethreaded valve outlet cap.
- 18. SW-2869-O north header to west header service water valve operator adjusted.
- 19. TS-4899 and TS-4903 primary auxiliary building battery rooms A and B alarm/control temperature switch calibrations.

DOCKET NO. 50-301

DATE: 01/05/95

COMPLETED BY: M. B. Koudelka

TELEPHONE: 414 755-6480

#### OPERATING STATUS

1. UNIT NAME: POINT BEACH NUCLEAR PLANT - UNIT 2 . NOTES

2. REPORTING PERIOD: December - 1994

- 3. LICENSED THERMAL POWER (MWT): 1518.5
- 4. NAMEPLATE RATING (GROSS MWE): 523.8
- 5. DESIGN ELECTRICAL RATING (NET MWE): 497.0
- 6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 509.0 .
- 8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
- 9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE): NA
- 10. REASONS FOR RESTRICTIONS, (IF ANY):

	THIS MONTH	YEAR TO DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	744.0	8,760.0	196,513.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	7,851.0	172,051.6
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	233.9
14. HOURS GENERATOR ON LINE	744.0	7,828.0	169,694.7
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	302.2
16. GROSS THERMAL ENERGY GENERATED (MWH)	1,115,420	11,610,741	243,981,925
17. GROSS ELECTRICAL ENERGY GENERATED	377,210	3,926,850	82,951,110
18. NET ELECTRICAL ENERGY GENERATED (MWH)	361.051	3,749,875	79,080,515
19. UNIT SERVICE FACTOR	100.0%	89.4%	86.4%
20. UNIT AVAILABILITY FACTOR	100.0%	89.4%	86.5%
21. UNIT CAPACITY FACTOR (USING MDC NET)	100.1%	88.3%	82.4%
22. UNIT CAPACITY FACTOR (USING DER NET)	97.6%	86.1%	81.0%
23. UNIT FORCED OUTAGE RATE	0.0%	0.0%	1.0%

24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC LETTER DATED SEPTEMBER 22, 1977

# UNIT SHUTDOWNS AND POWER REDUCTIONS

# REPORT MONTH DECEMBER - 1994

50-301 Docket No. Point Beach, Unit 2 Unit Name January 5, 1995 Date adelka 480\_

Completed By	M. B. Kou
Telephone No.	414/755-64

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor	Licensee Event Report No.	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause and Corrective Action To Prevent Recurrence
NA	NA	NA	NA	NA	NA	NA	NA	NA	NA NA
								Service of the	
				1000					

F: Forced S: Scheduled 2Reason:

A - Equipment Failure (explain)

B - Maintenance or Testing

C - Refueling

D - Regulatory Restriction

E - Operator Training & Licensing Exam

F - Administrative

G - Operational Error (explain)

H - Other (explain)

3Method:

1 - Manual

2 - Manual Scram

3 - Automatic Scram

4 - Continuation of Previous Shutdown

5 - Reduced Load

6 - Other (explain)

\*Exhibit G - Instructions for preparation of data entry sheets LER file (NUREG-0161)

5Exhibit I - Same Source

### AVERAGE DAILY UNIT POWER LEVEL

MONTH DECEMBER - 1994

DOCKET NO. 50-301

UNIT NAME Point Beach, Unit 2°

DATE January 5, 1995

COMPLETED BY M. B. Koudelka

TELEPHONE (414) 755-6480

DAY	AVERAGE DAILY POWER LEVEL MWe NET	DAY	AVERAGE DAILY POWER LEVEL MWe NET	DAY	AVERAGE DAILY POWER LEVEL MWe NET
			MING INC.	DAT	MAAGMET
1	474	11	486	21	486
2	487	12	485	22	487
3	491	13	485	23	486
4	487	14	484	24	486
5	483	15	486	25	486
6	487	16	484	26	486
7	487	17	483	27	486
8	486	18	486	28	487
9	485	19	484	29	484
10	486	20	485	30	486
				31	485

DOCKET NO. 50-301

UNIT NAME DATE

Point Beach Unit 2 December 6, 1994

COMPLETED BY M. B. Koudelka

TELEPHONE 414/755-6480

Unit 2 operated at an average of 485 MWe net for the report period.

Licensee Event Report 50-301/94-005-00, Violation of Technical Specifications Table 15.3.5-2 Overtemperature AT Minimum Degree of Redundancy Not Achieved, was submitted.

Safety-related maintenance included:

- 2CV-283B P2B charging pump discharge to T4 volume control tank relief valve replacement.
- 2CC-744A HX-8B boric acid evaporator component cooling supply valve bushing replaced.
- 2DY-01 Red 125 Vdc/120 Vac inverter contact burnished and bench tested.
- 2FI-607 and 2FI-116 flow indicators retubed. 4.
- 2RH-626 HX-11A&B residual heat removal heat exchanger bypass 5. flow control valve local position indicator installed.
- 2P11B component cooling water pump inboard/outboard seals and bearings replaced.