

U.S. NUCLEAR REGULATORY COMMISSION

REGION III

Report No. 50-461/91014(DRSS)

License No. NPF-62

Licensee: Illinois Power Company
500 South 27th Street
Decatur, IL 62525

Facility Name: Clinton Power Station

Inspection At: Clinton Site, Clinton, Illinois

Inspection Dates: July 15-19, 1991

Inspector: J. L. Belanger for
J. L. Belanger
Senior Physical Security
Inspector

8/7/91
Date

Approved By: James R. Creed
James R. Creed, Chief
Safeguards Section

8/7/91
Date

Inspection Summary

Inspection between July 15-19, 1991 (Report No. 50-461/91014))

Areas Inspected: Routine, unannounced physical security inspection involving: Management Support, Security Program Plans and Audits; Protected and Vital Area Physical Barriers; Detection and Assessment Aids; Protected and Vital Area Access Control of Personnel, and Packages and Vehicles.

Results: No violations of regulatory requirements within the areas examined or significant programmatic weaknesses were identified. Management support for the security program was demonstrated by their support for measures to heighten security awareness during the Persian Gulf war. Additionally, support was also evidenced by improvements to the assessment system, tactical response training, and security training instructor qualifications. The use of compensatory measures for security hardware failures, on the other hand, appears to be increasing because of the normal aging of the equipment. The licensee is evaluating a detailed proposal which would significantly upgrade key elements of the security system. The licensee's Quality Assurance audits and surveillances were thorough, complete, and effective. Security staffing is adequate to meet routine operational commitments.

Enclosure Contains
SAFEGUARDS INFORMATION
Upon Separation This
Page Is Declassified