

ENCLOSURE (1)

CALVERT CLIFFS NUCLEAR POWER PLANT SIMULATOR FOUR-YEAR CERTIFICATION REPORT

I. INTRODUCTION

The Calvert Cliffs Nuclear Power Plant Simulator four-year Certification Report is a supplement to the Simulation Certification form (NRC Form-474), the Simulator Annual Certification Report, and Simulator Support Unit Procedures. This report briefly provides a description of the simulator, the Certification Resubmittal checklist and a current status of simulator configuration modifications. Additional information concerning specific tests is available upon request. The last report was submitted January 11, 1991.

II. SIMULATOR INFORMATION

Simulator type:	Reference Plant Simulator
Manufacturer:	Combustion Engineering
Owner/Operator:	Baltimore Gas and Electric Company (BGE)
Reference Plant:	Calvert Cliffs Unit One
Plant Location:	Lusby, Maryland
Plant Type:	Pressurized Water Reactor
Plant Rating:	2700 Mwth
Date Available for Training:	January, 1985
Original Certification Date:	January 11, 1991
Type of Report:	Four-Year Certification
Applicable Standards:	
Design/Testing:	ANSI/ANS 3.8-1985 (Reference 2) NRC RG 1.149-1987 (Reference 3)

III. SIMULATOR PROCEDURES

The Simulator is controlled, operated, tested and modified using the following Calvert Cliffs procedures:

- TI 15 "Administrative Control of Changes to Training Programs."
- TI 16 "Simulator Issue Reports."
- TI 19 "Calvert Cliffs Simulator Facility Configuration Management."

IV. SIMULATOR DATABASE

Controlled drawings and procedures are used as a basis for handler logic and system flow calculations. The plant setpoint file is also used as an input to the simulator data base. Plant or Simulator Support Unit logs are used whenever possible to compare initial condition values. Plant or Engineering data is used when necessary to ensure the simulator data base closely models the plant. Feedback from plant operators, using the Simulator Issue Report (SIR) process, is an essential part of maintaining the simulator current with the plant.

ENCLOSURE (1)

CALVERT CLIFFS NUCLEAR POWER PLANT SIMULATOR FOUR-YEAR CERTIFICATION REPORT

V. DEVIATIONS SINCE LAST REPORT

Missing three Year One Annual Test hard copies. Documentation of the runs are contained in the Year One Annual Report. All annual tests were completed with satisfactory results.

Missed the performance of ANS 3.8 paragraph C.4 "Hot Standby to Minimum Load" in Year Two. The simulator was subsequently exercised with satisfactory results under the 100% Trip and Recovery test performed in 1994. This test was performed on January 6, 1995, with satisfactory results.

ANS 3.8 C.5 "Turbine Startup and Synchronization" and C.6 "Minimum Load to 100 Percent Power" were delayed two months to allow testing of new input/output (I/O) placed on the simulator in December 1992.

Missed the performance of Year Two Malfunction 165 during 1992. It was run with satisfactory results in 1991. This test was performed on January 5, 1995, with satisfactory results.

No additional major differences exist between the simulator and the reference plant.

VI. MAJOR CHANGES SINCE THE LAST REPORT

Inclusion of the Digital Feedwater Control System and Lovejoy in the Reference Plant and the Simulator eliminates the "Feedwater Panel" EXCEPTION in the original submittal.

Changed Malfunction 59 [Power Operated Relief Valve (PORV) Leakage] to Malfunction 66 (PORV Leakage) to allow the option for either PORV to be affected.

There were no discrepancies under the "MAJOR Simulator Fidelity" category.

VII. MAJOR CHANGE MILESTONES OCCURRING WITHIN THE NEXT YEAR

Host and I/O Computer replacement

Instructor Station replacement including workstations

Possible ability to perform Certification Testing off-line

Furniture replacement in the plant and on the simulator

Station Blackout Emergency Diesel Generator panel installation (Per Operations Request, the Simulator Installation will have Plant Installation to facilitate training.)

ENCLOSURE (1)

CALVERT CLIFFS NUCLEAR POWER PLANT SIMULATOR FOUR-YEAR CERTIFICATION REPORT

VIII. OUTSTANDING ITEMS FROM LAST SUBMITTAL

The following discrepancies have not been corrected:

<u>SIR No.</u>	<u>Discrepancy</u>	<u>Corrective Actions</u>
S1700	During 100% Power Trip & Recovery, at 20% Reactor Power the transfer from First Stage Pressure Feedback Out to First Stage Pressure Feedback In caused enough perturbations to cause a Reactor Trip.	Pending. Modifications were made to the software to reflect plant design. These changes caused major differences in other indications. After this attempt failed, the First Stage Pressure Feedback failed in the plant causing plant operations in First Stage Pressure Feedback OUT only, except for valve testing.
S1879	During the 75% Power Steady State Test MWE output was too high.	Pending. With the simulator matching plant conditions (summer time) the MWE fell into specification, but other indications fell out of specification.

IX. CERTIFICATION TESTING CHECKLIST

The attached Calvert Cliffs Nuclear Power Plant Simulator Certification Report Checkoff Sheet [Attachment (1)] indicates the audit completed to maintain simulator certification. Specific data is available upon request.

Certification tests are divided into three groups:

- | | | |
|-------------------|---|--|
| Annual Tests | - | Performed each year (Certification file on the simulator) |
| Performance Tests | - | Performed over a four-year period (Certification file on the simulator) |
| Malfunction Tests | - | 25% per year in accordance with the testing schedule (Certification file on the simulator) |

X. ADDITIONAL TESTING

SPIN Testing: Every time a "SPIN" (new training load) occurs, we run an integration test to ensure the changes are incorporated and that the changes do not detract from training. This testing includes ANS 3.8 2i "Main Steam Line Break" and 2h "LOCA with Loss of Offsite Power" because these tests exercise most of the computer models. Affected malfunction tests may also be used. Credit for this testing is not considered in the Certification Testing.

The computer replacement project included BENCHMARK testing to ensure the continued certification of the Calvert Cliffs Simulator. This testing included taking the simulator from "100% to Cold Shutdown," "Mass/Energy Balance" testing, "Simultaneous Trip of Both Steam Generator Feed Pumps,"

ENCLOSURE (1)

CALVERT CLIFFS NUCLEAR POWER PLANT SIMULATOR FOUR-YEAR CERTIFICATION REPORT

"Simultaneous Closure of Both Main Steam Isolation Valves," "Reactor Trip and Recovery from 100 Percent Power" and selected Malfunctions from Year Four.

The following MALFUNCTIONS were developed, tested and added to our test plan for the 1995-1998 Certification cycle:

Malfunction 5	Wide Range Nuclear Instrument Failure	Yr 3
Malfunction 52	Switchyard Breaker Fails to Trip	Yr 3
Malfunction 63	Pressurizer Pressure Safety Channel Failure	Yr 1
Malfunction 74	Tube Leak in the Non-Regenerative Heat Exchanger	Yr 3
Malfunction 97	Digital Feedwater Control System Central Processing Unit Failure	Yr 4
Malfunction 106	Loss of Steam Flow Input to Digital Feedwater Control System	Yr 3
Malfunction 107	Feed Flow Element F1111A/1121A Failure	Yr 2
Malfunction 152	Steam Generator Blowdown Fails to Isolate on High Radiation Signal	Yr 2
Malfunction 187	Low Pressure Safety Injection (LPSI) Pump Suction Break	Yr 4
Malfunction 195	Low Level in the Safety Injection Tank	Yr 1
Malfunction 214	Service Water Leak in Auxiliary Building	Yr 1
Malfunction 215	Service Water Leak in Turbine Building	Yr 2
Malfunction 217	Saltwater System Leak	Yr 3
Malfunction 218	Area Radiation Monitor Failure	Yr 1
Malfunction 231	Component Cooling Water Leak in Containment	Yr 4
Malfunction 240	Main Steam Isolation Valve (MSIV) Fails to Shut on Engineered Safety Feature Actuation Signal	Yr 1
Malfunction 241	Automatic Containment Isolation Signal (CIS) Fails to Actuate	Yr 2
Malfunction 242	Manual CIS Fails to Actuate	Yr 3
Malfunction 243	Automatic Steam Generator Isolation Signal (SGIS) Fails to Actuate	Yr 4
Malfunction 244	Spurious SGIS Actuation	Yr 2
Malfunction 245	Containment Radiation Monitor Failure	Yr 4
Malfunction 246	Failure of Shutdown Sequencer (SDS) Bus 11 to Unblock	Yr 1
Malfunction 247	Failure of SDS Bus 14 to Unblock	Yr 2
Malfunction 248	Failure of Loss-of-Coolant Incident Sequencer (LOCIS) Bus 11 to Unblock	Yr 3
Malfunction 249	Failure of LOCIS Bus 14 to Unblock	Yr 4
Malfunction 250	Steam Generator Wide Range Level Transmitters Fail	Yr 3
Malfunction 251	Failure of No. 12 Steam Generator Pressure Transmitters	Yr 4
Malfunction 252	Failure of No. 12 Steam Generator Protection Level Transmitters	Yr 1
Malfunction 253	Blockage of Salt Water Components	Yr 4

ENCLOSURE (1)

CALVERT CLIFFS NUCLEAR POWER PLANT SIMULATOR
FOUR-YEAR CERTIFICATION REPORT

XI. REFERENCES

1. Title 10, Code of Federal Regulations, Part 55, "Operators' Licenses."
2. ANSI/ANS 3.8-1985 American Nuclear Society "Nuclear Power Plant Simulators for Use in Operator Training"
3. United States Nuclear Regulatory Guide 1.149 "Nuclear Power Plant Simulation Facilities for Use in Operator License Exams" April 1987.

ATTACHMENT (1)

CALVERT CLIFFS UNIT ONE -- REFERENCE PLANT SIMULATOR DUAL UNIT SIMULATOR -- CHECKOFF SHEET

- | | <u>INIT / DATE</u> |
|--|---------------------|
| 1. Review SPIN and Annual Reports and list major changes since the last report. List these under Section VI. | <i>EH</i> 1.1/10/95 |
| 2. Review SPIN and Annual Reports for any changes to the simulator environment (lighting, painting, etc.) List these under Section VI. | <i>EH</i> 1.1/10/95 |
| 3. Review SPIN and Annual Reports for any major model changes, or model changes on SIRs which had "MAJOR Simulator Fidelity" checked. List these under Section VI. | <i>EH</i> 1.1/10/95 |
| 4. List all FCRs which were incorporated on the simulator since the last report. Have this list available for review. | <i>EH</i> 1.1/10/95 |
| 5. List any outstanding items to be completed within the next year. List these under Section VII. | <i>EH</i> 1.1/10/95 |
| 6. Verify Certification Documentation: | |
| a. List all tests from last report and include the dates they were run, Simulator Issue Reports written and resolution. | <i>EH</i> 1.1/10/95 |
| b. Verify testing was performed in accordance with the testing schedule last submitted or reasons for deviation documented in Section V. | <i>EH</i> 1.1/10/95 |
| c. List additional testing performed including SPIN tests. | <i>EH</i> 1.1/10/95 |
| 7. Give up to date evaluation of the simulator: | <i>EH</i> 1.1/10/95 |
| a. Have differences list available for review. | |
| b. List any major differences between the reference plant and the simulator concerning panels, communications, furniture and plant computer. If differences exist which were not addressed in the original submittal, include them in Section V. | <i>EH</i> 1.1/10/95 |
| c. List all of the initial conditions. Ensure conditions under the original submittal are still being met. | <i>EH</i> 1.1/10/95 |
| d. Have SIR list available for review. | <i>EH</i> 1.1/10/95 |
| e. Attach the test plan for the next four years. [Attachment (2)] | <i>EH</i> 1.1/10/95 |
| f. List any additional exceptions to the standard. | <i>EH</i> 1.1/10/95 |
| g. Review Examiners comments from exams performed including our reply. Have these available for review. | <i>EH</i> 1.1/10/95 |
| h. List any deviations from the standard. Include these in Section V. | <i>EH</i> 1.1/10/95 |
| i. List the qualifications of persons who performed, reviewed or approved testing over the last four years: | |

Charles Andrews	Former Licensed SRO (CCNPP)
Richard Best	Attached
Edmund Chrzanowski	Licensed SRO (CCNPP)
James Macklin	Licensed SRO (CCNPP)
Patrick Murphy	Former Licensed RO (CCNPP)
Douglas Tilton	Attached

EH 1.1/10/95

ATTACHMENT (2)

CALVERT CLIFFS UNIT ONE -- REFERENCE PLANT SIMULATOR DUAL UNIT SIMULATOR

ANNUAL TEST PLAN

ANS 3.8-1d	100% Power Drift Check
	Operability Check of Real Time Simulation
ANS 3.8-1a	25% Power Energy/Mass Balance
ANS 3.8-1b	50 ANS 3.8-1% Power Energy/Mass Balance
ANS 3.8-1c	75% Power Energy/Mass Balance
ANS 3.8-1d	100% Power Energy/Mass Balance
ANS 3.8-2a	Manual Reactor Trip
ANS 3.8-2b	Trip of 11 & 12 Steam Generator Feedwater Pumps
ANS 3.8-2c	Closure of 11 & 12 MSIVs
ANS 3.8-2d	Trip of All Reactor Coolant Pumps (RCPs)
ANS 3.8-2e	Trip of 12A RCP at 80% Power
ANS 3.8-2f	Main Turbine Trip at 12% Power
ANS 3.8-2g	Maximum Power Ramp 100% - 75% - 100% Power
ANS 3.8-2h	Large Break Loss-of-Coolant Accident with Loss of Offsite Power
ANS 3.8-2i	Main Steam Line Rupture
ANS 3.8-2j	Slow Reactor Coolant System Depressurization with Engineered Safety Feature Actuation System failed

ATTACHMENT (2)

CALVERT CLIFFS UNIT ONE -- REFERENCE PLANT SIMULATOR DUAL UNIT SIMULATOR

YEAR ONE TEST PLAN

I. PROCEDURES

Cold Shutdown to Hot Standby
Operation in Hot Standby

II. MALFUNCTIONS

- 002 Wide Range Nuclear Instrumentation Channel High Voltage Power Supply Failure
- 012 Power Range Subchannel Linear Amplifier Fails High
- 016 Reactor Protective System (RPS) Channel B Bistable Trip Relay Contact Fails to Open on Trip
- 019 Failure of Manual Reactor Trip
- 027 Uncoupled Control Element Assembly (CEA)
- 033 Individual CEA Reed Switch Position Indication Fails
- 035 Reactor Trip
- 036 Loss of Control Element Drive Mechanism Motor Generator Set
- 048 Failure of RCP First Stage Seal
- 063 Pressurizer Pressure Safety Channel Failure
- 073 Loss of Normal Letdown Due to 1-CVC-516 Failing Closed
- 082 Failure of Boric Acid Pump
- 083 Volume Control Tank Level Transmitter Fails Hi/Lo
- 093 MSIV Stuck at 90% of Full Open
- 094 MSIV Fails Closed
- 103 Turbine Bypass Valve's Fail Open (Any Combination)
- 108 Failure of Turbine Bypass Valve Control Loop From 1PIC-4056
- 109 Turbine Bypass Valve Controller Fails in Automatic Mode
- 110 Failure of Steam Flow Transmitter Hi/Lo
- 112 Atmospheric Dump Valve Controller Fails while in Automatic Mode
- 137 Main Generator Trip
- 140 Main Generator Automatic Voltage Regulator Misoperation
- 141 Loss of Stator Liquid Cooling
- 147 Loss of Unit Two Vital Instrument Bus
- 157 Loss of Pressurizer Heater Motor Control Centers
- 160 Loss of 250 VDC Emergency DC Bus
- 161 Failure of Emergency Diesel Generator to Start
- 171 Feedwater Regulating Valve Fails Full Open or Closed in Automatic Control
- 186 Failure of Auxiliary Feedwater Actuation System to Actuate
- 191 High Pressure Safety Injection (HPSI) Valves Fail-as-is
- 195 Low Level in Safety Injection Tank
- 203 Failure of Recirculation Actuation Signal to Actuate on Automatic Demand
- 207 Failure of Containment Cooling Fans
- 214 Service Water Leak in the Auxiliary Building
- 218 Area Radiation Monitor Failure

ATTACHMENT (2)

CALVERT CLIFFS UNIT ONE -- REFERENCE PLANT SIMULATOR
DUAL UNIT SIMULATOR

223	Loss of Component Cooling Pump
224	Loss of Service Water Pump
225	Loss of Salt Water Pump
234	Loss of Motor Driven Auxiliary Feed Pump
239	Core Exit Thermocouple Detector Failure
240	Failure of MSIV to Close on SGIS
246	Failure of SDS Bus 11 to Unblock
252	Failure of No. 12 Steam Generator Protection Level Transmitters

ATTACHMENT (2)

CALVERT CLIFFS UNIT ONE -- REFERENCE PLANT SIMULATOR DUAL UNIT SIMULATOR

YEAR TWO TEST PLAN

I. PROCEDURES

Hot Standby to 10% Power
Turbine Startup and Generator Synchronization
10% to 100% Power

II. MALFUNCTIONS

003 Wide Range Nuclear Instrumentation Channel Pre-amp Output Fails Low
008 Power Range Safety or Control Channel Detector Output Fails Low
011 Power Range Safety or Control Channel Output From Power Summer Fails Low
017 Failure of RPS Logic Matrix Relay AB-1
020 RPS Logic Matrix Power Supply Failure
028 CEAs Fail to Move on Demand (Manual)
029 Control Pulses Sent But CEA Doesn't Move. CEA is Trippable
030 Stuck CEA. Will Not Trip
037 Inadvertent Opening of Individual Reactor Trip Breakers
049 Failure of RCP Second Stage Seal
050 Failure of RCP Third Stage Seal
070 Loss of Flow From Charging Pump
077 Volume Control Tank Level Transmitter LT-227 Fails Hi/Lo
091 Steam Generator Tube Leakage
096 Steam Generator Level Transmitter For Protection Channels Fails Hi/Lo
102 Inadvertent Slow Closure of MSIV
105 Steam Line Rupture Outside Containment
107 Feed Flow Element F1111A/1121A Failure
115 Failure of Automatic Turbine Trips. Manual Trip Will Function
131 Variable High Vibration on Main Turbine
135 Moisture Separator Relief Valve Fails Open
152 Failure of Steam Generator Blowdown to Isolate on RMS Alarm
153 Loss of 4 KV Bus
154 Loss of 480 V Bus
155 Loss of 480 V Reactor Motor Control Center
163 Loss of Condenser Vacuum
164 Hotwell Level Control Problems
166 Loss of Condensate Pump
167 Loss of Condensate Booster Pump
170 Steam Generator Feed Pump Trip
174 Feedwater Regulating Valve Differential Pressure Transmitter Fails Hi/Low
180 Loss of Heater Drain Pump
183 Loss of Auxiliary Feedwater Pump
189 Failure of LPSI Pump
190 Failure of Containment Spray Pump

ATTACHMENT (2)

CALVERT CLIFFS UNIT ONE -- REFERENCE PLANT SIMULATOR DUAL UNIT SIMULATOR

215	Service Water Leak in the Turbine Building
241	Failure of Automatic CIS Actuation
244	Spurious SGIS Actuation
247	Failure of SDS Bus 14 to Unblock

ATTACHMENT (2)

CALVERT CLIFFS UNIT ONE -- REFERENCE PLANT SIMULATOR DUAL UNIT SIMULATOR

YEAR THREE TEST PLAN

I. PROCEDURES

100% Power to Cold Shutdown

II. MALFUNCTIONS

- 005 Wide Range Nuclear Instrumentation Failure
- 010 Power Range Safety or Control Channel Output From Power Summer Fails High
- 018 Failure of Automatic Reactor Trip
- 021 Failure of CEA Withdrawal Interlocks to Block Outward CEA Motion
- 023 Uncontrolled Withdrawal of Individual CEA or Group of CEAs
- 025 Uncontrolled Withdrawal of a Single CEA
- 026 Uncontrolled Insertion of a Single CEA
- 032 Dropped CEA
- 038 Loop 12B Double-ended Rupture of RCS Cold Leg
- 042 Failure of Reactor Vessel Level Detector
- 043 RCP Trip
- 047 Failure of RCP Lift Pump to Reach Operating Pressure When Running
- 052 Switchyard Breaker Fails to Trip
- 054 Pressurizer Spray Valve 100E Fails Open
- 062 Pressurizer Pressure Control Fails Hi/Lo
- 064 Low Range Pressurizer Pressure Transmitters Fail Hi/Lo
- 065 Pressurizer Level Control Fails Hi/Lo
- 074 Tube Rupture in Non-Regenerative Heat Exchanger
- 075 Loss of Component Cooling to the Non-Regenerative Heat Exchanger
- 078 Failure of the Boronometer
- 079 Inadvertent Boration
- 098 Steam Generator Pressure Transmitters Fail Hi/Lo
- 104 Steam Line Rupture Inside Containment
- 106 Steam Flow Input to Digital Feedwater Control System Failure
- 113 Main Steam Safety Valve's Fail Open
- 114 Turbine Trip
- 116 Turbine Control Valve Fails Open
- 150 Loss of 13 KV Service Transformer
- 151 Loss of 13 KV Bus
- 156 Loss of a Turbine Motor Control Center
- 162 Loss of 125 Vital DC Bus
- 165 Gross Condenser Tube Leakage
- 172 Feedwater Regulating Valve Mechanical Failure
- 177 Feed Line Rupture Outside of the Containment
- 185 Auxiliary Feedwater Pipe Rupture
- 188 Failure of HPSI Pump
- 204 Failure of the Diverse Scram System (DDS) to open
- 217 Salt Water System Leak

ATTACHMENT (2)

CALVERT CLIFFS UNIT ONE -- REFERENCE PLANT SIMULATOR
DUAL UNIT SIMULATOR

- 219 High Radiation Alarms on Process Radiation Monitors
- 221 Intake Structure Traveling Screens Obstructed
- 226 Loss of Service Water to Turbine Building
- 242 Failure of Manual CIS Actuation
- 248 Failure of LOCIS Bus 11 to Unblock
- 250 Steam Generator Wide Range Level Transmitters Fail

ATTACHMENT (2)

CALVERT CLIFFS UNIT ONE -- REFERENCE PLANT SIMULATOR DUAL UNIT SIMULATOR

YEAR FOUR TEST PLAN

I. PROCEDURES

100% Power Reactor Trip and Recovery to 100% Power

II. MALFUNCTIONS

- 004 Wide Range Nuclear Instrumentation Channel Startup Rate Degradation
- 024 Uncontrolled Insertion of Individual CEA or Group of CEAs
- 031 Stuck CEA. Will Trip
- 034 Rupture of Control Element Drive Mechanism Housing (CEA #1)
- 039 RCS Leak into Containment
- 045 Locked Rotor on RCP 11B
- 060 PORV Minor Leakage
- 061 Pressurizer Safety Valve Leakage
- 066 Major Leakage of PORVs (Previously Malfunction 59)
- 068 Leak in Letdown Line Inside Containment (Between Check Valve & 1-TE-221)
- 069 Leak in Letdown Line in Penetration Room
- 086 Leakage Through Letdown Line Relief Valves
- 087 Charging Pump Primary Packing Leak
- 092 Steam Generator Gross Tube Failure
- 097 Digital Feedwater Control System Central Processing Unit Failure
- 100 Steam Generator Differential Pressure Transmitter Fails Hi/Lo
- 138 Load Rejection
- 149 Loss of Off-site Power
- 158 Loss of Non-Vital 120/208 VAC Instrument Bus
- 159 Loss of 120 VAC Vital Instrument Bus
- 173 Erratic Operation of Feedwater Regulating Valve
- 175 Feedwater Line Rupture Inside the Containment; Before Check Valve
- 176 Feedwater Line Rupture Inside the Containment; After Check Valve
- 181 Feedwater Flow Transmitter Input to Control Channel Fails
- 187 LPSI Pump Suction Break
- 196 Failure of Safety Injection Actuation Signal (SIAS) to Actuate on Automatic Demand
- 197 Failure of SIAS Manual Initiation
- 199 Failure of Containment Spray Actuation Signal (CSAS) to Actuate on Automatic Demand
- 200 Failure of CSAS Manual Initiation
- 205 Spurious CIS
- 213 Failed Fuel Equivalent to 1 Fuel Pin
- 216 Accidental Release of Gaseous Waste
- 227 Loss of Instrument Air
- 228 Loss of Instrument Air in Containment
- 231 Component Cooling Water Leak in Containment
- 233 Loss of Component Cooling Water to Containment
- 238 Core Exit Thermocouple Meter Failure
- 243 Failure of Automatic SGIS Actuation

ATTACHMENT (2)

CALVERT CLIFFS UNIT ONE -- REFERENCE PLANT SIMULATOR
DUAL UNIT SIMULATOR

- | | |
|-----|---|
| 245 | Containment Radiation Monitor Failure |
| 249 | Failure of LOCIS Bus 14 to Unblock |
| 251 | Failure of No. 12 Steam Generator Pressure Transmitters |
| 253 | Blockage of Salt Water Components |

RICHARD L. BEST

Instructor

EDUCATION

US Navy Nuclear Power School

**LICENSE AND
CERTIFICATIONS**

NRC Reactor Operator License, Salem 1 and 2
Senior Reactor Operators Certification, Salem 1 and 2

**WORK EXPERIENCE
1993-PRESENT**

NPS Technical Services

Mr. Best is assigned to the Procedures Upgrade Project, revising Abnormal Operating Procedures by verifying them against the latest revisions of plant drawings and reference materials.

1992-1993

General Physics Corporation

Mr. Best was assigned to the Operations Training Unit at Calvert Cliffs, working for the Simulator Support Group. He conducted ANSI 3.5 testing to maintain simulator certification, verified Simulator Modification Requests and tested software modifications prior to inclusion into training loads.

1980 - 1992

Public Service Electric & Gas, Salem 1 and 2

As the Salem Simulator Configuration Engineer, Mr. Best's responsibilities included tracking of Design Changes for applicability on the simulator and design of the work package to implement and test the changes. During this period the Salem Simulator gained NRC Certification under his supervision. Mr. Best maintained his SRO and Instructor Certification by teaching a minimum of five sessions per quarter.

As the Lead Simulator Instructor, Mr. Best was responsible for the development of the initial training materials used on the simulator for New Licensed and Requalification Training. During this period he assisted in the development of Salem Emergency Operating Procedures and their subsequent verification and validation in accordance with Westinghouse Emergency Response Guidelines. He also developed the operations portions of the plant Emergency Response drills.



DOUGLAS R. TILTON

EDUCATION B.S., Nuclear Engineering Technology, Thomas Edison State College

LICENSES AND CERTIFICATIONS Licensed Senior Reactor Operator, Seabrook Station
Licensed Reactor Operator, Salem Nuclear Generating Station
Certified Classroom and Simulator Instructor, Calvert Cliffs

EXPERIENCE
5/89 - Present

General Physics Corporation

Mr. Tilton was assigned to the Calvert Cliffs Nuclear Power Plant supporting the Initial Operator Training Unit. He conducts classroom and simulator training in all areas including theory, plant systems, integrated operations and transients. He also served as the simulator operator during numerous NRC License examinations.

As a member of the License Operator Requalification Training Unit, he conducted both classroom and simulator training. He served as a utility representative for three NRC Requal Exams and was also responsible for validation of NRC requalification exam and Emergency Plan simulator scenarios. He is also responsible for writing and reviewing simulator issue reports and malfunction testing.

6/85 - 5/89

New Hampshire Yankee, Seabrook Station

As a Senior Simulator Instructor, Mr. Tilton provided simulator training for licensed and non-licensed operators. He was also responsible for modification and malfunction testing of the simulator. After a core model upgrade he validated the new model and tested core response prior to releasing the model for training. Mr. Tilton developed the simulator instructor station operating procedures. He acted as Technical Assistant to the Emergency Operations Manager during Emergency Plan activation.

10/81 - 6/85

Public Service Electric and Gas Company, Salem Nuclear Generating Station

As a Nuclear Control Operator, Mr. Tilton was licensed on both Units. He was responsible for 10 equipment and utility operators. He participated in normal plant operations, surveillance testing and several refueling outages. Mr. Tilton was part of a team that validated the response of the Salem simulator after initial delivery.

RICHARD L. BEST

Instructor

EDUCATION

US Navy Nuclear Power School

**LICENSE AND
CERTIFICATIONS**

NRC Reactor Operator License, Salem 1 and 2
Senior Reactor Operators Certification, Salem 1 and 2

**WORK EXPERIENCE
1993-PRESENT**

NPS Technical Services

Mr. Best is assigned to the Procedures Upgrade Project, revising Abnormal Operating Procedures by verifying them against the latest revisions of plant drawings and reference materials.

1992-1993

General Physics Corporation

Mr. Best was assigned to the Operations Training Unit at Calvert Cliffs, working for the Simulator Support Group. He conducted ANSI 3.5 testing to maintain simulator certification, verified Simulator Modification Requests and tested software modifications prior to inclusion into training loads.

1980 - 1992

Public Service Electric & Gas, Salem 1 and 2

As the Salem Simulator Configuration Engineer, Mr. Best's responsibilities included tracking of Design Changes for applicability on the simulator and design of the work package to implement and test the changes. During this period the Salem Simulator gained NRC Certification under his supervision. Mr. Best maintained his SRO and Instructor Certification by teaching a minimum of five sessions per quarter.

As the Lead Simulator Instructor, Mr. Best was responsible for the development of the initial training materials used on the simulator for New Licensed and Requalification Training. During this period he assisted in the development of Salem Emergency Operating Procedures and their subsequent verification and validation in accordance with Westinghouse Emergency Response Guidelines. He also developed the operations portions of the plant Emergency Response drills.

RICHARD L. BEST

As Training Supervisor, Mr. Best acted as the Plant/Trainer liaison to the vendor during the last nine months of the simulator construction at the factory. In this capacity he oversaw the merge of the simulation models and Integrated Operations testing, and conducted the on site Acceptance Test once the simulator was delivered to the training center.

As Training Specialist, Mr. Best developed the Theory and Instrument & Controls portion of the New Licensed Operator training program. He taught both Licensed and Non-Licensed operator courses. He also received his NRC Reactor Operator License during this period.

1973-1980

U.S. Navy

While stationed at the Nuclear Power Training Unit, Windsor, Ct., Mr. Best held the position of Crew Training Coordinator and was a member of the Staff Training Group. He qualified as Reactor Operator, Engineering Watch Supervisor, and Engineering Officer of the Watch.

Mr. Best was stationed on board the USS George Bancroft, and qualified as Reactor Operator and Engineering Watch Supervisor.



DOUGLAS R. TILTON

EDUCATION B.S., Nuclear Engineering Technology, Thomas Edison State College

LICENSES AND CERTIFICATIONS Licensed Senior Reactor Operator, Seabrook Station
Licensed Reactor Operator, Salem Nuclear Generating Station
Certified Classroom and Simulator Instructor, Calvert Cliffs

EXPERIENCE
5/89 - Present

General Physics Corporation

Mr. Tilton was assigned to the Calvert Cliffs Nuclear Power Plant supporting the Initial Operator Training Unit. He conducts classroom and simulator training in all areas including theory, plant systems, integrated operations and transients. He also served as the simulator operator during numerous NRC License examinations.

As a member of the License Operator Requalification Training Unit, he conducted both classroom and simulator training. He served as a utility representative for three NRC Requal Exams and was also responsible for validation of NRC requalification exam and Emergency Plan simulator scenarios. He is also responsible for writing and reviewing simulator issue reports and malfunction testing.

6/85 - 5/89

New Hampshire Yankee, Seabrook Station

As a Senior Simulator Instructor, Mr. Tilton provided simulator training for licensed and non-licensed operators. He was also responsible for modification and malfunction testing of the simulator. After a core model upgrade he validated the new model and tested core response prior to releasing the model for training. Mr. Tilton developed the simulator instructor station operating procedures. He acted as Technical Assistant to the Emergency Operations Manager during Emergency Plan activation.

10/81 - 6/85

Public Service Electric and Gas Company, Salem Nuclear Generating Station

As a Nuclear Control Operator, Mr. Tilton was licensed on both Units. He was responsible for 10 equipment and utility operators. He participated in normal plant operations, surveillance testing and several refueling outages. Mr. Tilton was part of a team that validated the response of the Salem simulator after initial delivery.