

WOLF CREEK

NUCLEAR OPERATING CORPORATION

Otto L. Maynard
Vice President Plant Operations

January 13, 1995

WO 95-0009


U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Mail Station P1-137
Washington, D. C. 20555

Subject: Docket No. 50-482: December, 1994, Monthly
Operating Report

Gentlemen:

Attached is the December, 1994, Monthly Operating Report for Wolf Creek Generating Station. This submittal is being made in accordance with the requirements of Technical Specification 6.9.1.8.

Very truly yours,



Otto L. Maynard

OLM/jad

Attachment

cc: L. J. Callan (NRC), w/a
D. D. Chamberlain (NRC), w/a
D. N. Graves (NRC), w/a
J. F. Ringwald (NRC), w/a
J. C. Stone (NRC), w/a

190084

9501200190 941231
PDR ADDCK 05000482
R PDR

P.O. Box 411 / Burlington, KS 66839 / Phone: (316) 364-8831

An Equal Opportunity Employer M/F/HC/VET

JE24,1

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

MONTHLY OPERATING REPORT

MONTH: DECEMBER YEAR: 1994

Docket No.: 50-482

Facility Operating License No.: NPF-42

Report No. 118

SUMMARY

The following report highlights the operating experience of Wolf Creek Generating Station for the month of December, 1994. This report is being provided pursuant to Technical Specification 6.9.1.8.

I. SUMMARY OF OPERATING EXPERIENCE

The unit operated at or near 100% for the month of December, 1994.

MAJOR SAFETY RELATED MAINTENANCE ACTIVITIES

NONE

OPERATING DATA REPORT
DOCKET NO. 50-482
WOLF CREEK GENERATING STATION
WOLF CREEK NUCLEAR OPERATING CORPORATION
DATE 1-05-95
TELEPHONE 316-364-8831

OPERATING STATUS

1. Reporting Period: December, 1994 Gross Hours in Reporting Period: 744
 2. Currently Authorized Power Level (MWt): 3565 Max. Depend. Capacity (MWe-Net): 1160
Design Electrical Rating (MWe-Net): 1170
 3. Power Level to Which Restricted (If Any) (MWe-Net): N/A
 4. Reasons for Restriction (If Any): N/A
- | | This Month | Yr. to Date | Cumulative |
|---------------------------------------------|------------------|-------------------|--------------------|
| 5. Number of Hours Reactor was Critical | <u>744.0</u> | <u>7,605.7</u> | <u>65,968.1</u> |
| 6. Reactor Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>339.8</u> |
| 7. Hours Generator on Line | <u>744.0</u> | <u>7,501.2</u> | <u>65,154.6</u> |
| 8. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>0.0</u> |
| 9. Gross Thermal Energy Generated (MWh) | <u>2,636,320</u> | <u>25,767,938</u> | <u>215,032,349</u> |
| 10. Gross Electrical Energy Generated (MWh) | <u>915,452</u> | <u>8,910,666</u> | <u>74,764,215</u> |
| 11. Net Electrical Energy Generated (MWh) | <u>879,799</u> | <u>8,529,002</u> | <u>71,374,674</u> |
| 12. Reactor Service Factor | <u>100.0%</u> | <u>86.8%</u> | <u>80.7%</u> |
| 13. Reactor Availability Factor | <u>100.0%</u> | <u>86.8%</u> | <u>81.1%</u> |
| 14. Unit Service Factor | <u>100.0%</u> | <u>85.6%</u> | <u>79.7%</u> |
| 15. Unit Availability Factor | <u>100.0%</u> | <u>85.6%</u> | <u>79.7%</u> |
| 16. Unit Capacity Factor (Using MDC) | <u>101.9</u> | <u>84.7%</u> | <u>77.0%</u> |
| 17. Unit Capacity Factor (Using Design MWe) | <u>101.1</u> | <u>83.2%</u> | <u>74.6%</u> |
| 18. Unit Forced Outage Rate | <u>0.0%</u> | <u>0.8%</u> | <u>5.1%</u> |
19. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of each):
No outages are scheduled at this time.
 20. If Shut Down at End of Report Period, Estimate Date of Startup: N/A

AVERAGE DAILY UNIT POWER LEVEL
 DOCKET NO. 50-482
 WOLF CREEK GENERATING STATION
 WOLF CREEK NUCLEAR OPERATING CORPORATION
 DATE 1-05-95
 TELEPHONE 316-364-8831

MONTH December, 1994

DAY AVERAGE DAILY POWER LEVEL
 (MWe-Net)

1	1183
2	1168
3	1180
4	1188
5	1186
6	1168
7	1177
8	1185
9	1182
10	1186
11	1186
12	1186
13	1185
14	1185
15	1184
16	1179

DAY AVERAGE DAILY POWER LEVEL
 (MWe-Net)

17	1186
18	1186
19	1185
20	1185
21	1185
22	1170
23	1182
24	1186
25	1186
26	1186
27	1186
28	1186
29	1186
30	1174
31	1185

UNIT SHUTDOWN AND POWER REDUCTIONS

DOCKET NO. 50-482

WOLF CREEK GENERATING STATION

WOLF CREEK NUCLEAR OPERATING CORPORATION

DATE 1-05-95TELEPHONE 316-364-8831

No	Date	Type	DURATION (Hours)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUCING POWER (2)	CORRECTIVE ACTIONS/COMMENTS
		F: FORCED S: SCHEDULED				
		None				

SUMMARY:

The unit operated at or near 100% for the month of December, 1994.

- 1) REASON: A: EQUIPMENT FAILURE (EXPLAIN) E: OPERATOR TRAINING AND LICENSE EXAMINATION (2) METHOD: 1. MANUAL
 B: MAINTENANCE OR TEST F: ADMINISTRATIVE 2. MANUAL SCRAM
 C: REFUELING G: OPERATIONAL ERROR (EXPLAIN) 3. AUTOMATIC SCRAM
 D: REGULATORY RESTRICTION H: OTHER (EXPLAIN) 4. CONTINUED
 5. REDUCED LOAD
 9. OTHER

WOLF CREEK NUCLEAR OPERATING CORPORATION

WOLF CREEK GENERATING STATION

UNIT NO. 1

MONTH December, 1994

SUMMARY OF OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reduction or resulted in significant non-load related incidents.

<u>DATE</u>	<u>TIME</u>	<u>EVENT</u>
None	None	None