



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

IN RESPONSE, PLEASE
REFER TO: M830916A

September 16, 1983

OFFICE OF THE
SECRETARY

MEMORANDUM FOR: William J. Dircks, Executive Director
for Operations

FROM: Samuel J. Chilk, Secretary *[Signature]*

SUBJECT: STAFF REQUIREMENTS - DISCUSSION/POSSIBLE
VOTE ON FULL POWER OPERATING LICENSE FOR
SAN ONOFRE-3, 10:00 A.M., FRIDAY,
SEPTEMBER 16, 1983, COMMISSIONERS'
CONFERENCE ROOM, D.C. OFFICE (OPEN
PORTION)

The Commission met to be briefed by staff on the readiness of San Onofre Unit 3 to exceed 5 percent power. The Commission also heard from David Fogarty, Executive Vice President and Ken Baskin, Vice President, Southern California Edison Company. (A portion of this meeting was held in closed session.)

The Commission:

1. by a vote of 5-0 agreed to accept the backup EOF as proposed by Southern California Edison;
2. by a vote of 5-0 authorized staff to allow Unit 3 to exceed 5 percent when staff felt it appropriate;
(NRR)
3. by a vote of 5-0 specified a license condition requiring Southern California Edison to report to the NRC all component failures relating to the auxiliary feedwater system reliability. The scope of reporting would also include maintenance and operator errors which are significant to evaluating auxiliary feedwater reliability. The staff will evaluate the data submitted and report back to the Commission in one year.
(NRR) (SECY Suspense: 10/1/84)

The staff voted that a report on the need for PORVs in CE reactors is due the Commission December 15, 1983.
(NRR)

cc: Chairman Palladino
Commissioner Gilinsky
Commissioner Roberts
Commissioner Asselstine
Commissioner Bernthal
Commission Staff Offices
PDR - Advance
VCS - 016 Phillips

8309260416 830916
PDR 10CFR
PT9.7