

January 27, 1995

Mr. Harold B. Ray
Senior Vice President
Southern California Edison Co.
Irvine Operations Center
23 Parker Street
Irvine, California 92718

SUBJECT: REVISED CALCULATIONAL METHOD FOR DETERMINING CHANGES IN TRANSMITTER CALIBRATION FOR THE SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 (TAC NOS. M90451 AND M90452)

Dear Mr. Ray:

By letter dated July 11, 1994, the Southern California Edison Company (SCE) responded to the staff's February 15, 1994, letter evaluating the proposed calculational method for determining changes in transmitter calibration. The staff's February 15, 1994, evaluation was based on information provided in SCE letter dated September 28, 1992, on the same topic, and concluded that insufficient information had been provided to support the proposed methodology.

The staff has reviewed the additional information provided in the July 11, 1994, letter, and has concluded that the revised calculational method is acceptable for determining changes in transmitter calibration frequency for the transmitters listed in the July 11, 1994 submittal. Enclosed is our Safety Evaluation report on this issue.

Sincerely,

ORIGINAL SIGNED BY:

Mel B. Fields, Project Manager
Project Directorate IV-2
Division of Reactor Projects III\IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-361 and 50-362

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION:
Docket File, T-5C3 MFields
 PUBLIC OGC
 PDIV-2 Reading ACRS (4)
 JRoe KPerkins, RIV/WCFO
 TQuay OC/LFDCB
 DFoster-Curseen

DOCUMENT NAME: TRANSMIT.LTR

OFC	DRPW/LA <i>J-C</i>	PDIV-2/PM
NAME	DFoster-Curseen	MFields:ye
DATE	1/27/95	1/27/95

OFFICIAL RECORD COPY

NRC FILE CENTER COPY

9802 1305 98012
7PM LOCK CK 003e
PDR

DFOI

January 27, 1995

Mr. Harold B. Ray
Senior Vice President
Southern California Edison Co.
Irvine Operations Center
23 Parker Street
Irvine, California 92718

SUBJECT: REVISED CALCULATIONAL METHOD FOR DETERMINING CHANGES IN TRANSMITTER CALIBRATION FOR THE SAN ONOFRE NUCLEAR GENERATING STATION, UNITS 2 AND 3 (TAC NOS. M90451 AND M90452)

Dear Mr. Ray:

By letter dated July 11, 1994, the Southern California Edison Company (SCE) responded to the staff's February 15, 1994, letter evaluating the proposed calculational method for determining changes in transmitter calibration. The staff's February 15, 1994, evaluation was based on information provided in SCE letter dated September 28, 1992, on the same topic, and concluded that insufficient information had been provided to support the proposed methodology.

The staff has reviewed the additional information provided in the July 11, 1994, letter, and has concluded that the revised calculational method is acceptable for determining changes in transmitter calibration frequency for the transmitters listed in the July 11, 1994 submittal. Enclosed is our Safety Evaluation report on this issue.

Sincerely,

ORIGINAL SIGNED BY:

Mel B. Fields, Project Manager
Project Directorate IV-2
Division of Reactor Projects III\IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-361 and 50-362

Enclosure: Safety Evaluation

cc w/encl: See next page

DISTRIBUTION:

Docket File, T-5C3 MFields
PUBLIC OGC
PDIV-2 Reading ACRS (4)
JRoe KPerkins, RIV/WCFO
TQuay OC/LFDCB
DFoster-Curseen

DOCUMENT NAME: TRANSMIT.LTR

OFC	DRPW/LA <i>J-C</i>	PDIV-2/PM
NAME	DFoster-Curseen	MFields:ye
DATE	1/27/95	1/27/95

OFFICIAL RECORD COPY

Mr. Harold B. Ray
Southern California Edison Company

San Onofre Nuclear Generating Station
Unit Nos. 2 and 3

cc:

Mr. R. W. Krieger, Vice President
Southern California Edison Company
San Onofre Nuclear Generating Station
P. O. Box 128
San Clemente, California 92674-0128

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
Harris Tower & Pavilion
611 Ryan Plaza Drive, Suite 400
Arlington, Texas 76011-8064

Chairman, Board of Supervisors
County of San Diego
1600 Pacific Highway, Room 335
San Diego, California 92101

Mr. Richard Krumvieda
Manager, Nuclear Department
San Diego Gas & Electric Company
P. O. Box 1831
San Diego, California 92111

Alan R. Watts, Esq.
Rourke & Woodruff
701 S. Parker St. No. 7000
Orange, California 92668-4702

Mr. Steve Hsu
Radiologic Health Branch
State Department of Health Services
Post Office Box 942732
Sacramento, California 94234

Mr. Sherwin Harris
Resource Project Manager
Public Utilities Department
City of Riverside
3900 Main Street
Riverside, California 92522

Resident Inspector/San Onofre NPS
c/o U.S. Nuclear Regulatory Commission
Post Office Box 4329
San Clemente, California 92674

Dr. Harvey Collins, Chief
Division of Drinking Water and
and Environmental Management
California Department of Health Services
P. O. Box 942732
Sacramento, California 94234-7320

Mayor
City of San Clemente
100 Avenida Presidio
San Clemente, California 92672