



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
801 WARRENVILLE ROAD
LISLE, ILLINOIS 60532-4351

*Buckley
file*

JAN 28 1994

MEMORANDUM FOR: Mike Boyle, NRR/DRPE Tech Assistant
FROM: Edward G. Greenman, Director, Division of Reactor Projects,
Region III
SUBJECT: NOED UPDATE

In response to your request, we have enclosed the updated list of NOEDs you transmitted to us on January 11, 1994.

If you have any questions, please contact Bob Hasse (708) 829-9615.

Edward G. Greenman
Edward G. Greenman, Director
Division of Reactor Projects,

Enclosure: As Stated

cc w/enclosure:
R. W. DeFayette, RIII
J. A. Zwolinski, NRR

RT

9502020284 940517
PDR FDIA
RICC1094-167 PDR

2020284

B/20

NOTICES OF ENFORCEMENT DISCRETION ISSUED IN 1993

FOR REGION III PLANTS

PD	NOED #	PLANT(S)	TITLE	DATE NOED LTR ISSUED	STATUS	NOED GRANTED BY	NOED START DATE	NOED END DATE
32	93-3-006	BRAIDWOOD 1	INOPERABLE CHARGING PUMP	09/21/93	G	REGION	09/18	09/20
31	93-3-001	COOK 2	WEST CERT CHARGING PUMP OPERABILITY	07/13/93	G	REGION	07/09	07/12
33	93-6-013	DIANE ARNOLD	APP J EXEMPTION-CONTAINMENT AIRLOCK	04/30/93	G	NRR	04/20	/
31	93-3-002	FERMI 2	CHVAC DIV II SUPPLY FAN REPAIRS	07/13/93	G	REGION	07/09	07/10
31	93-3-004	FERMI 2	MODULAR POWER UNIT	09/00/93	G	REGION	09/07	09/08
33	93-3-007	KEWAUNEE	A RHU PUMP CASING LEAK	11/05/93	G	REGION	11/04	11/11
32	93-6-020	LASALLE 1	INOPERABLE SERV	12/13/93	G	NRR	12/04	/
31	93-6-003	PALISADES	CONTROL ROOM DRIVE TESTING	01/15/93	G	NRR	01/14	/
33	93-6-001	POINT BEACH 1/2	DEGRADED GRID VOLTAGE RELAY SET.	01/14/93	G	NRR	01/14	/
33	93-3-008	POINT BEACH 1/2	AUX ELECTRICAL SYSTEMS	02/23/93	G	REGION	02/22	02/25
33	93-3-008	POINT BEACH 1/2	EDG ALLOWED OUTAGE TIME	12/07/93	G	REGION	12/03	12/03
33	93-6-012	POINT BEACH 2	RPS & SAFEGUARDS CIRCUIT TESTING	04/15/93	G	NRR	04/09	05/13
32	93-6-007	ZION 1	ECCS PUMPS INOPERABLE	01/07/93	G	REGION	01/04	01/05
32	93-6-007	ZION 1	CONT RECIRC SUMP LEVEL INSTRUMENT	03/02/93	G	NRR	02/26	06/30
32	93-6-005	ZION 1/2	LOW TEMPERATURE OVERPRESSURE PROT	01/29/93	G	NRR	01/28	02/22

Missing NOED# 93-3-003 and 93-3-005

93-3-003, DUNESDALE, INOPERABLE CONTAINMENT COOLING, 8/19/93 = GRANTED REGION
 93-3-005, PRAIRIE ISLAND, INOPERABLE SAFEGUARDS BUS, 9/15/93, REGION

NOTICES OF ENFORCEMENT DISCRETION ISSUED IN 1993

FOR REGION I PLANTS

Region III Plant

PD	NOED #	PLANT(S)	TITLE	DATE NOED LTR ISSUED	STATUS	NOED GRANTED BY	NOED START DATE	NOED END DATE
13	93-6-020	BEAVER VALLEY 1	CONTAINMENT AIRLOCK LEAK TESTING	08/13/93	G	NRR	08/10	08/17
13	93-6-010	BEAVER VALLEY 2	REACTOR TRIP BREAKER TESTING	04/09/93	G	NRR	04/05	09/17
32	93-6-027	BRAIDWOOD 1	SG LEAKAGE LIMIT	11/24/93	G	NRR	11/05	/
11	93-1-003	INDIAN POINT 2	WC&PPS OPERABILITY REQUIREMENTS	09/15/93	G	REGION	09/10	09/11
11	93-1-001	INDIAN POINT 3	EDG OPERABILITY	06/03/93	G	REGION	06/05	06/09
14	93-6-002	MILLSTONE 1	MAIN STEAM LINE RAD MONITOR	01/15/93	G	NRR	01/14	02/26
14		MILLSTONE 2	STRUCTURAL INTEGRITY OF SW LINE	03/26/93	R	REGION	03/25	04/01
14	93-6-004	MILLSTONE 3	SNUBBER SURVEILLANCE REQUIREMENTS	01/25/93	G	NRR	01/22	09/30
14	93-6-074	MILLSTONE 3	SHM'L LEAK COLLECTION & RELEASE SYS	10/27/93	G	NRR	10/25	10/31
14	93-6-025	MILLSTONE 3	SUPPLEMENTARY LEAK COLLECTION ...	11/05/93	G	NRR	11/05	/
11	93-6-019	NINE MILE POINT 2	H2 ANALYZERS CONT. ISOL. VALVES	08/06/93	G	NRR	08/04	/
12		SALEM 1	RESETTING OF TORQUE SWITCH	03/18/93	N		/	/
12	93-1-002	SALEM 1	125 VOLT DC BATTERY	08/26/93	G	REGION	08/24	08/31
14	93-6-022	SEABROOK	FSFAS INST. SURV. REQUIREMENTS	08/30/93	G	NRR	08/25	/
12	93-6-021	SUSQUEHANNA 2	INOPERABLE CONTAINMENT PURGE VALVE	09/10/93	G	NRR	09/08	/
13	93-6-011	VERMONT YANKEE	SCRAM INSERTION TIME LIMITS	04/09/93	G	NRR	04/06	04/08

G = GRANTED
N = NOT NEEDED/WITHDRAWN