

Docket File



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 7, 1994

LICENSEE: Commonwealth Edison Company (ComEd)
FACILITIES: Byron Station, Units 1 and 2
Braidwood Station, Units 1 and 2
SUBJECT: SUMMARY OF SEPTEMBER 15, 1994 MEETING

On September 15, 1994, a public meeting was held between the NRC and ComEd (the licensee) to discuss the licensee's request for approval to use a positive moderator temperature coefficient (PMTC). A list of attendees is enclosed (Enclosure 1). Enclosure 2 is a copy of the licensee's handout.

In a submittal dated March 23, 1994, the licensee submitted a request for a license amendment for approval of several changes to the plants' technical specifications, including the use of a PMTC of +7 pcm. On July 26, 1994, the staff sent a request for additional information (RAI) which was answered by the licensee on August 16, 1994. Upon review of the response the licensee was informed that the NRC staff needed to understand of how application of a PMTC would affect the plants' response to an anticipated transient without scram (ATWS). The licensee requested a meeting to discuss how it might best address that issue.

At the meeting, the licensee was informed that approvals for PMTCs always include an evaluation of how they would affect the design basis accidents. It also considers the total effect of the PMTC on plant performance. However, because of the trend to higher PMTCs by the industry, it has become apparent that the aspects of the plant specific response to an ATWS should be addressed. The licensee and Westinghouse representatives, using a Westinghouse risk analysis, discussed how they believe that the plants would still meet the ATWS rule with a PMTC. The risk analyses is contained in WCAP 11992, "Joint Westinghouse Owners Group/Westinghouse Program: ATWS Rule Administration Process" and WCAP 11993, "Joint Westinghouse Owners Group/Westinghouse Program: Assessment of Compliance with ATWS Rule Bases for Westinghouse PWRs". While the staff was aware of the methodology, the reports had not been submitted for review.

The staff noted the licensee could use a deterministic analysis with a primary pressure of 3200 psig as the determining criterion to show that, with a given PMTC, the basis for the ATWS rule was maintained. This was believed to be a straightforward analysis that could be reviewed by the staff in a reasonable amount of time. An alternative would be to submit a risk methodology and analysis (e.g., the Westinghouse method) for detailed review, along with a discussion on how equipment availability consistent with the risk assessment would be ensured. A review of this approach would take considerably longer.

140000

9411160142 941107
PDR ADOCK 05000454
P PDR

NRC FILE CENTER COPY

DFI

The licensee indicated that it would consider its alternatives and inform the staff at a later date of what approach it would take.

Original signed by
George F. Dick, Jr., Project Manager
Project Directorate III-2
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket Nos. STN 50-454, STN 50-455,
STN 50-456, STN 50-457

Enclosures: 1. List of Meeting Attendees
2. Licensee's Handout

cc w/encls.: See next page

DISTRIBUTION (w/encl. 1 & 2)

Docket File
PUBLIC
PDIII-2 r/f
GDick
RAsa
LMiller, RIII

DISTRIBUTION (w/encl. 1 only)

WRussell/FMiraglia
RZimmerman
JRoe
RCapra
CMoore
OGC
EJordan, AEOD
RJones
LPhillips
HRichings
AEI-Bassioni
RLaufer
ACRS(4)
BMcCabe, EDO

DOCUMENT NAME: G:\CMRCJR\BYRON\0915MTG.SUM

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	LA:PDIII-2	PM:PDIII-2	E	SRXB	E	D:PDIII-2	E		
NAME	CMoore <i>and for</i>	GDick:rc <i>and</i>		RJones <i>and</i>		RCapra <i>and</i>			
DATE	11/1/94	11/01/94		11/2/94		11/7/94		11/ /94	

OFFICIAL RECORD COPY

Commonwealth Edison Company

cc:

Mr. William P. Poirier
Westinghouse Electric Corporation
Energy Systems Business Unit
Post Office Box 355, Bay 236 West
Pittsburgh, Pennsylvania 15230

Joseph Gallo
Gallo & Ross
1250 Eye St., N.W., Suite 302
Washington, DC 20005

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, Illinois 6013

Ms. Bridget Little Rorem
Appleseed Coordinator
117 North Linden Street
Essex, Illinois 60935

U.S. Nuclear Regulatory Commission
Braidwood Resident Inspectors Office
Rural Route #1, Box 79
Braceville, Illinois 60407

Mr. Ron Stephens
Illinois Emergency Services
and Disaster Agency
110 East Adams Street
Springfield, Illinois 62706

Howard A. Learner
Environmental Law and Policy
Center of the Midwest
203 North LaSalle Street
Suite 1390
Chicago, Illinois 60601

EIS Review Coordinator
U.S. Environmental Protection Agency
77 W. Jackson Blvd.
Chicago, Illinois 60604-3590

Chairman
Will County Board of Supervisors
Will County Board Courthouse
Joliet, Illinois 60434

Byron/Braidwood Power Stations

U.S. Nuclear Regulatory Commission
Byron/Resident Inspectors Office
4448 North German Church Road
Byron, Illinois 61010-9750

Ms. Lorraine Creek
Rt. 1, Box 182
Manteno, Illinois 60950

Mrs. Phillip B. Johnson
1907 Stratford Lane
Rockford, Illinois 61107

Attorney General
500 South 2nd Street
Springfield, Illinois 62701

Michael Miller, Esquire
Sidley and Austin
One First National Plaza
Chicago, Illinois 60690

George L. Edgar
Newman & Holtzinger, P.C.
1615 L Street, N.W.
Washington, DC 20036

Commonwealth Edison Company
Byron Station Manager
4450 North German Church Road
Byron, Illinois 61010

Illinois Dept. of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Commonwealth Edison Company
Braidwood Station Manager
Rt. 1, Box 84
Braceville, Illinois 60407

Chairman, Ogle County Board
Post Office Box 357
Oregon, Illinois 61061

Mr. D. L. Farrar
Manager, Nuclear Regulatory Services
Commonwealth Edison Company
Executive Towers West, Suite 500
1400 OPUS Place
Downers Grove, Illinois 60515

LIST OF MEETING ATTENDEES
September 15, 1994

NRC

Robert Jones
Robert Capra
Larry Phillips
Howard Richings
Adel El-Bassioni
Ramin Assa
Rich Laufer
George Dick

ComEd

Kenneth Graesser
Irene Johnson
Joseph Bauer
Penny Reister
Xavier Polanski
Denise Saccomando
Laurel Zech
Harry Pontious

Westinghouse

Baard Johansen
Gary Ament

STS, Inc.

Lynn Connor

Brief History

- ATWS Rule (10CFR50.62) issued in 1984 based on SECY-83-293
- Required AMSAC installation in Westinghouse PWRs
- NRC later expressed concern about increasing trend in MTC across industry

Brief History (Cont'd)

- WOG program to develop plant-specific methodology to assess reactivity feedback effects on ATWS completed in 1988 with issue of WCAP-11992 and WCAP-11993
- ComEd has been using WCAP method since 1992 (Zion 1 Cycle 13)

Unfavorable Exposure Time (UET)

The time during cycle life that the combination of reactivity feedback and RCS pressure relieving conditions will not be sufficient to prevent peak RCS pressure exceeding the stress criterion (3200 PSIG)

Risk Calculation Procedure

- UET calculation using critical trajectory methodology and cycle-specific core design
- UETs adjusted to account for frequency of transients throughout cycle
- Calculate PR nodes based on adjusted UETs and PORV/SRV reliability

Projected ATWS Risk Values

<u>Unit/Cycle</u>	<u>MTC</u>	CDF with WCAP-11993 <u>Inputs</u>	CDF with Byron IPE <u>inputs</u>
Bradwood 2 Cycle 5	<0.0	7.0E-07	6.8E-08
Byron 1 Cycle 7	<0.0	7.1E-07	6.8E-08
Byron 2 Cycle 6	+1.5	7.7E-07	6.9E-08

Conclusions

- WCAP methodology demonstrates acceptable ATWS risk on a plant and cycle specific basis
- Generic values from WCAP provide a conservative evaluation of ATWS risk when compared to Byron specific IPE values