

UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of )  
 )  
NIAGARA MOHAWK POWER CORPORATION ) Docket No. 50-220  
 )  
Nine Mile Point Nuclear Station Unit 1 )

APPLICATION FOR AMENDMENT

TO

OPERATING LICENSE

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation, holder of Facility Operating License No. DPR-63, hereby requests that Specification 3.4.1, "Leakage Rate" to that License be amended. The proposed changes have been reviewed in accordance with Technical Specification Section 6.5, "Review and Audit."

The proposed Technical Specification changes contained herein represent revision to Specification 3.4.1, "Leakage Rate" and the associated Bases. Specifically, the revision reflects reduction in the allowable Reactor Building leakage rate from 2000 cfm to 1600 cfm. This change is being proposed to reflect the design basis of the Reactor Building and Reactor Building Emergency Ventilation System (RBEVS). This change does not result in any change to the radiological consequences of either the design basis loss of coolant accident or refueling accident.

The proposed changes will not authorize any change in the types of effluents or in the authorized power level of the facility. Supporting information and analysis which demonstrate that the proposed changes involve no significant hazards consideration pursuant to 10CFR50.92 are included as Attachment B.

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-63 be amended in the forms attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By B. Ralph Sylvia  
B. Ralph Sylvia  
Exec. Vice President - Nuclear

Subscribed and sworn to before me  
on this 24 day of Jan 1995.

Beverly W. Ripka  
NOTARY PUBLIC

9502060119 950124  
PDR ADOCK 05000220  
P PDR

BEVERLY W. RIPKA  
Notary Public State of New York  
Qual. in Oswego Co. No. 4644879  
My Commission Exp. Mar 31/96  
2/28/96