LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	?	(2)	0	0	-	0	0	0	0	0	-	0	0	(3)	4	1	1	1	1	(4)		(5)

LICENSEE CODE (14) LICENSE NUMBER (25) LICENSE TYPE (30) CAT (58)

CON'T

0	1	REPORT SOURCE	L	(6)	0	5	0	0	0	3	1	6	(7)	0	9	2	0	8	3	(8)	1	0	0	5	8	3	(9)

DOCKET NUMBER (68) EVENT DATE (74) REPORT DATE (80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0	2	DURING A SURVEILLANCE TEST ON THE SOLID STATE PROTECTION SYSTEM (TRAIN A), TWO LOGIC
0	3	POSITIONS TESTED UNSATISFACTORILY. THIS AFFECTED THE REACTOR COOLANT PUMP UNDERVOLTAGE
0	4	POSITION OF THE AUTOMATIC LOGIC, TECHNICAL SPECIFICATION TABLE 3.3-1 ITEM 22. AFTER
0	5	THE ONE HOUR TIME LIMIT, (ACTION ITEM #1), PREPARATIONS TO BE IN HOT STANDBY WITHIN
0	6	SIX HOURS WERE INITIATED. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. PREVIOUS
0	7	OCCURRENCES INCLUDE: 050-315/83-081, 81-043, 78-067 AND 50-316/83-033, 038, 047,
0	8	82-056, 78-076.

0	9	SYSTEM CODE	I B (11)	CAUSE CODE	E (12)	CAUSE SUBCODE	G (13)	COMPONENT CODE	I N S T R U (14)	COMP SUBCODE	X (15)	VALVE SUBCODE	Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 8 3 — SEQUENTIAL REPORT NO. 0 9 0 — OCCURRENCE CODE 0 3 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
A (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	Y (24)	N (25)	W 1 2 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	UNIVERSAL CARD A-311 (WESTINGHOUSE, PART NO. 6056D21G01) WAS FOUND TO BE DEFECTIVE.
1	1	THE LOGIC CARD WAS REPLACED. THE SURVEILLANCE TEST WAS PERFORMED ON TRAIN "A" TO
1	2	VERIFY SYSTEM OPERABILITY. NO FURTHER ACTION IS PLANNED.
1	3	
1	4	

1	5	FACILITY STATUS	E (28)	% POWER	1 0 0 (29)	OTHER STATUS (30)	NA	METHOD OF DISCOVERY	B (31)	DISCOVERY DESCRIPTION (32)	SURVEILLANCE TEST

1	6	ACTIVITY RELEASED	Z (33)	CONTENT OF RELEASE	Z (34)	AMOUNT OF ACTIVITY (35)	NA	LOCATION OF RELEASE (36)	NA

PERSONNEL EXPOSURES

1	7	NUMBER	0 0 0 (37)	TYPE	Z (38)	DESCRIPTION (39)	NA

PERSONNEL INJURIES

1	8	NUMBER	0 0 0 (40)	DESCRIPTION (41)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

1	9	TYPE	Z (42)	DESCRIPTION	NA

PUBLICITY

2	0	ISSUED	N (44)	DESCRIPTION (45)	NA

8310140140 831005
PDR ADOCK 05000316
S PDR

NRC USE ONLY

NAME OF PREPARER R. A. PALMER PHONE 616-465-5901