

February 7, 1995

Distribution w/encl:

Mr. Robert E. Link, Vice President
Nuclear Power Department
Wisconsin Electric Power Company
231 West Michigan Street, Room P379
Milwaukee, WI 53201

Docket Files ACRS (10)
PUBLIC OPA
PD3-3 Reading RZimmerman
JRoe WRussell/FMiraglia
EGreenman, RIII RSpessard
EJordan JLieberman
OC/LFDCB BMcCabe, EDO
GHill(4)

SUBJECT: POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2 - REQUEST FOR
RELIEF FOR PUMP AND VALVE INSERVICE TESTING PROGRAM
(TAC NOS. M91187 AND M91188)

Dear Mr. Link:

By letter dated December 12, 1994, your staff submitted Request for Relief VRR-38 from the Point Beach Nuclear Plant, Units 1 and 2 inservice testing program. Granting of this relief will allow pressurizer code safety valves to be seat tightness tested using subcooled water as opposed to saturated steam.

The staff has reviewed your submittal, and has found it acceptable. Request for Relief VRR-38 is granted pursuant to 10 CFR 50.55a(a)(3)(i). The staff's evaluation and conclusions are contained in the attached safety evaluation.

Sincerely,

Original signed by

Leif J. Norrholm, Project Director
Project Directorate III-3
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-266
and 50-301

Enclosure: Safety Evaluation

cc w/encls: See next page

DOCUMENT NAME: G:\PTBEACH\PTB91187.RR

* See previous concurrence

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure
"N" = No copy

PD33:LA	E	PD33:PM	E	EMEB:BC	E	PD3-3:PD	E	OGC	
MRushbrook *		AHansen *		RWessman		LNorrholm		Exowen	
1/23/95		1/23/95		1/24/95		2/17/95		2/13/95	

OFFICIAL RECORD COPY

000024

9502100105 950207
PDR ADOCK 05000266
P PDR

NRC FILE CENTER COPY

DF01

Mr. Robert E. Link, Vice President
Wisconsin Electric Power Company

Point Beach Nuclear Plant
Unit Nos. 1 and 2

cc:

Ernest L. Blake, Jr.
Shaw, Pittman, Potts & Trowbridge
2300 N Street, N.W.
Washington, DC 20037

Mr. Gregory J. Maxfield, Manager
Point Beach Nuclear Plant
Wisconsin Electric Power Company
6610 Nuclear Road
Two Rivers, Wisconsin 54241

Town Chairman
Town of Two Creeks
Route 3
Two Rivers, Wisconsin 54241

Chairman
Public Service Commission
of Wisconsin
Hills Farms State Office Building
Madison, Wisconsin 53702

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, Illinois 60532-4531

Resident Inspector's Office
U.S. Nuclear Regulatory Commission
6612 Nuclear Road
Two Rivers, Wisconsin 54241