

NRC FORM 366
(12-81)

U.S. NUCLEAR REGULATORY COMMISSION
LICENSEE EVENT REPORT

APPROVED BY OMB
3150-0011
EXPIRES 4-30-82

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MDCNN 200-00000-0034111145
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

CONT

01 REPORT SOURCE L605000318701018380922839
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At 0300, during normal shutdown operation, pressure indicator PIC-103
03 failed low. Investigation revealed that the transmitter leads were inad-
04 vertantly lifted rendering ERV-402 inoperable (T.S.3.4.9.3). PIC-103 was
05 returned to service and ERV-402 declared operable at 0405. ERV-404 re-
06 mained operable during this event. Similar events: None.
07
08

09 SYSTEM CODE C F 11 CAUSE CODE A 12 CAUSE SUBCODE C 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE X 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
17 LER/RO REPORT NUMBER 83 EVENT YEAR 83 SEQUENTIAL REPORT NO. 002 OCCURRENCE CODE 03 REPORT TYPE X REVISION NO. 1
18 ACTION TAKEN H 19 FUTURE ACTION Z 20 EFFECT ON PLANT Z 21 SHUTDOWN METHOD Z 22 HOURS 0000 ATTACHMENT SUBMITTED N 23 NPRO-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER B 1 3 0
33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 An Engineering Review was conducted and determined the existing method
11 of selection of test cables adequate, additionally, all shop personnel
12 have been counseled on the ramifications of this event. No further
13 actions deemed necessary.
14

15 FACILITY STATUS D 28 % POWER 000 29 OTHER STATUS N/A 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

16 ACTIVITY CONTENT RELEASED Z 33 AMOUNT OF ACTIVITY Z 34 N/A 35 LOCATION OF RELEASE N/A 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

17 PERSONNEL EXPOSURES NUMBER 000 37 TYPE Z 38 DESCRIPTION N/A 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

18 PERSONNEL INJURIES NUMBER 000 40 DESCRIPTION N/A 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION N/A 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

20 PUBLICITY ISSUED N 44 DESCRIPTION N/A 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

8310200004 830922
PDR ADOCK 05000318
S PDR

NRC USE ONLY

NAME OF PREPARER J.W. Raynor

PHONE: (301) 269-4713

BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

NUCLEAR POWER DEPARTMENT
CALVERT CLIFFS NUCLEAR POWER PLANT
LUSBY, MARYLAND 20657

September 22, 1983

Dr. Thomas E. Murley
Regional Administrator
U.S. Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, PA 19406


Docket No. 50-318
License No. DPR-69

Dear Dr. Murley,

In accordance with Technical Specification 6.9.1.9.b, please find the attached update report for LER 83-002/SX.

Should you have any questions regarding this report, we would be pleased to discuss them with you.

Very truly yours,


L.B. Russell
Plant Superintendent

LBR:JWR:jcs

cc: Director, Office of Management Information
and Program Control

Messrs: A.E. Lundvall, Jr.
J.A. Tiernan

IE22
11