

February 6, 1995

Wyle Laboratories
Attn: Sherwyn Hyten,
Senior Vice President
7800 Governors Drive
Huntsville, AL 35807

SUBJECT: NRC INSPECTION 99900902/95-02

Dear Mr Hyter:

This letter refers to the inspection led by Mr. K.R. Naidu of this office on January 25-28, 1995. The inspection included a review of activities conducted at your facility in Huntsville, Alabama. At the conclusion of the inspection, the findings were discussed with Dr. C Thibault and other members of your staff identified in the enclosed report.

Areas examined during the inspection and our findings are discussed in the enclosed report. The inspectors reviewed the actions taken to correct a violation and nonconformances identified in inspection report 99900902/92-01, and evaluated selected areas of the program established and executed by Wyle to implement the provisions of Part 21 of Title 10 of the Code of Federal Regulations (10 CFR Part 21) for reporting defects and noncompliance, and Appendix B to 10 CFR Part 50. The inspectors also observed selected seismic qualification tests being performed to qualify 4.16-kV switchgear supplied for installation at Pacific Gas and Electric Company's Diablo Canyon Power Plant. Within these areas, the inspection consisted of an examination of procedures and representative documents, interviews with personnel, and observation by the inspectors.

Within the scope of this inspection, we found no instance where you failed to meet NRC requirements. Therefore, no response to this letter is required.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosures will be placed in the NRC Public Document Room.

Sincerely,

(Original signed by)

Robert M. Gallo, Chief
Special Inspection Branch
Division of Technical Support
Office of Nuclear Reactor Regulation

9502150003 950206
PDR GA999 EMV*****
99900902 PDR

Docket No.: 99900902
Enclosure: As stated
cc: See Next Page

Distribution:

ETBaker BRogers
TDQuay Central Files
TSIB R/F PUBLIC

Docket Files/RIDS IE:09

004061

DOCUMENT NAME: G:\NAIDU\WYLECOVER

To receive a copy of this document, indicate in the box: "C" = Copy without enclosures "E" = Copy with enclosures "N" = No copy

OFFICE	TSIB:DOTS	E	TSIB:DOTS	E	TSIB:DOTS	E	TSIB:DOTS	E	TSIB:DOTS	E
NAME	KNaidu:smp		SAlexander		RMendez		GCCwalina		RMGallo	
DATE	02/02/95*		02/03/95*		02/03/95*		02/03/95*		02/6/95	

* See previous concurrence

RETURN TO REGULATORY CENTRAL FILES

OFFICIAL RECORD COPY 1-L-4-1, PT. 21-REPORTING Requirements

IDR-13

cc: Mr. Gregory M. Rueger
Nuclear Power Generation
B 14A
Pacific Gas & Electric Company
77 Beale Street, Room 145
P.O. Box 77000
San Francisco, CA 94106

Mr. D. R. Michaud
Products Manager
NTS
533 Main Street
Acton, MA 01720

Mr. J. L. Bachmann
Project Manager
Power Distribution Services, Inc.
9870 Crescent Drive
West Chester, Ohio 45069