

Point Beach Nuclear Plant 6610 Nuclear Rd., Two Rivers, WI 54241

(414) 755-2321

PBL 95-0042

February 7, 1995

Document Control Desk
U. S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, DC 20555

Gentlemen:

DOCKETS 50-266 AND 50-301 MONTHLY OPERATING REPORTS POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Attached are monthly operating reports for Units 1 and 2 of the Point Beach Nuclear Plant for the calendar month of January, 1995.

Sincerely,

G. J. Maxfield PBNP Manager

yce

Attachments

cc: L. L. Smith, PSCW

NRC Regional Administrator, Region III

NRC Resident Inspector

110211

9502150371 950131 PDR ADDCK 05000266 R PDR IF74

OPERATING DATA REPORT

DOCKET NO. 50-266

DATE: 02/07/95

COMPLETED BY: M. B. Koudelka

TELEPHONE: 414 755-6840

OPERATING STATUS

1. UNIT NAME: POINT BEACH NUCLEAR PLANT - UNIT 1 . NOTES

2. REPORTING PERIOD: January - 1995

- 3. LICENSED THERMAL POWER (MWT): 1518.5
- 4. NAMEPLATE RATING (GROSS MWE): 523.8
- 5. DESIGN ELECTRICAL RATING (NET MWE): 497.0
- 6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 509.0 .
- 8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
- 9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE): NA
- 10. REASONS FOR RESTRICTIONS, (IF ANY):

	THIS MONTH	YEAR TO DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	744.0	744.0	212,472.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	744.0	177,583.6
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	667.3
14. HOURS GENERATOR ON LINE	744.0	744.0	174,456.4
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	846.9
16. GROSS THERMAL ENERGY GENERATED (MWH)	1,124,328	1,124,328	246,669,325
17. GROSS ELECTRICAL ENERGY GENERATED	382,470	382,470	83,321,120
18. NET ELECTRICAL ENERGY GENERATED (MWH)	366,676	366,676	79,427,327
19. UNIT SERVICE FACTOR	100.0%	100.0%	82.1%
20. UNIT AVAILABILITY FACTOR	100.0%	100.0%	8≤.5%
21. UNIT CAPACITY FACTOR (USING MDC NET)	101.6%	101.6%	76.7%
22. UNIT CAPACITY FACTOR (USING DER NET)	99.2%	99.2%	75.2%
23. UNIT FORCED OUTAGE RATE	0.0%	0.0%	1.5%

24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):
Refueling, 03/11/95, 36 days

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC LETTER DATED SEPTEMBER 22, 1977

		POINT BEACH NUC	LEAR PLANT	DOCKET NO.	50-266
		AVERAGE DAILY U	NIT POWER LEVEL	UNIT NAME	Point Beach, Unit 1
		MONTH JANUA	ARY - 1995	PATE	February 7, 1995
				COMPLETED BY	M. B. Koudelka
				TELEPHONE	(414) 755-6480
DAY	AVERAGE DAILY POWER LEVEL MWe NET	DAY	AVERAGE DAILY POWER LEVEL MWe NET	DAY	AVERAGE DAILY POWER LEVEL MWe NET
1	419	11	494	21	496
2	495	12	495	22	496
3	495	13	493	23	496
4	495	14	495	24	495
5	496	15	497	25	496
6	495	16	495	26	495
7	496	17	496	27	494
8	495	18	494	28	496
9	495	19	496	29	496
10	495	20	495	30	496
				31	495

POINT BEACH NUCLEAR PLANT

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH JANUARY - 1995

Docket No. Unit Name Date

Completed By

Telephone No.

50-266 Point Beach, Unit 1

February 7, 1995 M. B. Koudelka

414/755-6480

No.	Date	Type ¹	Duration	Reason ²	Method of Snutting Down	Licensee Event	System	Component	Cause and Corrective Action
NA	NA	NA	NA	NA	NA	NA	NA	NA	NA NA

F: Forced

S: Scheduled

²Reason:

- A Equipment Failure (explain)
- B Maintenance or Testing
- C Refueling
- D Regulatory Restriction
- E Operator Training & Licensing Exam
- F Administrative
- G Operational Error (explain)
- H Other (explain)

3Method:

- 1 Manual
- 2 Manual Scram
- 3 Automatic Scram
- 4 Continuation of Previous Shutdown
- 5 Reduced Load
- 6 Other (explain)

⁴Exhibit G - Instructions for preparation of data entry sheets LER file (NUREG-0161)

⁵Exhibit I - Same Source

DOCKET NO.

50-266

UNIT NAME DATE

Point Beach Unit 1 February 7, 1995

COMPLETED BY M. B. Koudelka TELEPHONE

414/755-6480

Unit 1 operated at an average of 493 MWe net for the report period.

Safety-related maintenance included:

- 1852-12B power to PP-14 pressurizer backup heater C group power panel amptector setpoints adjusted and tested.
- 2. DO8 DO6 dc station battery charger relay rewired.
- LT-4038/PT-2844 condensate storage tank level and service water 3. north header pressure transmitter calibrations.
- 1N42/1N46 nuclear instrumentation power range comparator channel calibrations and adjustments.
- 5. . P10 residual heat removal pump rotating assembly rebuilt.
- P32F service water pump repacked.
- 6. 1S-6050A-C turbine overspeed protection channels A-C calibrations and adjustments.
- SW-2912-DS south service water header Zurn strainer piston seals and bearing, replaced.

DOCKET NO. 50-301

DATE: 02/07/95

COMPLETED BY: M. B. Koudelka

TELEPHONE: 414 755-6480

OPERATING STATUS

1. UNIT NAME: POINT BEACH NUCLEAR PLANT - UNIT 2 . NOTES

2. REPORTING PERIOD: January - 1995

- 3. LICENSED THERMAL POWER (MWT): 1518.5
- 4. NAMEPLATE RATING (GROSS MWE): 523.8
- 5. DESIGN ELECTRICAL RATING (NET MWE): 497.0
- 6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 509.0 .
- 8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:
- 9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE): NA
- 10. REASONS FOR RESTRICTIONS, (IF ANY):

	THIS MONTH	YEAR TO DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	744.0	744.0	197,257.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	744.0	172 95.6
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	233.9
14. HOURS GENERATOR ON LINE	744.0	744.0	170,438.7
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	302.2
16. GROSS THERMAL ENERGY GENERATED (MWH)	1,116,815	1,116,815	245,098,740
17. GROSS ELECTRICAL ENERGY GENERATED	377,140	377,140	83,328,250
18. NET ELECTRICAL ENERGY GENERATED (MWH)	360,956	360,956	79,441,471
19. UNIT SERVICE FACTOR	100.0%	100.0%	86.4%
20. UNIT AVAILABILITY FACTOR	100.0%	100.0%	86.6%
21. UNIT CAPACITY FACTOR (USING MDC NET)	100.0%	100.0%	82.5%
22. UNIT CAPACITY FACTOR (USING DER NET)	97.6%	97.6%	81.0%
23. UNIT FORCED OUTAGE RATE	0.0%	0.0%	1.0%
A CHEROCOMO COMPANIO	DE DAME AND DEPLATED OF		

^{24.} SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):
NONE

^{25.} IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:

⁻ DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC LETTER DATED SEPTEMBER 22, 1977

		POINT BEACH NUC	CLEAR PLANT	DOCKET NO.	50-301
		AVERAGE DAILY U	NIT POWER LEVEL	UNIT NAME	Point Beach, Unit 2
		MONTH JANU	ARY - 1995	DATE	February 7, 1995
				COMPLEYED BY	M. B. Koudelka
				TELEPHONE	(414) 755-6480
DAY	AVERAGE DAILY POWER LEVEL MWe NET	DAY	AVERAGE DAILY POWER LEVEL MWe NET	DAY	AVERAGE DAILY POWER LEVEL MWe NET
1	485	11	486	21	487
2	484	12	486	22	487
3	485	13	473	23	484
4	486	14	498	24	487
5	486	15	466	25	485
6	486	16	486	26	486

POINT BEACH NUCLEAR PLANT

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH JANUARY - 1995

Docket No. Unit Name Date

50-301 Point Beach, Unit 2

February 7, 1995

Completed By M. B. Koudelka Telephone No. 414/755-6480

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action To Prevent Recurrence
NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
The second secon									

F: Forced

S: Scheduled

²Reason:

A - Equipment Failure (explain)

B - Maintenance or Testing

C - Refueling

D - Regulatory Restriction

E - Operator Training &

Licensing Exam

F - Administrative

G - Operational Error (explain)

H - Other (explain)

3Method:

1 - Manual

2 - Manual Scram

3 - Automatic Scram

4 - Continuation of Previous Shutdown

5 - Reduced Load

6 - Other (explain)

⁴Exhibit G - Instructions

for preparation of data entry sheets

LER file (NUREG-0161)

5Exhibit I - Same Source

DOCKET NO. 50-301

UNIT NAME Point Beach Unit 2
DATE December 6, 1994
COMPLETED BY M. B. Koudelka
TELEPHONE 414/755-6480

Unit 2 operated at an average of 485 MWe net for the report period.

Safety-related maintenance included:

- 2B52-30C power to PP-17 pressurizer control heater E group power panel retrofit installation.
- 2FI-115 P1A reactor coolant pump seal water injection flow indicator retubed.
- 3. 2P2B charging pump varidrive controller adjustment.
- 2P/P-626 HX-11A&B residual heat removal heat exchanger bypass flow control positioner steam and sleeve replacements.
- 5. 2WG-1786 T16 reactor coolant drain tank vent valve operator stem guide plate attached.