



Tennessee Valley Authority Post Office Box 2000, Soddy-Daisy, Tennessee 37375

February 9, 1995

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of	)	Docket Nos. 50-327
Tennessee Valley Authority	)	50-328

SEQUOYAH NUCLEAR PLANT (SQN) - JANUARY 1995 MONTHLY OPERATING REPORT

Enclosed is the January 1995 Monthly Operating Report as required by SQN Technical Specification 6.9.1.10.

If you have any questions concerning this matter, please call
J. W. Proffitt at (615) 843-6651.

Sincerely,

R. H. Shell

R. H. Shell
Manager
SQN Site Licensing

Enclosure
cc: See page 2

140210

9502150379 950131
PDR ADOCK 03000327
R PDR

IF 2A
11

U.S. Nuclear Regulatory Commission
Page 2
February 9, 1995

cc (Enclosure):

INPO Records Center
Institute of Nuclear Power Operations
700 Galleria Parkway
Atlanta, Georgia 30339-5957

Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852-2739

Mr. Joseph Santucci, Manager
Advanced Reactor Department
Electric Power Research Institute
3340 Hillview Avenue
Palo Alto, California 94304

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy-Daisy, Tennessee 37379-3624

Regional Administration
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323-2711

Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323-2711

Mr. F. Yost, Director Research Services
Utility Data Institute
1200 G Street, NW, Suite 250
Washington, D.C. 20005

TENNESSEE VALLEY AUTHORITY

SEQUOYAH NUCLEAR PLANT

MONTHLY OPERATING REPORT

TO THE

NUCLEAR REGULATORY COMMISSION

JANUARY 1995

UNIT 1

DOCKET NUMBER 50-327

LICENSE NUMBER DPR-77

UNIT 2

DOCKET NUMBER 50-328

LICENSE NUMBER DPR-79

OPERATIONAL SUMMARY
JANUARY 1995

UNIT 1

Unit 1 generated 884,860 megawatthours (MWh) (gross) electrical power during January with a capacity factor of 103 percent. Unit 1 operated at near 100 percent power throughout the month of January.

UNIT 2

Unit 2 generated 752,983 megawatthours (MWh) (gross) electrical power during January with a capacity factor of 88.3 percent.

On January 5 at 0015 Eastern standard time (EST), with Unit 2 operating at 100 percent reactor power, an automatic turbine trip and subsequent reactor trip occurred. The signal was generated by the gas-operated relay on the C-phase main bank transformer. Operation of the gas-operated relay resulted when the control room operator attempted to remove the lens cover of a cooling group indication light that was not lit following receiving an alarm regarding the cooler group operation. When the lens cover was rotated, the control power for the main bank transformer cooler group shorted, resulting in the cycling of the pumps in both cooler groups. This resulted in a pressure surge in the transformer cooling oil which operated the gas operated relay. Subsequent to the trip, Unit 2 entered Mode 3.

The Unit 2 reactor was taken critical again on January 5 at 2235 EST and was tied online on January 6 at 0956 EST. Unit 2 was again operating at 100 percent reactor power on January 8 at 2320 EST.

Unit 2 was manually removed from the grid on January 13 at 2113 EST as a result of a hot spot on the A-phase main transformer. The reactor power was maintained at approximately 28 percent while maintenance was performed. Unit 2 was tied online on January 15 at 0102 EST and reached 100 percent reactor power at 2130 EST that same day.

Unit 2 operated at near 100 percent reactor power through the remainder of January.

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-327 UNIT No. One DATE: 02-02-95
 COMPLETED BY: T. J. Hollomon TELEPHONE: (615) 843-7528
 MONTH: JANUARY 1995

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	1154	17	1153
2	1154	18	1148
3	1154	19	1151
4	1151	20	1151
5	1152	21	1152
6	1154	22	1154
7	1158	23	1147
8	1157	24	1149
9	1151	25	1150
10	1156	26	1152
11	1157	27	1152
12	1152	28	1148
13	1153	29	1152
14	1152	30	1150
15	1156	31	1149
16	1152		

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-328 UNIT No. Two DATE: 02-02-95
 COMPLETED BY: T. J. Hollomon TELEPHONE: (615) 843-7528
 MONTH: JANUARY 1995

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	1143	17	1146
2	1146	18	1142
3	1143	19	1142
4	1141	20	1144
5	-22	21	1144
6	125	22	1144
7	282	23	1144
8	795	24	1142
9	1139	25	1143
10	1142	26	1142
11	1139	27	1144
12	1139	28	1143
13	849	29	1142
14	-37	30	1142
15	652	31	1143
16	1139		

OPERATING DATA REPORT

DOCKET NO. 50-327
DATE 02/02/95
COMPLETED BY T. J. Hollomon
TELEPHONE (615) 843-7528

OPERATING STATUS

1. Unit Name: Sequoyah Unit One
2. Reporting Period: January 1995
3. Licensed Thermal Power (MWt): 3411.0
4. Nameplate Rating (Gross MWe): 1220.6
5. Design Electrical Rating (Net MWe): 1148.0
6. Maximum Dependable Capacity (Gross MWe): 1151.0
7. Maximum Dependable Capacity (Net MWe): 1111.0
8. If Changes Occur in Capacity Ratings (Item Numbers 3 Through 7) Since Last Report, Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr-to-Date	Cumulative
11. Hours in Reporting Period	<u>744</u>	<u>744</u>	<u>119,113</u>
12. Number of Hours Reactor Was Critical	<u>744.0</u>	<u>744.0</u>	<u>62,794</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>744.0</u>	<u>744.0</u>	<u>61,348.3</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>2,533,903.4</u>	<u>2,533,903.4</u>	<u>200,109,900</u>
17. Gross Electrical Energy Generated (MWH)	<u>884,860</u>	<u>884,860</u>	<u>67,935,744</u>
18. Net Electrical Energy Generated (MWH)	<u>857,686</u>	<u>857,686</u>	<u>65,121,099</u>
19. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>51.5</u>
20. Unit Availability Factor	<u>100.0</u>	<u>100.0</u>	<u>51.5</u>
21. Unit Capacity Factor (Using MDC Net)	<u>103.8</u>	<u>103.8</u>	<u>49.2</u>
22. Unit Capacity Factor (Using DER Net)	<u>100.4</u>	<u>100.4</u>	<u>47.6</u>
23. Unit Forced Outage Rate	<u>0.0</u>	<u>0.0</u>	<u>36.4</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _____

OPERATING DATA REPORT

DOCKET NO. 50-328
DATE 02/02/95
COMPLETED BY T. J. Hollomon
TELEPHONE (615) 843-7528

OPERATING STATUS

1. Unit Name: Sequoia Unit Two
2. Reporting Period: January 1995
3. Licensed Thermal Power (Mwt): 3411.0
4. Nameplate Rating (Gross MWe): 1220.6
5. Design Electrical Rating (Net MWe): 1148.0
6. Maximum Dependable Capacity (Gross MWe): 1146.0
7. Maximum Dependable Capacity (Net MWe): 1106.0
8. If Changes Occur in Capacity Ratings (Item Numbers 3 Through 7) Since Last Report, Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Yr-to-Date	Cumulative
11. Hours in Reporting Period	<u>744</u>	<u>744</u>	<u>111,073</u>
12. Number of Hours Reactor Was Critical	<u>721.7</u>	<u>721.7</u>	<u>65,078</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
14. Hours Generator On-Line	<u>682.7</u>	<u>682.7</u>	<u>63,392.4</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>0</u>
16. Gross Thermal Energy Generated (MWH)	<u>2,198,286.6</u>	<u>2,198,286.6</u>	<u>199,725,749</u>
17. Gross Electrical Energy Generated (MWH)	<u>752,903</u>	<u>752,983</u>	<u>67,760,592</u>
18. Net Electrical Energy Generated (MWH)	<u>723,807</u>	<u>723,807</u>	<u>64,837,989</u>
19. Unit Service Factor	<u>91.8</u>	<u>91.8</u>	<u>57.1</u>
20. Unit Availability Factor	<u>91.8</u>	<u>91.8</u>	<u>57.1</u>
21. Unit Capacity Factor (Using MDC Net)	<u>88.0</u>	<u>88.0</u>	<u>52.8</u>
22. Unit Capacity Factor (Using DER Net)	<u>84.7</u>	<u>84.7</u>	<u>50.8</u>
23. Unit Forced Outage Rate	<u>3.2</u>	<u>3.2</u>	<u>34.9</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: _____

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO: 50-327

UNIT NAME: One

DATE: 02/02/95

COMPLETED BY: T. J. Hollomon

TELEPHONE: (615) 843-7528

REPORT MONTH: January 1995

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
									There were no outages or power reductions of greater than 20 percent to report in January.

¹F: Forced
S: Scheduled²Reason:

A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training and License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³Method:

1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continuation of Existing Outage
 5-Reduction
 9-Other

⁴Exhibit G-Instructions
for Preparation of Data

Entry sheets for Licensee
 Event Report (LER) File
 (NUREG-1022)

⁵Exhibit I-Same Source

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH: January 1995DOCKET NO: 50-328UNIT NAME: TwoDATE: 02/02/95COMPLETED BY: T. J. HollomonTELEPHONE: (615) 843-7528

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
1	950105	F	33.7	A	3	328/95001	IU	IL	On January 5 at 0015 EST, with Unit 2 operating at 100 percent reactor power, an automatic turbine and reactor trip occurred. The gas relay tripped the main transformer, resulting in subsequent turbine and reactor trips. The cause of this event was a failure to design the light socket installation with an adequate barrier to prevent an electrical short from occurring. The electrical short resulted in the cycling of the transformer cooler group pumps and the actuation of the gas-operated relay. The Unit 2 and common control room panel lamp sockets were inspected to ensure that they were properly installed. Eight deficiencies were identified and corrected. A preventive maintenance instruction will be developed to periodically check the tightness of control room light sockets. The Unit 1 control room sockets will be checked during the next refueling outage.

¹ F: Forced
S: Scheduled

² Reason:
A-Equipment Failure (Explain)
B-Maintenance or Test
C-Refueling
D-Regulatory Restriction
E-Operator Training and License Examination
F-Administrative
G-Operational Error (Explain)
H-Other (Explain)

³ Method:
1-Manual
2-Manual Scram
3-Automatic Scram
4-Continuation of Existing Outage
5-Reduction
9-Other

⁴ Exhibit G-Instructions
for Preparation of Data
Entry sheets for Licensee
Event Report (LER) File
(NUREG-1022)

⁵ Exhibit I-Same Source

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH: January 1995
 DOCKET NO: 50-328
 UNIT NAME: Two
 DATE: 02/02/95
 COMPLETED BY: T. J. Hollomon
 TELEPHONE: (615) 843-7528

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
2	950113	F	27.6	B	5	N/A	N/A	N/A	Unit 2 was removed from the grid on January 13 at 2113 EST as a result of a hot spot on the A-phase bus bushing connection. The A-phase transformer was removed from service, and the spare transformer was placed in service. The bushing will be repaired or replaced as appropriate.

¹F: Forced
 S: Scheduled

²Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training and License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continuation of Existing Outage
 5-Reduction
 9-Other

⁴Exhibit G-Instructions
 for Preparation of Data
 Entry sheets for Licensee
 Event Report (LER) File
 (NUREG-1022)

⁵Exhibit I-Same Source