

DOCKETED
USNRC

BEFORE THE ATOMIC SAFETY AND LICENSING APPEAL BOARD

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH

Docket Nos. 50-275 O.L.
50-323 O.L.

Pursuant to 10 C.F.R. § 2.788, the SAN LUIS OBISPO MOTHERS FOR PEACE, SCENIC SHORELINE PRESERVATION CONFERENCE, INC., ECOLOGY ACTION CLUB, SANDRA SILVER, GORDON SILVER, ELIZABETH APFELBERG, and JOHN J. FORSTER ("Joint Intervenor") hereby renew their September 10, 1981 application to the Atomic Safety and Licensing Appeal Board ("Appeal Board") for an order staying the effectiveness of (1) the Atomic Safety and Licensing Board's ("licensing board") July 17, 1981 Partial Initial Decision ("PID") which authorized the issuance of licenses to load fuel and conduct low power tests at Diablo Canyon Nuclear Power Plant ("Diablo Canyon"), Units 1 and 2; (2) the Appeal Board's May 18, 1983 decision affirming the licensing board's July 17, 1981 PID; and (3) the Commission's September 21, 1981 decision authorizing issuance of a low power operating license for Diablo Canyon, Unit 1. The Joint Intervenor request the stay in order to prevent irreparable harm and to preserve the status quo until administrative appellate review of all issues underlying issuance of the fuel loading and low power operating license is complete, including review of all quality assurance matters pending before this Appeal Board or the Commission.

A similar application for a stay was filed by the Joint Intervenors in September 1981. Prior to a decision by the Appeal Board, however, the first of a continuing series of design and construction errors was discovered at Diablo Canyon, and, on November 19, 1981, the Commission suspended the low power operating license indefinitely. During the past two years, a design verification program has been implemented by PGandE and by Teledyne Engineering Services, an auditor hired by PGandE in response to the Commission's suspension order. Although the verification is incomplete in numerous respects, the Commission is expected to vote on reissuance of the suspended license on November 8, 1983.

I. SUMMARY OF THE DECISIONS TO BE STAYED

Each of the decisions to be stayed has authorized issuance of the fuel loading and low power operating license for Diablo Canyon, Unit 1. More specifically, the licensing board approved the adequacy of (1) the PGandE quality assurance/quality control ("QA/QC") programs for design and construction, and (2) the on-site and off-site emergency response plans for purposes of low power operation. The May 18, 1983 Appeal Board decision affirmed the licensing board's decision, and the Commission's September 21, 1981 decision constituted the immediate effectiveness review of all matters underlying issuance of the license.

II. GROUND FOR THE STAY

The factors prescribed by 10 C.F.R. § 2.788(e) to be considered by the Appeal Board in connection with a request for stay are:

- (1) whether the moving party has made a strong showing that it is likely to prevail on the merits;
- (2) whether the party will be irreparably injured unless a stay is granted;
- (3) whether the granting of a stay would harm other parties; and
- (4) where the public interest lies.

A. There is a Strong Probability that the Joint Intervenors Will Prevail on the Merits

1. Quality Assurance. In its July 17, 1981 PID, the licensing board relied upon the mistaken assurances of PGandE and NRC Staff witnesses in finding that:

The Diablo Canyon quality assurance programs for both the Design and Construction Phase and the Operations Phase have been and are in compliance with the requirements of 10 C.F.R. 50, Appendix B, and that the implementation of both programs is acceptable to the Board.

The disclosure during the past two years of numerous design and construction errors, including a breakdown of the quality assurance programs of PGandE and its major subcontractors, has discredited the board's finding. In July 1982, the Joint Intervenors and the Governor of California requested reopening of the record on the issue of quality assurance, which application was granted by this Board as to design.^{1/} In a related order, the Appeal Board found that "there is now substantial uncertainty whether any particular structure, system or component was designed in accordance with stated criteria and commitments."^{2/}

In light of this conclusion and the significant new evidence of a similar breakdown in construction quality assurance, there is no longer any factual basis in the record to support the licensing board's findings under Appendix B or the findings required by the Atomic Energy Act and the Commission's regulations to justify issuance of a license.^{3/} Because of the long recognized importance of quality assurance in nuclear power plant design and construction,^{4/} and the undeniable breakdown of QA/QC during the design and construction of Diablo Canyon, it must be proven on the record that an effective substitute for regulatory compliance has

1/ In the Matter of Pacific Gas and Electric Company (Diablo Canyon Nuclear Power Plant, Units 1 and 2), ALAB-___, Memorandum and Order, at 2-3 (April 21, 1983).

2/ Id., Order, at 4 (August 16, 1983).

3/ See, e.g., 10 C.F.R. § 50.57(a).

4/ See, e.g., In the Matter of Consumers Power Company (Midland Plant, Units 1 and 2), ALAB-106, 6 AEC 182, 183 (1972); In the Matter of Duke Power Company (William B. McGuire Nuclear Station, Units 1 and 2), ALAB-128, 6 AEC 399, 410 (1973).

provided the factual basis for the § 50.57(a) and Appendix B findings. Until such a showing has been made, the Atomic Energy Act and the Commission's regulations prohibit licensing of Diablo Canyon.

2. License Suspension and Amendment. Currently pending before the Commission are two applications for hearings to be held prior to a decision to reissue the suspended license, both of which are based on § 189(a) of the Atomic Energy Act, 42 U.S.C. § 2239(a).^{5/} Both because the Commission has suspended the fuel loading and low power license, and because PGandE has applied for an amendment extending the term of the suspended license from one to three years,^{6/} § 189(a) guarantees the right to a formal adjudicatory hearing prior to reissuance of the license or granting of the amendment. See, e.g., In the Matter of Metropolitan Edison Co. (Three Mile Island Nuclear Power Plant, Unit 1), No. 50-289, Order (July 12, 1979); id., 10 N.R.C. 141, 142 (August 9, 1979); Brooks v. Atomic Energy Commission, 476 F.2d 924 (D.C.Cir. 1973); Sholly v. U.S. Nuclear Regulatory Commission, 651 F.2d 780 (D.C.Cir. 1980), vacated on other grounds, __ U.S. __, 51 U.S.L.W. 3610 (February 22, 1983), on remand, __ F.2d __, 19 E.R.C. 1055 (April 4, 1983).^{7/}

3. Validity of the License. Because of the extended period that has elapsed since expiration of the suspended low power license in September 1982, PGandE's

^{5/} Section 189(a) guarantees the right to a prior hearing "in any proceeding under this chapter for the...suspending,...or amending of any license...."

^{6/} License Amendment Request No. 83-08 (August 17, 1983).

^{7/} In Sholly, the D.C. Circuit Court of Appeals noted explicitly that the time for hearing on an amendment was before any decision:

By requiring a hearing upon request whenever a license is "grant[ed], suspend[ed], revok[ed], or amend[ed], Congress apparently contemplated that interested parties would be able to intervene before any significant change in the operation of a nuclear facility.

651 F.2d at 791 (emphasis added). On remand, the Court of Appeals made clear that the only circumstance in which a hearing on an amendment may be held after its effective date is where "no significant hazards considerations exist." 19 ERC 1055, 1056. Thus, under the circumstances of this case, § 189(a) requires a hearing prior to a decision on the proposed license amendment.

amendment application seeking renewal of the license must be denied. PGandE has requested an extension under 10 C.F.R. § 2.109,^{8/} but this type of provision has previously been held inapplicable under similar circumstances:

The kind of case that the statute was meant to cover was that in which time exigencies within the agency prevent it from passing on a renewal application, when an activity of a continuing nature such as radio broadcasting or shipping services is involved.

By contrast, in the case before us, time exigencies played no part in the Corps' refusal to renew. Instead a substantive problem arose with the application which had to be resolved before the Corps could grant a new permit.

Bankers Life & Casualty Co. v. Callaway, 530 F.2d 625, 634 (5th Cir. 1976), cert. denied, 429 U.S. 1073 (1977) (emphasis added).

In this proceeding, a year has elapsed since the license term expired, and the Commission has taken no action, not because of "time exigencies" but because of a "substantive problem" precluding the Commission from issuing a license -- the discovery of massive design and construction deficiencies demonstrating that PGandE was not entitled to a license in the first instance. Thus, just as the court in Bankers Life concluded that the license had expired, PGandE's license has also expired and cannot be amended.

4. Class Nine Accident Analysis. In the past, the Commission did not require consideration under the National Environmental Policy Act ("NEPA"), 42 U.S.C. § 4321 et seq., of the effect on the environment of core melt accidents ("Class 9" accidents). The premise was that occurrence of a Class 9 accident was of such low probability that neither NEPA nor the Atomic Energy Act required its consideration. The accident at Three Mile Island ("TMI") destroyed that premise, and the Commission

^{8/} That regulation provides:

If, at least thirty (30) days prior to the expiration of an existing license authorizing any activity of a continuing nature, a licensee files an application for a renewal or for a new license for the activity so authorized, the existing license will not be deemed to have expired until the application has been finally determined.

recognized this fact in its "Statement of Interim Policy" by amending its prior policy to require NEPA consideration of Class 9 accident sequences.^{9/} But despite the Commission's explicit recognition that the prior policy was erroneous, it limited this amendment to prospective application absent "special circumstances," and as a result has repeatedly denied Joint Intervenors' requests for NEPA consideration of a Class 9 accident. The Commission's action is illegal for two reasons. First, NEPA imposes a statutory duty to supplement an Environmental Impact Statement ("EIS") to reflect significant new information or changed circumstances occurring after the filing of the final EIS.^{10/} By the Commission's own admission, the TMI accident constitutes such significant new information, and the Commission cannot legally limit a pre-existing statutory requirement merely by stating that it shall apply only to future EISs. Second, apart from NEPA requirements, the Commission has violated its own policy that consideration of a Class 9 accident is required where special circumstances exist, including -- as at Diablo Canyon -- the proximity of the plant to a man-made or natural hazard.^{11/} On either basis, therefore, issuance of a license for Diablo Canyon absent consideration of the effects of a Class 9 accident is unlawful.

5. Earthquake Emergency Preparedness. The Commission's regulations explicitly provide that "no operating license for a nuclear power reactor will be issued unless a finding is made by the NRC that adequate protective measures can and will be taken in the event of a radiological emergency." 10 C.F.R. § 50.47(a)(1) (emphasis

^{9/} "Nuclear Power Plant Accident Considerations Under the National Environmental Policy Act of 1969," 45 Fed.Reg. 40101.

^{10/} See, e.g., Warm Springs Dam Task Force v. Gribble, 621 F.2d 1017, 1023-24 (9th Cir. 1980) (per curiam); Aluli v. Brown, 437 F.Supp. 602, 606 (D.Hawaii 1977), rev'd in part on other grounds, 602 F.2d 876 (9th Cir. 1979).

^{11/} In the Matter of Public Service Company of Oklahoma (Black Fox Station, Units 1 and 2), CLI-80-8, at 434-35 (March 21, 1980).

added). The evidence at the hearing was uncontradicted, and all parties conceded, that existing applicant, state, and local emergency plans fail to consider and allow for the effects of a major earthquake on the Hosgri fault occurring simultaneously with a radiological emergency at Diablo Canyon.^{12/} Particularly in light of the Commission's appreciation of the greater seismic risk associated with nuclear plants in California and the continuing importance of seismic safety in this proceeding, this failure is a critical deficiency in emergency preparedness at Diablo Canyon.^{13/} Nevertheless, the Appeal Board concluded that the licensing board was without jurisdiction to consider the issue, citing the Commission's San Onofre decision. In so doing, the Board violated the Joint Intervenors' right to a hearing guaranteed by § 189(a) of the Atomic Energy Act, 42 U.S.C. § 2239(a), with respect to a safety issue unique to Diablo Canyon. Because its decision was without independent factual basis, there has been a clear failure by the agency to consider a relevant safety issue, either on a generic basis or within individual licensing proceedings.^{14/} Accordingly, issuance of the license must be reversed.

B. Joint Intervenors Will Be Irreparably Injured in the Absence of a Stay

If a license is issued for fuel loading and low power testing at Diablo Canyon, Joint Intervenors will be irreparably harmed in several significant respects. First, nuclear materials will for the first time be introduced into the reactors, thereby posing a risk not only of worker exposure but of contamination of the facility's

^{12/} See Low Power Hearing Transcript, Jorgensen, at 2; Sears, at 7; Sears Tr. 11060, 11283; Schiffer Tr. 10878-79 (May 1981).

^{13/} In the Matter of Southern California Edison Company (San Onofre Nuclear Generating Station, Units 2 and 3), Nos. 50-361-OL, 50-362-OL, Order, at 3 (July 29, 1981) (Raising on the board's motion an issue concerning earthquakes and emergency planning); see also, In the Matter of Southern California Edison Co. (San Onofre Nuclear Power Generating Station), Memorandum and Order, at 2 (April 8, 1981).

^{14/} See Natural Resources Defense Council v. Nuclear Regulatory Commission, 685 F.2d 459 (D.C.Cir. 1982), rev'd on other grounds sub nom. Baltimore Gas and Electric Co. v. Natural Resources Defense Council, ___ U.S. ___, 103 S.Ct. 2246 (1983).

components and systems. (Hubbard Affidavit, attached hereto.) This irretrievable commitment of resources prejudices the Joint Intervenor's rights by predisposing this agency to issuance of a full power license for the plant prior to final disposition of significant safety issues, and makes further plant modifications less likely, even though such modifications may later be determined to be necessary.

Second, when an agency has taken an action in violation of NEPA -- such as the failure to supplement in the instant case -- there is a presumption that injunctive relief should be granted against the continuation of that action until the agency complies with the Act. See Realty Income Trust v. Eckerd, 564 F.2d 447, 456 (D.C.Cir. 1977).^{15/} Environmental factors must be fully considered not only before actual harm occurs, but before the agency's plans are so advanced that they acquire "irreversible momentum." Id. at 511; Lathan v. Volpe, 455 F.2d 1111, 1121 (9th Cir. 1971) (It is "especially important" that an EIS be prepared early so that "flexibility in selecting alternative plans" is not lost). As the First Circuit recently observed,

[o]nce large bureaucracies are committed to a course of action, it is difficult to change that course -- even if new, or more thorough, NEPA statements are prepared and the agency is told to "redecide."

Massachusetts v. Watt, ___ F.2d ___, 19 ERC 1745, 1750 (1st Cir. Sept. 16, 1983).^{16/} Courts should therefore intervene as early as possible to forestall the formation of

^{15/} The purpose of such relief is two-fold. First, NEPA was intended not only to prevent harm to the environment, but to ensure that agency decision-makers fully explore the consequences of their actions. Consequently, "courts will not hesitate to stop projects that are in the process of affecting the environment when the agency is in illegal ignorance of the consequences, as when it should have prepared an EIS but failed to do so." Id. (emphasis in original). Second, injunctive relief against non-compliance with NEPA preserves the agency's freedom to choose alternative, less environmentally damaging methods of proceeding in the future. State of Alaska v. Andrus, 580 F.2d 465, 485 (D.C.Cir. 1978).

^{16/} The court held in Watt that plaintiffs were entitled to a preliminary injunction against a planned lease sale of offshore oil tracts because the Department of the Interior had failed to prepare a supplement to its EIS reflecting its revised estimates of oil likely to be found on the tracts. Plaintiffs would have suffered

[continued]

a chain of commitment "that will become progressively harder to undo the longer it continues." Id.

Third, if low power operations are allowed to commence, Joint Intervenor will in effect be deprived of any right to appeal because the proposed low power test program will be completed before appellate review can be obtained. Irreparable harm of this sort -- the loss of a right to judicial review before the activity in dispute has been completed -- has been recognized by numerous courts in granting a stay.^{17/}

Fourth, once fuel has been loaded into the reactor, the time and associated costs to remove it at some future time should circumstances warrant will, as a practical matter, prejudice the NRC's consideration of those circumstances by "tipping the scales" away from removal of the fuel. Thus, the Joint Intervenor's rights will be irreparably harmed due to the economic considerations involved with loading of fuel.

C. The Granting of a Stay Will Not Harm PGandE

The grant of a stay will postpone fuel loading and low power testing of Diablo Canyon only until administrative review of pending appeals has been completed, resulting in minimal harm to PGandE. Low power testing is beneficial to PGandE only as a step toward full power operation. However, full power operation of Diablo Canyon cannot realistically be expected before March-June 1984, even assuming that PGandE will prevail on all issues pending before the Commission or its adjudicatory

[footnote 16 cont'd]
irreparable harm once the Department was committed to the lease, since the oil companies, the Department, and the state agencies would have begun to plan development of the tracts, making it more difficult to reverse the decision later. Here, similarly, the granting even of a license to load fuel will commit PGandE to a course of action which will lessen the chances that the environmental consequences of Diablo Canyon's operation at full power will ever be fully examined.

^{17/} See, e.g., Public Utilities Commission v. Capital Transit Co., 214 F.2d 242, 245 (D.C.Cir. 1954); Isbrandtsen Co. v. United States, 211 F.2d 51, 55 (D.C.Cir.), cert. denied, 347 U.S. 990 (1954); Zenith Radio Corp. v. United States, 505 F.Supp. 216 (Int. Trade 1980); National Wildlife Federation v. Andrus, 440 F.Supp. 1245 (D.D.C. 1977); Perez v. Wainwright, 440 F.Supp. 1037 (S.D.Fl. 1977), rev'd on other grounds, 594 F.2d 159 (5th Cir. 1979), vacated, 447 U.S. 932 (1980).

boards. Accordingly, a postponement of low power operation until the pending matters are resolved will still permit PGandE to conduct its testing program without the need to delay full power operation.

D. The Public Interest Favors a Stay

The public interest would be best served by granting a stay in order to assure that operation of the plant will be safe and will comply with all applicable regulations. Holding safety hearings after the plant has already been licensed and contaminated by radioactive material makes a mockery of the regulatory process, and undermines public confidence in the agency's willingness to place the public health and safety ahead of the economic interests of those whom the agency is charged to oversee.

IV. CONCLUSION

For the reasons stated above, Joint Intervenors hereby request this Appeal Board to stay the effectiveness of the decisions cited herein.

DATED: October 31, 1983

Respectfully submitted,

JOEL R. REYNOLDS, ESQ.
JOHN R. PHILLIPS, ESQ.
ERIC R. HAVIAN, ESQ.
Center for Law in the
Public Interest
10951 W. Pico Boulevard
Los Angeles, CA 90064
(213)470 3000

DAVID S. FLEISCHAKER, ESQ.
P. O. Box 1178
Oklahoma City, OK 73101

By /s/ Joel R. Reynolds /cc
JOEL R. REYNOLDS

Attorneys for Joint Intervenors
SAN LUIS OBISPO MOTHERS FOR PEACE
SCENIC SHORELINE PRESERVATION
CONFERENCE, INC.
ECOLOGY ACTION CLUB
SANDRA SILVER
ELIZABETH APFELBERG
JOHN J. FORSTER

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

BEFORE THE APPEAL BOARD

In The Matter Of

PACIFIC GAS AND ELECTRIC COMPANY

(Diablo Canyon Nuclear Power
Plant, Units Nos. 1 and 2)

Docket Nos. 50-275 O.L.
50-323 O.L.

AFFIDAVIT OF RICHARD B. HUBBARD

RICHARD B. HUBBARD, being duly sworn, deposes and says
as follows:

1. The purpose of this affidavit is threefold. First, to estimate the elapsed time which is likely to be required after issuance of a low power operating license to load fuel and to complete the special low power tests at or below 5% of Rated Thermal Power as Pacific Gas and Electric Company has proposed for the Diablo Canyon Unit 1; second, to describe the substantial fission product inventory that would be created in less than one month of 5 percent power operation; and third, to identify the technical difficulties and increased costs associated with modifying the structures, systems, and components of the plant should further modifications be required after fuel has been loaded and operation commenced. A recent statement of my professional qualifications and experience is attached hereto as Appendix A.

2. In preparing this affidavit, I have reviewed PG&E's proposed special low power test program as set forth in the low power license application and as further described in PG&E's safety analysis report provided to the NRC Staff on February 6, 1981. I also attended, as a consultant to Governor Brown's counsel, all sessions of the recent low power test proceedings which were held in San Luis Obispo from May 19 to May 22, 1981. Thus, I am familiar with the duration of the low power tests as postulated by PG&E and Staff witnesses. Further, I have reviewed the actual schedule for fuel loading, initial criticality and zero power testing, and low power testing of large pressurized water reactors (PWR's) which have occurred in the post-TMI period, particularly North Anna-2, Salem-2, and Sequoyah-1. In addition, on July 10, 1981, I accompanied NRC Commissioner Gilinsky on his tour of the Diablo Canyon facility. The results of my review are summarized in the following paragraphs.

A. INITIAL CRITICALITY AND DURATION OF LOW POWER TEST PROGRAM

3. During Commissioner Gilinsky's tour of the Diablo Canyon facility, both NRC and PG&E personnel emphasized PG&E's readiness to load fuel. The necessary fuel is presently on site in a building immediately adjacent to the Containment Building. Further, due to the duration of the licensing process, PG&E has had sufficient time to conduct, and in some cases reconduct,

its pre-operational tests as set forth in Section 14.1 of the Final Safety Analysis Report ("FSAR"). Thus, I conclude that Diablo Canyon Unit 1 equipment is in an advanced state of readiness to load fuel, and that virtually all preliminary testing such as that described in the FSAR Table 14.1-1 possible prior to fuel loading has been completed. ^{*/} Further, I conclude that PB&E should be able to promptly load fuel once such authorization is received from the NRC.

4. I estimate that the fuel loading task should be completed in less than one week elapsed time. For example, at Salem-2, a Westinghouse-designed PWR similar in design and rating to Diablo Canyon, fuel loading began on May 23, 1980 and was completed on May 27, 1980. Following fuel loading, the Precritical Test Program of eleven tests, as set forth by PG&E in Table 14.1-2 of the Diablo Canyon FSAR, should require no more than two weeks to complete. Thus, there is no technical reason that initial criticality could not be achieved within two weeks after fuel loading is completed. Therefore, I conclude that it is reasonable to expect that the fuel loading and precritical test program could be completed in no more than 30 days after the issuance of a low power test license. The reactor could be made critical immediately thereafter.

^{*/} A recent Nucleonics Week article indicated that all steps prior to fuel load will be completed by approximately August 12, 1981 (p. 4, July 23, 1981). In general, all pre-operational testing will be completed before fuel loading (FSAR, p. 14.1-8).

5. The next phase of startup and testing includes initial criticality (i.e., commencement of the nuclear reaction) and testing (of the reactor at power levels up to 5 percent of rated capacity). FSAR Table 14.1-2 summarizes the normal tests which will be performed. In addition, the scope and duration of the special low power tests were described in detail during the recent low power proceedings in San Luis Obispo. The Licensing Board, in the Partial Initial Decision dated July 17, 1981, noted at page 24, paragraph 61, that PG&E has proposed a series of eight special low power tests. The proposed tests would probably last for no more than one month and in actuality, as cited by the Board, would perhaps only take about eighteen days (Tr. 10,826-10,728). Other references to the "relatively few days" encompassed by the proposed low power test program are set forth in the recent decision by the Board at page 25 (paragraph 65), page 32 (paragraph 82), and page 33 (paragraph 83). Therefore, I believe that it is reasonable to expect that, absent major problems or absent discretionary delay by PG&E (for instance, to conduct some other tests), initial criticality can be achieved and low power testing can be conducted in an elapsed time of less than 30 days. Thus, assuming a 30-day period for fuel loading and precritical testing, the entire fuel load and testing program can readily be completed in no more than 60 days.

6. The reasonableness of a 60-day cycle from license issuance to completion of the special low power tests was further confirmed during Commissioner Gilinsky's tour of the Diablo Canyon facility. In response to a question, the Diablo Canyon Plant Manager, Robert C. Thornberry, stated in my presence that PG&E's current schedules forecast that fuel loading, zero power testing, and the special low power test program will be completed approximately 58 days after receipt of a low power license. Mr. Thornberry added that the schedule might need to be increased if major unanticipated problems were encountered during the test program.

7. In order to be conservative, I believe it may be appropriate to add 15 to 30 days to the fuel loading and low power testing schedule to allow time for resolution of any routine unanticipated events. Thus, at the outside, I would expect the entire low power program at Diablo Canyon to take no more than 90 days. I understand that the NRC Staff recently indicated that the entire program would be completed in 101 days, which I feel is consistent with the schedule set forth herein. */

8. The post-TMI experience and the current schedules for startup testing lend further support to the preceding conclusions. The first plant granted an operating license in the post-TMI period was Sequoyah-1, which received a low power

*/ See Attachment to Transcript of NRC Commissioner Briefing of August 27, 1981.

license on February 29, 1980. Fuel loading commenced on March 2, 1980 and was completed on March 8, 1980. Two major problems thereafter seriously delayed the initial criticality of Sequoyah-1. First, in response to I&E Bulletin 79-14, TVA required approximately 60 days to inspect and rework pipe hangers and supports. Second, in parallel with the hanger reinspection, TVA conducted a base line inspection of the turbine blades. The turbine reinspection required 4-5 weeks of elapsed time. Routine maintenance problems and pre-operational testing resulted in further delays. Initial criticality was achieved on July 5, 1980. Following zero power testing, the special low power testing program began on July 12 and was completed on July 18, 1980.

9. The second plant to receive a post-TMI license to load fuel and conduct special low power tests was North Anna-2. The authorization to load fuel was issued on April 11, 1980 and the low power testing was completed by July 1, 1980, an elapsed time of less than 80 days.

10. The Salem-2 low power license was issued on April 18, 1980. As set forth in paragraph 4, fuel loading was completed on May 27, 1980. Initial criticality was achieved on August 2, 1980. The two months delay between fuel loading and initial criticality was largely due to the need to conduct routine pre-operational maintenance testing and surveillance testing (such

as valve operability) which could have been accomplished prior to fuel load. As presented in paragraph 3, I believe that these pre-operational tests will be accomplished at Diablo Canyon prior to fuel loading. Thus, I conclude that the actual duration of the Salem-2, North Anna-2, and Sequoyah-1 fuel loading and low power testing programs is not inconsistent with my conclusions for Diablo Canyon as set forth herein.

B. FISSION PRODUCT HAZARD

11. There is sufficient evidence in the record of the recent low power test proceeding to show that the consequences of a severe accidental release during low power operation would be serious. The basis for my views are as follows: First, Table I of the testimony of Applicant's witness, Dr. Brunot, sets forth the fission product inventories which will be produced in the core during the proposed Diablo Canyon LPTP. The inventory of iodine-131, one of the radionuclides which is a significant contributor to the dominant exposure modes for accidents requiring off-site emergency preparedness, is estimated by Dr. Brunot as 4,500,000 curies (approximately 1/20th the full power value as set forth in FSAR Table 11.1-4). In contrast, for the design basis LOCA addressed by the Applicant in the FSAR, only 192 curies of iodine-131 were postulated to be released to the environment in the first two hours. The corresponding two-hour thyroid doses cited in the FSAR are as follows:

<u>Nuclide</u>	Activity Released*/ (Curies)	Thyroid Doses (Rem)**/ <u>800</u> <u>10,000</u> (Meters) (Meters)	
I-131	27.0	7.3	0.3
I-131 ORG	73.4	19.9	0.8
I-131 PAR	91.8	24.9	1.0
TOTALS:	192.2	52.1	2.1

12. Furthermore, in the Diablo Canyon Emergency Plan***/
the Applicant has calculated that if the equivalent of 1000
curies of iodine-131 were to be released during a "Site Emergency"
class****/
accident, and assuming the design basis meteorological
conditions, then the thyroid dose at the plume centerline would
be as follows:

<u>Nuclide</u>	Activity Released (Curies)	Thyroid Doses (Rem) <u>800</u> <u>10,000</u> (Meters) (Meters)	
I-131	1000	270	12

The preceding relationships between releases and exposures are
all based on numbers in the record in the low power proceeding.
By observation, it can be inferred that the thyroid doses can

*/ FSAR Table 15.5-12 (attached hereto as Appendix B).
 **/ FSAR Table 15.5-14 (attached hereto as Appendix C).
 ***/ Emergency Plan, p. 4-5 (attached hereto as Appendix D).
 ****/ The release potential and significance for a larger class
 of accidents, the "General Emergency," were not quantified
 by the Applicant in the Diablo Canyon Emergency Plan.

be scaled approximately linearly with fission product releases. This relationship is not surprising in that Dr. Brunot stated in his testimony that estimated exposure is directly proportional to the core inventory which could contribute to that exposure.^{*/} (We believe he must be assuming a constant release fraction). Brunot further estimated exposure levels by scaling exposures linearly based on the reduced fission product inventories at LP as compared to the FP operation.^{**/} Thus, using the Brunot scaling methodology, and assuming release fractions of 1.0 percent or 0.1 percent, the exposures for an accident during the Diablo Canyon LPTP can reasonably be extrapolated approximately as follows:

<u>Nuclide</u>	Activity Released (Curies)	Thyroid Doses (Rem)	
		<u>800</u> (Meters)	<u>10,000</u> (Meters)
I-131	4,500 (0.1%)	1,221	49
I-131	45,000 (1.0%)	12,211	492

In either of the preceding cases, the potential thyroid exposures appear to be of significant magnitude. Thus, the next question is whether the postulated release fractions are reasonable.

13. The probabilities for nine major PWR release categories (PWR-1 to PWR-9) were developed in the NRC's Reactor Safety Study (WASH-1400).^{***/} The event sequences in PWR-1-7 lead to

^{*/} Brunot Testimony, p. 11.

^{**/} Brunot Testimony, p. 12.

^{***/} The dominant PWR accident sequences from WASH-1400 for each of the release categories are set forth in Appendix E which is attached hereto.

(partial or complete melting of the reactor core while those in the last two categories do not involve melting of the core. These severe accidents can be distinguished from design basis accidents in that they involve deterioration of the capability of the containment structure to perform its intended function of limiting the release of radioactive materials to the environment. In release categories 1 to 3, the event sequences include containment failure by steam explosion, hydrogen burning, or overpressure. In release categories 6 and 7, the dominant containment failure mode is by melt-through of the containment base mat. The other release categories contain event sequences in which the systems intended to isolate the containment fail to act properly. The uncertainties in the absolute values of the probabilities are significant. The error band for the probabilities of some of the event sequences could be as great as a factor of 100 as discussed by Staff witness Lauben in the low power proceeding. The containment releases postulated in WASH-1400 are described in more detail in Appendix F which is attached hereto. It is important to note that the magnitudes (curies) of radioactive releases for each PWR category are obtained by multiplying the release fractions shown in Table VI 2-1 of Appendix F by the amounts of radionuclides that would be present in the core at the time of the hypothetical accident (for Diablo Canyon LP inventory, see Table I of Brunot testimony). For

example, if one started with the iodine-131 inventory of 4.500,000 curies calculated by Brunot and the release fractions set forth by the WASH-1400 authors, the magnitude of the iodine releases for each of the nine PWR accidents, if it occurred during the proposed Diablo Canyon LPTP, would be as follows:

<u>PWR Release Category</u>	<u>Release Fractions</u>	<u>Activity Released (Curies)</u>
1	0.70	3,150,000
2	0.70	3,150,000
3	0.20	900,000
4	0.09	405,000
5	0.03	135,000
6	8×10^{-4}	3,600
7	2×10^{-5}	90
8	1×10^{-4}	450
9	1×10^{-7}	0.45

14. Several conclusions are obvious. First, the 1.0% release fraction postulated herein is exceeded by a factor of 3 to 70 for WASH-1400 release Categories 1 through 5. The 0.1% release is consistent with a Category 6 release occurring during LP operation. Thus, I conclude that the proposed 1.0% and 0.1% release fractions are conservative representations of the potential releases.* / Therefore, because of the relatively rapid buildup (half-life of hours to days) of the radioactive isotopes

* / Indeed, the NRC indicated recently that the possession of as little as 3.3 curies of I-131 constitutes a sufficient amount to be "of potential significant concern in the event of a major accident....." 46 Federal Register 29714 (June 3, 1981). The I-131 inventory after one month of low power operation of Diablo Canyon will be 4.5 million curies, or more than one million times greater than the NRC's recently stated threshold level of concern.

listed in Table 3 of NUREG-0654*/ which dominate prompt health consequences resulting from postulated accidental releases, I conclude that even at 5% power after less than 30 days the fission products available for release pose a significant potential hazard.

C. PLANT CONTAMINATION

15. Operation at low power will not only cause a buildup of fission products within the reactor core, making it inaccessible for contact repair and/or modification, but will also cause a spread of radioactive contaminants throughout the primary portion of the steam supply system. It will also contaminate certain auxiliary systems such as the Chemical and Volume Control System, Equipment and Floor Drainage Systems, and the Liquid Radioactive Waste System. If fuel failures and/or steam generator tube failures or leaks are experienced, a large number of other systems, including the turbine, condensate, and other components within the Steam and Power Conversion System could become contaminated. Contamination and irradiation of such equipment greatly increases the care required and the time and cost of future modifications that could be required at Diablo Canyon. I conclude, therefore, that it is important that power operation, including low power testing, not be permitted until reviews and evaluations that could lead to required plant modifications have been completed.

*/ NUREG-0654, Rev. 1 (FEMA-REP-1), Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants, November, 1980.

D. CONCLUSION


16. Based on the foregoing, I conclude: (a) that fuel loading, initial criticality, and low power testing, including the special low power tests, can be accomplished at Diablo Canyon Unit 1 within approximately 60 days, with an outside maximum elapsed time of approximately 90 days, after issuance of the low power operating license; (b) that it is feasible for fuel loading to be completed within one week after issuance of the low power license; and (c) that the fuel loading and pre-critical testing portion of the startup schedule should be completed within less than 30 days following issuance of the low power license and that immediately thereafter initial criticality could be achieved. Further, I conclude that because of the relatively rapid buildup of the radioactive isotopes which dominate health consequences, even at 5% power the fission products such as iodine-131 available for release pose a significant hazard. Finally, I conclude that operation at low power will contaminate some of the facility's components and systems. This unnecessary commitment of resources creates technical difficulties and increased costs associated with modifying the reactor, should further modification be required after fuel has been loaded and power operation commenced.

I have read the foregoing and swear that it is true and accurate to the best of my knowledge.

Richard B. Hubbard

RICHARD B. HUBBARD

Subscribed and sworn to before me this 9 day of September, 1981.



James F. Lehman

NOTARY PUBLIC

My commission expires 8/21/84

PROFESSIONAL QUALIFICATIONS OF RICHARD B. HUBBARD

RICHARD B. HUBBARD
MHB Technical Associates
1723 Hamilton Avenue
Suite K
San Jose, California 95125
(408) 266-2716

EXPERIENCE:

9/76 - PRESENT

Vice-President - MHB Technical Associates, San Jose, California.
Founder, and Vice-President of technical consulting firm. Specialists in independent energy assessments for government agencies, particularly technical and economic evaluation of nuclear power facilities. Consultant in this capacity to Oklahoma and Illinois Attorney Generals, Minnesota Pollution Control Agency, German Ministry for Research and Technology, Governor of Colorado, Swedish Energy Commission, Swedish Nuclear Inspectorate, and the U.S. Department of Energy. Also provided studies and testimony for various public interest groups including the Center for Law in the Public Interest, Los Angeles; Public Law Utility Group, Baton Rouge, Louisiana; Friends of the Earth (FOE), Italy; and the Union of Concerned Scientists, Cambridge, Massachusetts. Provided testimony to the U.S. Senate/House Joint Committee on Atomic Energy, the U.S. House Committee on Interior and Insular Affairs, the California Assembly, Land Use, and Energy Committee, the Advisory Committee on Reactor Safeguards, and the Atomic Safety and Licensing Board. Performed comprehensive risk analysis of the accident probabilities and consequences at the Barseback Nuclear Plant for the Swedish Energy Commission and edited, as well as contributed to, the Union of Concerned Scientist's technical review of the NRC's Reactor Safety Study (WASH-1400).

2/76 - 9/76

Consultant, Project Survival, Palo Alto, California.
Volunteer work on Nuclear Safeguards Initiative campaigns in California, Oregon, Washington, Arizona, and Colorado. Numerous presentations on nuclear power and alternative energy options to civic, government, and college groups. Also resource person for public service presentations on radio and television.

5/75 - 1/76

Manager - Quality Assurance Section, Nuclear Energy Control and Instrumentation Department, General Electric Company, San Jose, California.

Report to the Department General Manager. Develop and implement quality plans, programs, methods, and equipment which assure that products produced by the Department meet quality requirements as defined in NRC regulation 10 CFR 50, Appendix B, ASME Boiler and Pressure Vessel Code, customer contracts, and GE Corporate policies and procedures. Product areas include radiation sensors, reactor vessel internals, fuel handling and servicing tools, nuclear plant control and protection instrumentation systems, and nuclear steam supply and Balance of Plant control room panels. Responsible for approximately 45 exempt personnel, 22 non-exempt personnel, and 129 hourly personnel with an expense budget of nearly 4 million dollars and equipment investment budget of approximately 1.2 million dollars.

11/71 - 5/75

Manager - Quality Assurance Subsection, Manufacturing Section of Atomic Power Equipment Department, General Electric Company, San Jose, California.

Report to the Manager of Manufacturing. Same functional and product responsibilities as in Engagement #1, except at a lower organizational report level. Developed a quality system which received NRC certification in 1975. The system was also successfully surveyed for ASME "N" and "NPT" symbol authorization in 1972 and 1975, plus ASME "U" and "S" symbol authorizations in 1975. Responsible for from 23 to 39 exempt personnel, 7 to 14 non-exempt personnel, and 53 to 97 hourly personnel.

3/70 - 11/71

Manager - Application Engineering Subsection, Nuclear Instrumentation Department, General Electric Company, San Jose, California. Responsible for the post order technical interface with architect engineers and power plant owners to define and schedule the instrumentation and control systems for the Nuclear Steam Supply and Balance of Plant portion of nuclear power generating stations. Responsibilities included preparation of the plant instrument list with approximate location, review of interface drawings to define functional design requirements, and release of functional requirements for detailed equipment designs. Personnel supervised included 17 engineers and 5 non-exempt personnel.

12/69 - 3/70

Chairman - Equipment Room Task Force, Nuclear Instrumentation Department, General Electric Company, San Jose, California.
Responsible for a special task force reporting to the Department General Manager to define methods to improve the quality and reduce the installation time and cost of nuclear power plant control rooms. Study resulted in the conception of a factory-fabricated control room consisting of signal conditioning and operator control panels mounted on modular floor sections which are completely assembled in the factory and thoroughly tested for proper operation of interacting devices. Personnel supervised included 10 exempt personnel.

12/65 - 12/69

Manager - Proposal Engineering Subsection, Nuclear Instrumentation Department, General Electric Company, San Jose, California.
Responsible for the application of instrumentation systems for nuclear power reactors during the proposal and pre-order period. Responsible for technical review of bid specifications, preparation of technical bid clarifications and exceptions, definition of material list for cost estimating, and the "as sold" review of contracts prior to turnover to Application Engineering. Personnel supervised varied from 2 to 9 engineers.

1/64 - 12/65

Sales Engineer, Nuclear Electronics Business Section of Atomic Power Equipment Department, General Electric Company, San Jose, California.
Responsible for the bid review, contract negotiation, and sale of instrumentation systems and components for nuclear power plants, test reactors, and radiation hot cells. Also responsible for industrial sales of radiation sensing systems for measurement of chemical properties, level, and density.

10/61 - 8/64

Application Engineer, Low Voltage Switchgear Department, General Electric Company, Philadelphia, Pennsylvania.
Responsible for the application and design of advanced diode and silicon-controlled rectifier constant voltage DC power systems and variable voltage DC power systems for industrial applications. Designed, followed manufacturing and personally tested an advanced SCR power supply for product introduction at the Iron and Steel Show. Project Engineer for a DC power system for an aluminum pot line sold to Anaconda beginning at the 161KV switchyard and encompassing all the equipment to convert the power to 700 volts DC at 160,000 amperes.

9/60 - 10/61

GE Rotational Training Program

Four 3-month assignments on the GE Rotational Training Program for college technical graduates as follows:

- a. Installation and Service Eng. - Detroit, Michigan.
Installation and startup testing of the world's largest automated hot strip steel mill.
- b. Tester - Industry Control - Roanoke, Virginia.
Factory testing of control panels for control of steel, paper, pulp, and utility mills and power plants.
- c. Engineer - Light Military Electronics - Johnson City, New York.
Design of ground support equipment for testing the auto pilots on the F-105.
- d. Sales Engineer - Morrison, Illinois.
Sale of appliance controls including range timers and refrigerator cold controls.

EDUCATION:

Bachelor of Science Electrical Engineering, University of Arizona, 1960.

Master of Business Administration, University of Santa Clara, 1969.

PROFESSIONAL AFFILIATION:

Registered Quality Engineer, License No. QU805, State of California.

Member of Subcommittee 8 of the Nuclear Power Engineering Committee of the IEEE Power Engineering Society responsible for the preparation and revision of the following 3 national Q.A. Standards:

- a. IEEE 498 (ANSI N45.2.16): Requirements for the Calibration and Control of Measuring and Test Equipment used in the Construction and Maintenance of Nuclear Power Generating Stations.

PROFESSIONAL AFFILIATION: (Contd)

- b. IEEE 336 (ANSI N45.2.4): Installation, Inspection, and Testing Requirements for Class 1E Instrumentation and Electric Equipment at Nuclear Power Generating Stations.
- c. IEEE 467 : Quality Assurance Program Requirements for the Design and Manufacture of Class 1E Instrumentation and Electric Equipment for Nuclear Power Generating Stations.

I am currently a member of the IEEE Ad Hoc Committee which recommended the issues to be addressed in the development of a standard relating to the selection and utilization of replacement parts for Class 1E equipment during the construction and operation phase. I am also a member of the work group which will prepare this proposed standard.

PERSONAL DATA:

Birth Date: 7/08/37
Married; three children
Health: Excellent

PUBLICATIONS AND TESTIMONY:

- 1. In-Core System Provides Continuous Flux Map of Reactor Cores, R.B. Hubbard and C.E. Foreman, Power, November, 1967.
- 2. Quality Assurance: Providing It, Proving It, R.B. Hubbard, Power, May, 1972.
- 3. Testimony of R.B. Hubbard, D.G. Bridenbaugh, and G.C. Minor before the United States Congress, Joint Committee on Atomic Energy, February 18, 1976, Washington, DC. (Published by the Union of Concerned Scientists, Cambridge, Massachusetts.) Excerpts from testimony published in Quote Without Comment, Chemtech, May, 1976.
- 4. Testimony of R.B. Hubbard, D.G. Bridenbaugh, and G.C. Minor to the California State Assembly Committee on Resources, Land Use, and Energy, Sacramento, California, March 8, 1976.
- 5. Testimony of R. B. Hubbard and G.C. Minor before California State Senate Committee on Public Utilities, Transit, and Energy, Sacramento, California, March 23, 1976.
- 6. Testimony of R.B. Hubbard and G.C. Minor, Judicial Hearings Regarding Grafenrheinfeld Nuclear Plant, March 16 & 17, 1977, Wurzburg, Germany.

PUBLICATIONS AND TESTIMONY: (Contd)

7. Testimony of R.B. Hubbard to United States House of Representatives, Subcommittee on Energy and the Environment, June 30, 1977, Washington, DC, entitled, Effectiveness of NRC Regulations - Modifications to Diablo Canyon Nuclear Units.
8. Testimony of R.B. Hubbard to the Advisory Committee on Reactor Safeguards, August 12, 1977, Washington, DC, entitled, Risk Uncertainty Due to Deficiencies in Diablo Canyon Quality Assurance Program and Failure to Implement Current NRC Practices.
9. The Risks of Nuclear Power Reactors: A Review of the NRC Reactor Safety Study WASH-1400, Kendall, et al, edited by R.B. Hubbard and G.C. Minor for the Union of Concerned Scientists, August, 1977.
10. Swedish Reactor Safety Study: Barsebäck Risk Assessment, MHB Technical Associates, January 1978 (Published by Swedish Department of Industry as Document DSI 1978:1).
11. Testimony of R.B. Hubbard before the Energy Facility Siting Council, March 31, 1978, in the matter of Pebble Springs Nuclear Power Plant, Risk Assessment: Pebble Springs Nuclear Plant, Portland, Oregon.
12. Presentation by R.B. Hubbard before the Federal Ministry for Research and Technology (BMFT), August 31 and September 1, 1978, Meeting on Reactor Safety Research, Risk Analysis, Bonn, Germany.
13. Testimony by R.B. Hubbard, D.G. Bridenbaugh, and G.C. Minor before the Atomic Safety and Licensing Board, September 25, 1978, in the matter of the Black Fox Nuclear Power Station Construction Permit hearings, Tulsa, Oklahoma.
14. Testimony of R.B. Hubbard before the Atomic Safety and Licensing Board, November 17, 1978, in the matter of Diablo Canyon Nuclear Power Plant Operating License Hearings, Operating Basis Earthquake and Seismic Reanalysis of Structures, Systems, and Components, Avila Beach, California.
15. Testimony of R.B. Hubbard and D.G. Bridenbaugh before the Louisiana Public Service Commission, November 19, 1978, Nuclear Plant and Power Generation Costs, Baton Rouge, Louisiana.
16. Testimony of R.B. Hubbard before the California Legislature, Subcommittee on Energy, Los Angeles, April 12, 1979.

PUBLICATIONS AND TESTIMONY: (Contd)

17. Testimony of R.B. Hubbard and G.C. Minor before the Federal Trade Commission, on behalf of the Union of Concerned Scientists, Standards and Certification Proposed Rule 16 CFR Part 457, May 18, 1979.
18. ALO-62, Improving the Safety of LWR Power Plants, MHB Technical Associates, prepared for U.S. Department of Energy, Sandia National Laboratories, September, 1979, available from NTIS.
19. Testimony by R.B. Hubbard before the Arizona State Legislature, Special Interim House Committee on Atomic Energy, Overview of Nuclear Safety, Phoenix, AZ, September 20, 1979.
20. "The Role of the Technical Consultant," Practising Law Institute program on "Nuclear Litigation," New York City and Chicago, November, 1979. Available from PLI, New York City.
21. Uncertainty in Nuclear Risk Assessment Methodology, MHB Technical Associates, January, 1980, prepared for and available from the Swedish Nuclear Power Inspectorate, Stockholm, Sweden.
22. Italian Reactor Safety Study: Caorso Risk Assessment, MHB Technical Associates, March, 1980, prepared for and available from Friends of the Earth, Rome, Italy.
23. Development of Study Plans: Safety Assessment of Monticello and Prairie Island Nuclear Stations, MHB Technical Associates, August, 1980, prepared for and available from the Minnesota Pollution Control Agency.
24. Affidavit of Richard B. Hubbard and Gregory C. Minor before the Illinois Commerce Commission, In the Matter of an Investigation of the Plant Construction Program of the Commonwealth Edison Company, prepared for the League of Woman Voters of Rockford, Illinois, November 12, 1980, ICC Case No. 78-0646.
25. Systems Interaction and Single Failure Criterion, MHB Technical Associates, January, 1981, prepared for and available from the Swedish Nuclear Power Inspectorate, Stockholm, Sweden.

TABLE 15.5-12

CALCULATED ACTIVITY RELEASES FROM LOCA- DESIGN BASIS CASE (CURIES)

NUCLIDE	0-2 Hrs	2-8 Hrs	8-24 Hrs	24-96 Hrs	4-30 Days
I-131	0.2702E 02 0.0	0.0	0.0	0.0	0.0
I-132	0.3915E 02 0.0	0.0	0.0	0.0	0.0
I-133	0.6207E 02 0.0	0.0	0.0	0.0	0.0
I-134	0.7663E 02 0.0	0.0	0.0	0.0	0.0
I-135	0.5712E 02 0.0	0.0	0.0	0.0	0.0
I-131ORG	0.7540E 02 0.2170E 03	0.5561E 03	0.1070E 04	0.3227E 04	
I-132ORG	0.8225E 02 0.8762E 02	0.1862E 02	0.240E-01	0.0557E-10	
I-133ORG	0.1639E 02 0.4314E 03	0.8078E 03	0.5263E 03	0.5383E 02	
I-134ORG	0.9047E 02 0.2469E 02	0.2045E 00	0.2811E-06	0.2665E-31	
I-135ORG	0.1411E 02 0.2838E 03	0.2668E 03	0.3148E 02	0.1034E-01	
I-131PAR	0.9175E 02 0.2713E 03	0.6951E 03	0.1338E 04	0.4033E 04	
I-132PAR	0.1041E 03 0.1095E 03	0.2327E 02	0.1155E 00	0.1070E-09	
I-133PAR	0.2048E 03 0.5392E 03	0.1010E 04	0.6579E 03	0.6728E 02	
I-134PAR	0.1231E 03 0.3086E 02	0.2557E 00	0.3514E-06	0.3331E-31	
I-135PAR	0.1764E 03 0.3548E 03	0.3335E 03	0.3935E 02	0.2293E-01	
KR-83M	0.9280E 03 0.7487E 03	0.8940E 02	0.1154E 00	0.2578E-12	
KR-85	0.6279E 02 0.1913E 03	0.5097E 03	0.1145E 04	0.9827E 04	
KR-85M	0.2823E 04 0.4660E 04	0.2723E 04	0.1141E 03	0.1413E-02	
KR-87	0.3847E 04 0.1864E 04	0.7273E 02	0.5752E-02	0.4530E-19	
KR-88	0.7090E 04 0.8484E 04	0.2388E 04	0.2220E 02	0.3333E-06	
XF-133	0.1664E 05 0.4942E 05	0.1241E 06	0.2205E 06	0.4392E 06	
XE-133M	0.4250E 05 0.1212E 04	0.2819E 04	0.3766E 04	0.2556E 04	
XE-135	0.7402E 04 0.1655E 05	0.2028E 05	0.4316E 04	0.1510E 02	
XE-135M	0.8506E 03 0.4137E 01	0.4690E-06	0.7061E-25	0.0	
XE-138	0.2504E 04 0.6552E 01	0.1164E-06	0.1252E-27	0.0	

(Source: Diablo Canyon FSAR)

APPENDIX B

TABLE 15.5-14

THYROID DOSE - TWO HOUR - CONTAINMENT LEAKAGE - DESIGN BASIS CASE (REM)

DISTANCE FROM RELEASE POINT											
NUCLIDE	000M	1200M	2000M	4000M	7000M	10000M	20000M				
I-131	0.7342E 01	0.4719E 01	0.2555E 01	0.1080E 01	0.4983E 00	0.3053E 00	0.1728E 00				
I-132	0.3913E 00	0.2515E 00	0.1383E 00	0.5755E-01	0.2656E-01	0.1627E-01	0.6547E-02				
I-133	0.4558E 01	0.2929E 01	0.1611E 01	0.6703E 00	0.3093E 00	0.1845E 00	0.7625E-01				
I-134	0.3241E 00	0.2083E 00	0.1146E 00	0.4767E-01	0.2200E-01	0.1248E-01	0.5422E-02				
I-135	0.1300E 01	0.8256E 00	0.4506E 00	0.1912E 00	0.0823E-01	0.5407E-01	0.2175E-01				
I-1310EG	0.1094E 02	0.1282E 02	0.7049E 01	0.2933E 01	0.1353E 01	0.8292E 00	0.2336E 00				
I-132GRG	0.8176E 00	0.5255E 00	0.2890E 00	0.1202E 00	0.5548E-01	0.3400E-01	0.1368E-01				
I-133GRG	0.1203E 02	0.7734E 01	0.4253E 01	0.1770E 01	0.8166E 00	0.5004E 00	0.2013E 00				
I-134GRG	0.4519E 00	0.2904E 00	0.1597E 00	0.6646E-01	0.3067E-01	0.1874E-01	0.7560E-02				
I-135GRG	0.3211E 01	0.2084E 01	0.1135E 01	0.4723E 00	0.2179E 00	0.1336E 00	0.5372E-01				
I-131PAK	0.2492E 02	0.1882E 02	0.8811E 01	0.3666E 01	0.1692E 01	0.1037E 01	0.4170E 00				
I-132PAK	0.1022E 01	0.6508E 00	0.3613E 00	0.1503E 00	0.6936E-01	0.4250E-01	0.1710E-01				
I-133PAK	0.1504E 02	0.9867E 01	0.5317E 01	0.2212E 01	0.1021E 01	0.6255E 00	0.2516E 00				
I-134PAK	0.5648E 00	0.2630E 00	0.1497E 00	0.6307E-01	0.2833E-01	0.2349E-01	0.9450E-02				
I-135PAK	0.4014E 01	0.2580E 01	0.1419E 01	0.5804E 00	0.2724E 00	0.1669E 00	0.6715E-01				
TOTAL	0.9593E 02	0.6166E 02	0.3291E 02	0.1411E 02	0.6511E 01	0.3990E 01	0.1605E 01				

(Source: Diablo Canyon FSAR)

APPENDIX C

(Source: Diablo Canyon Emergency Plan)

4.1.3 Site Emergency

4.1.3.1 Description

The Site Emergency action level reflects conditions where there is a clear potential for significant releases, such releases are likely, or they are occurring, but in all cases where a core meltdown situation is not indicated based on current information. Because the possible release associated with a Site Emergency is significant, care must be taken in alerting offsite authorities to distinguish whether the release is merely potential, likely, or actually occurring. Response of offsite authorities will be guided initially by this determination.

4.1.3.2 Release Potential and Significance

The Site Emergency class includes releases up to 1000 Ci of I-131 equivalent and/or up to 10^6 Ci of Xe-133 equivalent.

Assuming design basis meteorological conditions, the maximum Site Emergency release would produce the following doses due to direct exposure to the plume centerline:

DOWNWIND DISTANCE	ASSUMED	WHOLE BODY DOSE FROM Xe-133	THYROID DOSE FROM I-131
(m)	(χ/Q)(sec/m ³)	(mrem)	(rem)
800 (site boundary)	5.3×10^{-4}	6000	270
10000 (edge of LPZ)	2.2×10^{-5}	250	12
16000 (10 mile zone)	1.2×10^{-5}	140	7

As can be seen, such a release occurring with unfavorable meteorological conditions would certainly require that protective measures be taken on the site and in the downwind sectors throughout the plume exposure Emergency Planning Zone. However, even in the case of a maximum release, it is likely that offsite doses would be much lower than those tabulated above due to such factors as more favorable meteorology and the effects of sheltering. The appropriate near term response for such an occurrence is to make an assessment of conditions as they actually exist and take action based on this assessment, as discussed below.

(Source: WASH-1400, Main Report)

TABLE 5-2 PWR DOMINANT ACCIDENT SEQUENCES vs. RELEASE CATEGORIES

	RELEASE CATEGORIES						Core Melt		No Core Melt
	1	2	3	4	5	6	7	8	9
LARGE LOCA A	AB-G 1×10^{-11} AF-G 1×10^{-10} ACD-G 5×10^{-11} AG-G 9×10^{-11}	AB-Y 1×10^{-10} AB-B 4×10^{-11} AHF-Y 2×10^{-11}	AD-G 2×10^{-8} AH-G 1×10^{-8} AF-B 1×10^{-8} AG-B 9×10^{-9}	ACD-B 1×10^{-11}	AD-B 4×10^{-9} AH-B 3×10^{-9}	AB-L 1×10^{-9} AHF-C 1×10^{-10} ADF-C 2×10^{-10}	AD-C 2×10^{-6} AH-C 1×10^{-6}	A-B 2×10^{-7}	A 1×10^{-4}
A Probabilities	2×10^{-9}	1×10^{-8}	1×10^{-7}	1×10^{-8}	4×10^{-8}	3×10^{-7}	3×10^{-6}	1×10^{-5}	1×10^{-4}
SMALL LOCA S ₁	S ₁ B-G 3×10^{-11} S ₁ CD-G 7×10^{-11} S ₁ F-G 1×10^{-10} S ₁ G-G 3×10^{-10}	S ₁ B-Y 4×10^{-10} S ₁ B-B 1×10^{-10} S ₁ HF-Y 6×10^{-11}	S ₁ D-G 3×10^{-8} S ₁ H-G 3×10^{-8} S ₁ F-B 3×10^{-8} S ₁ G-B 3×10^{-8}	S ₁ CD-B 1×10^{-11}	S ₁ H-B 3×10^{-9} S ₁ D-B 1×10^{-9}	S ₁ DF-C 3×10^{-10} S ₁ B-C 1×10^{-9} S ₁ HF-C 4×10^{-10}	S ₁ D-C 3×10^{-6} S ₁ H-C 1×10^{-6}	S ₁ -B 6×10^{-7}	S ₁ 3×10^{-4}
S ₁ Probabilities	3×10^{-9}	2×10^{-8}	2×10^{-7}	3×10^{-8}	8×10^{-8}	6×10^{-7}	6×10^{-6}	3×10^{-5}	3×10^{-4}
SMALL LOCA S ₂	S ₂ B-G 1×10^{-10} S ₂ F-G 1×10^{-9} S ₂ CD-G 2×10^{-10} S ₂ G-G 9×10^{-10} S ₂ C-G 2×10^{-8}	S ₂ B-Y 1×10^{-9} S ₂ HF-Y 2×10^{-10} S ₂ B-B 4×10^{-10}	S ₂ D-G 9×10^{-8} S ₂ H-G 6×10^{-8} S ₂ F-B 1×10^{-7} S ₂ C-B 2×10^{-6} S ₂ G-B 9×10^{-8}	S ₂ DG-B 1×10^{-12}	S ₂ D-B 2×10^{-8} S ₂ H-B 1×10^{-8}	S ₂ B-C 8×10^{-9} S ₂ CD-C 2×10^{-8} S ₂ HF-C 1×10^{-9}	S ₂ D-C 9×10^{-6} S ₂ H-C 6×10^{-6}		
S ₂ Probabilities	1×10^{-7}	3×10^{-7}	3×10^{-6}	3×10^{-7}	3×10^{-7}	2×10^{-6}	2×10^{-5}		
REACTOR VESSEL RUPTURE - R	RC-G 2×10^{-12}	RC-Y 3×10^{-11} RF-B 1×10^{-11} RC-B 1×10^{-12}	R-G 1×10^{-9}				R-C 1×10^{-7}		
R Probabilities	2×10^{-11}	1×10^{-10}	1×10^{-9}	2×10^{-10}	1×10^{-9}	1×10^{-8}	1×10^{-7}		
INTERFACING SYSTEMS LOCA (CHECK VALVE) - V		V 4×10^{-6}							
V Probabilities	4×10^{-7}	4×10^{-6}	4×10^{-7}	4×10^{-8}					
TRANSIENT EVENT - T	THLB'-G 3×10^{-8}	THLB'-Y 7×10^{-7} THLB'-B 2×10^{-6}	THL-G 6×10^{-8} TKQ-G 3×10^{-8} TKMQ-G 1×10^{-8}		THL-B 3×10^{-10} TKQ-B 3×10^{-10}	THLB'-C 6×10^{-7}	THL-C 6×10^{-6} TKQ-C 3×10^{-6} TKMQ-C 1×10^{-6}		
T Probabilities	3×10^{-7}	3×10^{-6}	4×10^{-7}	7×10^{-8}	2×10^{-7}	2×10^{-6}	1×10^{-5}		
(I) SUMMATION OF ALL ACCIDENT SEQUENCES PER RELEASE CATEGORY									
MEDIAN (50% VALUE)	9×10^{-7}	8×10^{-6}	4×10^{-6}	5×10^{-7}	7×10^{-7}	6×10^{-6}	4×10^{-5}	4×10^{-5}	4×10^{-4}
LOWER BOUND (5% VALUE)	9×10^{-8}	8×10^{-7}	6×10^{-7}	9×10^{-8}	2×10^{-7}	2×10^{-6}	1×10^{-5}	4×10^{-6}	4×10^{-5}
UPPER BOUND (95% VALUE)	9×10^{-6}	8×10^{-5}	4×10^{-5}	5×10^{-6}	4×10^{-6}	2×10^{-5}	2×10^{-4}	4×10^{-4}	4×10^{-3}

Notes: The probabilities for each release category for each event tree and the I for all accident sequences are the median values of the dominant accident sequences summed by Monte Carlo simulation plus a 10% contribution from the adjacent release category probability.

KEY TO TABLE 5-2 ON FOLLOWING PAGE

KEY TO PWR ACCIDENT SEQUENCE SYMBOLS

- A - Intermediate to large LOCA.
- B - Failure of electric power to ESFs.
- B' - Failure to recover either onsite or offsite electric power within about 1 to 3 hours following an initiating transient which is a loss of offsite AC power.
- C - Failure of the containment spray injection system.
- D - Failure of the emergency core cooling injection system.
- F - Failure of the containment spray recirculation system.
- G - Failure of the containment heat removal system.
- H - Failure of the emergency core cooling recirculation system.
- K - Failure of the reactor protection system.
- L - Failure of the secondary system steam relief valves and the auxiliary feedwater system.
- M - Failure of the secondary system steam relief valves and the power conversion system.
- Q - Failure of the primary system safety relief valves to reclose after opening.
- R - Massive rupture of the reactor vessel.
- S₁ - A small LOCA with an equivalent diameter of about 2 to 6 inches.
- S₂ - A small LOCA with an equivalent diameter of about 1/2 to 2 inches.
- T - Transient event.
- V - LPIS check valve failure.
- α - Containment rupture due to a reactor vessel steam explosion.
- β - Containment failure resulting from inadequate isolation of containment openings and penetrations.
- γ - Containment failure due to hydrogen burning.
- δ - Containment failure due to overpressure.
- c - Containment vessel melt-through.

KEY TO TABLE 5-

APPENDIX F

(Source: WASH-1400, Appendix VI)

Section 2

Releases from Containment

2.1 GENERAL REMARKS

A large portion of the work of the Reactor Safety Study was expended in determining the probability and magnitude of various radioactive releases. This work is described in detail in the preceding appendices as well as Appendices VII, and VIII. In order to define the various releases that might occur, a series of release categories were identified for the postulated types of containment failure in both BWRs and PWRs. The probability of each release category and the associated magnitude of radioactive releases (as fractions of the initial core radioactivity that might leak from the containment structure) are used as input data to the consequence model.

In addition to probability and release magnitude, the parameters that characterize the various hypothetical accident sequences are time of release, duration of release, warning time for evacuation, height of release, and energy content of the released plume.

The time of release refers to the time interval between the start of the hypothetical accident and the release of radioactive material from the containment building to the atmosphere; it is used to calculate the initial decay of radioactivity. The duration of release is the total time during which radioactive material is emitted into the atmosphere; it is used to account for continuous releases by adjusting for horizontal dispersion due to wind meander. These parameters, time and duration of release, represent the temporal behavior of the release in the dispersion model. They are used to model a "puff" release from the calculations of release versus time presented in Appendix V.

The warning time for evacuation (see section 11.1.1) is the interval between awareness of impending core melt and the release of radioactive material from the containment building. Finally, the height of release and the energy content of the released plume gas affect the manner in which the plume would be dispersed in the atmosphere.

Table VI 2-1 lists the leakage parameters that characterize the PWR and BWR release categories. It should be understood that these categories are composites of numerous event tree sequences with similar characteristics, as discussed in Appendix V.

2.2 ACCIDENT DESCRIPTIONS

To help the reader understand the postulated containment releases, this section presents brief descriptions of the various physical processes that define each release category. For more detailed information on the release categories and the techniques employed to compute the radioactive releases to the atmosphere, the reader is referred to Appendices V, VII, and VIII. The dominant event tree sequences in each release category are discussed in detail in section 4.6 of Appendix V.

PWR 1

This release category can be characterized by a core meltdown followed by a steam explosion on contact of molten fuel with the residual water in the reactor vessel. The containment spray and heat removal systems are also assumed to have failed and, therefore, the containment could be at a pressure above ambient at the time of the steam explosion. It is assumed that the steam explosion would rupture the upper portion of the reactor vessel and breach the containment barrier, with the result that a substantial amount of radioactivity might be released from the containment in a puff over a period of about 10 minutes. Due to the sweeping action of gases generated during containment-vessel meltthrough, the release of radioactive materials would continue at a relatively low rate thereafter. The total release would contain

approximately 70% of the iodines and 40% of the alkali metals present in the core at the time of release.¹ Because the containment would contain hot pressurized gases at the time of failure, a relatively high release rate of sensible energy from the containment could be associated with this category. This category also includes certain potential accident sequences that would involve the occurrence of core melting and a steam explosion after containment rupture due to overpressure. In these sequences, the rate of energy release would be lower, although still relatively high.

PWR 2

This category is associated with the failure of core-cooling systems and core melting concurrent with the failure of containment spray and heat-removal systems. Failure of the containment barrier would occur through overpressure, causing a substantial fraction of the containment atmosphere to be released in a puff over a period of about 30 minutes. Due to the sweeping action of gases generated during containment vessel meltthrough, the release of radioactive material would continue at a relatively low rate thereafter. The total release would contain approximately 70% of the iodines and 50% of the alkali metals present in the core at the time of release. As in PWR release category 1, the high temperature and pressure within containment at the time of containment failure would result in a relatively high release rate of sensible energy from the containment.

PWR 3

This category involves an overpressure failure of the containment due to failure of containment heat removal. Containment failure would occur prior to the commencement of core melting. Core melting then would cause radioactive materials to be released through a ruptured containment barrier. Approximately 20% of the iodines and 20% of the alkali metals present in the core at the time of release would be released to the atmosphere. Most of the release would occur over a period of about 1.5 hours. The release of radioactive material from containment would be caused by the sweeping action of gases generated by the reaction of the molten fuel with concrete. Since these gases would be initially heated by contact with the melt, the rate of sensible energy release to the atmosphere would be moderately high.

PWR 4

This category involves failure of the core-cooling system and the containment spray injection system after a loss-of-coolant accident, together with a concurrent failure of the containment system to properly isolate. This would result in the release of 9% of the iodines and 4% of the alkali metals present in the core at the time of release. Most of the release would occur continuously over a period of 2 to 3 hours. Because the containment recirculation spray and heat-removal systems would operate to remove heat from the containment atmosphere during core melting, a relatively low rate of release of sensible energy would be associated with this category.

PWR 5

This category involves failure of the core cooling systems and is similar to PWR release category 4, except that the containment spray injection system would operate to further reduce the quantity of airborne radioactive material and to initially suppress containment temperature and pressure. The containment barrier would have a large leakage rate due to a concurrent failure of the containment system to properly isolate, and most of the radioactive material would be released continuously over a period of several hours. Approximately 3% of the iodines and 0.9% of the alkali metals present in the core would be released. Because of the operation of the containment heat-removal systems, the energy release rate would be low.

¹The release fractions of all the chemical species are listed in Table VI 2-1. The release fractions of iodine and alkali metals are indicated here to illustrate the variations in release with release category.

PWR 6

This category involves a core meltdown due to failure in the core cooling systems. The containment sprays would not operate, but the containment barrier would retain its integrity until the molten core proceeded to melt through the concrete containment base mat. The radioactive materials would be released into the ground, with some leakage to the atmosphere occurring upward through the ground. Direct leakage to the atmosphere would also occur at a low rate prior to containment-vessel meltthrough. Most of the release would occur continuously over a period of about 10 hours. The release would include approximately 0.08% of the iodines and alkali metals present in the core at the time of release. Because leakage from containment to the atmosphere would be low and gases escaping through the ground would be cooled by contact with the soil, the energy release rate would be very low.

PWR 7

This category is similar to PWR release category 6, except that containment sprays would operate to reduce the containment temperature and pressure as well as the amount of airborne radioactivity. The release would involve 0.002% of the iodines and 0.001% of the alkali metals present in the core at the time of release. Most of the release would occur over a period of 10 hours. As in PWR release category 6, the energy release rate would be very low.

PWR 8

This category approximates a PWR design basis accident (large pipe break), except that the containment would fail to isolate properly on demand. The other engineered safeguards are assumed to function properly. The core would not melt. The release would involve approximately 0.01% of the iodines and 0.05% of the alkali metals. Most of the release would occur in the 0.5-hour period during which containment pressure would be above ambient. Because containment sprays would operate and core melting would not occur, the energy release rate would also be low.

PWR 9

This category approximates a PWR design basis accident (large pipe break), in which only the activity initially contained within the gap between the fuel pellet and cladding would be released into the containment. The core would not melt. It is assumed that the minimum required engineered safeguards would function satisfactorily to remove heat from the core and containment. The release would occur over the 0.5-hour period during which the containment pressure would be above ambient. Approximately 0.00001% of the iodines and 0.00006% of the alkali metals would be released. As in PWR release category 8, the energy release rate would be very low.

BWR 1

This release category is representative of a core meltdown followed by a steam explosion in the reactor vessel. The latter would cause the release of a substantial quantity of radioactive material to the atmosphere. The total release would contain approximately 40% of the iodines and alkali metals present in the core at the time of containment failure. Most of the release would occur over a 1/2 hour period. Because of the energy generated in the steam explosion, this category would be characterized by a relatively high rate of energy release to the atmosphere. This category also includes certain sequences that involve overpressure failure of the containment prior to the occurrence of core melting and a steam explosion. In these sequences, the rate of energy release would be somewhat smaller than for those discussed above, although it would still be relatively high.

This release category is representative of a core meltdown resulting from a transient event in which decay-heat-removal systems are assumed to fail. Containment overpressure failure would result, and core melting would follow. Most of the release would occur over a period of about 3 hours. The containment failure would be such that radioactivity would be released directly to the atmosphere without significant retention of fission products. This category involves a relatively high rate of energy release due to the sweeping action of the gases generated by the molten mass. Approximately 90% of the iodines and 50% of the alkali metals present in the core would be released to the atmosphere.

BWR 3

This release category represents a core meltdown caused by a transient event accompanied by a failure to scram or failure to remove decay heat. Containment failure would occur either before core melt or as a result of gases generated during the interaction of the molten fuel with concrete after reactor-vessel meltthrough. Some fission-product retention would occur either in the suppression pool or the reactor building prior to release to the atmosphere. Most of the release would occur over a period of about 3 hours and would involve 10% of the iodines and 10% of the alkali metals. For those sequences in which the containment would fail due to overpressure after core melt, the rate of energy release to the atmosphere would be relatively high. For those sequences in which overpressure failure would occur before core melt, the energy release rate would be somewhat smaller, although still moderately high.

BWR 4

This release category is representative of a core meltdown with enough containment leakage to the reactor building to prevent containment failure by overpressure. The quantity of radioactivity released to the atmosphere would be significantly reduced by normal ventilation paths in the reactor building and potential mitigation by the secondary containment filter systems. Condensation in the containment and the action of the standby gas treatment system on the releases would also lead to a low rate of energy release. The radioactive material would be released from the reactor building or the stack at an elevated level. Most of the release would occur over a 2-hour period and would involve approximately 0.08% of the iodines and 0.5% of the alkali metals.

BWR 5

This category approximates a BWR design basis accident (large pipe break) in which only the activity initially contained within the gap between the fuel pellet and cladding would be released into containment. The core would not melt, and containment leakage would be small. It is assumed that the minimum required engineered safeguards would function satisfactorily. The release would be filtered and pass through the elevated stack. It would occur over a period of about 5 hours while the containment is pressurized above ambient and would involve approximately 6×10^{-9} % of the iodines and 4×10^{-7} % of the alkali metals. Since core melt would not occur and containment heat-removal systems would operate, the release to the atmosphere would involve a negligibly small amount of thermal energy.

TABLE VI 2-1 SUMMARY OF RELEASE CATEGORIES REPRESENTING HYPOTHETICAL ACCIDENTS

Release Category	Probability (reactor-yr ⁻¹)	Time of Release (hr)	Duration of Release (hr)	Warning Time for Evacuation (hr)	Elevation of Release (meters)	Energy Release (10 ⁶ Btu/hr)	Fraction of Core Inventory Released (a)							
							Xe-Kr	Organic I (b)	I (b)	Ce-Rb	Te-Sb	Ba-Sr	Ru (c)	La (d)
PWR 1	9 × 10 ⁻⁷ (e)	2.5	0.5	1.0	25	20 and 520 (e)	0.9	6 × 10 ⁻³	0.7	0.4	0.4	0.05	0.4	3 × 10 ⁻³
PWR 2	8 × 10 ⁻⁶	2.5	0.5	1.0	0	170	0.9	7 × 10 ⁻³	0.7	0.5	0.3	0.06	0.02	4 × 10 ⁻³
PWR 3	4 × 10 ⁻⁶	5.0	1.5	2.0	0	6	0.8	6 × 10 ⁻³	0.2	0.2	0.3	0.02	0.03	3 × 10 ⁻³
PWR 4	5 × 10 ⁻⁷	2.0	3.0	2.0	0	1	0.6	2 × 10 ⁻³	0.09	0.04	0.03	5 × 10 ⁻³	3 × 10 ⁻³	4 × 10 ⁻⁴
PWR 5	2 × 10 ⁻⁷	2.0	4.0	1.0	0	0.3	0.3	2 × 10 ⁻³	0.03	9 × 10 ⁻³	5 × 10 ⁻³	1 × 10 ⁻³	6 × 10 ⁻⁴	7 × 10 ⁻⁵
PWR 6	4 × 10 ⁻⁶	12.0	10.0	1.0	0	N/A	0.5	2 × 10 ⁻³	8 × 10 ⁻⁴	8 × 10 ⁻⁴	1 × 10 ⁻³	9 × 10 ⁻⁵	7 × 10 ⁻⁵	1 × 10 ⁻⁵
PWR 7	4 × 10 ⁻⁵	10.0	10.0	1.0	0	N/A	6 × 10 ⁻³	2 × 10 ⁻⁵	2 × 10 ⁻⁵	1 × 10 ⁻⁵	2 × 10 ⁻⁵	1 × 10 ⁻⁶	1 × 10 ⁻⁶	2 × 10 ⁻⁷
PWR 8	4 × 10 ⁻⁵	0.5	0.5	N/A (f)	0	N/A	2 × 10 ⁻³	5 × 10 ⁻⁶	1 × 10 ⁻⁴	5 × 10 ⁻⁴	1 × 10 ⁻⁶	1 × 10 ⁻⁸	0	0
PWR 9	4 × 10 ⁻⁴	0.5	0.5	N/A	0	N/A	3 × 10 ⁻⁶	7 × 10 ⁻⁹	1 × 10 ⁻⁷	6 × 10 ⁻⁷	1 × 10 ⁻⁹	1 × 10 ⁻¹¹	0	0
BWR 1	1 × 10 ⁻⁶	2.0	0.5	1.5	25	130	1.0	7 × 10 ⁻³	0.40	0.40	0.70	0.05	0.5	5 × 10 ⁻³
BWR 2	6 × 10 ⁻⁶	30.0	3.0	2.0	0	30	1.0	7 × 10 ⁻³	0.90	0.50	0.30	0.10	0.03	4 × 10 ⁻³
BWR 3	2 × 10 ⁻⁵	30.0	3.0	2.0	25	20	1.0	7 × 10 ⁻³	0.10	0.10	0.30	0.01	0.02	4 × 10 ⁻³
BWR 4	2 × 10 ⁻⁶	5.0	2.0	2.0	25	N/A	0.6	7 × 10 ⁻⁴	8 × 10 ⁻⁴	5 × 10 ⁻³	4 × 10 ⁻³	6 × 10 ⁻⁴	6 × 10 ⁻⁴	1 × 10 ⁻⁴
BWR 5	1 × 10 ⁻⁴	3.5	5.0	N/A	150	N/A	5 × 10 ⁻⁶	2 × 10 ⁻⁹	6 × 10 ⁻¹¹	4 × 10 ⁻⁹	8 × 10 ⁻¹²	8 × 10 ⁻¹⁴	0	0

(a) Background on the isotope groups and release mechanisms is presented in Appendix VII.

(b) Organic iodine is combined with elemental iodines in the calculations. Any error is negligible since its release fraction is relatively small for all large release categories.

(c) Includes Ba, Pb, Co, Mo, Tc.

(d) Includes W, La, Er, Nd, Ce, Pr, Hf, Np, Pu, Am, Cm.

(e) Accident sequences within PWR 1 category have two distinct energy releases that affect consequences. PWR 1 category is subdivided into PWR 1A with a probability of 4 × 10⁻⁷ per reactor-year and 20 × 10⁶ Btu/hr and PWR 1B with a probability of 5 × 10⁻⁷ per reactor-year and 520 × 10⁶ Btu/hr.

(f) Not applicable.

(g) A 10 meter elevation is used in place of zero representing the mid-point of a potential containment break. Any impact on the results would be slight and conservative.

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
BEFORE THE ATOMIC SAFETY AND LICENSING APPEAL BOARD

In the Matter of)	
)	
PACIFIC GAS AND ELECTRIC COMPANY)	Docket Nos. 50-275 O.L.
)	50-323 O.L.
(Diablo Canyon Nuclear Power)	
Plant, Units 1 and 2))	
)	
)	

CERTIFICATE OF SERVICE

I hereby certify that on this 31st day of October, 1983, I have served copies of the foregoing JOINT INTERVENORS' APPLICATION FOR A STAY mailing them through the U.S. mails, first class, postage prepaid.

**Thomas S. Moore, Chairman
Atomic Safety & Licensing
Appeal Board
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Mr. Fredrick Eissler
Scenic Shoreline Preservation
Conference, Inc.
4623 More Mesa Drive
Santa Barbara, CA 93105

**Dr. W. Reed Johnson
Atomic Safety & Licensing
Appeal Board
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

**Malcolm H. Furbush, Esq.
Vice President & General
Counsel
Philip A. Crane, Esq.
Pacific Gas & Electric Company
77 Beale Street, Room 3135
San Francisco, CA 94106

**Dr. John H. Buck
Atomic Safety & Licensing
Appeal Board
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

*Nunzio Palladino,
Chairman
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

*Victor Gilinsky,
Commissioner
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

*Thomas Roberts,
Commissioner
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

Mr. Harold Denton
Director of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

*Herzel Plaine, Esq.
Office of General Counsel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

*Docket and Service Branch
Office of the Secretary
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

**Lawrence Chandler, Esq.
Office of the Executive Legal Director - BETH 042
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Janice E. Kerr, Esq.
Lawrence Q. Garcia, Esq.
J. Calvin Simpson, Esq.
California Public Utilities Commission
5246 McAllister Street
San Francisco, CA 94102

**John Van de Kamp, Attorney General
Andrea Sheridan Ordin, Chief Attorney General
Michael J. Strumwasser, Special Counsel to the
Attorney General
State of California
3580 Wilshire Boulevard, Suite 800
Los Angeles, CA 90010

*James Asselstine,
Commissioner
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

*Frederick Bernthal,
Commissioner
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

*Samuel J. Chilk,
Secretary
U.S. Nuclear Regulatory
Commission
Washington, D.C. 20555

David S. Fleischaker, Esq.
Post Office Box 1178
Oklahoma City, OK 73101

Richard Hubbard
MHB Technical Associates
1723 Hamilton Avenue, Suite K
San Jose, CA 95725

Arthur C. Gehr, Esq.
Snell & Wilmer
3100 Valley Center
Phoenix, AZ 85073

**Bruce Norton, Esq.
Norton, Burke, Berry & French, P.C.
2002 E. Osborn
Phoenix, AZ 89016

**Maurice Axelrad, Esq.
Lowenstein, Newman, Reis & Axelrad, P.C.
1025 Connecticut Avenue, N.W.
Washington, D.C. 20036

Virginia and Gordon Bruno
Pecho Ranch
Post Office Box 6289
Los Osos, CA 93402

Sandra and Gordon Silver
1760 Alisal Street
San Luis Obispo, CA 93401

Nancy Culver
192 Luneta
San Luis Obispo, CA 93402

Carl Neiburger
Telegram Tribune
Post Office Box 112
San Luis Obispo, CA 93402

Betsy Umhoffer
1493 Southwood
San Luis Obispo, CA 93401


CHRISTINA CONCEPCION

* Delivered via Express Mail

**Delivered by Hand at Design Hearings in Avila Beach, CA