



**CENTERIOR
ENERGY**

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
PO. BOX 97
PERRY, OHIO 44081

Robert A. Stratman
VICE PRESIDENT - NUCLEAR

December 15, 1994
PY-CEI/NRR-1894L

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Perry Nuclear Power Plant
Docket No. 50-440
Monthly Operating Report

Gentlemen:

Attached is the November 1994 Monthly Operating Report for Perry Unit 1.
This report is submitted in accordance with Technical Specification
6.9.1.8.

If you have questions or require additional information, please contact
Mr. James D. Kloosterman, Manager - Regulatory Affairs at (216) 280-5833.

Very truly yours,

LKR:sc

Attachment

cc: NRC Project Manager
NRC Resident Inspector Office
NRC Region III
Director, Office of Resource Management

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

6 9412210038 941130
PDR ADOCK 05000440
R PDR

JE24

CLEVELAND ELECTRIC ILLUMINATING COMPANY

PERRY NUCLEAR POWER PLANT

November 1, 1994 - November 30, 1994

MONTHLY OPERATING REPORT TO NRC

DOCKET NUMBER : 50-440

LICENSE NUMBER: NPF-58

Table of Contents

Average Daily Unit Power Level 1
Operating Data Report 2
Unit Shutdowns and Power Reductions 3

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-440
 UNIT PERRY ONE
 DATE 12/15/94
 CONTACT G. M. NEUMAN
 TELEPHONE (216)280-5815

MONTH NOVEMBER 1994

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
1	1184
2	1186
3	1180
4	1170
5	1175
6	1177
7	1189
8	1181
9	1184
10	1191
11	1193
12	1188
13	1180
14	1176
15	1187
16	1190

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
17	1187
18	1182
19	1189
20	1187
21	1182
22	1191
23	1192
24	1192
25	1188
26	1193
27	1187
28	1183
29	1189
30	1191
31	N/A

OPERATING DATA REPORT

UNIT: PERRY ONE
 DATE: 12/15/94

OPERATING STATUS

1. Docket: 50-440
2. Reporting Period: NOVEMBER 1994
3. Utility Contact: G.M.NEUMAN
4. Licensed Thermal Power (MWt): 3579
5. Nameplate Rating (Gross MWe): 1250
6. Design Electrical Rating (net MWe): 1191
7. Maximum Dependable Capacity (Gross MWe): 1225
8. Maximum Dependable Capacity (Net MWe): 1166
9. If Changes Occur in Capacity Ratings (Item Numbers 4 through 8) Since Last Report, Give Reasons:
NONE
10. Power Level to Which Restricted, IF any (Net MWe): 100%
11. Reasons for Restrictions, IF Any: OPERATING LICENSE

	This Month	Yr-to-Date	Cumulative
12. Hours In Reporting Period	720.0	8,016.0	61,668.0
13. Hours Reactor was Critical	720.0	3,655.0	41,186.4
14. Reactor reserve Shutdown Hours	0	0.0	0.0
15. Hours Generator On-Line	720.0	3,408.4	39,544.0
16. Unit Reserve Shutdown Hours	0	0.0	0.0
17. Gross thermal Energy (MWH)	2,575,771	11,829,276	134,710,036
18. Gross Electrical Energy (MWH)	891,896	4,046,772	46,271,764
19. Net Electrical Energy (MWH)	853,517	3,849,567	43,942,496
20. Unit Service Factor	100.0%	42.5%	64.1%
21. Unit Availability Factor	100.0%	42.5%	64.1%
22. Unit Capacity Factor (using MDC Net)	101.7%	41.2%	61.7%
23. Unit Capacity Factor (Using DER Net)	99.5%	40.3%	59.8%
24. Unit Forced Outage Rate	0.0%	1.6%	11.6%
25. Forced Outage Hours	0	56.2	5,195.0
26. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): <u>NONE</u>			
27. If Shutdown at end of Report Period, Estimated Date of Startup: <u>N/A</u>			

UNIT SHUTDOWNS AND POWER REDUCTIONS
REPORT MONTH NOVEMBER 1994

DOCKET NO. 50-440
UNIT NAME PERRY ONE
DATE 12/15/94
CONTACT G.M. NEUMAN
TELEPHONE (216)280-5815

NO.	DATE	TYPE 1	DURATION HOURS	REASON 2	METHOD 3	LER #	SYSTEM 4	COMP. 5	CAUSE & CORRECTIVE ACTION TO PREVENT RECURRENCE

SUMMARY: PERRY UNIT ONE REMAINED ON LINE THROUGH THE MONTH OF NOVEMBER 1994.

1. F: FORCED
S: SCHEDULED

2. REASON:
A-EQUIPMENT FAILURE (EXPLAIN)
B-MAINTENANCE OR TEST
C-REFUELING
D-REGULATORY RESTRICTION
E-OPERATOR TRAINING &
LICENSE EXAMINATION
F-ADMINISTRATIVE
G-OPERATIONAL ERROR (EXPLAIN)
H-OTHER (EXPLAIN)

3. METHOD
1-MANUAL
2-MANUAL SCRAM
3-AUTOMATIC SCRAM
4-CONTINUED
5-REDUCED LOAD
9-OTHER

4. EXHIBIT G- INSTRUCTIONS
FOR PREPARATION OF DATA
ENTRY SHEETS FOR LICENSEE
EVENT REPORT (LER) FILE
(NUREG 1022)
5. EXHIBIT 1-SAME SOURCE