



*Southern California Edison Company*

SAN ONOFRE NUCLEAR GENERATING STATION  
P. O. BOX 128  
SAN CLEMENTE, CALIFORNIA 92672

November 3, 1983

RECEIVED  
NRC  
SCE  
1983 NOV -7 PM 12:51  
REGION V IRE

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket No. 50-362  
30-Day Report  
Licensee Event Report No. 83-085  
San Onofre Nuclear Generating Station, Unit 3

Pursuant to Section 6.9.1.13.b of Appendix A, Technical Specifications to Facility Operating License NPF-15 for San Onofre Unit 3, this submittal provides the required 30-day written report and a copy of the Licensee Event Report (LER) form for an occurrence involving Limiting Condition for Operation (LCO) 3.3.4 associated with the Turbine Overspeed Protection.

On October 7, 1983, at 1955, with Unit 3 in Mode 1 at 20% power, the Low Pressure Turbine No. 1, Intercept Valve 3UV2200L, failed the Trip Solenoid A and Trip Solenoid B tests during the Monthly Turbine Overspeed Valve Operability Test, SO23-3-3.34. Intercept Valve 3UV2200L was declared inoperable and, at 1959, in accordance with LCO 3.3.4, Action Statement 'a', Low Pressure Turbine No. 1, Stop Valve 3UV2200M, was closed isolating the turbine from the affected steam lead.

The inoperability of Intercept Valve 3UV2200L was due to a failed logic card in the control circuit. On October 9, 1983, at 0215, after replacing the failed logic card for Intercept Valve 3UV2200L and, in accordance with surveillance procedure SO23-3-3.34, Intercept Valve 3UV2200L was returned to service.

1/1 DE 22

Mr. J. B. Martin


-2-

November 3, 1983

This is considered an isolated occurrence and no further corrective action is planned. There was no impact on the health and safety of plant personnel or the public associated with this event.

If you require any additional information, please so advise.

Sincerely,



J. G. HAYNES  
STATION MANAGER

Enclosure: LER No. 83-085

cc: A. E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)  
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement

U. S. Nuclear Regulatory Commission  
Division of Technical Information and Document Control

Institute of Nuclear Power Operations (INPO)