

Westinghouse Proprietary Class 3

RESPONSE TO NUCLEAR REGULATORY STAFF
REQUEST FOR ADDITIONAL INFORMATION ON
VIPRE/WRB-2 DNBR THERMAL LIMIT FOR
WESTINGHOUSE 17X17 OFA AND VANTAGE 5 FUEL


Document Number NFSR-0090 RAI Response #1

Lawrence K. Klasmier
Hak-Soo Kim


Nuclear Fuel Services Department
Commonwealth Edison Company
Chicago, Illinois

Prepared by: 

Date: 11/15/94

Reviewed by: 
Tracy A. Couteright
F-Official Check Only

Date: 11/15/94
11/15/94

Approved by: 

Date: 11/15/94
(Date Issued)

Statement of Disclaimer

This document was prepared by the Nuclear Fuel Services Department and is being made available to others upon the express understanding that neither Commonwealth Edison Company nor any of its officers, directors, agents, or employees makes any warranty or representation or assumes any obligation, responsibility or liability with respect to the contents of this document or its accuracy or completeness pertaining to any usage other than the originally stated purpose.

Proprietary Statement

This document contains proprietary information of Westinghouse Electric Corporation and is furnished in confidence solely for the purpose or purposes stated. No other use, direct or indirect, of the document or the information it contains is authorized. The recipient shall not publish or otherwise disclose this document or information therein to others without prior written consent of the Commonwealth Edison Company, and shall return the document at the request of the Commonwealth Edison Company.

Table of Contents

Question on VAN FAGE 5H DNBR Penalty	1
Question 1	2
Question 2	3
Question 3	6
Question 4	8
Question 5	9
Question 6	11
Question 7	13
Question 8	14
Question 9	15
Question 10	16
References	17
Appendix A - Owen's Method Reference	18
Appendix B - Tong F-Factor Values for Non-Uniform Test Cases	27
Test Section A-2	28
Test Section A-3	29
Test Section A-4	30
Test Section A-5	31
Test Section A-8	32
Test Section A-9	33
Appendix C - CHF Summary Output File Listings	34
Test Section A-2	35
Test Section A-3	37
Test Section A-4	38
Test Section A-5	40
Test Section A-6	41
Test Section A-7	43
Test Section A-8	45
Test Section A-9	47
Test Section A-10	49
Test Section A-11	51
Test Section A-12	53

List of Tables

Table 1: Test Bundle Geometrical Data References 12

List of Figures

Figure 1: Measured-to-Predicted Critical Heat Flux vs. Local Mass Flux	9
Figure 2: Measured-to-Predicted Critical Heat Flux vs. Local Quality.....	10
Figure 3: Measured-to-Predicted Critical Heat Flux vs. Pressure	10
Figure 4: VIPRE Radial Nodalization	15
Figure 5: Measured-to-Predicted Critical Heat Flux Data	16

Question on VANTAGE 5H DNBR Penalty

On June 27, 1994, Westinghouse informed the NRC that design corrective measures to resolve flow induced vibration problems for 17x17 VANTAGE 5H fuel with intermediate flow mixing grids resulted in reduced DNBR margin. Do you intend that your methodology be applicable for this design? If so, please address how the appropriate penalty is to be determined and the magnitude of the penalty to be imposed.

Response:

The Byron and Braidwood plants do not use 17x17 VANTAGE 5H fuel, nor does ComEd plan to use this fuel type. Therefore, the penalty associated with these design corrective measures does not apply to ComEd.

Question 1

(Page 4) A range of validity for the DNB correlation is given on this page. Please explain how your methodology assures that the correlation will not be used outside of the acceptable range.

Response

ComEd's procedures that govern generation and review of controlled work require verification that any assumptions, applicable correlation limits, etc. are applied correctly. This includes verification that the parameters used by correlations are within the ranges of applicability for the correlations.

Question 2

(Page 19) Please provide copies of the sections of Reference 1 ("Factors for One-Sided Tolerance Limits and for Variables Sampling Plans," SCR 607, D. B. Owen) which describe the basis for your statistical approach.

Response

Provided as **Appendix A** is Section 1.1 "One-sided tolerance limits for a normal distribution" and Table 2.4, Values of k for $f=n-1$ and $\gamma=.95$ from Reference 1. Section 1.1 provides a brief description of Owen's method used to calculate the VIPRE/WRB-2 thermal limit. Table 2.4 was used to determine K_p based on a 95/95 confidence level and the calculated degrees of freedom. Pages 9 and 10 of Reference 2, provide equations for calculating the mean, standard deviation, degrees of freedom, and thermal limit. The following provides more details on the VIPRE/WRB-2 thermal limit calculation:

$$TL = \frac{1}{\left(\frac{M}{P}\right)_{avg} - K_p S}$$

where,

$$\left(\frac{M}{P}\right)_{avg} = \frac{1}{J} \left[\sum_{j=1}^J \left(\frac{M}{P}\right)_{avg,j} \right]$$

$$\left(\frac{M}{P}\right)_{avg,j} = \frac{1}{N_j} \left[\sum_{i=1}^{N_j} \left(\frac{M}{P}\right)_{i,j} \right]$$

J = The total number of Test Series (11)

N_j = The number of tests in Test Series j

From Table 2 on Page 11 of Reference 2

$$\left(\frac{M}{P}\right)_{avg} = \frac{1}{11} [0.9791 + \dots + 0.9974] = 1.0040$$

$$S = \sqrt{SW^2 + SA^2}$$

where SW^2 = Variance within a group
 SA^2 = Variance between groups

The NRC recommended formulas for SA^2 and SW^2 are (Reference 3 and Westinghouse's Follow up Response to additional information Request #1 of Reference 4);

$$SA^2 = \frac{SSA}{FA}$$

$$SW^2 = \frac{SSW}{FW}$$

where

$$SSA = \sum_{j=1}^J \left[\left(\frac{M}{P} \right)_{avg,j} - \left(\frac{M}{P} \right)_{avg} \right]^2$$

$$SSW = \sum_{j=1}^J \sum_{i=1}^{N_j} \left[\left(\frac{M}{P} \right)_{i,j} - \left(\frac{M}{P} \right)_{avg,j} \right]^2 = \sum (N_j - 1) S_j^2$$

S_j = Standard Deviation of Test j

FA = $J - 1$

FW = $N - J$

N = Total number of tests (684)

From Table 2 on Page 11 of our Topical Report (Reference 4)

$$SSA = (0.9791 - 10040)^2 + \dots + (0.9974 - 10040)^2 = 0.00425 \text{ and,}$$

$$SSW = (51 - 1) 0.0713^2 + \dots + (73 - 1) 0.0812^2 = 4.39$$

Therefore

$$SA^2 = \frac{0.00425}{(11 - 1)} = 0.000425 \text{ and,}$$

$$SW^2 = \frac{4.39}{(684 - 11)} = 0.00653$$

$$S = \sqrt{0.000425 + 0.00653} = 0.0834$$

The Degrees of Freedom (F) is defined as:

$$F = \frac{(SW^2 + SA^2)^2}{\left(\frac{SW^4}{FW} + \frac{SA^4}{FA}\right)} = 594$$

From Table 2.4¹ of Reference 1

$$K_p = 1.753$$

Therefore the WRB-2 Thermal Limit is

$$TL = \frac{1}{10040 - 1753(0.0834)} = 11658 \therefore \text{Thermal Limit of 1.17 is used}$$

¹ Note this table is also included in **Appendix A** of this document.

Question 3

(Page 3) It is stated that the standard Tong F-factor is applied to account for non-uniform axial power profiles. Please give the exact form of this equation used defining each of the terms. Also, explain how each input parameter is obtained for both analysis of test data and in the application of your methodology for licensing analysis.

Response

The exact form of the Tong F-factor equation is (Reference 5);

$$F_c = \frac{C}{q_{\text{crit,NU}}(1 - e^{-Cl_{\text{crit}}})} \int_0^{l_{\text{crit}}} q''(z) e^{-C(l_{\text{crit}} - z)} dz$$

where F_c is used in the relation:

$$q_{\text{crit,NU}} = \frac{q_{\text{crit,EU}}}{F_c}$$

and C is empirically determined as

$$C = 0.15 \frac{(1 - \chi_{\text{crit}})^{4.31}}{(G / 10^6)^{0.478}} \text{ (in}^{-1}\text{)}$$

Variable Definitions

- χ_{crit} = Quality at critical heat flux location
- l_{crit} = Axial location of critical heat flux (in)
- $q''(z)$ = Heat flux at axial location z (BTU/hr-ft²)
- $q_{\text{crit,EU}}$ = Equivalent uniform critical heat flux (BTU/hr-ft²)
- $q_{\text{crit,NU}}$ = Non uniform critical heat flux (BTU/hr-ft²)
- G = Mass Velocity (lb/hr-ft²)

ComEd's implementation of the standard Tong F-factor equation for the WRB-2 correlation is identical to its implementation in the W-3 critical heat flux correlation function already written into VIPRE (Reference 6). Below is the standard Tong F-factor equations as used in VIPRE.

$$F_{\text{axial}} = \frac{C_j}{q_j (1 - e^{-C_j(X_j - X_b)})} \int_{X_b}^{X_j} q''(z) e^{-C_j(X_j - z)} dz$$

where F_{axial} is used in the relation:

$$q_{\text{CHF}_{\text{nonuniform}}} = \frac{q_{\text{CHF}_{\text{uniform}}}}{F_{\text{axial}}}$$

and

$$C_j = 0.15 \frac{(1 - x_j)^{4.31}}{(G_j / 10^6)^{0.478}} \text{in}^{-1}$$

X_j = axial distance from the inlet (inches) at node j

X_b = axial distance from inlet to first boiling node (determined using the Jen-Lottes correlation)

$q''(z)$ = heat flux at axial location z

q_j = local heat flux at node j

x_j = local quality at node j

G_j = local mass flux at node j

The only difference between the VIPRE implementation of the Tong F-factor and the original Tong paper is the integration limits. In a subsequent publication (Reference 7) Tong clarified the definition of the l_{crit} or l_{dnb} term as "the location of DNB measured from the inception of local boiling."

It is our understanding that the Technical Reviewer is planning to use a spread sheet to check the accuracy of ComEd's calculations. In order to help expedite the reviewer's check of our calculations, we have provided the VIPRE calculated Tong F-factors for all the Test Cases with non-uniform axial heat flux distributions in **Appendix B**. Please note that Test Bundles A-6, A-7, A-10, A-11, and A-12 have uniform axial heat flux distributions, therefore, the Tong F-factor is 1.0 for these cases.

Question 4

(Page 15) The figure on this page appears to show a consistent trend of the predicted CHF being conservative at low values of the local mass flux and non-conservative at high values of the mass flux. Please describe any analysis you have performed to quantify biases in the correlation. If no such analyses have been performed, justify that the apparent bias is acceptable by providing an upper bound on the bias.

Response

As addressed in the response to Question 5, ComEd also recognizes that there is a residual trend in the scatter plots. However, by comparing to Westinghouse's original submittal to the NRC (Reference 4), it is concluded that this residual trend is not a result of the implementation of the WRB-2 correlation in VIPRE. Any bias in the correlation will be bounded statistically by the 1.17 thermal limit; where the intent is that a calculated value of DNBR or 1.17 corresponds to 95% probability at a 95% confidence level of not experiencing DNB. Since DNBR is actually defined as the Predicted CHF/Measured CHF, the DNBR limit can be represented in terms of the Measured CHF/Predicted CHF value as $1/1.17$ or 0.855. The expected percentage of data points with a Measured CHF/Predicted CHF below 0.855 would therefore be approximately 5%. The 11 test series for the WRB-2 correlation contain a total of 684 data point. We would therefore expect fewer than 35 data points would have Measured CHF/Predicted CHF values less than 0.855. The actual data indicated 27 data points were below 0.855, which is less than the correlation infers, and is therefore conservative.

Question 5

Please provide the best linear fit of the data shown on page 15 as a linear function of mass flux. To determine whether there are other potential biases, please fit the data as a linear function of pressure and as a linear function of quality.

Response

Figure 1: Measured-to-Predicted Critical Heat Flux vs. Local Mass Flux, Figure 2: Measured-to-Predicted Critical Heat Flux vs. Local Quality, and Figure 3: Measured-to-Predicted Critical Heat Flux vs. Pressure, which follow, include the equation of the best linear fit as requested. Also note the Measured CHF/Predicted CHF value of 0.855 corresponding to the thermal limit of 1.17 is indicated with a dotted line on these figures.






Figure 1: Measured-to-Predicted Critical Heat Flux vs. Local Mass Flux



Question 6

Many of the parameters in the WRB-2 CHF correlation involve geometrical features of the Westinghouse test apparatus (e.g. hydraulic diameter, heated diameter, distance from the most recent upstream mixing vane). No mention is given in the report as to the values used for these parameters. Please provide the values used for each test section and channel type.

Response

The following information is required as input to the WRB-2 correlation

1. Pressure, P
2. Local Mass Flux, G_{loc}
3. Local Quality, X_{loc}
4. Hydraulic Diameter, D_h
5. Heated Diameter, D_e
6. Heated Length, Inlet to CHF Location, L_h
7. Grid Spacing, g_{sp}
8. Distance from the Last Vaned Grid to CHF Location, d_g

The first three items, pressure, local mass flux, and local quality can be found in **Appendix C** in the CHF Summary output listings from VIPRE. Table 1, Test Bundle Geometrical Data References, is a list of figures containing geometrical data for each test bundle. The figures referenced in this table contain the grid locations, grid spacing and the geometrical data required to calculate hydraulic and heated diameters. It should be noted that the test section numbering used in Reference 8 refers to the test numbering for the WRB-1 calculations. Cross references are included for clarity. Nine of the eleven WRB-2 test bundles were also used in calculating the WRB-1 thermal limit. ComEd used the Westinghouse logic to maximize the value of d_g , the distance from the last vaned grid to CHF location. An excellent description of Westinghouse's logic for determining d_g can be found in the response to question 12 of Westinghouse's Response to additional information Request #1 in Reference 4.

WRB-2 Test Number	WRB-1 Test Number	Test Bundle Cross Section	Test Bundle Axial Grid Location
A-2	N/A	Figure A-6, Reference 4	Figure A-8, Reference 4
A-3	N/A	Figure A-6, Reference 4	Figure A-8, Reference 4
A-4	A-20	Figure 7, Reference 8	Figure 17, Reference 8
A-5	A-21	Figure 8, Reference 8	Figure 17, Reference 8
A-6	A-3	Figure 1, Reference 8	Figure 10, Reference 8
A-7	A-1	Figure 1, Reference 8	Figure 10, Reference 8
A-8	A-5	Figure 1, Reference 8	Figure 13, Reference 8
A-9	A-18	Figure 6, Reference 8	Figure 13, Reference 8
A-10	A-4	Figure 2, Reference 8	Figure 12, Reference 8
A-11	A-19	Figure 2, Reference 8	Figure 12, Reference 8
A-12	A-2	Figure 2, Reference 8	Figure 11, Reference 8

Table 1: Test Bundle Geometrical Data References

Question 7

The report does not address the nodalization utilized in the VIPRE simulation. Please provide information regarding the mesh spacing. The nodalization is important for determination of geometrical parameters for input to the WRB-2 correlation, in particular, the resolution that can be achieved for such parameters as heated length, LH, and distance from the most recent mixing vane grid, dg.?

Response

The axial noding used was 50 uniform nodes (3.36 in.) for the 14 foot tests (A-2 to A-5, A-7 to A-9, A-12) and 48 uniform nodes (2 in.) for the 8 foot tests (A-6, A-10, A-11). All of the models noding began at the bottom of the heated length. Westinghouse (Reference 4) used these same axial noding schemes in their THINC/WRB-2 calculations.

Question 8

Tables A-1 through A-12 of the report provide only the predicted local heat flux and quality. Other parameters from the code simulations, such as local mass flux and heated length to the CHF position are necessary to make a prediction using the WRB-2 correlation. Please provide all applicable data that were used as input to the correlation.

Response

Please note that there is no Table A-1 in Reference 2. The data included as Appendix A in our topical is listed by Westinghouse Test Section Number (Reference 4).

Appendix C contains the output listings of the VIPRE CHF summary files for tests A-2 through A-12. These output listings contain the following information:


- 1) Case ID Number
- 2) Operating Conditions
 - System Pressure (psia)
 - Inlet Enthalpy (BTU/lb_m)
 - Inlet Mass Flux (Mlb_m/hr-ft²)
 - Average Heat Rate (BTU/sec-ft)
- 3) MDNBR
- 4) Critical Location
 - Hot Channel Index (see Figure 4 on page 15)
 - Hot Rod Index (see Figure 4 on page 15)
 - Axial Level (in)
- 5) Hot Channel Conditions
 - Mass Flux (Mlb_m/hr-ft²)
 - Equilibrium Quality
 - Heat Flux (MBTU/hr-ft²)
- 6) Predicted Critical Heat Flux (MBTU/hr-ft²)
- 7) Correlation Flag (WRB-2 in all Cases)
- 8) Time (sec) (0.00 in all cases)

Question 9

Please provide the radial layout of the VIPRE model of the test section tube bundle. For the data of Tables A-1 to A-12 identify which bundle subchannel is predicted to have the CHF and confirm that the local quality and mass flux values are for that channel? Do these "predicted" subchannels and rods match the experimental test data?

Response

Figure 4 shows the radial nodalization of the VIPRE model used for the eleven (11) Westinghouse tests (A-2 through A-12). Again, please note that Reference 2 does not include a Table A-1.




Appendix C contains the VIPRE CHF Summary output file listings for each test series. These output listings include the location of CHF for each test along with fluid conditions at that location. ComEd does not have access to the measured subchannel and rod locations where CHF was observed. This information was not included in Reference 4. However, the VIPRE/WRB-2 predicted location of the subchannels and rods where CHF occurred were consistent with expectations. For the thimble channel tests, A-5, A-9, and A-11, the hot rod was always one of the 8 high powered rods (7, 8, 9, 12, 14, 17, 18, or 19) and the hot channel was one of the four channels associated with that rod. For the remaining cases, representative of a typical channel, the hot channel was always one of the four center channels (15, 16, 21, or 22) and the hot rod was one of the four rods associated with this channel.

Question 10

(Page 13) For the purposes of establishing the accuracy of the correlation, please show the least square linear fit to the measured versus predicted data.

Response

The dashed line on Figure 5: Measured-to-Predicted Critical Heat Flux Data, indicates that ComEd's VIPRE/WRB-2 95/95 thermal limit of 1.17. Also shown on the Figure is the equation for the linear fit as indicated on the plot.



References

- 1) "Factors for One-Sided Tolerance Limits and for Variables Sampling Plans," SCR-607, Sandia National Laboratories, D. B. Owen, March 1963.
- 2) "VIPRE/WRB-2 DNBR Thermal Limit for Westinghouse 17x17 OFA and VANTAGE 5 Fuel," Commonwealth Edison Company, Document Number NFSR-0090, L. Klasmier and H. Kim, dated September 8, 1992.
- 3) "New Westinghouse Correlation WRB-1 for Predicting Critical Heat Flux in Rod Bundles with Mixing Vane Grids," WCAP-8762-P-A, F. E. Motley, et al., July 1984.
- 4) "Reference Core Report Vantage 5 Fuel Assembly," WCAP-10444-P-A, edited by S. L. Davidson and W. R. Kramer, September 1985.
- 5) Tong, L. S., "Boiling Crisis and Critical Heat Flux," TID-25887, 1972.
- 6) "VIPRE-01: A Thermal-Hydraulic Code for Reactor Cores," Volume 1: Mathematical Modeling (Revision 3), EPRI NP-2511-CCM-A, August 1989.
- 7) "Boiling Heat Transfer and Two-Phase Flow," L. S. Tong, Westinghouse Electric Corporation, 1975.
- 8) "Commonwealth Edison Project, Byron/Braidwood Nuclear Power Plant, Zion Nuclear Power Plant, Thermal-Hydraulic Technology Transfer," Letter from J. W. Swogger (West.) to M. F. Finn (CECo), 88CW*-G-0024, April 29, 1988.

Appendix A - Owen's Method Reference

FACTORS FOR ONE-SIDED TOLERANCE LIMITS AND FOR VARIABLES SAMPLING PLANS

1. INTRODUCTION.

1.1 One-sided tolerance limits for a normal distribution.

For a normal random variable X with known mean μ and known standard deviation σ , it is possible to say that exactly a proportion P of the normal population is below $\mu + K_p \sigma$, where K_p is read from a table of the inverse normal probability distribution (e. g., see Reference [52], p. 12). For example, one can say that exactly 95% of the population is below $\mu + 1.64485\sigma$. The quantity $\mu + K_p \sigma$ is an upper tolerance limit.

In most cases, however, μ and σ are unknown and it is necessary to estimate both of them from a sample. Then a tolerance limit of the form $\bar{x} + ks$ may be used where \bar{x} is an estimate of μ and s is an estimate of σ . Since \bar{x} and s will be random variables, however, the tolerance limit statement can only be made with a given probability attached.

The problem then reduces to finding k such that the probability is γ that at least a proportion P of the population is below $\bar{x} + ks$. Tables of factors for one-sided tolerance limits for a normal distribution have been given in References [29], [37], [50], and [52] for the case where a sample x_1, x_2, \dots, x_n is taken and the sample mean,

$$\bar{x} = \frac{1}{n} \sum_{i=1}^n x_i,$$

and the sample standard deviation,

$$s = \sqrt{\frac{1}{n-1} \sum_{i=1}^n (x_i - \bar{x})^2},$$

are computed.

A value of k is given in the tables of Section 2 such that "at least a proportion P of the normal population is less than $\bar{x} + ks$ with probability equal to γ ." The value $\bar{x} + ks$ is called an upper tolerance limit. For a lower tolerance limit $\bar{x} - ks$ is used and the statement is "at least a proportion P of the population is greater than $\bar{x} - ks$ with confidence γ ." If a two-sided limit is desired the reader is referred to References [12], [35], [52], and [76].

If the normal distribution has mean μ and standard deviation σ and either of these are known, there are entries in the tables of Sections 3 and 4 which will give the required tolerance limit. When the mean is known, k may be read from the tables of Section 4 with $n = \infty$, i. e., the tables of Sections 4.1.15,

4.2.15, and 4.3.15. Similarly, if the standard deviation is known, k may be found from the tables of Section 4 with $f = \infty$, i.e., as the last entry for each table. The tables of Sections 3.1, 3.2 and 3.3 may be useful if $n = 1$ or ∞ or if $f = 1$ or ∞ .

It is convenient to define the term degrees of freedom for \bar{x} as that value of n which occurs in the statement \bar{x} has mean μ and standard deviation σ/\sqrt{n} . Similarly, the degrees of freedom for s is that value of f which occurs in the statement fs^2/σ^2 has a chi-square distribution with f degrees of freedom.

In addition to giving more extensive tables of k than [29], [37], and [50], this report extends the tables of k to the cases where the degrees of freedom for s are not necessarily one less than the degrees of freedom for \bar{x} . The degrees of freedom for s will be designated by f , and the degrees of freedom for \bar{x} will be designated by n . Values for $n = 1, 2, 3$ and 4 only are given in [52] for this case where $f \neq n - 1$. The present report can also be considered an extension of the work in References [35] and [75] which cover the two-sided tolerance limit problem with \bar{x} based on n degrees of freedom and s based on f degrees of freedom, where again f is not necessarily equal to $n - 1$. The extension given here, of course, is from the two-sided case to the one-sided case.

The values of k given in Sections 2, 3.1, 3.2, 3.3, and 4 correspond to percentage points (divided by the square root of n) of the noncentral t -distribution. Specifically,

$$\Pr\{\text{noncentral } t \leq k\sqrt{n} \mid \delta = K_p\sqrt{n}\} = \gamma,$$

where the noncentral t has f degrees of freedom and K_p is such that $\Pr\{\text{a standardized normal variable} \leq K_p\} = P$.

1.2 Johnson and Welch type tables for computing k .

A discussion of the tables of Section 5 follows. Among other things these tables may be used whenever there is a combination of values of f , n , and P for which there is not an entry in the tables of Sections 2, 3 or 4 and for which interpolation in Sections 2, 3 or 4 would not be satisfactory. Note also that the values of γ which are available in Section 5 include $(1 - \gamma)$ for each γ listed since $\Pr\{\text{noncentral } t \leq t_0 \mid \delta\} = 1 - \Pr\{\text{noncentral } t \leq -t_0 \mid -\delta\}$ and both positive and negative values of t and δ appear in the tables.

Section 5 follows a procedure used by Johnson and Welch [32] and contains values of γ such that if

$$\eta = \frac{\delta}{\sqrt{2f}} \left(1 + \frac{\delta^2}{2f}\right)^{-\frac{1}{2}},$$

$$t_0 = \frac{\delta + \lambda \left(1 + \frac{\delta^2}{2f} - \frac{\lambda^2}{2f}\right)^{\frac{1}{2}}}{\left(1 - \frac{\lambda^2}{2f}\right)},$$

2.4 Values of k for $f = n - 1$ and $\gamma = .95$

$$\Pr \left\{ T_f \leq k\sqrt{V} \mid K_p \sqrt{V} \right\} = \gamma$$

n	P							
	.75000	.90000	.95000	.97500	.99000	.99900	.99990	.99999
2	11.763	20.581	26.260	31.257	37.096	49.276	59.306	68.810
3	3.806	6.155	7.656	8.986	10.553	13.857	16.596	18.986
4	2.618	4.162	5.166	6.015	7.062	9.216	11.014	12.593
5	2.150	3.607	4.203	4.909	5.761	7.502	8.966	10.263
6	1.895	3.006	3.708	4.329	5.062	6.612	7.901	9.025
7	1.732	2.755	3.399	3.970	4.642	6.063	7.266	8.275
8	1.618	2.582	3.187	3.723	4.356	5.688	6.796	7.763
9	1.532	2.456	3.031	3.562	4.163	5.413	6.469	7.390
10	1.465	2.355	2.911	3.402	3.981	5.203	6.219	7.105
11	1.411	2.275	2.815	3.292	3.852	5.036	6.020	6.878
12	1.366	2.210	2.736	3.201	3.767	4.900	5.858	6.696
13	1.328	2.155	2.671	3.125	3.659	4.787	5.723	6.540
14	1.296	2.109	2.616	3.060	3.585	4.690	5.609	6.409
15	1.268	2.068	2.566	3.005	3.520	4.607	5.510	6.297
16	1.243	2.033	2.526	2.956	3.466	4.535	5.426	6.199
17	1.220	2.002	2.486	2.913	3.416	4.471	5.348	6.113
18	1.201	1.976	2.453	2.875	3.370	4.415	5.281	6.037
19	1.185	1.954	2.423	2.841	3.331	4.366	5.221	5.968
20	1.166	1.926	2.396	2.810	3.295	4.318	5.167	5.906
21	1.152	1.905	2.371	2.781	3.263	4.277	5.118	5.850
22	1.138	1.886	2.349	2.756	3.233	4.239	5.073	5.795
23	1.125	1.869	2.328	2.732	3.206	4.206	5.031	5.752
24	1.114	1.853	2.309	2.710	3.181	4.172	4.996	5.709
25	1.103	1.838	2.292	2.690	3.158	4.142	4.959	5.670
26	1.093	1.826	2.275	2.672	3.136	4.115	4.926	5.633
27	1.083	1.811	2.260	2.656	3.116	4.089	4.896	5.598
28	1.075	1.799	2.246	2.638	3.098	4.066	4.868	5.566
29	1.066	1.788	2.232	2.623	3.080	4.045	4.841	5.536
30	1.058	1.777	2.220	2.608	3.066	4.022	4.816	5.508
31	1.051	1.767	2.208	2.595	3.048	4.002	4.793	5.481
32	1.044	1.758	2.197	2.582	3.036	3.986	4.771	5.456
33	1.037	1.749	2.186	2.570	3.020	3.966	4.750	5.433
34	1.031	1.740	2.176	2.559	3.007	3.950	4.730	5.410
35	1.025	1.732	2.167	2.548	2.995	3.936	4.712	5.389
36	1.019	1.725	2.158	2.538	2.983	3.919	4.696	5.369
37	1.014	1.717	2.149	2.528	2.972	3.906	4.677	5.350
38	1.009	1.710	2.141	2.518	2.961	3.891	4.661	5.332
39	1.004	1.704	2.133	2.510	2.951	3.878	4.646	5.314
40	.999	1.697	2.125	2.501	2.941	3.865	4.631	5.298
41	.996	1.691	2.118	2.493	2.932	3.854	4.617	5.282
42	.990	1.685	2.111	2.485	2.923	3.842	4.603	5.266
43	.986	1.680	2.105	2.478	2.916	3.831	4.591	5.252
44	.982	1.676	2.098	2.470	2.906	3.821	4.578	5.238
45	.978	1.669	2.092	2.463	2.898	3.811	4.566	5.226

2.4 Values of k for $f = n - 1$ and $\gamma = .95$ (Continued)

$$Pr\{T_f \leq k\sqrt{n} \mid K_p \sqrt{n}\} = \gamma$$

n	P							
	.75000	.90000	.95000	.97500	.99000	.99900	.99990	.99999
46	.974	1.666	2.086	2.457	2.890	3.201	4.555	5.211
47	.971	1.659	2.081	2.450	2.883	3.792	4.546	5.199
48	.967	1.654	2.075	2.444	2.876	3.783	4.533	5.187
49	.966	1.650	2.070	2.438	2.869	3.774	4.523	5.175
50	.960	1.646	2.065	2.432	2.862	3.766	4.513	5.164
51	.957	1.641	2.060	2.427	2.856	3.758	4.504	5.153
52	.954	1.637	2.055	2.421	2.850	3.750	4.494	5.142
53	.951	1.633	2.051	2.416	2.844	3.742	4.485	5.132
54	.948	1.630	2.046	2.411	2.838	3.735	4.477	5.123
55	.945	1.626	2.042	2.406	2.833	3.728	4.468	5.113
56	.943	1.622	2.038	2.401	2.827	3.721	4.460	5.104
57	.940	1.619	2.034	2.397	2.822	3.714	4.452	5.095
58	.938	1.615	2.030	2.392	2.817	3.708	4.445	5.086
59	.935	1.612	2.026	2.388	2.812	3.701	4.437	5.078
60	.933	1.609	2.022	2.384	2.807	3.695	4.430	5.070
61	.930	1.606	2.019	2.380	2.802	3.689	4.423	5.062
62	.928	1.603	2.015	2.376	2.798	3.684	4.416	5.054
63	.926	1.600	2.012	2.372	2.793	3.678	4.410	5.047
64	.924	1.597	2.008	2.368	2.789	3.673	4.403	5.039
65	.921	1.594	2.005	2.364	2.785	3.667	4.397	5.032
66	.919	1.591	2.002	2.361	2.781	3.662	4.391	5.025
67	.917	1.589	1.999	2.357	2.777	3.657	4.385	5.018
68	.915	1.586	1.996	2.354	2.773	3.652	4.379	5.012
69	.913	1.584	1.993	2.351	2.769	3.647	4.373	5.005
70	.911	1.581	1.990	2.347	2.765	3.643	4.368	5.000
71	.910	1.579	1.987	2.344	2.762	3.638	4.362	4.993
72	.908	1.576	1.984	2.341	2.758	3.633	4.357	4.987
73	.906	1.574	1.982	2.338	2.755	3.629	4.352	4.981
74	.904	1.572	1.979	2.335	2.751	3.625	4.347	4.975
75	.903	1.570	1.976	2.332	2.748	3.621	4.342	4.970
76	.901	1.568	1.974	2.329	2.745	3.617	4.337	4.964
77	.899	1.565	1.971	2.327	2.742	3.613	4.333	4.959
78	.898	1.563	1.969	2.324	2.739	3.609	4.328	4.954
79	.896	1.561	1.967	2.321	2.736	3.605	4.323	4.949
80	.895	1.559	1.964	2.319	2.733	3.601	4.319	4.944
81	.893	1.557	1.962	2.316	2.730	3.597	4.315	4.939
82	.892	1.556	1.960	2.314	2.727	3.594	4.310	4.934
83	.890	1.554	1.958	2.311	2.724	3.590	4.306	4.929
84	.889	1.552	1.956	2.309	2.721	3.587	4.302	4.925
85	.888	1.550	1.954	2.306	2.719	3.583	4.298	4.920
86	.886	1.548	1.952	2.304	2.716	3.580	4.294	4.916
87	.885	1.547	1.950	2.302	2.714	3.577	4.291	4.911
88	.884	1.545	1.948	2.300	2.711	3.574	4.287	4.907
89	.882	1.543	1.946	2.297	2.709	3.571	4.283	4.903
90	.881	1.542	1.944	2.295	2.706	3.567	4.279	4.899

2.4 Values of k for $f = n - 1$ and $\gamma = .95$ (Continued)

$$\Pr \left\{ T_f \leq k\sqrt{n} \mid K_p \sqrt{n} \right\} = \gamma$$

n	P							
	.75000	.90000	.95000	.97500	.99000	.99900	.99990	.99999
91	.860	1.540	1.942	2.293	2.704	3.564	4.276	4.895
92	.879	1.538	1.940	2.291	2.701	3.561	4.272	4.891
93	.877	1.537	1.938	2.289	2.699	3.559	4.269	4.887
94	.876	1.535	1.937	2.287	2.697	3.556	4.266	4.883
95	.875	1.534	1.935	2.285	2.695	3.553	4.262	4.879
96	.874	1.532	1.933	2.283	2.692	3.550	4.259	4.876
97	.873	1.531	1.931	2.281	2.690	3.547	4.256	4.872
98	.872	1.530	1.930	2.279	2.688	3.545	4.253	4.869
99	.871	1.528	1.928	2.278	2.686	3.542	4.250	4.865
100	.870	1.527	1.927	2.276	2.684	3.539	4.247	4.862
101	.869	1.525	1.925	2.274	2.682	3.537	4.244	4.858
102	.868	1.524	1.923	2.272	2.680	3.534	4.241	4.855
103	.867	1.523	1.922	2.271	2.678	3.532	4.238	4.852
104	.866	1.521	1.920	2.269	2.676	3.530	4.235	4.848
105	.865	1.520	1.919	2.267	2.674	3.527	4.232	4.845
106	.864	1.519	1.917	2.266	2.672	3.525	4.229	4.842
107	.863	1.518	1.916	2.264	2.671	3.523	4.227	4.839
108	.862	1.517	1.915	2.262	2.669	3.520	4.224	4.836
109	.861	1.515	1.913	2.261	2.667	3.518	4.221	4.833
110	.860	1.514	1.912	2.259	2.665	3.516	4.219	4.830
111	.859	1.513	1.911	2.258	2.663	3.514	4.216	4.827
112	.858	1.512	1.909	2.256	2.662	3.511	4.214	4.824
113	.857	1.511	1.908	2.255	2.660	3.509	4.211	4.821
114	.856	1.510	1.907	2.253	2.658	3.507	4.209	4.819
115	.855	1.508	1.905	2.252	2.657	3.505	4.206	4.816
116	.855	1.507	1.904	2.251	2.655	3.503	4.204	4.813
117	.854	1.506	1.903	2.249	2.654	3.501	4.201	4.811
118	.853	1.505	1.902	2.248	2.652	3.499	4.199	4.808
119	.852	1.504	1.900	2.246	2.651	3.497	4.197	4.805
120	.851	1.503	1.899	2.245	2.649	3.495	4.194	4.803
121	.851	1.502	1.898	2.244	2.648	3.493	4.192	4.800
122	.850	1.501	1.897	2.242	2.646	3.492	4.190	4.798
123	.849	1.500	1.896	2.241	2.645	3.490	4.188	4.795
124	.848	1.499	1.895	2.240	2.643	3.488	4.186	4.793
125	.848	1.498	1.894	2.239	2.642	3.486	4.184	4.790
126	.847	1.497	1.893	2.237	2.640	3.484	4.182	4.788
127	.846	1.496	1.891	2.236	2.639	3.483	4.180	4.786
128	.845	1.496	1.890	2.235	2.638	3.481	4.178	4.784
129	.845	1.495	1.889	2.234	2.636	3.479	4.176	4.781
130	.844	1.494	1.888	2.233	2.635	3.478	4.174	4.779
131	.843	1.493	1.887	2.232	2.634	3.476	4.172	4.777
132	.843	1.492	1.886	2.230	2.632	3.474	4.170	4.773
133	.842	1.491	1.885	2.229	2.631	3.473	4.168	4.772
134	.841	1.490	1.884	2.228	2.630	3.471	4.166	4.770
135	.841	1.489	1.883	2.227	2.628	3.469	4.164	4.768

2.4 Values of k for $f = n - 1$ and $\gamma = .95$ (Continued)

$$\Pr\{T_f \leq k\sqrt{n} \mid K_p \sqrt{n}\} = \gamma$$

n	P							
	.75000	.90000	.95000	.97500	.99000	.99900	.99990	.99999
136	.840	1.489	1.882	2.226	2.627	3.468	4.162	4.766
137	.839	1.488	1.881	2.225	2.626	3.466	4.160	4.764
138	.839	1.487	1.880	2.224	2.625	3.465	4.159	4.762
139	.838	1.486	1.879	2.223	2.624	3.465	4.157	4.760
140	.837	1.485	1.879	2.222	2.622	3.462	4.155	4.758
141	.837	1.485	1.878	2.221	2.621	3.460	4.153	4.756
142	.836	1.484	1.877	2.220	2.620	3.459	4.152	4.754
143	.836	1.483	1.876	2.219	2.619	3.457	4.150	4.752
144	.835	1.482	1.875	2.218	2.618	3.456	4.148	4.750
145	.834	1.481	1.874	2.217	2.617	3.455	4.147	4.748
146	.834	1.481	1.873	2.216	2.616	3.453	4.145	4.747
147	.833	1.480	1.872	2.215	2.615	3.452	4.143	4.745
148	.833	1.479	1.872	2.214	2.613	3.451	4.142	4.743
149	.832	1.479	1.871	2.213	2.612	3.449	4.140	4.741
150	.832	1.478	1.870	2.212	2.611	3.448	4.139	4.739
151	.831	1.477	1.869	2.211	2.610	3.447	4.137	4.737
152	.830	1.476	1.868	2.210	2.609	3.445	4.136	4.736
153	.830	1.476	1.867	2.209	2.608	3.444	4.134	4.734
154	.829	1.475	1.867	2.208	2.607	3.443	4.133	4.733
155	.829	1.474	1.866	2.207	2.606	3.441	4.131	4.731
156	.828	1.474	1.865	2.207	2.605	3.440	4.130	4.729
157	.828	1.473	1.864	2.206	2.604	3.439	4.128	4.728
158	.827	1.472	1.864	2.205	2.603	3.438	4.127	4.726
159	.827	1.472	1.863	2.204	2.602	3.436	4.125	4.724
160	.826	1.471	1.862	2.203	2.601	3.435	4.124	4.723
161	.826	1.470	1.861	2.202	2.600	3.434	4.122	4.721
162	.825	1.470	1.861	2.201	2.600	3.433	4.121	4.720
163	.825	1.469	1.860	2.201	2.599	3.432	4.120	4.718
164	.824	1.469	1.859	2.200	2.598	3.431	4.118	4.716
165	.824	1.468	1.858	2.199	2.597	3.429	4.117	4.715
166	.823	1.467	1.858	2.198	2.596	3.428	4.116	4.713
167	.823	1.467	1.857	2.198	2.595	3.427	4.114	4.712
168	.822	1.466	1.856	2.197	2.594	3.426	4.113	4.710
169	.822	1.466	1.856	2.196	2.593	3.425	4.112	4.709
170	.822	1.465	1.855	2.195	2.592	3.424	4.111	4.708
171	.821	1.464	1.854	2.194	2.592	3.423	4.109	4.706
172	.821	1.464	1.854	2.194	2.591	3.422	4.108	4.705
173	.820	1.463	1.853	2.193	2.590	3.421	4.107	4.703
174	.820	1.463	1.852	2.192	2.589	3.420	4.106	4.702
175	.819	1.462	1.852	2.192	2.588	3.419	4.104	4.701
176	.819	1.462	1.851	2.191	2.587	3.418	4.103	4.699
177	.818	1.461	1.850	2.190	2.587	3.417	4.102	4.698
178	.818	1.460	1.850	2.189	2.586	3.416	4.101	4.696
179	.818	1.460	1.849	2.189	2.585	3.415	4.100	4.695
180	.817	1.459	1.849	2.188	2.584	3.414	4.098	4.694

2.4 Values of k for $f = n - 1$ and $\gamma = .95$ (Continued)

$$\Pr \left\{ T_f \leq k\sqrt{n} \mid K_p \sqrt{n} \right\} = \gamma$$

n	P							
	.75000	.90000	.95000	.97500	.99000	.99900	.99990	.99999
141	.817	1.459	1.844	2.187	2.585	3.413	4.097	4.692
142	.816	1.458	1.847	2.187	2.585	3.412	4.096	4.691
143	.816	1.458	1.847	2.186	2.582	3.411	4.095	4.690
144	.815	1.457	1.846	2.185	2.581	3.410	4.094	4.689
145	.815	1.457	1.846	2.185	2.580	3.409	4.093	4.687
146	.815	1.456	1.845	2.184	2.580	3.408	4.092	4.686
147	.814	1.456	1.844	2.183	2.579	3.407	4.090	4.685
148	.814	1.455	1.844	2.183	2.578	3.406	4.089	4.684
149	.814	1.455	1.843	2.182	2.577	3.405	4.088	4.682
150	.813	1.454	1.843	2.181	2.577	3.404	4.087	4.681
151	.813	1.454	1.842	2.181	2.576	3.403	4.086	4.680
152	.812	1.453	1.842	2.180	2.575	3.402	4.085	4.679
153	.812	1.453	1.841	2.179	2.575	3.401	4.084	4.678
154	.812	1.452	1.840	2.179	2.574	3.401	4.083	4.676
155	.811	1.452	1.840	2.178	2.573	3.400	4.082	4.675
156	.811	1.451	1.839	2.178	2.572	3.399	4.081	4.674
157	.811	1.451	1.839	2.177	2.572	3.398	4.080	4.673
158	.810	1.450	1.838	2.176	2.571	3.397	4.079	4.672
159	.810	1.450	1.838	2.176	2.570	3.396	4.078	4.671
160	.809	1.450	1.837	2.175	2.570	3.395	4.077	4.670
205	.808	1.447	1.835	2.172	2.566	3.391	4.072	4.664
210	.806	1.445	1.832	2.170	2.563	3.387	4.068	4.659
215	.804	1.443	1.830	2.167	2.560	3.384	4.063	4.654
220	.803	1.441	1.828	2.164	2.557	3.380	4.059	4.649
225	.801	1.439	1.825	2.162	2.555	3.376	4.055	4.644
230	.800	1.437	1.823	2.160	2.552	3.373	4.051	4.640
235	.798	1.436	1.821	2.157	2.549	3.370	4.047	4.635
240	.797	1.434	1.819	2.155	2.547	3.367	4.043	4.631
245	.796	1.432	1.817	2.153	2.544	3.365	4.040	4.627
250	.795	1.431	1.815	2.151	2.542	3.361	4.036	4.623
255	.793	1.429	1.814	2.149	2.540	3.358	4.033	4.619
260	.792	1.428	1.812	2.147	2.537	3.355	4.029	4.616
265	.791	1.426	1.810	2.145	2.535	3.352	4.026	4.612
270	.790	1.425	1.809	2.143	2.533	3.349	4.023	4.609
275	.789	1.423	1.807	2.141	2.531	3.347	4.020	4.605
280	.788	1.422	1.805	2.140	2.529	3.344	4.017	4.602
285	.787	1.421	1.804	2.138	2.527	3.342	4.014	4.599
290	.786	1.419	1.802	2.136	2.525	3.340	4.012	4.596
295	.785	1.418	1.801	2.135	2.524	3.337	4.009	4.593
300	.784	1.417	1.800	2.133	2.522	3.335	4.006	4.590
305	.783	1.416	1.798	2.132	2.520	3.333	4.004	4.587
310	.782	1.415	1.797	2.130	2.518	3.331	4.001	4.584
315	.781	1.413	1.796	2.129	2.517	3.329	3.999	4.581
320	.780	1.412	1.794	2.127	2.515	3.327	3.996	4.577
325	.779	1.411	1.793	2.126	2.514	3.325	3.994	4.576

2.4 Values of k for $f = n - 1$ and $\gamma = .95$ (Continued)

$$\Pr\{T_f \leq k\sqrt{n} \mid K_p \sqrt{n}\} = \gamma$$

n	P							
	.75000	.90000	.95000	.97500	.99000	.99900	.99990	.99999
330	.778	1.410	1.792	2.124	2.512	3.323	3.992	4.573
335	.778	1.409	1.791	2.123	2.511	3.321	3.990	4.571
340	.777	1.408	1.790	2.122	2.509	3.319	3.988	4.568
345	.776	1.407	1.789	2.121	2.508	3.318	3.986	4.566
350	.775	1.406	1.787	2.119	2.506	3.316	3.983	4.564
355	.775	1.405	1.786	2.118	2.505	3.314	3.981	4.562
360	.774	1.404	1.785	2.117	2.504	3.312	3.980	4.559
365	.773	1.404	1.784	2.116	2.502	3.311	3.978	4.557
370	.772	1.403	1.783	2.115	2.501	3.309	3.976	4.555
375	.772	1.402	1.782	2.114	2.500	3.308	3.974	4.553
380	.771	1.401	1.781	2.113	2.499	3.306	3.972	4.551
385	.770	1.400	1.780	2.112	2.498	3.305	3.970	4.549
390	.770	1.399	1.780	2.111	2.496	3.303	3.969	4.547
395	.769	1.399	1.779	2.109	2.495	3.302	3.967	4.545
400	.769	1.398	1.778	2.109	2.494	3.300	3.965	4.543
425	.766	1.396	1.774	2.104	2.489	3.294	3.957	4.536
450	.763	1.391	1.770	2.100	2.484	3.288	3.950	4.526
475	.761	1.388	1.766	2.096	2.480	3.282	3.944	4.519
500	.758	1.385	1.763	2.092	2.475	3.277	3.938	4.512
525	.756	1.382	1.760	2.089	2.472	3.272	3.932	4.506
550	.754	1.380	1.757	2.086	2.468	3.268	3.927	4.500
575	.752	1.378	1.755	2.083	2.465	3.264	3.922	4.495
600	.751	1.376	1.752	2.080	2.462	3.260	3.918	4.489
625	.749	1.374	1.750	2.077	2.459	3.256	3.913	4.485
650	.748	1.372	1.749	2.075	2.456	3.253	3.910	4.480
675	.746	1.370	1.746	2.073	2.454	3.250	3.906	4.476
700	.745	1.368	1.744	2.071	2.451	3.247	3.902	4.472
725	.744	1.367	1.742	2.069	2.449	3.244	3.899	4.468
750	.743	1.365	1.741	2.067	2.447	3.241	3.896	4.465
775	.741	1.364	1.739	2.065	2.445	3.238	3.893	4.461
800	.740	1.363	1.737	2.063	2.443	3.236	3.890	4.458
825	.739	1.361	1.736	2.062	2.441	3.234	3.887	4.455
850	.738	1.360	1.734	2.060	2.439	3.232	3.885	4.452
875	.737	1.359	1.733	2.059	2.438	3.229	3.882	4.449
900	.736	1.358	1.732	2.057	2.436	3.227	3.880	4.446
925	.736	1.357	1.731	2.056	2.434	3.225	3.877	4.444
950	.735	1.356	1.729	2.054	2.433	3.224	3.875	4.441
975	.734	1.355	1.728	2.053	2.432	3.222	3.873	4.439
1000	.733	1.354	1.727	2.052	2.430	3.220	3.871	4.437
1500	.722	1.340	1.712	2.035	2.411	3.196	3.842	4.404
2000	.716	1.332	1.703	2.024	2.399	3.181	3.825	4.385
3000	.708	1.323	1.692	2.012	2.385	3.164	3.806	4.363
5000	.701	1.313	1.681	2.000	2.372	3.147	3.786	4.340
10000	.693	1.304	1.670	1.988	2.358	3.130	3.766	4.318
∞	.674	1.282	1.645	1.960	2.326	3.070	3.719	4.265

Appendix B - Tong F-Factor Values for Non-Uniform Test Cases

Test Section A-2

Case ID	CHF Axial Location	Predicted CHF	Tong F-Factor
902			1.2104
2			1.1984
3			1.2038
4			1.1851
5			1.1895
6			1.1563
7			1.1915
8			1.2159
9			1.2052
10			1.2184
11			1.2091
12			1.1775
13			1.1770
14			1.2070
15			1.2190
16			1.2023
17			1.2026
18			1.1757
19			1.1924
20			1.1869
21			1.1530
22			1.1455
23			1.1631
24			1.1775
25			1.2154
26			1.2062

Case ID	CHF Axial Location	Predicted CHF	Tong F-Factor
27			1.2009
28			1.2119
29			1.2147
30			1.1967
31			1.2112
32			1.2194
33			1.1794
34			1.1915
35			1.1988
36			1.1853
37			1.1939
38			1.1990
39			1.2185
40			1.2024
41			1.2017
42			1.2061
43			1.1825
44			1.1765
45			1.1604
46			1.2108
47			1.2160
48			1.2140
49			1.1971
50			1.2089
51			1.2141

*(b,c)

Test Section A-3

Case ID	CHF Axial Location	Predicted CHF	Tong F-Factor
903			1.2147
2			1.2101
3			1.2168
4			1.2188
5			1.2023
6			1.2066
7			1.1934
8			1.1772
9			1.2166
10			1.2119
11			1.1986
12			1.2039
13			1.1909
14			1.4004
15			1.1769
16			1.2037
17			1.2112
18			1.1849
19			1.2219
20			1.2117
21			1.2274
22			1.1771
23			1.1971
24			1.2130
25			1.2095
26			1.2133
27			1.2068
28			1.3369
29			1.3491
30			1.1415
31			1.2139

+(b,c)

Test Section A-4

Case ID	CHF Axial Location	Predicted CHF	Tong F-Factor
502			+ 1.0921
2			1.0878
3			1.0935
4			1.0861
5			1.0947
6			1.0836
7			1.0955
8			1.0881
9			1.3447
10			1.0976
11			1.0971
12			1.0994
13			1.0992
14			1.0987
15			1.0994
16			1.3453
17			1.2815
18			1.3063
19			1.0737
20			1.2920
21			1.0747
22			1.2794
23			1.3934
24			1.3611
25			1.1005
26			1.0860
27			1.0893
28			1.2606
29			1.0609
30			1.0686
31			1.0749
32			1.0782

Case ID	CHF Axial Location	Predicted CHF	Tong F-Factor
33			+ 1.0616
34			1.3044
35			1.3810
36			1.3400
37			1.0965
38			1.0959
39			1.4094
40			1.3553
41			1.0949
42			1.3719
43			1.2866
44			1.0767
45			1.3265
46			1.3125
47			1.0857
48			1.0865
49			1.3477
50			1.3116
51			1.0929
52			1.0960
53			1.1010
54			1.1009
55			1.0942
56			1.3485
57			1.3810
58			1.3369
59			1.3680
60			1.0996
61			1.0955
62			1.0999
63			1.0952

+(b,c)

Test Section A-5

Case ID	CHF Axial Location	Predicted CHF	Tong F-Factor
503			+ 1.3094
2			1.0839
3			1.0910
4			1.3184
5			1.0954
6			1.0896
7			1.3334
8			1.3183
9			1.0943
10			1.0832
11			1.3676
12			1.0868
13			1.0931
14			1.0936
15			1.1001
16			1.0943
17			1.0941
18			1.0834
19			1.0854
20			1.0980
21			1.0967
22			1.3214
23			1.0918
24			1.0923
25			1.3534
26			1.3464
27			1.3449
28			1.0992
29			1.0988
30			1.0992
31			1.3261
32			1.2795
33			1.0834
34			1.0758
35			1.0678
36			1.0796
37			1.3184
38			1.0949

Test Section A-8

Case ID	CHF Axial Location	Predicted CHF	Tong F-Factor
164			+ 1.2524
2			1.2370
3			1.2340
4			1.2160
5			1.2262
6			1.2158
7			1.2714
8			1.2547
9			1.2441
10			1.2602
11			1.3479
12			1.2634
13			1.2583
14			1.2674
15			1.2737
16			1.2741
17			1.2907
18			1.3072
19			1.3001
20			1.2962
21			1.3414
22			1.3317
23			1.3350
24			1.3217
25			1.3438
26			1.3284
27			1.3272
28			1.3287
29			1.3395
30			1.3649
31			1.3551
32			1.3470
33			1.3701
34			1.3440
35			1.3246
36			1.3180
37			1.3100

Case ID	CHF Axial Location	Predicted CHF	Tong F-Factor
38			+ 1.3359
39			1.3074
40			1.2922
41			1.2962
42			1.2727
43			1.2472
44			1.2569
45			1.3391
46			1.3158
47			1.2948
48			1.2859
49			1.2907
50			1.2837
51			1.2421
52			1.2881
53			1.2724
54			1.1859
55			1.1981
56			1.2329
57			1.2542
58			1.1787
59			1.1821
60			1.2769
61			1.2576
62			1.3686
63			1.2596
64			1.3038
65			1.2250
66			1.2902
67			1.2829
68			1.2595
69			1.3446
70			1.2022
71			1.2706
72			1.2350
73			1.2819
74			1.2763

+(b,c)

Test Section A-9

Case ID	CHF Axial Location	Predicted CHF	Tong F-Factor
162			+ 1.2434
2			1.2142
3			1.2033
4			1.2329
5			1.2550
6			1.2516
7			1.2541
8			1.2596
9			1.2303
10			1.2707
11			1.2781
12			1.3505
13			1.3197
14			1.2945
15			1.3298
16			1.3294
17			1.3266
18			1.3246
19			1.3254
20			1.3658
21			1.3490
22			1.3265
23			1.3580
24			1.3457
25			1.3207
26			1.3200
27			1.3433
28			1.3329
29			1.2980
30			1.2834
31			1.3247
32			1.3107
33			1.2613
34			1.2706
35			1.2685

Case ID	CHF Axial Location	Predicted CHF	Tong F-Factor
36			+ 1.2941
37			1.2658
38			1.3167
39			1.2923
40			1.3033
41			1.2892
42			1.2881
43			1.2802
44			1.0834
45			1.3131
46			1.2406
47			1.2388
48			1.2953
49			1.0805
50			1.2480
51			1.3484
52			1.3010
53			1.3032
54			1.2947
55			1.2180
56			1.2906
57			1.2802
58			1.3272
59			1.2805
60			1.2232
61			1.2043
62			1.2005
63			1.2064
64			1.2012
65			1.2832
66			1.3604
67			1.2991
68			1.2584
69			1.2268
70			1.2798

+(b,c)

Appendix C - CHF Summary Output File Listings

Test Section A-2

***** OPERATING CONDITIONS *****				***** CRITICAL LOCATION*** HOT CHANNEL CONDITIONS *****				***** PREDICTED **			
SYSTEM	INLET	INLET	AVERAGE	AXIAL*MASS FLUX		HEAT FLUX*		CRITICAL			
*PRESSURE	ENTHALPY	MASS FLUX	HEAT RATE	*HOT	HOT LEVEL*(MLBM/HR-	EQUIL. (MBTU/HR-	HEAT FLUX	*CORR	TIME		
CASE*	(PSIA)	(BTU/LBM)	(MLBM/HR-FT2)	(BTU/SEC-FT)	*MDNBR*CHANNEL	ROD (IN.)*	FT2)	QUALITY	FT2)	*FLAG*	(SEC)
902											
2				1.064	22	19				WRB2	0.000
3				0.931	22	19				WRB2	0.000
4				1.018	22	19				WRB2	0.000
5				0.912	22	19				WRB2	0.000
6				0.962	22	19				WRB2	0.000
7				0.919	22	19				WRB2	0.000
8				0.963	22	19				WRB2	0.000
9				1.010	22	19				WRB2	0.000
10				0.970	22	19				WRB2	0.000
11				1.012	22	19				WRB2	0.000
12				1.017	22	19				WRB2	0.000
13				1.022	22	19				WRB2	0.000
14				0.995	22	19				WRB2	0.000
15				1.132	22	19				WRB2	0.000
16				1.176	22	19				WRB2	0.000
17				1.067	22	19				WRB2	0.000
18				1.150	22	19				WRB2	0.000
19				1.045	22	19				WRB2	0.000
20				1.084	22	19				WRB2	0.000
21				1.096	22	19				WRB2	0.000
22				0.980	22	19				WRB2	0.000
23				0.950	22	19				WRB2	0.000
24				0.981	22	19				WRB2	0.000
25				0.933	22	19				WRB2	0.000
26				1.137	22	19				WRB2	0.000
27				1.015	22	19				WRB2	0.000
28				1.006	22	19				WRB2	0.000
29				0.987	22	19				WRB2	0.000
30				1.049	22	19				WRB2	0.000
31				1.034	22	19				WRB2	0.000
32				0.944	22	19				WRB2	0.000
33				0.908	22	19				WRB2	0.000
34				0.995	22	19				WRB2	0.000
35				1.016	22	19				WRB2	0.000
36				1.091	22	19				WRB2	0.000
37				0.968	22	19				WRB2	0.000
38				1.026	22	19				WRB2	0.000
39				1.080	22	19				WRB2	0.000
40				0.944	22	19				WRB2	0.000
41				0.931	22	19				WRB2	0.000
42				1.166	22	19				WRB2	0.000
43				1.139	22	19				WRB2	0.000
44				1.181	22	19				WRB2	0.000
				1.131	22	19				WRB2	0.000

45] +	1.115	22	19]
46		0.978	22	19	
47		1.188	22	19	
48		0.990	22	19	
49		0.966	22	19	
50		0.990	22	19	
51		1.004	22	19	

] +	WRB2	0.000	+ (b,c
	WRB2	0.000	
	WRB2	0.000	
	WRB2	0.000	
	WRB2	0.000	
	WRB2	0.000	

Test Section A-3

***** OPERATING CONDITIONS *****				***** CRITICAL LOCATION**** HOT CHANNEL CONDITIONS ***** PREDICTED **			
* SYSTEM	INLET	INLET	AVERAGE	* AXIAL*MASS FLUX	HEAT FLUX*	CRITICAL	*
*PRESSURE	ENTHALPY	MASS FLUX	HEAT RATE	* HOT	HOT LEVEL*(MLBM/HR-	EQUIL. (MBTU/HR-*	HEAT FLUX
CASE* (PSIA)	(BTU/LBM)	(MLBM/HR-FT2)	(BTU/SEC-FT)	*MDNBR*	CHANNEL RCD (IN.)*	QUALITY FT2)	*(MBTU/HR-FT2)*
							CORR TIME *
							FLAG (SEC) *
903				1.090	16	14	WRB2 0.000
2				1.076	16	14	WRB2 0.000
3				0.898	16	14	WR32 0.000
4				0.962	16	14	WRB2 0.000
5				1.012	16	14	WRB2 0.000
6				0.993	16	14	WRB2 0.000
7				1.024	16	14	WRB2 0.000
8				0.955	16	14	WRB2 0.000
9				0.950	16	14	WRB2 0.000
10				1.027	16	14	WRB2 0.000
11				1.012	16	14	WRB2 0.000
12				0.997	16	14	WRB2 0.000
13				0.997	16	14	WRB2 0.000
14				0.967	16	14	WRB2 0.000
15				0.946	16	14	WRB2 0.000
16				0.941	16	14	WRB2 0.000
17				0.973	16	14	WRB2 0.000
18				0.919	16	14	WRB2 0.000
19				0.918	16	14	WRB2 0.000
20				1.024	16	14	WRB2 0.000
21				0.942	16	14	WRB2 0.000
22				0.854	16	14	WRB2 0.000
23				0.890	16	14	WRB2 0.000
24				1.088	16	14	WRB2 0.000
25				0.984	16	14	WRB2 0.000
26				0.974	16	14	WRB2 0.000
27				1.060	16	14	WRB2 0.000
28				0.972	16	14	WRB2 0.000
29				1.013	16	14	WRB2 0.000
30				0.881	16	14	WRB2 0.000
31				1.062	16	14	WRB2 0.000

+(b,c)

Test Section A-4

***** OPERATING CONDITIONS *****				***** CRITICAL LOCATION *****				***** HOT CHANNEL CONDITIONS *****				***** PREDICTED *****	
* SYSTEM	INLET	INLET	AVERAGE	* MDNBR	* CHANNEL	* HOT	* HOT	AXIAL*MASS FLUX	EQUIL.	HEAT FLUX*	HEAT FLUX*	* CORR*	* TIME *
* PRESSURE	ENTHALPY	MASS FLUX	HEAT RATE			LEVEL*(MLBM/HR-	ROD		QUALITY	(MBTU/HR-*	(MBTU/HR-FT2)	* FLAG*	(SEC) *
CASE*	(PSIA)	(BTU/LBM)	(MLBM/HR-FT2)	(BTU/SEC-FT)		(IN.)*		FT2)		FT2)			
502				1.185	22	19						WRB2	0.000
2				1.085	22	19						WRB2	0.000
3				1.140	22	19						WRB2	0.000
4				1.050	22	19						WRB2	0.000
5				1.145	22	19						WRB2	0.000
6				1.067	22	19						WRB2	0.000
7				1.103	22	19						WRB2	0.000
8				1.039	22	19						WRB2	0.000
9				1.182	22	19						WRB2	0.000
10				1.201	22	19						WRB2	0.000
11				1.160	22	19						WRB2	0.000
12				1.102	22	19						WRB2	0.000
13				1.202	22	19						WRB2	0.000
14				1.082	22	19						WRB2	0.000
15				1.155	22	19						WRB2	0.000
16				1.154	22	19						WRB2	0.000
17				0.962	22	19						WRB2	0.000
18				0.980	22	19						WRB2	0.000
19				0.997	22	19						WRB2	0.000
20				0.975	22	19						WRB2	0.000
21				0.981	22	19						WRB2	0.000
22				0.973	22	19						WRB2	0.000
23				0.869	22	19						WRB2	0.000
24				0.912	22	19						WRB2	0.000
25				0.989	22	19						WRB2	0.000
26				1.020	22	19						WRB2	0.000
27				0.991	22	19						WRB2	0.000
28				0.982	22	19						WRB2	0.000
29				1.014	22	19						WRB2	0.000
30				0.917	22	19						WRB2	0.000
31				1.019	22	19						WRB2	0.000
32				0.973	22	19						WRB2	0.000
33				1.055	22	19						WRB2	0.000
34				0.901	22	19						WRB2	0.000
35				0.807	22	19						WRB2	0.000
36				0.904	22	19						WRB2	0.000
37				0.977	22	19						WRB2	0.000
38				1.051	22	19						WRB2	0.000
39				0.878	22	19						WRB2	0.000
40				0.834	22	19						WRB2	0.000
41				0.889	22	19						WRB2	0.000
42				0.831	22	19						WRB2	0.000
43				0.925	22	19						WRB2	0.000
44				0.962	22	19						WRB2	0.000

+(b,c)

est Section A-5

***** OPERATING CONDITIONS *****				*CRITICAL LOCATION*** HOT CHANNEL CONDITIONS ***** PREDICTED **								
* SYSTEM	INLET	INLET	AVERAGE	* AXIAL*	MASS FLUX	HEAT FLUX*	CRITICAL					
* PRESSURE	ENTHALPY	MASS FLUX	HEAT RATE	* HOT	HOT LEVEL*(MLBM/HR-	EQUIL. (MBTU/HR-	HEAT FLUX					
CASE* (PSIA)	(BTU/LBM)	(MLBM/HR-FT2)	(BTU/SEC-FT)	*MDNBR*	CHANNEL ROD (IN.)*	FT2)	*(MBTU/HR-FT2)*					
						QUALITY	FLAG*					
							TIME					
							(SEC)					
503				+	1.074	28	19		+	WRB2	0.000	+(b,c)
2					1.059	28	19			WRB2	0.000	
3					0.937	22	19			WRB2	0.000	
4					0.973	28	19			WRB2	0.000	
5					1.025	22	19			WRB2	0.000	
6					0.976	22	19			WRB2	0.000	
7					0.896	28	19			WRB2	0.000	
8					0.986	28	19			WRB2	0.000	
9					1.049	22	19			WRB2	0.000	
10					1.136	22	19			WRB2	0.000	
11					1.039	28	19			WRB2	0.000	
12					1.011	28	19			WRB2	0.000	
13					1.054	28	19			WRB2	0.000	
14					1.070	22	19			WRB2	0.000	
15					1.055	28	19			WRB2	0.000	
16					1.020	22	19			WRB2	0.000	
17					1.070	22	19			WRB2	0.000	
18					1.013	28	19			WRB2	0.000	
19					0.998	22	19			WRB2	0.000	
20					1.066	28	19			WRB2	0.000	
21					1.051	22	19			WRB2	0.000	
22					1.014	28	19			WRB2	0.000	
23					0.952	28	19			WRB2	0.000	
24					0.981	22	19			WRB2	0.000	
25					0.911	28	19			WRB2	0.000	
26					1.023	28	19			WRB2	0.000	
27					1.087	28	19			WRB2	0.000	
28					1.029	28	19			WRB2	0.000	
29					0.987	22	19			WRB2	0.000	
30					1.112	22	19			WRB2	0.000	
31					0.861	23	19			WRB2	0.000	
32					0.949	23	19			WRB2	0.000	
33					1.031	28	19			WRB2	0.000	
34					0.934	28	19			WRB2	0.000	
35					0.966	22	19			WRB2	0.000	
36					1.025	22	19			WRB2	0.000	
37					1.003	28	19			WRB2	0.000	
38				2	1.085	22	19			WRB2	0.000	

Test Section A-6

***** OPERATING CONDITIONS *****				*CRITICAL LOCATION** HOT CHANNEL CONDITIONS **** PREDICTED **							
* SYSTEM	INLET	INLET	AVERAGE	* AXIAL*	MASS FLUX	HEAT FLUX*	CRITICAL				
* PRESSURE	ENTHALPY	MASS FLUX	HEAT RATE	* HOT	HOT LEVEL*(MLBM/HR-	EQUIL. (MBTU/HR-	HEAT FLUX				
CASE*	(PSIA)	(BTU/LBM)	(MLBM/HR-FT2)	(BTU/SEC-FT)	*MDNBR*	CHANNEL ROD (IN.)*	FT2)	* (MBTU/HR-FT2)	* CORR*	TIME *	
*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	*****	
160				1.026	22	19			WRB2	0.000	+(b,c)
2				1.009	22	19			WRB2	0.000	
3				0.998	22	19			WRB2	0.000	
4				0.967	22	19			WRB2	0.000	
5				1.008	22	19			WRB2	0.000	
6				0.933	22	19			WRB2	0.000	
7				0.923	22	19			WRB2	0.000	
8				0.927	22	19			WRB2	0.000	
9				1.074	22	19			WRB2	0.000	
10				0.964	22	19			WRB2	0.000	
11				0.959	22	19			WRB2	0.000	
12				0.880	22	19			WRB2	0.000	
13				1.046	22	19			WRB2	0.000	
14				0.881	22	19			WRB2	0.000	
15				0.882	22	19			WRB2	0.000	
16				0.866	22	19			WRB2	0.000	
17				0.860	22	19			WRB2	0.000	
18				0.923	22	19			WRB2	0.000	
19				0.902	22	19			WRB2	0.000	
20				0.916	22	19			WRB2	0.000	
21				0.919	22	19			WRB2	0.000	
22				0.875	22	19			WRB2	0.000	
23				0.868	22	19			WRB2	0.000	
24				0.930	22	19			WRB2	0.000	
25				0.855	22	19			WRB2	0.000	
26				0.894	22	19			WRB2	0.000	
27				0.870	22	19			WRB2	0.000	
28				0.895	22	19			WRB2	0.000	
29				0.932	22	19			WRB2	0.000	
30				0.976	22	19			WRB2	0.000	
31				0.944	22	19			WRB2	0.000	
32				0.948	22	19			WRB2	0.000	
33				0.975	22	19			WRB2	0.000	
34				1.024	22	19			WRB2	0.000	
35				0.984	22	19			WRB2	0.000	
36				0.993	22	19			WRB2	0.000	
37				1.016	22	19			WRB2	0.000	
38				1.173	22	19			WRB2	0.000	
39				1.082	22	19			WRB2	0.000	
40				1.136	22	19			WRB2	0.000	
41				1.060	22	19			WRB2	0.000	
42				1.077	22	19			WRB2	0.000	
43				0.957	22	19			WRB2	0.000	
44				0.985	22	19			WRB2	0.000	

Test Section A-7

***** OPERATING CONDITIONS *****				*CRITICAL LOCATION** HOT CHANNEL CONDITIONS **** PREDICTED **			
* SYSTEM	INLET	INLET	AVERAGE	* AXIAL*MASS FLUX	HEAT FLUX*	CRITICAL	*
*PRESSURE	ENTHALPY	MASS FLUX	HEAT RATE	* HOT	HOT LEVEL*(MLBM/HR-	EQUIL. (MBTU/HR-*	HEAT FLUX *CORR* TIME *
CASE* (PSIA)	(BTU/LBM)	(MLBM/HR-FT2)	(BTU/SEC-FT)	*MDNBR*CHANNEL	ROD (IN.)*	FT2) QUALITY	FT2) *(MBTU/HR-FT2)*FLAG* (SEC) *
161				+ 1.083	22	19	+ WRB2 0.000 + (b,c
2				1.164	22	19	WRB2 0.000
3				1.032	22	19	WRB2 0.000
4				0.970	22	19	WRB2 0.000
5				1.020	22	19	WRB2 0.000
6				0.945	22	19	WRB2 0.000
7				0.874	22	19	WRB2 0.000
8				1.051	22	19	WRB2 0.000
9				1.076	22	19	WRB2 0.000
10				1.144	22	19	WRB2 0.000
11				1.076	22	19	WRB2 0.000
12				1.121	22	19	WRB2 0.000
13				1.003	22	19	WRB2 0.000
14				1.049	22	19	WRB2 0.000
15				1.039	22	19	WRB2 0.000
16				1.059	22	19	WRB2 0.000
17				0.992	22	19	WRB2 0.000
18				0.995	22	19	WRB2 0.000
19				0.966	22	19	WRB2 0.000
20				0.911	22	19	WRB2 0.000
21				0.943	22	19	WRB2 0.000
22				0.981	22	19	WRB2 0.000
23				0.989	22	19	WRB2 0.000
24				0.983	22	19	WRB2 0.000
25				0.916	22	19	WRB2 0.000
26				0.984	22	19	WRB2 0.000
27				1.157	22	19	WRB2 0.000
28				1.048	22	19	WRB2 0.000
29				1.063	22	19	WRB2 0.000
30				1.050	22	19	WRB2 0.000
31				1.018	22	19	WRB2 0.000
32				1.003	22	19	WRB2 0.000
33				0.998	22	19	WRB2 0.000
34				1.015	22	19	WRB2 0.000
35				0.987	22	19	WRB2 0.000
36				0.934	22	19	WRB2 0.000
37				0.919	22	19	WRB2 0.000
38				0.969	22	19	WRB2 0.000
39				0.909	22	19	WRB2 0.000
40				0.933	22	19	WRB2 0.000
41				0.922	22	19	WRB2 0.000
42				0.890	22	19	WRB2 0.000
43				1.000	22	19	WRB2 0.000
44				0.846	22	19	WRB2 0.000

Test Section A-8

***** OPERATING CONDITIONS *****				***** CRITICAL LOCATION** HOT CHANNEL CONDITIONS *****				***** PREDICTED **	
* SYSTEM	INLET	INLET	AVERAGE	* * *	AXIAL*MASS FLUX	HEAT FLUX*	CRITICAL	* * *	* * *
*PRESSURE	ENTHALPY	MASS FLUX	HEAT RATE	* * *	HOT	HOT LEVEL*(MLBM/HR-	EQUIL. (MBTU/HR-	HEAT FLUX	*CORR* TIME *
CASE* (PSIA)	(BTU/LBM)	(MLBM/HR-FT2)	(BTU/SEC-FT)	*MDNBR*	CHANNEL ROD	(IN.)*	FT2) QUALITY	FT2) *(MBTU/HR-FT2)	*FLAG* (SEC) *
164				+	1.040	22	19		
2					1.072	22	19		WRB2 0.000 + (b,c)
3					1.034	22	19		WRB2 0.000
4					1.078	22	19		WRB2 0.000
5					0.956	22	19		WRB2 0.000
6					0.974	22	19		WRB2 0.000
7					1.105	22	19		WRB2 0.000
8					1.073	22	19		WRB2 0.000
9					1.096	22	19		WRB2 0.000
10					0.989	22	19		WRB2 0.000
11					0.880	22	19		WRB2 0.000
12					1.207	22	19		WRB2 0.000
13					1.181	22	19		WRB2 0.000
14					1.083	22	19		WRB2 0.000
15					1.118	22	19		WRB2 0.000
16					1.085	22	19		WRB2 0.000
17					1.226	22	19		WRB2 0.000
18					1.136	22	19		WRB2 0.000
19					1.157	22	19		WRB2 0.000
20					1.200	22	19		WRB2 0.000
21					1.055	22	19		WRB2 0.000
22					1.001	22	19		WRB2 0.000
23					1.001	22	19		WRB2 0.000
24					1.108	22	19		WRB2 0.000
25					1.011	22	19		WRB2 0.000
26					1.070	22	19		WRB2 0.000
27					1.087	22	19		WRB2 0.000
28					1.054	22	19		WRB2 0.000
29					1.102	22	19		WRB2 0.000
30					0.912	22	19		WRB2 0.000
31					0.954	22	19		WRB2 0.000
32					1.003	22	19		WRB2 0.000
33					0.945	22	19		WRB2 0.000
34					0.953	22	19		WRB2 0.000
35					0.987	22	19		WRB2 0.000
36					1.020	22	19		WRB2 0.000
37					1.098	22	19		WRB? 0.000
38					0.985	22	19		WRB2 0.000
39					0.962	22	19		WRB2 0.000
40					1.012	22	19		WRB2 0.000
41					1.043	22	19		WRB2 0.000
42					1.186	22	19		WRB2 0.000
43					1.183	22	19		WRB2 0.000
44					1.160	22	19		WRB2 0.000

45		+	0.968	22	19						
46			0.921	22	19				WRB2	0.000	+(b,
47			0.974	22	19				WRB2	0.000	
48			1.016	22	19				WRB2	0.000	
49			0.995	22	19				WRB2	0.000	
50			0.915	22	19				WRB2	0.000	
51			1.093	22	19				WRB2	0.000	
52			0.906	22	19				WRB2	0.000	
53			0.861	22	19				WRB2	0.000	
54			0.963	22	19				WRB2	0.000	
55			0.904	22	19				WRB2	0.000	
56			1.020	22	19				WRB2	0.000	
57			0.945	22	19				WRB2	0.000	
58			0.938	22	19				WRB2	0.000	
59			1.030	22	19				WRB2	0.000	
60			1.014	22	19				WRB2	0.000	
61			1.090	22	19				WRB2	0.000	
62			0.952	22	19				WRB2	0.000	
63			0.963	22	19				WRB2	0.000	
64			0.932	22	19				WRB2	0.000	
65			1.037	22	19				WRB2	0.000	
66			0.887	22	19				WRB2	0.000	
67			0.957	22	19				WRB2	0.000	
68			1.060	22	19				WRB2	0.000	
69			0.930	22	19				WRB2	0.000	
70			0.966	22	19				WRB2	0.000	
71			0.936	22	19				WRB2	0.000	
72			1.088	22	19				WRB2	0.000	
73			0.936	22	19				WRB2	0.000	
74			0.934	22	19				WRB2	0.000	

45	+	0.917	28	19	WRB2	0.000	+(b,
46		1.148	28	19	WRB2	0.000	
47		1.118	22	19	WRB2	0.000	
48		0.947	28	19	WRB2	0.000	
49		1.112	22	19	WRB2	0.000	
50		1.145	22	19	WRB2	0.000	
51		1.030	23	19	WRB2	0.000	
52		1.103	23	19	WRB2	0.000	
53		0.986	23	19	WRB2	0.000	
54		0.938	23	19	WRB2	0.000	
55		1.054	23	19	WRB2	0.000	
56		0.863	23	19	WRB2	0.000	
57		0.970	23	19	WRB2	0.000	
58		0.961	23	19	WRB2	0.000	
59		0.970	23	19	WRB2	0.000	
60		0.996	23	15	WRB2	0.000	
61		1.053	23	19	WRB2	0.000	
62		0.914	23	19	WRB2	0.000	
63		0.995	22	19	WRB2	0.000	
64		0.905	22	19	WRB2	0.000	
65		1.008	23	19	WRB2	0.000	
66		0.930	23	19	WRB2	0.000	
67		0.927	23	19	WRB2	0.000	
68		0.920	23	19	WRB2	0.000	
69		1.004	22	19	WRB2	0.000	
70		0.900	28	19	WRB2	0.000	

Test Section A-10

***** OPERATING CONDITIONS *****				*CRITICAL LOCATION** HOT CHANNEL CONDITIONS ***** PREDICTED **								
* SYSTEM	INLET	INLET	AVERAGE	* AXIAL*	MASS FLUX	HEAT FLUX*	CRITICAL					
*PRESSURE	ENTHALPY	MASS FLUX	HEAT RATE	* HOT	HOT LEVEL*(MLBM/HR-	EQUIL. (MBTU/HR-	HEAT FLUX					
CASE* (PSIA)	(BTU/LBM)	(MLBM/HR-FT2)	(BTU/SEC-FT)	*MDNBR*	CHANNEL ROD (IN.)*	QUALITY FT2)	*(MBTU/HR-FT2)*					
							CORR TIME *					
							FLAG (SEC) *					
157				+	0.928	22	19					
2					1.033	22	19					
3					1.075	22	19					
4					1.053	22	19					
5					1.087	22	19					
6					1.055	22	19					
7					0.992	22	19					
8					1.038	22	19					
9					1.057	22	19					
10					0.958	22	19					
11					0.992	22	19					
12					0.922	22	19					
13					1.056	22	19					
14					1.016	22	19					
15					1.026	22	19					
16					0.947	22	19					
17					0.949	22	19					
18					0.980	22	19					
19					0.960	22	19					
20					0.901	22	19					
21					0.931	22	19					
22					0.973	22	19					
23					1.038	22	19					
24					0.963	22	19					
25					1.075	22	19					
26					0.937	22	19					
27					0.970	22	19					
28					1.200	22	19					
29					1.145	22	19					
30					0.963	22	19					
31					1.046	22	19					
32					0.870	22	19					
33					1.206	22	19					
34					0.976	22	19					
35					0.987	22	19					
36					0.970	22	19					
37					0.958	22	19					
38					0.910	22	19					
39					0.996	22	19					
40					0.938	22	19					
41					0.924	22	19					
42					0.888	22	19					
43					0.958	22	19					
44					1.049	22	19					

+ WRB2 0.000 + (b)

45	+	1.051	22	19	+	WRB2	0.000	+(b,c)
46		0.839	22	19		WRB2	0.000	
47		0.969	22	19		WRB2	0.000	
48		0.978	22	19		WRB2	0.000	
49		1.015	22	19		WRB2	0.000	
50		0.947	22	19		WRB2	0.000	
51		0.970	22	19		WRB2	0.000	
52		0.971	22	19		WRB2	0.000	
53		1.000	22	19		WRB2	0.000	
54		1.021	22	19		WRB2	0.000	
55		0.988	22	19		WRB2	0.000	
56		0.930	22	19		WRB2	0.000	
57		1.073	22	19		WRB2	0.000	
58		0.970	22	19		WRB2	0.000	
59		0.911	22	19		WRB2	0.000	
60		0.921	22	19		WRB2	0.000	
61		0.985	22	19		WRB2	0.000	
62		1.153	22	19		WRB2	0.000	
63		0.963	22	19		WRB2	0.000	
64		0.933	22	19		WRB2	0.000	
65		0.877	22	19		WRB2	0.000	
66		0.855	22	19		WRB2	0.000	
67		0.841	22	19		WRB2	0.000	
68		0.991	22	19		WRB2	0.000	
69		0.913	22	19		WRB2	0.000	
70		0.963	22	19		WRB2	0.000	
71		0.882	22	19		WRB2	0.000	
72		0.907	22	19		WRB2	0.000	
73		1.033	22	19		WRB2	0.000	
74		0.921	22	19		WRB2	0.000	
75		0.871	22	19		WRB2	0.000	
76		0.874	22	19		WRB2	0.000	
77		0.876	22	19		WRB2	0.000	
78		0.877	22	19		WRB2	0.000	

Test Section A-11

***** OPERATING CONDITIONS *****				***** CRITICAL LOCATION*** HOT CHANNEL CONDITIONS *****				***** PREDICTED **	
* SYSTEM	INLET	INLET	AVERAGE	* * *	* * *	AXIAL*MASS FLUX	HEAT FLUX*	CRITICAL	* * *
*PRESSURE	ENTHALPY	MASS FLUX	HEAT RATE	* * *	* * *	(MLBM/HR -	(MBTU/HR -	HEAT FLUX	*CORR* TIME
CASE* (PSIA)	(BTU/LBM)	(MLBM/HR-FT2)	(BTU/SEC-FT)	*MDNBR*	*CHANNEL	ROD (IN.)*	FT2)	*(MBTU/HR-FT2)*	*FLAG* (SEC) *
158				+	0.918	28	19		
2					0.998	22	19		WRB2 0.000
3					0.984	22	19		WRB2 0.000
4					0.941	22	19		WRB2 0.000
5					0.926	28	19		WRB2 0.000
6					0.983	22	19		WRB2 0.000
7					0.990	22	19		WRB2 0.000
8					0.989	22	19		WRB2 0.000
9					1.248	28	19		WRB2 0.000
10					1.165	28	19		WRB2 0.000
11					1.057	22	19		WRB2 0.000
12					1.082	22	19		WRB2 0.000
13					1.123	28	19		WRB2 0.000
14					1.080	28	19		WRB2 0.000
15					0.946	28	19		WRB2 0.000
16					1.082	28	19		WRB2 0.000
17					0.940	22	19		WRB2 0.000
18					0.990	22	19		WRB2 0.000
19					0.854	22	19		WRB2 0.000
20					0.927	22	19		WRB2 0.000
21					0.968	22	19		WRB2 0.000
22					0.977	22	19		WRB2 0.000
23					0.959	28	19		WRB2 0.000
24					0.993	28	19		WRB2 0.000
25					1.160	28	19		WRB2 0.000
26					1.071	28	19		WRB2 0.000
27					0.861	22	19		WRB2 0.000
28					0.897	22	19		WRB2 0.000
29					0.873	28	19		WRB2 0.000
30					0.953	23	19		WRB2 0.000
31					0.971	28	19		WRB2 0.000
32					1.173	28	19		WRB2 0.000
33					1.043	28	19		WRB2 0.000
34					1.077	28	19		WRB2 0.000
35					1.043	23	19		WRB2 0.000
36					0.954	22	19		WRB2 0.000
37					1.072	22	19		WRB2 0.000
38					1.057	28	19		WRB2 0.000
39					1.057	28	19		WRB2 0.000
40					1.077	28	19		WRB2 0.000
41					1.110	28	19		WRB2 0.000
42					1.126	28	19		WRB2 0.000
43					0.926	28	19		WRB2 0.000
44					0.901	23	19		WRB2 0.000

+(b,c)

45	+	0.924	22	19	:	+	WRB2	0.000	+(b,c
46		0.955	22	19	:		WRB2	0.000	
47		0.968	22	19	:		WRB2	0.000	
48		0.961	28	19	:		WRB2	0.000	
49		0.969	23	19	:		WRB2	0.000	
50		0.989	28	19	:		WRB2	0.000	
51		0.990	22	19	:		WRB2	0.000	
52		1.097	22	19	:		WRB2	0.000	
53		0.901	28	19	:		WRB2	0.000	
54		0.824	22	19	:		WRB2	0.000	
55		0.887	22	19	:		WRB2	0.000	
56		0.802	28	19	:		WRB2	0.000	
57		0.842	28	19	:		WRB2	0.000	
58		0.893	22	19	:		WRB2	0.000	
59		0.918	28	9	:		WRB2	0.000	
60		0.909	22	19	:		WRB2	0.000	
61		1.040	28	19	:		WRB2	0.000	
62		1.121	28	19	:		WRB2	0.000	
63		1.028	28	19	:		WRB2	0.000	
64		0.873	22	19	:		WRB2	0.000	
65		0.939	28	19	:		WRB2	0.000	
66		0.881	28	19	:		WRB2	0.000	
67		0.828	22	19	:		WRB2	0.000	
68		1.027	22	19	:		WRB2	0.000	

Test Section A-12

***** OPERATING CONDITIONS *****				***** CRITICAL LOCATION*** HOT CHANNEL CONDITIONS ***** PREDICTED **						
* SYSTEM	INLET	INLET	AVERAGE	* HOT	HOT	AXIAL*MASS FLUX	HEAT FLUX*	CRITICAL	*CORR*	TIME *
*PRESSURE	ENTHALPY	MASS FLUX	HEAT RATE	* MDNBR*	CHANNEL	LEVEL*(MLBM/HR-	(MBTU/HR-	HEAT FLUX	*FLAG*	(SEC) *
CASE*	(PSIA)	(BTU/LBM)	(MLBM/HR-FT2)	(BTU/SEC-FT)		(IN.)*	FT2)	(MBTU/HR-FT2)		
						ROD	QUALITY			
156										
2										
3										
4										
5										
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
31										
32										
33										
34										
35										
36										
37										
38										
39										
40										
41										
42										
43										
44										

45	1.080	22	19	WRB2	0.000	+(b,c)
46	0.984	22	19	WRB2	0.000	
47	1.019	22	19	WRB2	0.000	
48	0.977	22	19	WRB2	0.000	
49	1.095	22	19	WRB2	0.000	
50	1.046	22	19	WRB2	0.000	
51	1.008	22	19	WRB2	0.000	
52	0.960	22	19	WRB2	0.000	
53	1.009	22	19	WRB2	0.000	
54	1.012	22	19	WRB2	0.000	
55	1.060	22	19	WRB2	0.000	
56	1.067	22	19	WRB2	0.000	
57	1.070	22	19	WRB2	0.000	
58	0.909	22	19	WRB2	0.000	
59	0.907	22	19	WRB2	0.000	
60	1.240	22	19	WRB2	0.000	
61	1.093	22	19	WRB2	0.000	
62	0.942	22	19	WRB2	0.000	
63	0.910	22	19	WRB2	0.000	
64	0.938	22	19	WRB2	0.000	
65	0.969	22	19	WRB2	0.000	
66	1.010	22	19	WRB2	0.000	
67	0.978	22	19	WRB2	0.000	
68	1.081	22	19	WRB2	0.000	
69	1.046	22	19	WRB2	0.000	
70	1.001	22	19	WRB2	0.000	
71	1.111	22	19	WRB2	0.000	
72	0.931	22	19	WRB2	0.000	
74	1.140	22	19	WRB2	0.000	