

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH APRIL

DOCKET NO. 50-348
 UNIT NAME J.M. Farley-Unit 1
 DATE 5/02/83
 COMPLETED BY W.G. Hairston, III
 TELEPHONE (205) 899-5156

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
002	830413	S	38.3	B	1	NA	NA	NA	Turbine overspeed trip test; maintenance outage.

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A Equipment Failure (Explain)
 B Maintenance of Test
 C Refueling
 D Regulatory Restriction
 E Operator Training & License Examination
 F Administrative
 G Operational Error (Explain)
 H Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) Form INUREG-0161)

⁵
 Exhibit I - Same Source