

February 22, 1995

Mr. John F. Opeka  
Executive Vice President, Nuclear  
Connecticut Yankee Atomic Power Company  
Northeast Nuclear Energy Company  
Post Office Box 270  
Hartford, CT 06141-0270

SUBJECT: HADDAM NECK PLANT - (TAC NO. M88583)

Dear Mr. Opeka:

Enclosed is a copy of the Environmental Assessment and Finding of No Significant Impact related to your application for amendment dated December 22, 1993. Connecticut Yankee Atomic Power Company (CYAPCO) has proposed to revise Technical Specification (TS) 3/4.4.10, "Structural Integrity," Surveillance Requirement 4.4.10. The staff has approved for the Cycle 18 refueling outage a footnote to extend the reactor coolant pump flywheel inspection for pumps 1 and 2 until the next cycle.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

Original signed by Ronald W. Hernan

for: Alan B. Wang, Project Manager  
Project Directorate I-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-213

Enclosure: Environmental Assessment

cc w/encl: See next page

DISTRIBUTION:

Docket File	PMcKee	ACRS (4)
PUBLIC	AWang	OPA
PDI-4 Plant	SNorris	LNicholson, RGI
SVarga	CGC	
JZwolinski	EJordan	

9502270216 950222  
PDR ADOCK 05000213  
P PDR

NRC FILE CENTER COPY

\*See previous concurrence

DOCUMENT NAME: G:\WANG\M88583.ENV

OFFICE	LA:PDI-4	PM:PDI-4	D:PDI-4	OGC	*
NAME	SNorris	AWang:cn	PMcKee	CMarco	
DATE	02/21/95	02/21/95	02/22/95	02/16/95	

OFFICIAL RECORD COPY

DFOI

February 22, 1995

Mr. John F. Opeka  
Executive Vice President, Nuclear  
Connecticut Yankee Atomic Power Company  
Northeast Nuclear Energy Company  
Post Office Box 270  
Hartford, CT 06141-0270

SUBJECT: HADDAM NECK PLANT - (TAC NO. M88583)

Dear Mr. Opeka:

Enclosed is a copy of the Environmental Assessment and Finding of No Significant Impact related to your application for amendment dated December 22, 1993. Connecticut Yankee Atomic Power Company (CYAPCO) has proposed to revise Technical Specification (TS) 3/4.4.10, "Structural Integrity," Surveillance Requirement 4.4.10. The staff has approved for the Cycle 18 refueling outage a footnote to extend the reactor coolant pump flywheel inspection for pumps 1 and 2 until the next cycle.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

Original signed by Ronald W. Hernan

for: Alan B. Wang, Project Manager  
Project Directorate I-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-213

Enclosure: Environmental Assessment

cc w/encl: See next page

DISTRIBUTION:

Docket File	PMcKee	ACRS (4)
PUBLIC	AWang	OPA
PDI-4 Plant	SNorris	LNicholson, RGI
SVarga	OGC	
JZwolinski	EJordan	

\*See previous concurrence

DOCUMENT NAME: G:\WANG\M88583.ENV

OFFICE	LA:PDI-4	PM:PDI-4	D:PDI-4	OGC	*
NAME	SNorris	AWang:cn	PMcKee	CMarco	
DATE	02/21/95	02/21/95	02/22/95	02/16/95	

OFFICIAL RECORD COPY



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

February 22, 1995

Mr. John F. Opeka  
Executive Vice President, Nuclear  
Connecticut Yankee Atomic Power Company  
Northeast Nuclear Energy Company  
Post Office Box 270  
Hartford, CT 06141-0270

SUBJECT: HADDAM NECK PLANT - (TAC NO. M88583)

Dear Mr. Opeka:

Enclosed is a copy of the Environmental Assessment and Finding of No Significant Impact related to your application for amendment dated December 22, 1993. Connecticut Yankee Atomic Power Company (CYAPCO) has proposed to revise Technical Specification (TS) 3/4.4.10, "Structural Integrity," Surveillance Requirement 4.4.10. The staff has approved for the Cycle 18 refueling outage a footnote to extend the reactor coolant pump flywheel inspection for pumps 1 and 2 until the next cycle.

The assessment is being forwarded to the Office of the Federal Register for publication.

Sincerely,

*Ronald W. Herman for*  
Alan B. Wang, Project Manager  
Project Directorate I-4  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Docket No. 50-213

Enclosure: Environmental Assessment

cc w/encl: See next page

Mr. John F. Opeka  
Northeast Nuclear Energy Company

Haddam Neck Plant

cc:

Ms. L. M. Cuoco, Senior Nuclear Counsel  
Northeast Utilities Service Company  
Post Office Box 270  
Hartford, Connecticut 06141-0270

R. M. Kacich, Director  
Nuclear Planning, Licensing & Budgeting  
Northeast Utilities Service Company  
Post Office Box 128  
Waterford, Connecticut 06385

J. M. Solymossy, Director  
Nuclear Quality and Assessment Services  
Northeast Utilities Service Company  
Post Office Box 128  
Waterford, Connecticut 06385

S. E. Scace, Vice President  
Nuclear Operations Services  
Northeast Utilities Service Company  
Post Office Box 128  
Waterford, Connecticut 06385

Kevin T. A. McCarthy, Director  
Monitoring and Radiation Division  
Department of Environmental Protection  
79 Elm Street  
Hartford, Connecticut 06106-5127

Regional Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

Allan Johanson, Assistant Director  
Office of Policy and Management  
Policy Development and Planning Division  
80 Washington Street  
Hartford, Connecticut 06106

Board of Selectmen  
Town Office Building  
Haddam, Connecticut 06438

J. J. LaPlatney  
Haddam Neck Unit Director  
Connecticut Yankee Atomic Power Company  
362 Injun Hollow Road  
East Hampton, Connecticut 06424-3099

Resident Inspector  
Haddam Neck Plant  
c/o U.S. Nuclear Regulatory Commission  
361 Injun Hollow Road  
East Hampton, Connecticut 06424-3099

Donald B. Miller, Jr.  
Senior Vice President  
Millstone Station  
Northeast Nuclear Energy Company  
Post Office Box 128  
Waterford, Connecticut 06385

Nicholas S. Reynolds  
Winston & Strawn  
1400 L Street, NW  
Washington, DC 20005-3502

Betsy Higgins Congram (5)  
Environmental Review Coordinator  
John F. Kennedy Federal Building  
Room 2203  
Boston, Massachusetts 02203