



Tennessee Valley Authority, 401 Market Street, Chattanooga, Tennessee 37403

JUN 11 1991

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)
Tennessee Valley Authority

Docket No. 50-327

SEQUOYAH NUCLEAR PLANT (SQN) - TVA RESPONSE TO NRC SAFETY EVALUATION
REPORT (SER) CONCERNING SQN'S UNIT 1 10-YEAR IN-SERVICE INSPECTION (ISI)
PROGRAM

Reference: NRC letter to TVA dated February 7, 1991, "First 10-Year
Interval Inservice Inspection Program (TAC 59457) - Sequoyah
Nuclear Plant, Unit 1"

By the referenced letter, NRC provided the SER for SQN's Unit 1 10-Year
ISI. TVA has completed a review of the subject SER and has identified
one area of concern. The concern pertains to TVA's request for relief
(RFR) ISI-4 and involves the lower-cone transition circumferential shell
weld on the steam generator (SG) secondary side.

NRC evaluation of TVA's RFR was included in the technical evaluation
report (TER) attached to the referenced SER (pages 31 and 33). This
evaluation acknowledges that the lower-cone transition weld is partially
inaccessible because of a permanent support ring and pads on each SG.
American Society of Mechanical Engineers (ASME), Section XI, requires
that 100 percent of one of these welds from one SG be examined each
inspection interval. As a result of the ASME, Section XI, code
requirement and the weld being partially inaccessible, the TER "concluded
that relief from the Code requirements of a volumetric examination of the
above mentioned steam generator circumferential shell welds should be
granted, provided that the welds from other steam generators be
volumetrically examined to the extent that the total examination on the
steam generator welds equals 100% of one weld required to be examined."

9106140019 910611
PDR ADOCK 05000327
PDR

A047
1/8

U.S. Nuclear Regulatory Commission

JUN 11 1991

TVA requests that the original proposed alternative examination of RFR ISI-4 as submitted by TVA be granted without the additional examinations as concluded in the TER. TVA considers this approach to be justified based on the following:

- There is a small probability of weld failure based on history.
- Approximately 68 percent of the weld is volumetrically examined.
- The weld volume examined is spaced around the SG circumference and is well distributed. TVA considers this weld volume to be adequate for detection of problems such as cracking.


Please note that the withdrawal of this requirement for the additional examination will allow consistency with the Unit 2 ISI program previously approved by NRC. This request has been discussed with NRC technical staff.

It is requested that NRC's response be provided by July 31, 1991, to support the scheduling of outage activities for the Unit 1 Cycle 5 refueling outage. This outage is currently scheduled to begin October 4, 1991.

Please direct questions concerning this issue to D. V. Goodin at (615) 843-7734.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


E. G. Wallace, Manager
Nuclear Licensing and
Regulatory Affairs

cc: See page 3

U.S. Nuclear Regulatory Commission

cc: Ms. S. C. Black, Deputy Director
Project Directorate II-4
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. D. E. LaBarge, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

NRC Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323