

NORTHEAST UTILITIES



The Connecticut Light and Power Company
Western Massachusetts Electric Company
Holyoke Water Power Company
Northeast Utilities Service Company
Northeast Nuclear Energy Company

General Offices: Seiden Street, Berlin, Connecticut

P.O. BOX 270
HARTFORD, CONNECTICUT 06414-0270
(203) 665-5000

Docket No. 50-245
Re: 10CFR50, Appendix R

June 18, 1991
MP-91-502

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Millstone Nuclear Power Station, Unit No. 1
Diesel Generator Room - Fire Barrier

Gentlemen:

In accordance with the Special Reporting requirements of Millstone Unit No. 1's Technical Specification 3.12.F.2, Northeast Nuclear Energy Company (NNECO) is providing the NRC Staff with the following information.


On May 20, 1991, at 1700 hours, the Diesel Generator room fire door was removed, rendering the fire barrier inoperable. A continuous fire watch was established in accordance with Technical Specification 3.12.F.2. The fire door was removed to allow the removal of the Diesel Generator rotor, which had to be sent out to be steam cleaned. After evaluation, it was determined that the rotor would have to be rewound. At present, the rotor is being rewound at a vendor location. The door is scheduled to be replaced after the Diesel Generator rotor is returned to the site. The current expected arrival date for the rotor is June 21, 1991.

The fire door will be made operable once the work associated with Diesel Generator rotor installation is completed. In the interim, a continuous fire watch is being maintained in accordance with Technical Specification 3.12.F.2.

Should you have any questions, please feel free to contact my staff.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY


Stephen E. Scace
Director, Millstone Station

SES:ljs

cc: T. T. Martin, Region I Administrator
D. Jaffe, NRC Project Manager, Millstone Unit Nos. 1 and 3
W. Raymond, Senior Resident Inspector, Millstone Unit No. 1

9106260003 910618
PDR ADOCK 05000245
S PDR

IF22
10