

THE CINCINNATI GAS & ELECTRIC COMPANY



E. A. BORGMANN
SENIOR VICE PRESIDENT

June 2, 1982

Docket No. 50-358

Mr. Harold Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

RE: WM. H. ZIMMER NUCLEAR POWER STATION -
UNIT 1 - CONTAINMENT LEAKAGE TESTING

Dear Mr. Denton:

Please refer to the previous CG&E letter on this topic dated November 17, 1981. This is in response to Section 1.8, "Summary of Outstanding Issues" in the second supplement (SSER-2) to the Zimmer Safety Evaluation Report (NUREG-0528). The outstanding issue of containment leakage testing is discussed further in Subsection 6.2-6 of SSER-2.

CG&E will air test its ECCS Injection Lines Isolation Valves. This air test will be accomplished by pressuring the bonnets of the valves. This will be documented in a subsequent FSAR Revision.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By


E. A. BORGMANN

EAB:dew

cc: John H. Frye III
M. Stanley Livingston
Frank F. Hooper
Troy B. Conner, Jr.
James P. Fenstermaker
Steven G. Smith
William J. Moran
J. Robert Newlin
Samuel H. Porter
James D. Flynn
W. F. Christianson
Lynne Bernabei
John D. Woliver
Deborah F. Webb
David K. Martin

George E. Pattison
Andrew B. Dennison

8206080220 820602
PDR ADOCK 05000358
PDR
E

13001