

Duke Power Company  
Nuclear Production Dept.  
P.O. Box 1097  
Charlotte, N.C. 28201-1097

M.S. TUCKMAN  
Vice President  
Nuclear Operations  
(704) 373-3651



DUKE POWER

October 2, 1991

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D. C. 20555

Subject: McGuire Nuclear Station  
Docket Nos. 50-369 and 50-370  
Technical Specification 3.7.8 Amendment  
Inspection of Snubbers

As discussed in a telecon with Mr. Tim Reed of ONRR on October 1, 1991, Duke Power is requesting that the previous Technical Specification (TS) Amendment Submittal for TS 3.7.8, Snubbers, dated August 8, 1991, be revised as follows:

TS page 3/4 7-20, Insert D, 4th line;

"...reclassified acceptable by functionally testing each snubber starting with the piston in the as-found setting,..."

If there are further questions regarding this amendment request, please contact David V. Ethington at (704) 373-2025.

Very truly yours,

M. S. Tuckman, Vice President  
Nuclear Operations

ts378/

cc: Mr. S. D. Ebnetter  
Regional Administrator

American Nuclear Insurers

Dayne Brown, Director  
Division of Radiation Protection

M&M Nuclear Consultants

Mr. P. K. VanDoorn  
Senior Resident Inspector

INPO Records Center

\$110090132 911002  
PDR ADOCK 05000369  
P PDR

A001  
1/0