

Admin JPM RO-A1.1

Facility: Davis-Besse Task No: 004-006-01-0100

Task Title: Perform a BWST Fill Calculation

K/A Reference: 2.1.23 (4.3) Job Performance Measure No: RO-A1.1 (JPM 172)

Examinee: _____

NRC Examiner: _____ Date: _____

Method of testing:

Simulated Performance ____ Actual Performance X

Classroom X Simulator ____ Plant ____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

The plant conditions are specified in the Initial Conditions and Initiating Cues.

Task Standard:

Perform a BWST fill calculation in accordance with Attachment 4 of DB OP-06015, Borated Water Storage Tank Operating Procedure

Required Materials:

Attachment 4 of DB-OP-06015
Calculator

General References:

None

Initiating Cue:

The Initiating Cues are specified in the Examiner/Student Copy Performance Measure pages.

Time Critical Task:

No

Alternate Path:

No

Validation Time:

30 minutes

EXAMINER COPY**INITIAL CONDITIONS:**

The plant is in Mode 5 following a refueling outage

The BWST is at 38 feet and 2640 ppmB

BAAT 1 is at 12000 ppmB

CWRT 1 is at 1100 ppmB

The START program is NOT available

INITIATING CUES:

The Shift Manager desires the BWST level to be raised to 40.5 feet and boron concentration maintained at 2640 ppmB

The Unit Supervisor directs you to perform a BWST fill calculation in accordance with Attachment 4 of DB-OP-06015, Borated Water Storage Tank Operating Procedure using Boric Acid Addition Tank 1 and Clean Waste Receiver Tank 1

(Provide the examinee a copy of Attachment 4 of DB-OP-06015 and a calculator)

CANDIDATE COPY**INITIAL CONDITIONS:**

The plant is in Mode 5 following a refueling outage

The BWST is at 38 feet and 2640 ppmB

BAAT 1 is at 12000 ppmB

CWRT 1 is at 1100 ppmB

The START program is NOT available

INITIATING CUES:

The Shift Manager desires the BWST level to be raised to 40.5 feet and boron concentration maintained at 2640 ppmB

The Unit Supervisor directs you to perform a BWST fill calculation in accordance with Attachment 4 of DB-OP-06015, Borated Water Storage Tank Operating Procedure using Boric Acid Addition Tank 1 and Clean Waste Receiver Tank 1

PERFORMANCE INFORMATION

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is assumed unless denoted in the "Comments".

START TIME: _____

1. PERFORMANCE STEP: Determine Calculation Method

STANDARD: Use Method B of Attachment 4

CUE: **None**

SAT UNSAT

2. PERFORMANCE STEP: Calculate the initial volume of the BWST
.....**C**.....

STANDARD: $12,962 \text{ gal/ft} \times 38 \text{ ft} + 4316 \text{ gal} = 496872 \text{ gal}$
Enter 496872 gal and 2640 ppmB

CUE: **None**

SAT UNSAT

3. PERFORMANCE STEP: Calculate desired BWST volume after the solution addition
.....**C**.....

STANDARD: $12,962 \text{ gal/ft} \times 40.5 \text{ ft} + 4316 \text{ gal} = 529277 \text{ gal}$
Enter 529277 gal and 2640 ppmB

CUE: **None**

SAT UNSAT

4. PERFORMANCE STEP: Calculate total volume to be added to the BWST
.....**C**.....

STANDARD: $529277 \text{ gal} - 496872 \text{ gal} = 32405 \text{ gal}$

CUE: **None**

SAT UNSAT

5. PERFORMANCE STEP: Initiate Part 2 of Section B of Attachment 4

STANDARD: Enter the following values in Part 2:

Volume to be added - 32405 gal

Boron concentration of solution - 2640 ppmB

Boron source and concentration - BAAT 1, 12,000 ppmB

Water source and concentration - CWRT 1, 1100 ppmB

CUE: **None**SAT UNSAT

6. PERFORMANCE STEP: Calculate volume of acid solution

.....**C**.....STANDARD: $\frac{32405 \text{ gal} \times (2640 \text{ ppmB} - 1100 \text{ ppmB})}{12000 \text{ ppmB} - 1100 \text{ ppmB}} = 4578.3211 \text{ gal}$

NOTE: Acceptable range is 4578 to 4579 gal

CUE: **None**SAT UNSAT

7. PERFORMANCE STEP: Calculate volume of water solution

.....**C**.....STANDARD: $32405 \text{ gal} - 4578.3211 \text{ gal} = 27826.6789 \text{ gal}$

NOTE: Acceptable range is 27826 to 27827 gal

CUE: **None**SAT UNSAT

8. PERFORMANCE STEP: Complete Attachment 4

STANDARD: Sign and date attachment

CUE: **None**SAT UNSAT

TERMINATING CUES: This JPM is complete. (Terminated by the examinee)

END TIME _____

Admin JPM RO-A1.2

Facility: Davis-Besse

Task No: 004-006-01-0100

Task Title: Determine the boron concentration needed to ensure 1% SDM with two stuck rods

K/A Reference: 2.1.25 (3.9) Job Performance Measure No: RO-A1.2 (JPM 272)

Examinee: _____

NRC Examiner: _____

Date: _____

Method of testing:

Simulated Performance ____ Actual Performance X

Classroom X Simulator ____ Plant ____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

The plant conditions are specified in the Initial Conditions and Initiating Cues.

Task Standard:

Determine the boron concentration needed to ensure 1% SDM with two stuck rods

Required Materials:

- DB-NE-06202
- DB-NE-06201
- Calculator and ruler

General References:

None

Initiating Cue:

The Initiating Cues are specified in the Examiner/Student Copy Performance Measure pages.

Time Critical Task:

No

Alternate Path:

No

Validation Time:

30 minutes

EXAMINER COPY**INITIAL CONDITIONS:**

The plant is in Mode 3 following a reactor trip.

Two control rods failed to insert on the trip.

The START program is not available.

The following conditions exist:

- Burnup: 500 EFPD
- Tave: 552°F

The Reactor Engineer reports the following values:

- Reactivity worth due to transient poisons: (-) 2.6 % Δ K/K
- Correction factor for Boron 10 depletion: 0.96
- Reactivity Anomaly: 0.0

INITIATING CUES:

The Unit Supervisor directs you to determine the boron concentration needed to ensure 1% shutdown margin in accordance with Section 14 of DB-NE-06202, Reactivity Balance Calculations, and DB-NE-06201, Reactor Operators Curve Book

It is desired to take credit for transient poisons

Provide Candidate a copy of;

- DB-NE-06202
- DB-NE-06201
- Ruler and calculator

CANDIDATE COPY**INITIAL CONDITIONS:**

The plant is in Mode 3 following a reactor trip.

Two control rods failed to insert on the trip.

The START program is not available.

The following conditions exist:

- Burnup: 500 EFPD
- Tave: 552°F

The Reactor Engineer reports the following values:

- Reactivity worth due to transient poisons: (-) 2.6 % Δ K/K
- Correction factor for Boron 10 depletion: 0.96
- Reactivity Anomaly: 0.0

INITIATING CUES:

The Unit Supervisor directs you to determine the boron concentration needed to ensure 1% shutdown margin in accordance with Section 14 of DB-NE-06202, Reactivity Balance Calculations, and DB-NE-06201, Reactor Operators Curve Book

It is desired to take credit for transient poisons

PERFORMANCE INFORMATION

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is assumed unless denoted in the "Comments".

START TIME: _____

1. PERFORMANCE STEP: Determine B (ROCB SDM)

.....**C**.....

STANDARD: Determine B(ROCB SDM) from Figure 6C. Determines the value to be 1475 to 1485 ppmB and enters this value on Attachment 10.

COMMENT: Actual value is 1480 ppmB % Δ K/K.

COMMENT: Sequence NOT required for this JPM except for last step

CUE: **None**

SAT UNSAT

2. PERFORMANCE STEP: Determine CF(B10)

STANDARD: Enters 0.96 value for CF(B10) value from Initial Conditions

CUE: **None**

SAT UNSAT

3. PERFORMANCE STEP: Determine Reactivity Worth of HFP Anomaly

STANDARD: Enters 0 for anomaly value from Initial Conditions

CUE: **None**

SAT UNSAT

4. PERFORMANCE STEP: Determine the Differential Boron Worth (DBW).

STANDARD: Determine DBW value from Figure 5A. Determines value of -0.00719 to -0.00723 % Δ K/K.

COMMENT: Actual value is -0.00721 % Δ K/K. Student may skip this step since it will divide into zero and be zero regardless of the value.

CUE: **None**

SAT UNSAT

5. PERFORMANCE STEP: Determine Transient Poison worth, $\rho(tp)$, for Transient Reactivity Boron Equivalent (B(tr))

STANDARD: Enters (-)2.6 % Δ K/K for $\rho(tp)$ value from the Initial Conditions

CUE: **None**

SAT UNSAT

6. PERFORMANCE STEP: Determine Pu-239 worth, $\rho(PU-max)$, for Transient Reactivity
.....**C**..... Boron Equivalent (B(tr))

STANDARD: From Figure 20B, determines a value of 0.1375 to 0.1385 % Δ K/K for $\rho(PU-max)$

COMMENT: Actual value is 0.138 % Δ K/K

CUE: **None**

SAT UNSAT

7. PERFORMANCE STEP: Determine Transient Poison Conversion Factor (TPCF) for
.....**C**..... Transient Reactivity Boron Equivalent, B(tr)

STANDARD: Determines a value of 85 from Table 1 of the ROCB

CUE: **None**

SAT UNSAT

8. PERFORMANCE STEP: Determine CF(B10) for Transient Reactivity Boron Equivalent, B(tr)

STANDARD: Enters 0.96 value for CF(B10) value from Initial Conditions

CUE: **None**

SAT UNSAT

9. PERFORMANCE STEP: Determine Transient Reactivity Boron Equivalent, B(tr)
.....**C**.....

STANDARD: Performs calculation for B(tr) on Attachment 10. Determine value of 217.94 to 218.04 ppmB

Comment: Actual value is 217.99

CUE: **None**

SAT UNSAT

10. PERFORMANCE STEP: Determine Minimum RCS Boron Concentration for 1% SDM
.....**C**.....

STANDARD: Performs calculation on Attachment 10. Determine value of 1331
to 1343 ppmB

COMMENT: Actual value is 1336.9 ppmB

CUE: **None**

SAT UNSAT

TERMINATING CUES: This JPM is complete. (Terminated by the examinee)

END TIME _____

**Admin JPM
RO-A2**

Facility: Davis-Besse **Task No:** 119-035-0100

Task Title: Determine isolation boundary and effect on safety related equipment

K/A Reference: 2.2.37 (3.6) **Job Performance Measure No:** RO-A2 (NEW-319)

Examinee: _____

NRC Examiner: _____ **Date:** _____

Method of testing:

Simulated Performance ____ Actual Performance X

Classroom X Simulator ____ Plant ____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

The plant conditions are specified in the Initial Conditions and Initiating Cues

Task Standard:

Identify boundary for isolating CC269 and recommend starting CCW Pump 1 to supply cooling water to MUP 1 or swap MUPs due to loss of non-essential cooling within 1 hour

Required Materials:

Operational Schematics OS-021 SH 1 and 2

General References:

None

Initiating Cue:

The Initiating Cues are specified in the Examiner/Student Copy Performance Measure pages.

Time Critical Task:

No

Alternate Path:

No

Validation Time:

20 minutes

EXAMINER COPY**INITIAL CONDITIONS:**

The Plant is at 100% Power

Component Cooling Water Pump 2 is in service

Make-up Pump 1 is in service

A small leak has developed in the piping near CC269, COMPONENT COOLING NON-ESSENTIAL HEADER TO MAKE-UP PUMPS SUPPLY HEADER TEST CONNECTION

INITIATION CUE:

The Shift Manager directs you to;

1. Determine the isolation boundaries for CC269, COMPONENT COOLING NON-ESSENTIAL HEADER TO MAKE-UP PUMPS SUPPLY HEADER TEST CONNECTION

AND

2. List what equipment is affected and recommend what actions should be taken on this page below

(Hand Candidate Copy of Operational Schematics OS-021 SH 1 and 2)

CANDIDATE COPY**INITIAL CONDITIONS:**

The Plant is at 100% Power

Component Cooling Water Pump 2 is in service

Make-up Pump 1 is in service

A small leak has developed in the piping near CC269, COMPONENT COOLING NON-ESSENTIAL HEADER TO MAKE-UP PUMPS SUPPLY HEADER TEST CONNECTION

INITIATION CUE:

The Shift Manager directs you to;

1. Determine the isolation boundaries for CC269, COMPONENT COOLING NON-ESSENTIAL HEADER TO MAKE-UP PUMPS SUPPLY HEADER TEST CONNECTION

AND

2. List what equipment is affected and recommend what actions should be taken on this page below

PERFORMANCE INFORMATION

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is NOT critical unless denoted in the "Comments".

START TIME: _____

NOTE: STEPS CAN BE PERFORMED IN ANY SEQUENCE

- 1. PERFORMANCE STEP: Determines that valve CC1460 must be closed
.....**C**.....

STANDARD: Identifies CC1460, CCW TO MAKE-UP PUMP HEADER INLET will be closed

NOTE: CC125, CCW TO MAKE-UP PUMP & EMERGENCY INSTRUMENT AIR COMPRESSOR HEADER INLET ISOLATION is also acceptable

CUE: **None**

SAT UNSAT

- 2. PERFORMANCE STEP: Determines that valve CC127 must be closed
.....**C**.....

STANDARD: Identifies CC127, MAKE-UP PUMP 1 CCW INLET STOP CHECK TO LUBE OIL COOLER will be closed

CUE: **None**

SAT UNSAT

- 3. PERFORMANCE STEP: Determines that CC128 should be closed (stop check valve)

STANDARD: Identifies CC128, MAKE-UP PUMP 2 CCW INLET STOP CHECK TO LUBE OIL COOLER will be closed

CUE: **None**

SAT UNSAT

3. PERFORMANCE STEP: Identifies the effect of isolating CC269 will have on plant
.....**C**..... equipment

COMMENT: CC1460, CCW TO MAKE UP PUMP HEADER INLET, supplies non-essential
CCW to the Makeup Pumps and the Makeup Pump Aux Gear Oil Systems.
When CC1460 is closed, Makeup Pump oil bearing cooling water will be
supplied by the respective CCW Essential Lines for the Makeup Pumps.

MU Pump operation without CCW cooling shall be limited to a maximum of
1 hour.

STANDARD: Identifies that closing CC1460 OR CC125 will isolate non-essential cooling
water to MUP 1

Recommends starting CCW Pump 1 to supply essential header cooling water
to MUP 1


NOTE: Swap MUPs is also acceptable

CUE: **None**

SAT UNSAT

TERMINATING CUES: This JPM is complete (Terminated by the examinee)

END TIME _____



CONTROL LOGICS

- MCL-1*** WITH REGARD TO THE COMPONENT COOLING WATER SYSTEM, THE FOLLOWING ACTIONS WILL OCCUR IN THE EVENT OF A SAFETY FEATURES ACTUATION SYSTEM (SFAS) SIGNAL.
- | COMPONENT | SIGNAL | ACTION | REMARKS |
|-----------------------|----------------|--------|-------------------------|
| LEVEL 2 SIGNAL | | | |
| PUMP 1-1 | SA231A | K-3 | STARTS BLOCK PUSHBUTTON |
| PUMP 1-2 | SA232A | D-3 | STARTS BLOCK PUSHBUTTON |
| PUMP 1-3 | SA231B, SA232B | D-3 | STARTS BLOCK PUSHBUTTON |
| LEVEL 3 SIGNAL | | | |
| VALVE 1450 | SA322A | C-10 | CLOSES BLOCK PUSHBUTTON |
| VALVE 1457 | SA311C | H-10 | OPENS BLOCK PUSHBUTTON |
| VALVE 1458 | SA312C | H-10 | OPENS BLOCK PUSHBUTTON |
| VALVE 1498 | SA321A | B-9 | CLOSES BLOCK PUSHBUTTON |
| LEVEL 4 SIGNAL | | | |
| VALVE 1328 | SA421D | B-34 | CLOSES BLOCK PUSHBUTTON |
| VALVE 1338 | SA422D | C-34 | CLOSES BLOCK PUSHBUTTON |
| VALVE 1407A | SA421B | C-27 | CLOSES BLOCK PUSHBUTTON |
| VALVE 1407B | SA422B | C-29 | CLOSES BLOCK PUSHBUTTON |
| VALVE 1411A | SA421A | D-27 | CLOSES BLOCK PUSHBUTTON |
| VALVE 1411B | SA422A | D-29 | CLOSES BLOCK PUSHBUTTON |
| VALVE 1567A | SA421C | B-28 | CLOSES BLOCK PUSHBUTTON |
| VALVE 1567B | SA422C | B-30 | CLOSES BLOCK PUSHBUTTON |
- TO STOP A COMPONENT COOLING WATER PUMP OR TO CHANGE POSITION OF A COMPONENT COOLING WATER VALVE DURING AN SFAS, EACH COMPONENT'S "BLOCK" PUSHBUTTON MUST BE DEPRESSED FIRST.
- MCL-2*** COMPONENT COOLING WATER PUMP 1-1 (ZONE K-3) WILL TRIP IF ANY OF THE FOLLOWING CONDITIONS EXIST:
- PHASE OR C TIME DELAY OVERCURRENT SENSED BY RELAY CO (SEE NOTE 5) AND PHASE A OR C INSTANTANEOUS OVERCURRENT SENSED BY RELAY IIT
 - INSTANTANEOUS GROUND OVERCURRENT SENSED BY 500S RELAY
 - PHASE A OR C INSTANTANEOUS OVERCURRENT SENSED BY RELAY IIT
- LOGIC FOR PUMPS 1-2 AND 1-3 (ZONES D-3 AND G-3) ARE SIMILAR.
- MCL-3*** COMPONENT COOLING WATER VALVE 1460 (ZONE C-10) WILL AUTOMATICALLY CLOSE IF COMPONENT COOLING WATER SURGE TANK LEVEL SIDE 2 > 38 IN AS SENSED BY LSL3757A (ZONE F-44).
- MCL-4*** COMPONENT COOLING WATER AUXILIARY EQUIPMENT INLET VALVE 1495 (ZONE B-9) WILL AUTOMATICALLY CLOSE IF COMPONENT COOLING WATER SURGE TANK LEVEL SIDE 1 > 47 IN AS SENSED BY LSL3757A (ZONE F-38).
- MCL-5*** COMPONENT COOLING WATER SURGE TANK ATMOSPHERIC VENT VALVE 1412 (ZONE A-4) WILL AUTOMATICALLY SHUT TO THE WASTE DRAIN TANK IF HIGH RADIATION IS SENSED BY RSH1412 OR RSH1413 (ZONES J-1 AND C-1).
- MCL-6*** DELETED
- MCL-7*** COMPONENT COOLING WATER LINE 1 VALVE 2645 (ZONE K-11) WILL AUTOMATICALLY CLOSE IF IT IS > 20% OPEN AND COMPONENT COOLING WATER SURGE TANK LEVEL SIDE 2 IS > 37.25 IN AS SENSED BY LSL3757B (ZONE E-38) AND > 37.25 IN AS SENSED BY LSL3757C (ZONE D-38) OR THE BREAKERS FOR PUMPS 1-1 AND 1-3 ARE BOTH OPEN. VALVE 2645 WILL AUTOMATICALLY OPEN IF CONDITIONS I, II, III AND (IV OR V) EXIST:
- VALVE > 20% OPEN
 - SURGE TANK LEVEL SIDE 1 > 37.125 IN AS SENSED BY LSL3757B AND LSL3757C
 - COMPONENT COOLING WATER FLOW < 1000 GPM AS SENSED BY F151423C (ZONE E-5)
 - BREAKER FOR PUMP 1-1 IS IN THE TEST OR RACKED OFF POSITION.
 - COMPONENT COOLING WATER FLOW < 1000 GPM AS SENSED BY F151427C (ZONE F-5).
- LOGIC FOR COMPONENT COOLING WATER HEADER DISCHARGE LINE 1 INLET ISOLATION VALVE 5095 (ZONE D-8) AND COMPONENT COOLING WATER HEADER INTAKE LINE 1 RETURN ISOLATION VALVE 5097 (ZONE J-11) IS SIMILAR.

NOTES

- ALL VALVES ARE PREFIXED WITH "CV" UNLESS OTHERWISE NOTED.
- FOR GENERAL NOTES, INSTRUMENTATION SYMBOLS, AND OPERATIONAL SCHEMATIC INDEX, SEE INDEX SHEET DWG 05-000.
- DELETED
- FOR THE OPERATION OF TIC1424, TIC1429 AND TIC1434 (ZONES K-7, G-7 AND D-7) SEE SERVICE WATER SYSTEM DWG 05-020, MCL-7*.
- WHITE INDICATING LIGHT ON HANDSWITCHES HIS1414, HIS1416A, HIS1416B AND HIS1418 (ZONES J-3, F-2, F-4 AND C-3) ONLY ILLUMINATES WHEN DELAYED OVERCURRENT ALARM RELAY HAS OPERATED. WHENEVER THE COMPONENT COOLING WATER SYSTEM IS IMPROPER, THE OPERATOR IS TO PLACE HANDSWITCH HS4801 (ZONE H-16) IN "NOT OPER" AS INDICATED BY THE "BYPASS" LIGHT (ZONE H-16).



NOTES CONT'D ON SH. 2

ANNUNCIATOR TABLE

ANNUNCIATOR	ANNUNCIATOR ENGRAVING
3-B	EDG 1 CCV FLOW LO
3-J	EDG 2 CCV FLOW LO
1-1	EDG RETURN RAD HI
1-2	CCW HX 1 OUTLET TEMP HI
1-3	CCW SURGE 1 LV. LO-LO
1-4	CCW HX 2 OUTLET TEMP HI
1-5	CCW SURGE 2 LV. LO
1-6	CCW HX 3 OUTLET TEMP HI
1-7	CCW SURGE 3 LV. LO
1-8	CCW PMP 1 FLOW LO
1-9	CCW PMP 2 FLOW LO
1-10	CCW PMP 3 FLOW LO

LEGEND

- GREEN DENOTES DEVICES LOCATED IN THE CONTROL ROOM
- BLUE DENOTES COMPONENT COOLING WATER LINE 1 FLOWPATH
- ORANGE DENOTES COMPONENT COOLING WATER LINE 2 FLOWPATH
- RED DENOTES COMPONENT COOLING WATER SYSTEM COMMON SUPPLY FLOWPATH
- PURPLE DENOTES COMPONENT COOLING WATER SYSTEM COMMON RETURN FLOWPATH

FOR CONTROL LOGICS, NOTES AND REFERENCES SEE 05-021 SH 2 AND SH 3

REV	DATE	BY	CHKD	APP'D	DESCRIPTION
1	11-15-00
2	08-15-04
3	02-28-05
4	05-09-07
5	01-14-08
6	08-15-08
7	08-15-08
8	08-15-08
9	08-15-08
10	08-15-08
11	08-15-08
12	08-15-08
13	08-15-08
14	08-15-08
15	08-15-08
16	08-15-08
17	08-15-08

DAVIS-BESSE NUCLEAR POWER STATION
UNIT NO 1

OPERATIONAL SCHEMATIC
COMPONENT COOLING WATER SYSTEM

DRAWING NO: 05-021 SH 1
REV: 39

DB 04-04-16
DPM / OPSCH/05211.DGN

**Admin JPM
RO-A3**

Facility: Davis-Besse Task No: 000-044-05-0100

Task Title: Calculate Steam Generator Tube Leak Rate

K/A Reference: 2.3.5 (2.9) Job Performance Measure No: RO-A3 (JPM 316)

Examinee: _____

NRC Examiner: _____ Date: _____

Method of testing:

Simulated Performance ____ Actual Performance X

Classroom X Simulator ____ Plant ____

Read to the examinee:

I will explain the initial conditions, which steps to simulate or discuss, and provide initiating cues. When you complete the task successfully, the objective for this job performance measure will be satisfied.

Initial Conditions:

The plant conditions are specified in the Initial Conditions and Initiating Cues.

Task Standard:

Determine SG Tube leak rate

Required Materials:

Calculator

General References:

DB-OP-02531, SG Tube Leaks, Attachment 1, SG Tube Leak Rate calculations
Chemistry Data Sheet

Initiating Cue:

The Initiating Cues are specified in the Examiner/Student Copy Performance Measure pages.

Time Critical Task:

No

Validation Time:

15 minutes

EXAMINER COPY**INITIAL CONDITIONS:**

The unit is at 100% power

SG 1 has a tube leak

Pressurizer level is 220 inches and steady

The Computer Calculation for RCS Leakage is NOT available

EO reports Steam Jet Air Ejector flow is 15 scfm

INITIATING CUE:

The Shift Manager directs you to perform a SG Tube Leak calculation using

- DB-OP-02531
- Attachment 1, RCS LEAK RATE CALCULATION
- Section 4, Leak Rate Estimation Using RE 1003A or RE 1003B

Provide the examinee a copy of

- **DB-OP-02531 Attachment 1, RCS Leak Rate Calculation**
- **Pictures of RE 1003A and RE 1003B**
- **Chemistry Data Sheet**

CANDIDATE COPY**INITIAL CONDITIONS:**

The unit is at 100% power

SG 1 has a tube leak

Pressurizer level is 220 inches and steady

The Computer Calculation for RCS Leakage is NOT available

EO reports Steam Jet Air Ejector flow is 15 scfm

INITIATING CUE:

The Shift Manager directs you to perform a SG Tube Leak calculation using

- DB-OP-02531
- Attachment 1, RCS LEAK RATE CALCULATION
- Section 4, Leak Rate Estimation Using RE 1003A or RE 1003B

PERFORMANCE INFORMATION

NOTE: Critical steps denoted with a "C". Failure to meet any one of these standards for this item constitutes failure. Sequence is assumed unless denoted in the "Comments".

START TIME: _____

1. PERFORMANCE STEP: Record Date and time

STANDARD: Correct date and time used

CUE: **None**

SAT UNSAT

2. PERFORMANCE STEP: Record Steam Jet Air Ejector radiation levels
.....**C**.....

STANDARD: Correctly read RE 1003A (1.02E4 cpm) and RE 1003B (3.97E3 cpm)

CUE: **None**

SAT UNSAT

3. PERFORMANCE STEP: Convert RE readings (cpm) to $\mu\text{Ci/cc}$
.....**C**.....

STANDARD: Correctly multiply SJAE reading by conversion factor:

RE 1003A = 6.63E-05 $\mu\text{Ci/cc}$

RE 1003B = 1.27E-04 $\mu\text{Ci/cc}$

COMMENT: Acceptable Range

RE 1003A = 6.6E-05 to 6.7E-05 $\mu\text{Ci/cc}$

RE 1003B = 1.2E-04 to 1.3E-04 $\mu\text{Ci/cc}$

CUE: **None**

SAT UNSAT

- 4. PERFORMANCE STEP: Record Steam Jet Air Ejector (SJAE) flow from FI1002
.....**C**.....

STANDARD: Correctly record 15 scfm, as given in the initial cue by an EO

CUE: **None**

SAT UNSAT

- 5. PERFORMANCE STEP: Record the latest RCS Xe-133 activity from Chemistry
.....**C**.....

STANDARD: Refers to the Chemistry Data Sheet, correctly record
RCS Xe-133 activity (6.66E-03 μ Ci/cc)

CUE: **None**

SAT UNSAT

- 6. PERFORMANCE STEP: Calculate primary-to-secondary tube leak using RE 1003B
.....**C**.....

STANDARD: Correctly calculate tube leak using RE 1003B (2.14 gpm)

COMMENT: Acceptable Range 2 to 3 gpm


CUE: **None**

SAT UNSAT

TERMINATING CUES: This JPM is complete (Terminated by the examinee)


END TIME _____

CHEMISTRY ANALYSES STATUS



PRIMARY (RCS)				SECONDARY (FEEDWATER)			
Date: Today				Date: Today			
Specification		Value		Specification		Value	
≤5	O ₂	<2	ppb	≤5	O ₂	<2	ppb
≤50	Cl ⁻	0.73	ppb	≥20	N ₂ H ₄	74	ppb
≤50	F ⁻	0.94	ppb	≤10	SiO ₂	<5	ppb
≤50	SO ₄ ⁻²	0.19	ppb	≤1	Na ⁺	0.06	ppb
DBRM-CHEM-0001	Li	1.27	ppm	≤3	Cl ⁻	0.28	ppb
25 - 50	H ₂	37.3	cc/kg	≤1	SO ₄ ⁻²	<0.064	ppb
≤10	Zinc	4.84	ppb	≤5	Total Iron	0.37	ppb
≤1.0	DEI-131	1.23E-4	μCi/gm	≥2	ETA	2.53	ppm
*2x steady state value	I-131	3.42E-5	μCi/gm	≥6	MPA	7.28	ppm
*Increase of ≥0.01	Xe-133	6.66E-03	μCi/gm	<100 Condensate Dissolved O ₂		8.1	ppb
*<1.0	Xe-133/Xe-135 Ratio	0.85		CEI-R (Month): 0.04 CEI-R (Rolling): 0.23			
100/Ē	Specific Act.	0.15	μCi/gm	Issues/Challenges: None.			
100/Ē	Maximum Limit	913	μCi/gm	Makeup Tank Pressure Band: 30-40 psig			
BORON (PPM)						Primary-To-Secondary Leakage	
Vessel	Measured	Effective	**Acceptable Range	Time	Date	Based on RI-1003: <1.98 gal per day	
RCS	291			0800	10/11/19	Based on DB-CH-03031: <5 gal per day	
PZR	345			1640	10/4/19	Details for RE1003A/B Equivalent cpm for OTSG leakage are on page 2 of 2	
BWST	2748	2711	2626 - 2772	0955	10/8/19		
BAAT 1	11372	11297	7954 - 12994	0130	10/5/19		
BAAT 2	12165	12153	7954 - 12994	0123	9/28/19		
CWRT 1	2691	2684	2626-2772	0920	8/27/19		
CWRT 2	1149			1730	8/23/18		
CFT 1	2916	2903	2626 - 3465	1048	9/19/19		
CFT 2	2880	2880	2626 - 3465	1425	9/19/19		
SFP	2608	2576	≥630	0820	10/8/19		
Refuel Canal	N/A		Per COLR	N/A	N/A		
<p>NOTES</p> <p>* <u>IF</u> any Fuel Integrity Action Level is reached, <u>THEN</u> make notifications in accordance with NOP-NF-1102, Fuel Integrity Monitoring and Assessment.</p> <p>** Acceptable Range is for Effective boron results and accounts for 1% analysis uncertainty. Effective boron results are corrected for Boron-10 depletion.</p>							
Comments:							

CHEMISTRY ANALYSES STATUS



RE 1003A/B Equivalent cpm for OTSG Leakage					
Date determined	Today				
Based on RCS Xe-133	6.66E-03 $\mu\text{Ci/cc}$				
Based on FI 1002	15 cfm				
			RE 1003A		RE 1003B
Efficiency used for calculation			6.5E-9	$\mu\text{Ci/cc/cpm}$	3.2E-8 $\mu\text{Ci/cc/cpm}$
5 GPD			1.2E2	cpm	1.5E2 cpm
30 GPD			1.5E2	cpm	1.5E2 cpm
75 GPD			2.0E2	cpm	1.6E2 cpm
150 GPD			2.9E2	cpm	1.8E2 cpm
Increase of 30 GPD			3.5E1	cpm \uparrow	7.1E0 cpm \uparrow

Comment: _____

Completed by _____ Date/Time _____ / _____

Verified by _____ Date/Time _____ / _____

Reviewed by _____ Date/Time _____ / _____

Shift Manager