



# MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

December 13, 1982

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30306

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Inoperable Fire Door  
LER 82-120/99 X-0  
AECM-82/592

During shutdown, fire door 1A106 was opened in order to drain Standby Service Water loop B. This event is reported pursuant to Technical Specification 3.7.7.a. Attached is an interim report, LER 82-120/99 X-0.

Yours truly,

*[Signature]*  
FOR J. P. McGaughy JR

JPM:sap  
Attachment

cc: Mr. N. L. Stamplev (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8212170137 821213  
PDR ADOCK 05000416  
S PDR

OFFICIAL COPY

LE 22