




UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

5.

June 7, 1983

OFFICE OF THE  
COMMISSIONER

MEMORANDUM FOR: Samuel J. Chilk, SECY  
FROM: James K. Asselstine   
SUBJECT: EMERGENCY OPERATIONS FACILITY FOR THE TROJAN NUCLEAR  
PLANT (SECY-83-199)

The subject paper is before the Commission as a negative consent paper. In some cases, I believe it may be acceptable for a licensee to have a primary Emergency Operations Facility (EOF) within 10 miles of the plant and a backup EOF between 10 and 20 miles of the plant, neither of which has complete habitability features. However, I agree with the staff's disapproval of the licensee's proposal in this case.

cc: Chairman Palladino  
Commissioner Gilinsky  
Commissioner Ahearne  
Commissioner Roberts  
OGC  
OPE  
EDO