

DUANE ARNOLD ENERGY CENTER	Page 1 of 66
TITLE: INSERVICE TESTING PROGRAM	Date 12-23-83 Rev. 5

DUANE ARNOLD ENERGY CENTER

INSERVICE TESTING PROGRAM

APPROVED BY:

James Rushmore
PLANT PERFORMANCE SUPERVISOR

12-20-83

DATE

APPROVED BY:

Daniel L. Mihalek
PLANT SUPERINTENDENT - NUCLEAR

12-20-83

DATE

REVIEWED BY:

Rocky Johnson
OPERATIONS COMMITTEE CHAIRMAN

12-20-83

DATE

REVIEWED BY:

Keith Young for
ALAR A COORDINATOR

12-20-83

DATE

Effective Date: 12/23/83

DUANE ARNOLD ENERGY CENTER	Page 2 of 66
TITLE: INSERVICE TESTING PROGRAM	Date 12-23-83 Rev. 5

List of Effective Pages

TITLE: Duane Arnold Energy Center
Inservice Testing Program

Page Number	Revision	Date
1 - 66	5	12-23-83
Appendix A		
1 - 3	5	12-23-83
Appendix B		
1 - 67	5	12-23-83
Appendix C		
1	5	12-23-83

DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

Page 3 of 66

Date 12-23-83 Rev. 5

Iowa Electric Light and Power Company

Duane Arnold Energy Center

(Docket No. 50-331)

ASME INSERVICE TESTING PROGRAM

FOR

PUMPS AND VALVES

RECORD OF REVISIONS

REVISION

DATE

Original

March 1, 1978

Rev. 1

October, 1978

Rev. 2

May 1, 1980

Rev. 3

November 1, 1980

Rev. 4

January 1, 1983

Rev. 5

December 23, 1983

DUANE ARNOLD ENERGY CENTER	Page 4 of 66
TITLE: INSERVICE TESTING PROGRAM	Date 12-23-83 Rev. 5

TABLE OF CONTENTS

	<u>Page</u>
Title Page	1
List of Effective Pages	2
Record of Revisions	3
Table of Contents	4
List of Tables	5
List of Figures	6
1.0 INTRODUCTION	7
2.0 TESTING PROGRAM FOR PUMPS	8
2.1 General Information	8
2.1.1 Applicable Code	8
2.1.2 Pump Program Tables	8
2.1.3 Measurement of Test Quantities	9
2.1.4 Allowable Ranges of Test Quantities	9
2.1.5 Bearing Lubricant	9
2.1.6 Instrument Accuracy	9
2.1.7 Exempted Pumps	9
2.2 Relief Requests for Pump Testing Program	10
3.0 TESTING PROGRAM FOR VALVES	23
3.1 General Information	23
3.2 Relief Requests for Valve Testing Program	29
Appendix A - Pump Testing Program	
Appendix B - Valve Testing Program	

DUANE ARNOLD ENERGY CENTER	Page 5 of 66
TITLE: INSERVICE TESTING PROGRAM	Date 12-23-83 Rev. 5

LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
PR-8.1	Allowable Ranges of Vibration Velocity Quantities	20
3.1-1	Inservice Valve Test	26
3.1-2	Test Frequency	28

DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

Page 6 of 66

Date 12-23-83 Rev. 5

LIST OF FIGURES

Figure

Title

Page

PR-5.1

Alternate testing Approach for
Determination of Hydraulic Change

16

1.0 INTRODUCTION

Revision 5 of the Duane Arnold Energy Center (Unit 1) ASME Inservice Testing Program for Pumps and Valves will be in effect through February 1, 1985, the end of the first 120-month (10-year) inspection interval. The program will be updated prior to the start of the second inspection interval in accordance with the requirements of 10CFR 50.55a(g).

This document outlines the inservice testing (IST) program for Duane Arnold Energy Center, based on the requirements of Section XI of the ASME Boiler & Pressure Vessel Code, 1980 Edition through the Winter 1980 Addenda. All references to IWP or IWF in this document correspond to Subsections IWP or IWF, respectively, of ASME Section XI, 1980 Edition through the Winter 1980 Addenda unless otherwise noted.

The inservice inspection (ISI) classification boundaries for the Duane Arnold Energy Center are identical to the design classification or quality group boundaries shown on the plant piping and instrument diagrams (P&IDs). This IST program was developed using the ISI classification boundaries and the following documents:

- Title 10, Code of Federal Regulations, Part 50, paragraph 50.55a(g)
- NRC Regulatory Guides Division 1
- Standard Review Plan 3.9.6, "Inservice Testing of Pumps and Valves"
- Division 1 (Draft) Regulatory Guide and Value/Impact Statement, "Identification of Valves for Inclusion in Inservice Test Programs"
- "NRC Staff Guidance for Preparing Pump and Valve Testing Programs and Associated Relief Request," January 1978
- Final Safety Analysis Report, Duane Arnold Energy Center
- Technical Specifications, Duane Arnold Energy Center

The inservice tests identified in this program will verify the operational readiness of pumps and valves whose functions are required to mitigate the consequences of an accident or to bring the reactor to a cold shutdown condition. The ISI classification of each pump and valve matches the ISI classification indicated on the P&IDs excepting those pumps and valves in the IST boundaries that are identified as non-classed (NC).

FOR INFORMATION
ONLY

2.0 TESTING PROGRAM FOR PUMPS2.1 General Information

2.1.1 Applicable Code

This Inservice Testing Program for ISI Class 1, 2, 3 and NC Pumps meets the requirements of Subsection IWP of Section XI of the ASME Boiler and Pressure Vessel Code, 1980 Edition through the Winter of 1980 Addenda. Where these requirements are determined to be impractical, specific requests for relief have been written and included in Section 2.2.

2.1.2 Pump Program Tables

The tables in Appendix A list all pumps included in the Duane Arnold Energy Center IST Program. Data contained in these tables identifies those pumps subject to inservice testing, the inservice test quantities, the inservice testing interval, and any applicable remarks. The column headings are listed and explained below:

- PUMP NUMBER: The pump identification number
- PUMP NAME: The system of which the pump is a component.
- CLASS: The ISI classification of the pump
- P&ID: The DAEC drawing number for the P&ID referring to the pump
- COOR: The drawing coordinate location of the pump on the P&ID
- SPEED, INLET PRES, DIFF PRES, FLOWRATE, VIBRATION AND BEARING TEMP: Inservice test quantities to be measured. When the character "Y" appears in a particular test quantity column, that quantity will be measured during inservice testing in accordance with Subsection IWP. If a modified test is planned or if the character "N" appears in a particular test quantity column, a request for relief number will be referenced. Requests for relief are identified PR-X. The requests for relief are included in Section 2.2.
- TEST INTERVAL: The frequency of testing.
- REMARKS: Remarks in the IST Program are coded as Note 001, Note 002, etc.

2.1.3 Measurement of Test Quantities

- SPEED: Per IWP-4400, shaft speed measurements are not applicable (NA) for pumps directly coupled to synchronous or induction-type drivers. For variable speed pumps, the pump speed is set at the reference speed per IWP-3100.
- INLET PRESSURE: For pumps taking suction from a tank or the residual heat removal (RHR) service water complex basin, inlet pressure will be calculated (using appropriate correction factors) from a measured tank or basin level. All other inlet pressure measurements will be taken using pressure instruments at or near the pump inlet.
- DIFFERENTIAL PRESSURE: Differential pressure will be calculated from inlet and discharge pressure measurements or by direct differential pressure measurement.
- FLOWRATE: Pump flowrate will be measured.
- VIBRATION: Pump vibration will be measured.
- BEARING TEMPERATURE: Pump bearing temperature(s) will be measured when practical.

2.1.4 Allowable Ranges of Test Quantities

The allowable ranges specified in Table IWP-3100-2 will be used for differential pressure, flow and vibration measurements except as discussed in PR-8. Should a measured test quantity fall outside the allowable range, the possibility of defining an expanded allowable range, in accordance with ASME Code interpretation XI-1-79-19, will be investigated. In some cases, the performance of a pump may be adequate to fulfill its safety function even though there may be some parameter variation outside of the allowable ranges.

2.1.5 Bearing Lubricant

As specified in Table IWP-3100-1, the pump bearing lubricant level or pressure will be observed during inservice testing.

2.1.6 Instrument Accuracy

Allowable instrument accuracies are given in Table IWP-4110-1. In some cases, relief has been requested from the requirements of Table IWP-4110-1. (See Relief Request No. PR-7)

2.1.7 Exempted Pumps

The reactor recirculation centrifugal pumps have been exempted from the IST program because they do not perform a safety function. The reactor recirculation jet pumps have been exempted from the IST program because Subsection IWP is applicable to centrifugal and positive displacement pumps only. These pumps have been exempted in accordance with IWP-1100.

DUANE ARNOLD ENERGY CENTER

Page 10 of 66

TITLE: INSERVICE TESTING PROGRAM

Date 12-23-83 Rev. 5

SECTION 2.2

RELIEF REQUESTS FOR PUMP TESTING PROGRAM

DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

Page 11 of 66

Date 12-23-83 Rev 5

RELIEF REQUEST NO. PR-1

PUMP NUMBER:

DIESEL FUEL OIL PUMPS IP-44A and IP-44B

SECTION XI REQUIREMENTS:

Measure pump vibration amplitude quarterly and bearing temperature annually.
(IWP-3100)

BASIS FOR RELIEF:

The diesel fuel oil pumps and motors are inaccessible during operation. Both the pump and motor are submerged inside the diesel fuel oil tank (IT-35).

ALTERNATE TESTING:

No alternate testing is proposed.

FOR INFORMATION
ONLY

RELIEF REQUEST NO. PR-2

PUMP NUMBER:

EMERGENCY SERVICE WATER (ESW) PUMPS 1P-99A and 1P-99B.

SECTION XI REQUIREMENTS:

Measure bearing temperature annually. (IWP-3100)

BASIS FOR RELIEF:

The ESW pump motors are provided with roller bearings immersed in an integral oil bath reservoir. Discussions with the manufacturer of the motors (General Electric Company) indicate that measuring bearing temperatures would be difficult and of marginal value. Likewise, measuring oil temperature on an annual basis, is also questionable. It is estimated that approximately four hours of pump operation would be required for the oil temperature to stabilize. Furthermore, in this particular case due to the arrangement of the oil reservoir, oil temperature is more a function of winding and ambient air temperatures than of bearing temperature. It is likely that annual trends of oil temperature in this case would be of little value in determining the condition of pump bearings.

ALTERNATE TESTING:

No alternate testing is proposed.

RELIEF REQUEST NO. PR-3

PUMP NUMBER:

HIGH PRESSURE COOLANT INJECTION (HPCI) booster and main pumps 1P-216
REACTOR CORE ISOLATION COOLING (RCIC) pump 1P-226

SECTION XI REQUIREMENTS:

Measure pump vibration amplitude quarterly and bearing temperature annually.
(IWP-3100)

BASIS FOR RELIEF:

These measurements require stationing a man in close proximity to the pumps in the HPCI and RCIC rooms. Because of the rooms' layout, the man would be in a confined area distant from the exits. Consequently, should an accident occur such as the rupture of a steam line rupture disc, which has occurred previously (Ref. RO 78-02), the man probably could not exit in time to prevent serious injury. Thus, measurement of HPCI and RCIC pump vibration and bearing temperatures represents a significant safety hazard.

ALTERNATE TESTING:

Installation of permanent sensors for bearing temperature and vibration with remote readouts is under evaluation and is slated for completion in 1985. At that time measurements will be taken in accordance with IWP-3100 or request for relief will be submitted.

RELIEF REQUEST NO. PR-4

PUMP NUMBER:

RHR SERVICE WATER PUMPS 1P-22A, B, C, & D
ESW PUMPS 1P-99A & B
RIVER WATER PUMPS 1P-117A, B, C, & D
DIESEL FUEL OIL TRANSFER PUMPS 1P-44A & B
STANDBY LIQUID CONTROL PUMPS 1P-230A & B

SECTION XI REQUIREMENTS:

Measure pump inlet pressure before starting the pump and during the test.
(Table IWP-3100-1)

BASIS FOR RELIEF:

Pumps other than 1P-230 A & B are submerged and have inlet pressures which correspond to levels of the wet pit, the river, or diesel oil storage tank. Because these levels remain relatively constant before and during the test, only one measurement per test is necessary.

In the case of the standby liquid control (SBL) pumps, no gauge is installed at the pump suction and suction pressure is assumed to be equivalent to the static head corresponding to the average height of test tank level above the pump suction.

ALTERNATE TESTING:

One inlet pressure, based on wet pit, river, or oil tank level, will be calculated per test.

One suction pressure for the SBL Pumps will be calculated from the average test tank level during the test.

RELIEF REQUEST NO. PR-5

PUMP NUMBER:

RIVER WATER PUMPS 1P-117A, B, C, and D
CORE SPRAY PUMPS 1P-211A and B
HPCI PUMP 1P-216
RCIC PUMP 1P-226
RHR PUMPS 1P-229A, P, C, and D

SECTION XI REQUIREMENT:

Reference values shall be at points of operation readily duplicated during subsequent inservice testing. (IWP-3110)

BASIS FOR RELIEF:

Operating experience has shown that flowrates (independent variables during inservice performance testing) cannot be readily duplicated with the present flow control systems. Efforts to exactly duplicate reference values would require excessive valve manipulation which could ultimately result in damage to valves or operators.

ALTERNATE TESTING:

DAEC will implement an alternate means of measuring pump performance. Reference values will be established for flowrate (Q_r) and differential pressure (dP_r) during the reference value tests. However, in lieu of duplicating Q_r during subsequent inservice performance tests, a flowrate (Q_1), lower than Q_r , will be obtained and recorded along with the corresponding differential pressure (dP_1). Next, a flowrate (Q_h), higher than Q_r , will be obtained and recorded along with its corresponding differential pressure (dP_h). These two points, (Q_1, P_1) and (Q_h, P_h), define a small portion of the pump curve which intersects the vertical line defined by Q_r . (See Figure PR-5.1). Using linear interpolation between the two points, a differential pressure (dP) will be computed from the intersection of the pump curve and the vertical line established by Q_r . This computed value for dP will be recorded and compared to the reference differential pressure (dP_r) per table IWP-3100-2.

The alternate testing procedure described above assumes that the pump curve is nearly linear between Q_1 and Q_h . Procedural limits for Q_1 and Q_h have been established and individual pump curves have been analyzed to ensure near linearity between Q_1 and Q_h .

FOR INFORMATION

ONLY




Figure PR-5.1 Alternate Testing Approach for Determination of Hydraulic Change

RELIEF REQUEST NO. PR-6

PUMP NUMBER:

DIESEL FUEL OIL TRANSFER PUMPS 1P-44A and B

SECTION XI REQUIREMENTS:

Each pump shall be run at least five minutes under conditions as stable as system permits. (IWP-3500)

BASIS FOR RELIEF:

The diesel fuel oil transfer pumps cannot be operated for five minutes because the available capacities of the diesel oil day tanks are too small. Sufficient volume for both five minutes of operation and flow measurement by increase in tank level is required. Since the tank is filled at the end of each diesel generator operability test, about two hours of operation of the diesel generator would be needed to reduce the tank level to that required for retesting of the fuel oil pumps. The additional hour of operation of the diesel generator, beyond the one hour technical specification requirement, is unacceptable.

ALTERNATE TESTING:

As soon as the diesel fuel oil transfer pumps reach stable operation at the reference conditions, as indicated by a steady reading of the discharge pressure gauges, test data will be recorded.

RELIEF REQUEST NO. PR-7

PUMP NUMBER:

DIESEL OIL TRANSFER PUMPS 1P-44A and B
RIVER WATER PUMPS 1P-117A, B, C and D
HPCI PUMP 1P-216
RCIC PUMP 1P-226

SECTION XI REQUIREMENTS:

Instrument accuracy shall be within the limits of Table IWP-4110-1.

BASIS FOR RELIEF.

Based on engineering judgement, the difference between an instrument with an accuracy of \pm 2.0 percent of full scale and one with an accuracy of \pm 2.25 percent of full scale is insignificant. The costs due to replacing the existing instrumentation with new devices that meet the limits of Table IWP-4110-1 are not justified since there will be no corresponding improvement in the level of plant safety.

ALTERNATE TESTING:

Inservice test measurements of pressure, differential pressure, and flowrate will be taken using instruments with instrument accuracies that are less than or equal to \pm 2.25 percent of full scale.

RELIEF REQUEST NO. PR-8

PUMP NUMBER:

All pumps (except Diesel Fuel Oil Transfer Pumps 1P-44 A & B).

SECTION XI REQUIREMENTS:

At least one displacement vibration amplitude (peak-to-peak composite) shall be read during inservice testing. (IWP-4510)

BASIS FOR RELIEF:

Measuring vibration in velocity units rather than amplitude is an industry accepted method considered to be more sensitive to small changes that oftentimes are indicative of developing mechanical problems. Velocity measurements detect not only high-amplitude vibration, characteristic of major mechanical problems, but low-amplitude vibrations caused by misalignment, imbalance, or bearing wear.

ALTERNATE TESTING:

Where practical, pump vibration measurements will be taken in velocity units. In all other cases, displacement measurements will conform to Paragraph IWP 4510. Acceptance criteria for velocity measurements will conform to ASME Publication 78-WA/NE-5 and Table PR-8.1.

TABLE PR-8.1

(1)

ALLOWABLE RANGES OF TEST QUANTITIES

QUANTITY	ACCEPTABLE RANGE	ALERT RANGE		REQUIRED ACTION RANGE	
		LOW	HIGH	LOW	HIGH
v When $0 \leq v_r \leq .15$ in/sec	0 to .3 in/sec	None	.3 in/sec to .45 in/sec	None	$v > .45$ in/sec
v When $.15$ in/sec $< v_r < .3$ in/sec	0 to .45 in/sec	None	.45 in/sec to .75 in/sec	None	$v > .75$ in/sec
v When $.3$ in/sec $< v_r < .6$ in/sec	0 to .9 in/sec	None	.9 in/sec to 1.5 in/sec	None	$v > 1.5$ in/sec
v When $.6$ in/sec $< v_r < 1.0$ in/sec	0 to 1.1 in/sec	None	1.1 in/sec to 1.5 in/sec	None	$v > 1.5$ in/sec

Where:

v = velocity measured in inches/second, peak.

 v_r = reference velocity measured.

(1) See ASME Technical Paper 78-WA/NE-5.

DUANE ARNOLD ENERGY CENTER
TITLE: INSERVICE TESTING PROGRAMPage 20 of 66
Date 12-23-83 Rev. 5

DUANE ARNOLD ENERGY CENTER

Page 21 of 66

TITLE: INSERVICE TESTING PROGRAM

Date 12-23-83 Rev. 5

RELIEF REQUEST NO. PR-9

PUMP NUMBER:

SCREEN WASH PUMPS 1P-112A and B

SECTION XI REQUIREMENTS:

An inservice test shall be run on each pump nominally every 3 months during normal plant operation. (IWP-3400)

BASIS FOR RELIEF:

There is currently no permanent instrumentation installed nor are there provisions for the installation of temporary instrumentation. An engineering evaluation is underway to identify instrumentation requirements and initiate necessary system modifications. Modifications will be accomplished during 1985.

ALTERNATE TESTING:

No alternate testing is proposed until modifications are completed. These pumps are currently test-operated as part of the DAEC surveillance test program.

RELIEF REQUEST NO. PR-10

PUMP NUMBER:

DIESEL FUEL OIL PUMPS 1P-44 A & B

SECTION XI REQUIREMENTS:

Pump test results shall be analyzed per IWP-3200.

BASIS FOR RELIEF:

The ASME recognizes that the characteristics of systems containing other than steam or water (eg. fuel oil) may not necessarily lend themselves to the type and detailed requirements as specified by Subsection IWP. This is so stated in the ASME response to WPPSS inquiry, File no. BC 77-666/NI 77-371 dated 1/8/79. (See Appendix C) In cases where test data is erratic or questionable, strict compliance with the Section XI requirements will likely result in unnecessary pump maintenance and excessive testing of the fuel oil pumps and the emergency diesel generators.

ALTERNATE TESTING:

Analysis of the quarterly test data will be based on IWP-3200. In those cases where the test results are obviously erratic or misleading, alternate acceptance criteria will be developed.

FOR INFORMATION
ONLY

3.0 INSERVICE TESTING PROGRAM FOR VALVES3.1 General Information

This testing program for ISI Class 1, 2, 3, and NC valves meets the requirements of Subsection IWV of Section XI of the ASME Boiler and Pressure Vessel Code, 1980 Edition through the Winter 1980 Addenda. Where these requirements are determined to be impractical, specific requests for relief have been written and included in Section 3.2.

The tables in Appendix 3 list all ISI Class 1, 2, 3, and NC valves that have been assigned valve categories. Valves exempt per IWV-1200 are not listed. The following information is included for each valve:

- VALVE NUMBER: The valve identification number.
- P&ID COORDINATE: The drawing coordinate location on the P&ID for the valve.
- CLASS: The ISI Classification of the valve.
- VALVE CATEGORY: The category(s) assigned to the valve based on the definitions per IWV-2200. Four (4) separate categories are defined in the Code:

CATEGORY A - Valves for which seat leakage is limited to a specific maximum amount in the closed position for fulfillment of their safety function.

CATEGORY B - Valves for which a specific amount of leakage in the closed position is not measured but which require stroke testing to verify their ability to fulfill their safety function.

CATEGORY C - Valves which are self-actuating in response to some system characteristic, such as pressure (relief valves) or flow direction (check valves).

CATEGORY D - Valves which are actuated by an energy source capable of only a single operation (eg. explosively-actuated valves).

- VALVE SIZE: The nominal size of the valve in inches.

• VALVE TYPE: The valve body design as indicated by the following abbreviations:

ANGLE	ANG
BALL	BAL
BUTTERFLY	BTF
CHECK	CK
EXCESS FLOW CHECK	XFC
GATE	GA
GLOBE	GL
NEEDLE	NDL
NOTCHED GLOBE	NGL
PLUG	PLG
RELIEF	RV
RUPTURE DIAPHRAGM	RPD
SAFETY	SV
SHEAR	SH
STOP CHECK	SCK
3-WAY	3WY
4-WAY	4WY

• ACTUATOR TYPE: The type of valve actuator as indicated by the following abbreviations:

MOTOR OPERATOR	MO
AIR-PILOT OPERATOR	AP
AIR OPERATOR	AO
SOLENOID OPERATOR	SO
HYDRAULIC OPERATOR	HO
EXPLOSIVE ACTUATOR	EXP
MANUAL	M
SELF ACTUATED & MANUAL OPERATED	MSA
SELF ACTUATED	SA
SELF ACTUATED & MOTOR OPERATED	SAM
SELF ACTUATED & PILOT OPERATED	SAP
SELF ACTUATED, TESTABLE CHECK	SAT

- NORMAL POSITION: The position of the valve during normal plant operation, specified as follows:

O	Normally Open
C	Normally Closed
O/LO	Normally Open/Locked Open
O/LC	Normally Open/Locked Closed
O/KL	Normally Open/Key Locked
O/FO	Normally Open/Fail Open
O/FC	Normally Open/Fail Closed
O/KO	Normally Open/Key Locked and Fail Open
C/LO	Normally Closed/Locked Open
C/LC	Normally Closed/Locked Closed
C/KL	Normally Closed/Key Locked
C/FO	Normally Closed/Fail Open
C/FC	Normally Closed/Fail Closed
C/KC	Normally Closed/Key Locked and Fail Closed
NE	Normally Energized
ND	Normally De-energized

Valves with fail-safe positions are indicated as either FO-fail open or FC-fail closed.

- TEST: The test(s) that will be performed to fulfill the requirements of Subsection I/WV. The test definitions and abbreviations used are identified in Table 3.1-1.
- TEST FREQUENCY: The frequency at which the above mentioned tests will be performed. Test frequencies are defined in Table 3.1-2.
- MAXIMUM STROKE TIME: The limiting maximum value of full stroke time, in seconds, for power-operated valves in Category A or B.
- MAXIMUM LEAKAGE: The maximum leakage allowed during the specified leaktest. The abbreviations for the units of measurement are:
 - C Standard cubic centimeters per minute.
 - P Pressure decay in pounds per square inch per minute
 - G Gallons per minute
- RELIEF REQUEST: The reference to a relief request in Section 3.2 for valve testing. Requests for relief are identified as VR-XX.
- REMARKS: Remarks in the IST Program are coded as NOTE 001, NOTE 002, etc.

TABLE 3.1-1
INSERVICE VALVE TESTS

<u>TEST</u>	<u>TEST NAME</u>	<u>TEST DESCRIPTION</u>
AT-1	Type C leaktest	Containment isolation valves will be seat leak tested in accordance with DAEC Technical Specification requirements and Appendix J, 10CFR50.
AT-2	Excess flow check valve test	Excess flow check valves will be tested in accordance with DAEC Technical Specifications, Section 4.7.D.
AT-3	Safety and relief valve	Safety and relief valve leakage is continuously monitored by the safety and relief valve tailpipe temperature monitor. An alarm at 250°F indicates safety or relief valve leakage. Refer to DAEC Technical Specifications, Section 4.6.D.
AT-4	Vacuum breaker leaktest	The suppression chamber-drywell vacuum breaker will be leak tested in accordance with DAEC Technical Specifications, Section 4.7.4.
AT-5	Pressure isolation valve leaktest	Those valves so designated will be leak tested in accordance with I&W-3420 using water as a test medium.
BTO	Full-stroke exercise test to the OPEN position (I&W-3412 and 3413)	Exercise testing in the open direction, verified by stroke time measurement, will be performed to confirm the full stroke capability of each valve. The stroke direction tested and timed (open) is based on the direction the valve disk must travel to fulfill a safety function.
BTC	Full-stroke exercise test to the CLOSE position (I&W-3412 and 3413)	Exercise testing in the close direction, verified by stroke time measurement, will be performed to confirm the full stroke capability of each valve. The stroke direction tested and timed (close) is based on the direction the valve disk must travel to fulfill a safety function.
BTD	Full-stroke exercise test to de-energized position	Solenoid valves, which direct control air to main air-operated valves, are shown to stroke to their de-energized position by the proper operation of the associated main valves.

TITLE: DUANE ARNOLD ENERGY CENTER
INSERVICE TESTING PROGRAM

Page 26 of 66
Date 12-23-83 Rev. 5

TABLE 3.1-1
INSERVICE VALVE TESTS (continued)

<u>TEST</u>	<u>TEST NAME</u>	<u>TEST DESCRIPTION</u>
BTE	Full-stroke exercise test to energized position valves.	Solenoid valves, which direct control air to main air-operated valves, are shown to stroke to their energized position by the proper operation of the respective main
CT-CO	Check valve exercise test to OPEN position (IWF-3412)	Check valves will be exercised from the fully closed to the fully open positions. Verification of safety basis system flow through a check valve shall be an adequate demonstration that the valve is full open. The stroke direction tested (open) is based on the direction the valve disk must travel to fulfill a safety function.
CT-CC	Check valve exercise test to CLOSED position (IWF-3412)	Check valves will be exercised from the fully open to the fully closed positions. The stroke direction tested (closed) is based on the direction the valve disk must travel to fulfill a safety function.
CT-SP	Relief valve set point verification test (IWF-3510)	Relief and safety valve set point will be verified in accordance with IWF-3510.
DT	Explosive valve test (IWF-3610 and 3620)	Explosively-actuated valves will be tested in accordance with IWF-3610.
FST	Fail-safe test (IWF-3415)	All valves with fail-safe actuators will be tested to verify proper fail-safe operation upon loss of actuator electric power.
PIT	Position indication checks (IWF-3300)	All valves with position indicators will be checked to verify that remote valve indicators accurately reflect valve operation

DUANE ARNOLD ENERGY CENTER TITLE: INSERVICE TESTING PROGRAM	Page 27 of 66
Date 12-23-83 Rev. 5	

TABLE 3.1-2
TEST FREQUENCY

(1)

<u>TEST FREQUENCY</u>	<u>OPERATIONAL CONDITION</u>	<u>FREQUENCY OF TESTING</u>
UP	Power operation	At least once per 92 days
CS	Cold shutdown	See (2) below
RR	Refueling	Not less than once every two years
SP	See appropriate relief request	See appropriate relief request
5Y	No operational condition limitations	Every five years (see Article IWF-3511). Applies to CT-SP test.
2Y	No operational condition limitations	Every two years (see Article IWF-3300). Applies to PIT test.

(1) Operational conditions are defined in DAEC Technical Specifications, page 1.0-3.

(2) Inservice valve testing will commence within 48 hours of reaching the cold shutdown condition as defined in the DAEC Technical Specifications. Testing not completed before startup may be completed during subsequent cold shutdowns. Valve testing need not be performed more often than once every three months. In the case of extended cold shutdowns, the testing need not be started within the 48-hour limitation. However, in these instances, all valve testing must be completed prior to startup.

NOTE: It is expected that the required testing will normally be completed within 96 hours following cold shutdown. However, completion of all valve testing during cold shutdowns is not required if plant operating conditions do not permit testing of specific valves.

DUANE ARNOLD ENERGY CENTER
TITLE: INSERVICE TESTING PROGRAM

Page 26 of 66
Date 12-23-83 Rev. 5

DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

Page 29 of 66

Date 12-23-83 Rev. 5

SECTION 3.2

RELIEF REQUESTS FOR INSERVICE VALVE TESTING PROGRAM

DUANE ARNOLD ENERGY CENTER

TITLE: INSERVICE TESTING PROGRAM

Page 30 of 66

Date 12-23-83 Rev. 5

RELIEF REQUEST NO. VR-1

-VOID-

RELIEF REQUEST NO. VR-2

SYSTEMS:

Various

COMPONENTS:

All solenoid and air-pilot operators without individual position indication.

CATEGORY:

A & B

FUNCTION:

Solenoid and air-pilot operators are used to control actuators on many valves.

TEST REQUIREMENT:

Stroke time evaluation per I WV-3413 (b).

BASIS FOR RELIEF:

Solenoid and air-pilot valves which control the air supply to a main valve usually do not have indicator lights. However, the operation of the main valve within its stroke time limit implies that the solenoid and/or air-pilot valve is performing satisfactorily.

ALTERNATE TESTING:

For solenoid-operated and air pilot-operated valves which control the air supply to air-operated valves and have no individual position indication, verification that the main valve has stroked to the correct position within its respective time limits will provide adequate evidence that the solenoid or air pilot-operated valve has stroked to its proper position within the required time. When the letters "NA" appear in the stroke time column of the Inservice Testing Program Listing, the valve's stroke time is verified indirectly by the stroke time measurement of its associated main valve.

DUANE ARNOLD ENERGY CENTER

Page 32 of 66

TITLE: INSERVICE TESTING PROGRAM

Date 12-23-83 Rev. 5

RELIEF REQUEST NO. VR-3

-VOID-

FOR INFORMATION
ONLY

DUANE ARNOLD ENERGY CENTER	Page 33 of 66
TITLE: INSERVICE TESTING PROGRAM	Date 12-23-83 Rev. 5

RELIEF REQUEST NO. VR-4

-VOID-

DUANE ARNOLD ENERGY CENTER

Page 34 of 66

TITLE: INSERVICE TESTING PROGRAM

Date 12-23-83 Rev. 5

RELIEF REQUEST NO. VR-5

-VOID-

**IMAGE EVALUATION
TEST TARGET (MT-3)**














IMAGE EVALUATION TEST TARGET (MT-3)



150mm

6"



RELIEF REQUEST NO. VR-6

SYSTEM:

NUCLEAR BOILER

COMPONENTS:Reactor Relief ValvesPIS No.

PSV-4400 *PSV-4401
PSV-4402 *
PSV-4405 *
PSV-4406 *
PSV-4407

Solenoid ValvesPIS No.

SV-4400
SV-4401
SV-4402
SV-4405
SV-4406
SV-4407

*Automatic Depressurization System (ADS)

CATEGORY:

A/C for the reactor relief valves

B for solenoid valves

FUNCTIONS:

The functions of the relief valves are to: (1) open upon receipt of an ADS signal to blowdown reactor vessel (for the ADS valves only) and (2) act as primary system safety valve actuating on high system pressure or capable manual actuation from the control room.

The function of the solenoid valves is to energize upon receipt of a manual or ADS relief valve actuation signal and, in so doing, vent the puppet valve assembly causing the associated main valves to open.

TEST REQUIREMENT:

Exercise and time valves every three months (BT0).

RELIEF REQUEST NO. VR-6 (continued)

BASIS FOR RELIEF:

Relief is requested from the Section XI required testing frequency of once every three months. Exercising these valves during normal operation would cause primary system pressure spikes and reactor power fluctuations which could lead to a reactor scram. These valves will be exercised once per operating cycle as specified in DAEC Technical Specifications, Section 4.6.D.3.

In addition, relief is requested from the stroke timing requirements of Section XI. It is impractical to measure stroke times for relief and solenoid valves since the stroke times are on the order of 100 milliseconds. An abrupt change in the turbine bypass valve position will verify that the solenoid and relief valves have performed their function.

NOTE: Stroke timing requirements for the solenoid valves are discussed in Relief Request No. VR-2.

ALTERNATE TESTING:

These valves will be exercised at least once per operating cycle. The response of these valves will be verified by observing an abrupt change in the turbine bypass valve position. No stroke times will be measured.

RELIEF REQUEST NO. VR-7

SYSTEM:

NUCLEAR BOILER

COMPONENTS:

PSV-4439A	PSV-4439D
PSV-4439B	PSV-4439E
PSV-4439C	PSV-4439F

CATEGORY:

C

FUNCTION:

During a relief valve discharge, these valves must be closed to prevent steam release into the drywell. After a relief valve discharge, steam remaining in the relief valve discharge piping will condense and draw a vacuum in the discharge line. These relief valves (vacuum breakers) open to admit air to the discharge line thus relieving the vacuum condition.

TEST REQUIREMENT:

Exercise in the open and close directions every three months (CT-CC, CT-CO).

BASIS FOR RELIEF:

These valves have no external means of actuation for exercising. The only practical method for exercising these valves is by manually pushing the disk from its seat. This requires access to the valves, which are located in the drywell.

ALTERNATE TESTING:

These valves will be exercised during each refueling outage concurrently with the setpoint verification tests (CT-SP).

RELIEF REQUEST NO. VR-8

SYSTEMS:

NUCLEAR BOILER, REACTOR RECIRCULATION, REACTOR CORE ISOLATION COOLING, CORE SPRAY, HIGH PRESSURE COOLANT INJECTION, and REACTOR VESSEL INSTRUMENTATION

COMPONENTS:

Excess flow check valves

CATEGORY:

A/C

FOR INFORMATION
ONLY

FUNCTIONS:

Excess flow check valves limit leakage from the reactor coolant system in the event of instrumentation piping failures outside containment by closing at 10 psid and perform a containment isolation function if an instrument line were to fail inside containment concurrent with a similar failure outside containment.

TEST REQUIREMENTS:

Exercise in the closed direction every three months (CT-CC).
Conduct valve seat leakage tests once every two (2) years. (AT-1)

BASIS FOR RELIEF:

Exercising of these valves is impractical during normal operation since it requires isolating instrumentation downstream of the excess flow check valves. Additionally, this testing involves a total of 94 valves which would require excessive cold shutdown time solely to accomplish this testing and would greatly increase total personnel radiation exposure.

The excess flow check valves, designated F1.0-FUSE by the manufacturer (Marietta Valve Corp, Boonton, New Jersey), have no provision for leaktesting nor are there such provisions in the upstream side of the lead-in tubing from the root valves. Thus, there is no practical method of conducting leaktests of these valves.

It should be noted that these valves see little or no flow and essentially function only during the exercise testing described below. Also, the significant internal components are fabricated from corrosion-resistant materials that are not expected to degrade during the plant lifetime. For these reasons, general seat degradation is highly unlikely. Gross failure of the seat, if present, will be identified during exercise testing.

ALTERNATE TESTING:

These valves will be exercised during each reactor refueling in accordance with DAEC Technical Specifications, Section 4.7.D.

DUANE ARNOLD ENERGY CENTER

Page 39 of 66

TITLE: INSERVICE TESTING PROGRAM

Date 12-23-83 Rev. 5

RELIEF REQUEST VR-9

-VOID-

DUANE ARNOLD ENERGY CENTER

Page 40 of 66

TITLE: INSERVICE TESTING PROGRAM

Date 12-23-83 Rev. 5

RELIEF REQUEST VR-10

-VOID-

RELIEF REQUEST NO. VR-11

SYSTEM:

CONTAINMENT ATMOSPHERE CONTROL

COMPONENTS:

CV-4327A	CV-4327F
CV-4327B	CV-4327G
CV-4327C	CV-4327H
CV-4327D	

CATEGORY:

A/C

FUNCTION:

These are the pressure suppression chamber to drywell vacuum breaker valves which equalize the pressure between the two volumes when the suppression chamber pressure exceeds that in the drywell.

TEST REQUIREMENT:

Measure valve seat leakage and compare the measured leakage to a specific maximum leakage for each valve (IWW-3426).

BASIS FOR RELIEF:

A specific maximum leakage per valve is not applicable to the vacuum breaker valve testing. As part of the containment integrity (Type A) test a pressure decay test is performed on the pressure suppression chamber atmosphere in accordance with DAEC Technical Specifications Section 4.7.A.4.d. This pressure decay test demonstrates the aggregate leak tightness of the vacuum breaker valves.

ALTERNATE TESTING:

The leak tightness of the pressure suppression chamber to drywell vacuum breakers will be demonstrated during the containment integrity (Type A) test. This test consists of establishing a drywell to suppression chamber pressure differential of 1.1 psi and then measuring the suppression chamber pressure increase over a ten (10) minute period. If this pressure increase is less than 0.009 psi/min the vacuum breakers have demonstrated adequate leak tightness.

RELIEF REQUEST NO. VR-12

SYSTEM:

CONTROL ROD DRIVE HYDRAULIC

COMPONENTS:

V-17-83

V-17-96

CATEGORY:

A/C

FUNCTIONS:

Prevent backflow through the reactor recirculation pumps seal purge line. They also function as primary containment isolation valves.

TEST REQUIREMENT:

Exercise every three (3) months (CT-CC).

BASIS FOR RELIEF:

These simple check valves cannot be remotely operated. They are located inside primary containment and are not accessible for testing during reactor operation. Additionally, the primary containment is inerted with nitrogen during plant operation. De-inerting and then re-inerting the containment atmosphere each cold shutdown solely for the purpose of conducting valve testing would represent an excessive operational burden. These valves cannot be exercised by utilizing outside drywell test lines because the reactor recirculation pumps would require venting, necessitating containment entry. These valves can be exercised closed during leakrate testing performed during refueling outages.

ALTERNATE TESTING:

Exercise valve for operability during each refueling outage (RR). Normal system operation implies that the valves are open. By verifying that the valves close with the leaktight, the valves are indirectly observed to stroke from their open to closed positions.

FOR INFORMATION

ONLY

RELIEF REQUEST NO. VR-13

SYSTEM:

CONTROL ROD DRIVE (CRD) HYDRAULIC

COMPONENTS:

CV-1849
CV-1850
SV-1855
SV-1856
V-18-118 thru 206
V-18-919 thru 1007
V-18-1453 thru 1541

CATEGORY:

CV-1849, CV-1850, SV-1855 and SV-1856 -- Category B V-18-118 thru 206, V-18-919 thru 1007, and V-18-1453 thru 1541-- Category C

FUNCTIONS:

- CV-1849 - Opens with SCRAM signal to pressurize lower side of CRD piston from accumulator.
- CV-1850 - Opens with SCRAM signal to vent top of CRD piston to scram discharge header.
- SV-1855 &
SV-1856 - Pilot valves for CV-1849 & CV-1850, respectively. Open on SCRAM signal to vent air operators.
- V-18-118
thru 206 - Prevent bypassing drive water to charging water header (if depressurized); open to charge accumulators following SCRAM.
- V-18-919
thru 1007 - Prevent backflow into cooling water header during SCRAM; allow cooling water circulation during normal operation.
- V-18-1453
thru 1541 - Open to allow flow from top of CRD pistons to the scram discharge header

Relief Request No. VR-13 (continued)

TEST REQUIREMENTS:

Exercise and time air-operated and solenoid valves every three months (BTO, BTC).

Exercise check valves every three months (CT-CO, CT-CC).

The corresponding fail-safe test is discussed in VR-17.

BASIS FOR RELIEF:

These valves can only be tested by scramming each individual control rod. Due to extensive effort and operational constraints associated with scram testing, this is impractical to accomplish on a quarterly basis or even during cold shutdown periods.

Exercising and measuring the individual stroke times of the air-operated scram valves (CV-1849 and CV-1850) is impractical due to design limitations. There is a single position indicating light for both valves that is energized only when both valves are not in the fully-closed position. Thus, in order to accurately measure stroke time, additional individual position indicating circuitry is required. Such a backfit would be costly and could possibly detract from the basic reliability of the present configuration.

Proper operation of the check valves is monitored during plant operation. Failure of any of these manifests itself in abnormal operation of the associated control rod drive which would be noted (and corrected) by the plant staff.

ALTERNATIVE TESTING:

Proper operation of these valves is demonstrated during normal plant operation and scram testing each operating cycle. The testing and acceptance criteria of the DAEC Technical Specifications, Sections 4.3.C and 3.3.C, will be substituted for stroke timing and exercising of individual valves.

RELIEF REQUEST NO. VR-14

SYSTEM:

CONTROL ROD DRIVE HYDRAULIC

COMPONENTS:

SV-1851
SV-1852
SV-1853
SV-1854

CATEGORY:

B

FUNCTIONS:

There are 89 sets of these valves--one for each control rod drive. Normal insertion and withdrawal of the CRD's is accomplished by opening and closing a particular set of valves (only one CRD can be moved at a time). These valves are not required to change position during a scram, but must be maintained in their normally-closed position.

TEST REQUIREMENT:

Exercise and time valves in the closed direction every three months (BTC). Fail-safe test (FST) valves every three months.

BASIS FOR RELIEF:

The proper operation of these valves is demonstrated frequently during normal operation as discussed in DAEC Technical Specifications, Section 4.3.A.2. Malfunctioning valves would be evidenced by unusual rod movement (drift). Therefore, a special exercise and timing test for operability is not required for these valves.

ALTERNATE TESTING:

The control rod drives will be continuously monitored for proper operation as required by the DAEC Technical Specifications. Weekly tests and periodic scram testing will demonstrate that the subject valves are in the closed position and operating properly. Stroke times will not be measured for the subject valves.

FOR INFORMATION
ONLY

DUANE ARNOLD ENERGY CENTER

Page 46 of 66

TITLE: INSERVICE TESTING PROGRAM

Date 12-23-83 Rev. 5

RELIEF REQUEST VR-15

-VOID-

DUANE ARNOLD ENERGY CENTER

Page 47 of 66

TITLE: INSERVICE TESTING PROGRAM

Date 12-23-83 Rev. 5

RELEASE REQUEST VR-16

-VOID-

RELIEF REQUEST NO. VR-17

SYSTEM:

ALL SYSTEMS

COMPONENTS:

All valves equipped to fail open or closed.

CATEGORY:

A and B

FUNCTION:

Upon loss of electrical power, the valve must stroke to its fail-safe position.

TEST REQUIREMENT:

Solenoid valves which control the air supply to air-operated valves and direct solenoid-operated valves must stroke to their fail-safe position upon interruption of their electrical supply. (FST).

BASIS FOR RELIEF:

De-energizing the solenoid valve has the same effect as loss of electrical power. Therefore, stroking the valve from the control room (BTO, BTC) to its fail-safe position constitutes an FST.

ALTERNATE TESTING:

Normal stroking (BTO, BTC), to the fail-safe position of valves equipped to fail open or closed constitutes an FST. No additional testing is necessary.

RELIEF REQUEST NO. VR-18

SYSTEM:

HIGH PRESSURE COOLANT INJECTION (HPCI)

COMPONENT:

SV-2219

CATEGORY:

B

FUNCTION:

This valve functions as the HPCI turbine drain pot level control valve and is a Class 2 isolation valve.

TEST REQUIREMENT:

Exercise and time valve every three months (BTC).

BASIS FOR RELIEF:

This valve has no individual handswitch, but is operated automatically by a local controller. Also, it has no position indication lights. As such, the valve cannot be operated to verify operability. However, during HPCI turbine operation, indirect verification of its operability can be made by observing that the HPCI turbine drain pot high level alarm actuates and then resets. This would mean that the valve is actually opening and closing as required to maintain proper drain pot level. Stroke timing, however, cannot be done.

ALTERNATE TESTING:

No alternate testing is proposed. Valve operability will be verified in the manner described above.

FOR INFORMATION
ONLY

RELIEF REQUEST NO. VR-19

SYSTEM:

NUCLEAR BOILER

COMPONENTS:

V-14-9	V-14-32	V-14-112
V-14-14	V-14-100	V-14-116
V-14-15	V-14-104	V-14-120
V-14-16	V-14-108	V-14-124

CATEGORY:

C

FUNCTION:

These valves must close upon loss of normal air or nitrogen supply to the automatic depressurization system (ADS) relief valve accumulators and the main steam isolation valve accumulators.

TEST REQUIREMENT:

Exercise valves in the closed direction every three months (CT-CC).

BASIS FOR RELIEF:

The position of these valves cannot be verified during normal operation since they are simple check valves and have no position indicators. In addition, access to these valves is limited since they are located either inside the drywell or the steam tunnel.

ALTERNATE TESTING:

These valves will be exercised during refueling. More frequent testing is not practical because a leaktest must be performed to verify that they are closed.

RELIEF REQUEST NO. VR-20

SYSTEM:

STANDBY LIQUID CONTROL (SLCS)

COMPONENTS:V-26-08
V-26-09CATEGORY:

A/C

FUNCTIONS:

The safety functions of these check valves are to open during system injection and close for containment isolation.

TEST REQUIREMENT:

Exercise valve in the open and closed directions every three months (CT-CO, CT-CC).

BASIS FOR RELIEF:

These check valves are normally closed. They can only be stroked closed during seat leakage tests performed during reactor refueling. To stroke these valves open, the SLCS pumps must discharge directly into the reactor vessel through the explosively-actuated isolation valves. This cannot be done during normal operation or cold shutdown since the SLCS system must be drained and flushed to prevent contamination of the reactor coolant with sodium pentaborate. In addition, extensive testing is required to replace the explosive charges of the isolation valves.

ALTERNATE TESTING:

These valves will be exercised open and closed during each reactor refueling.

RELIEF REQUEST NO. VR-21

SYSTEM:

HIGH PRESSURE COOLANT INJECTION (HPCI)
REACTOR CORE ISOLATION COOLING (RCIC)

COMPONENTS:

V-23-01
V-25-01

CATEGORY:

C

FUNCTIONS:

These valves are designed to prevent backflow into the suppression pool in the event of pump suction shift from the contaminated condensate storage tank (CCST) to the suppression pool. The safety-related function of these valves is to open to provide suction flow to the HPCI and RCIC pumps.

TEST REQUIREMENT:

Exercise every three months (CT-CO).

BASIS FOR RELIEF:

There is no convenient method for verifying the ability of these valves to swing to the full-open position. The system test circuits utilize the CCST for pump suction rather than the suppression pool. Taking suction from the suppression pool during testing is undesirable because, in so doing, torus water would be transferred to the condensate storage tank. Since torus water is not demineralized, the entire condensate storage tank inventory would require processing following each test.

ALTERNATE TESTING:

In lieu of the Code-required full-stroke test, valve operability will be demonstrated by disassembling the valves during each refueling outage and verifying that the valve disk swings freely to the open position. Since these valves have no function during normal operation, no internal wear-induced degradation is expected.

DUANE ARNOLD ENERGY CENTER

Page 53 of 66

TITLE: INSERVICE TESTING PROGRAM

Date 12-23-83 Rev. 5

RELIEF REQUEST VR-22

-VOID-

DUANE ARNOLD ENERGY CENTER

Page 54 of 66

TITLE: INSERVICE TESTING PROGRAM

Date 12-23-83 Rev. 5

RELIEF REQUEST VR-23

-VOID-

RELIEF REQUEST NO. VR-24

SYSTEM:

CONTAINMENT ATMOSPHERE CONTROL

COMPONENTS:

V-43-82
V-43-84
V-43-86
V-43-88

CATEGORY:

C

FUNCTION:

The function of these check valves is to prevent backflow from the containment into the containment atmosphere dilution (CAD) system.

TEST REQUIREMENT:

Exercise valve every three (3) months (CT-CO).

BASIS FOR RELIEF:

These valves are verified open during the CAD system functional test and verified closed during the Type C leak tests on the downstream containment isolation valves. Both of these tests are performed during reactor refueling.

ALTERNATE TESTING:

Valves will be exercised during each refueling outage (RR).

RELIEF REQUEST NO. VR-25

SYSTEM:

CONTAINMENT ATMOSPHERE CONTROL

COMPONENT:

V-43-214

CATEGORY:

A/C

FUNCTIONS:

This valve prevents backflow from the containment into the nitrogen inerting supply line and also functions as a primary containment isolation valve.

TEST REQUIREMENT:

Exercise valve every three (3) months (CT-CC).

BASIS FOR RELIEF:

This simple check valve cannot be remotely operated. It is located inside primary containment and is not accessible for testing during reactor operation. Additionally, the primary containment is inerted with nitrogen during plant operation. De-inerting and then re-inerting the containment atmosphere each cold shutdown solely for the purpose of conducting valve testing would represent an excessive operational burden. This valve can be exercised closed during leakrate testing performed during refueling outages.

ALTERNATE TESTING:

This valve will be exercised during each refueling outage (RR).

FOR INFORMATION
ONLY

DUANE ARNOLD ENERGY CENTER

Page 57 of 66

TITLE: INSERVICE TESTING PROGRAM

Date 12-23-83 Rev. 5

RELIEF REQUEST VR-26

-VOID-

DUANE ARNOLD ENERGY CENTER

Page 58 of 66

TITLE: INSERVICE TESTING PROGRAM

Date 12-23-83 Rev. 5

RELIEF REQUEST VR-27

-VOID-

DUANE ARNOLD ENERGY CENTER

Page 59 of 66

TITLE: INSERVICE TESTING PROGRAM

Date 12-23-83 Rev. 5

RELIEF REQUEST VR-28

-VOID-

RELIEF REQUEST NO. VR-29

SYSTEMS:

NUCLEAR BOILER, RESIDUAL HEAT REMOVAL, CORE SPRAY, HIGH PRESSURE COOLANT INJECTION, REACTOR CORE ISOLATION COOLING, RADWASTE SUMP, CONDENSATE & DEMINERALIZED WATER

COMPONENTS:

CV-2211	MO-1900	V-09-111
CV-2410	MO-1908	
CV-3704	MO-2117	
CV-3728	MO-2137	
	MO-2238	
	MO-2400	
	MO-4423	

CATEGORY:

A

FUNCTIONS:

These valves are subject to 10 CFR 50, Appendix J, Type C leak testing.

TEST REQUIREMENT:

Valve seat leakage tests shall be made with the pressure differential in the same direction as when the valve is performing its function. These valves are gate valves and are not exempt from the above requirement (IWF-3423).

BASIS FOR RELIEF:

Wedge disk gate valves have the same sealing characteristics in either direction. Therefore, testing these valves in the opposite direction to that in which they perform their containment isolation function is equivalent to testing in the accident direction.

ALTERNATE TESTING:

The piping between the two isolation valves will be pressurized and the low-pressure side of each valve will be vented. The combined leakage from the two containment isolation valves in series will be conservatively attributed to the penetration being tested.

RELIEF REQUEST NO. VR-30

SYSTEM:

CONTROL ROD DRIVE (CRD) HYDRAULIC

COMPONENTS:V-17-52
V-17-53CATEGORY:

A/C

FUNCTION:

These valves provide containment isolation for the control rod drive hydraulic system.

TEST REQUIREMENT:

Check valves will be exercised from the full-open to the full-closed positions every three months (CT-CC).

BASIS FOR RELIEF:

These valves are in the CRD return line to the reactor vessel. In accordance with NUREG-0619, this system is no longer used. Therefore, these check valves are now passive valves and verifying that they stroke from the open to closed positions is not necessary.

ALTERNATE TESTING:

The closed position is verified during leaktests performed once each cycle.

RELIEF REQUEST NO. VR-31

SYSTEM:

NEUTRON MONITORING

COMPONENT:

TIP-CK

CATEGORY:

A/C

FUNCTION:

This valve provides containment isolation for the nitrogen purge portion of the TIP system.

TEST REQUIREMENT:

Check valves will be exercised from the full-open to the full-closed positions every three months (CT-CC).

BASIS FOR RELIEF:

This valve is a simple check valve and thus the only practical method to verify closure is by performing a leaktight test. Conducting such tests every three months is excessively time consuming and difficult.

ALTERNATE TESTING:

This valve will be full stroke exercised to the closed position during each refueling outage (RR).

FOR INFORMATION
ONLY

RELIEF REQUEST NO. VR-32

SYSTEM:

CONTAINMENT ATMOSPHERE MONITORING SYSTEM
POST ACCIDENT SAMPLING SYSTEM

COMPONENTS:

SV-8101A	SV-8106A	SV-4594A
SV-8101B	SV-8106B	SV-4594B
SV-8102A	SV-8107A	SV-8772A
SV-8102B	SV-8107B	SV-8772B
SV-8103A	SV-8108A	
SV-8103B	SV-8108B	
SV-8104A	SV-8109A	
SV-8104B	SV-8109B	
SV-8105A	SV-8110A	
SV-8105B	SV-8110B	

CATEGORY:

A

FUNCTION:

These valves provide containment isolation for the containment atmosphere monitoring and post accident sampling systems.

TEST REQUIREMENT:

Exercise valves in the closed direction every three months (BTC). The stroke time of all power-operated valves shall be measured. (IWW-3413)

BASIS FOR RELIEF:

These valves are not provided with individual position indicators and thus the only reasonable means of verifying the close position is by performing leaktests--tests that are impractical to perform during normal operation. Also, meaningful stroke time measurements cannot be taken.

ALTERNATE TESTING:

These valves will be exercised every three months. Verification of the close position will be performed during each reactor refueling. Stroke times will not be measured.

RELIEF REQUEST NO. VR-33

SYSTEM:

CORE SPRAY

COMPONENTS:

CV-2118

CV-2138

CATEGORY:

C

FUNCTIONS:

These check valves provide a flowpath for core spray to the reactor vessel and prevent backflow from the reactor vessel to the core spray system.

TEST REQUIREMENT:

Exercise check valves in the open and closed direction every three months (CT-CG, CT-CC).

BASIS FOR RELIEF:

These check valves are normally closed. To open the valves, the core spray pumps are operated at rated flow and discharged directly into the reactor vessel. This cannot be done during normal operation as these valves cannot be opened against normal reactor pressure. The air operators on these valves (used for testing only) have proven to be unreliable and a continuing source of nitrogen inleakage in the drywell. Thus, operating nitrogen is normally cut-off to the operator. Currently, an engineering evaluation is being conducted to determine if these operators should be replaced or removed. In the first case this would allow for testing of these valves during cold shutdown. In the event the operators are removed, these valves can only be tested during refueling.

ALTERNATE TESTING:

These valves will be exercised at each refueling outage by verifying that each division of core spray can deliver rated flow to the reactor vessel.

RELIEF REQUEST NO. VR-34

SYSTEM:

CONTAINMENT ATMOSPHERE DILUTION

COMPONENTS:

SV-4331A	SV-4333A
SV-4331B	SV-4333B
SV-4332A	SV-4334A
SV-4332B	SV-4334B

CATEGORY:

A/B

FUNCTIONS:

These valves function to provide a flowpath into the containment in the event that containment dilution is required during an accident and serve as containment isolation valves.

TEST REQUIREMENT:

Evaluate stroke times in accordance with IWF-3413 (b).

BASIS FOR RELIEF:

It is impractical to apply the requirements of IWF-3413 (b) to valves with stroke times on the order of 1-2 seconds without installing sophisticated timing devices. Operator reaction times could easily vary by .5 seconds or more thereby invalidating the 50% criteria for increasing the surveillance frequency.

ALTERNATE TESTING:

Stroke times for these valves will be measured; however, the frequency of testing will be increased to once each month if an increase in measured stroke time of 100% or more from the previous test is observed and the stroke time is greater than 2 seconds.

RELIEF REQUEST NO. VR-35

SYSTEM:

EMERGENCY SERVICE WATER (ESW)

COMPONENTS:

CV-1956 A

CV-1956 B

CATEGORY:

B

FUNCTIONS:

These valves open to provide a return path for ESW cooling water from the control building chillers.

TEST REQUIREMENT:

Stroke time shall be measured during exercise testing. (IWW-3413)

BASIS FOR RELIEF:

These valves are actuated by the starting logic of the associated emergency service water pump, with no individual control handswitch. Also, there are no position indicators for these valves. Thus, stroke time measurements are impractical.

ALTERNATE TESTING:

These valves will be exercised every three months. During this testing, valve operation will be observed. Based on visual observation, any erratic operation or excessively long stroke time will be cause for failure.

FOR INFORMATION
ONLY

APPENDIX A
PUMP TESTING PROGRAM

PREPARED BY : PIETECH
PROGRAM : PRESTH

INSERVICE TESTING PROGRAM
EST CLASS 1, 2, 3 AND NC PUMPS
DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

PAGE 1
1ST PROGRAM REVISION 905 12/23/83

PUMP NUMBER	PUMP NAME	1ST CLASS	P&ID	F&D COOR	SPEED	INLET PRESS	DIFF PRESS	FLOW RATE	VIBRA	BEAR TEMP	TEST INTERVAL	REMARKS
IP-022A	RHRSW	3	B-146	B-8	NA	Y:PR-4	Y	Y	Y	Y	QUARTERLY	
IP-022B	RHRSW	3	B-146	B-8	NA	Y:PR-4	Y	Y	Y	Y	QUARTERLY	
IP-022C	RHRSW	3	B-146	B-8	NA	Y:PR-4	Y	Y	Y	Y	QUARTERLY	
IP-022D	RHRSW	3	B-146	B-8	NA	Y:PR-4	Y	Y	Y	Y	QUARTERLY	
IP-044A	DEO	NC	B-132	A-2	NA	Y:PR-4	Y:PR-6	Y:PR-6	N:PR-1	N:PR-1	QUARTERLY	NOTE-001
IP-044B	DEO	NC	B-132	A-3	NA	Y:PR-4	Y:PR-6	Y:PR-6	N:PR-1	N:PR-1	QUARTERLY	NOTE-001
IP-029A	ESW	3	B-146	B-7	NA	Y:PR-4	Y	Y	Y	N:PR-2	QUARTERLY	
IP-029B	ESW	3	B-146	B-6	NA	Y:PR-4	Y	Y	Y	N:PR-2	QUARTERLY	
IP-112A	SCREEN	NC	B-129	C-7	NA	Y:PR-9	Y:PR-9	Y:PR-9	Y:PR-9	Y:PR-9	QUARTERLY	
IP-112B	SCREEN	NC	B-129	C-3	NA	Y:PR-9	Y:PR-9	Y:PR-9	Y:PR-9	Y:PR-9	QUARTERLY	
IP-117A	RM	NC	B-129	D-7	NA	Y:PR-4	Y:PR-5	Y:PR-5	Y	Y	QUARTERLY	
IP-117C	RM	NC	B-129	D-4	NA	Y:PR-4	Y:PR-5	Y:PR-5	Y	Y	QUARTERLY	
IP-117C	RM	NC	B-129	D-6	NA	Y:PR-4	Y:PR-5	Y:PR-5	Y	Y	QUARTERLY	
IP-117D	RM	NC	B-129	D-3	NA	Y:PR-4	Y:PR-5	Y:PR-5	Y	Y	QUARTERLY	
IP-211A	CS	2	B-121	C-3	NA	Y	Y:PR-5	Y:PR-5	Y	Y	QUARTERLY	
IP-211B	CS	2	B-121	C-4	NA	Y	Y:PR-5	Y:PR-5	Y	Y	QUARTERLY	
IP-216	HPT	2	B-123	D-2	Y	Y	Y:PR-5	Y:PR-5	N:PR-3	N:PR-3	QUARTERLY	
IP-216	RHTC	2	B-125	D-4	Y	Y	Y:PR-5	Y:PR-5	N:PR-3	N:PR-3	QUARTERLY	
IP-227B	RHS	2	B-120	B-3	Na	Y	Y:PR-5	Y:PR-5	Y	Y	QUARTERLY	

PREPARED BY : NUTECH
PROGRAM : PRESIM

INSERVICE TESTING PROGRAM
EST CLASS 1, 2, 3 AND NC PUMPS
DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

PAGE 2
EST PROGRAM REVISION 005 12/23/83

PUMP NUMBER	PUMP NAME	EST CLASS	P&ID	P&ED COOR	INSERVICE TEST QUANTITIES							TEST INTERVAL	REMARKS
					SPEED	INLET PRESS	DIFF PRESS	FLOW RATE	VIBRA	BEAR TEMP			
IP-229B	RHR	2	H-119	B-7	NA	Y	Y:PR-5	Y:PR-5	Y	Y	QUARTERLY		
IP-222E	KHR	2	H-120	B-2	NA	Y	Y:PR-5	Y:PR-5	Y	Y	QUARTERLY		
IP-229B	RHR	2	H-119	B-8	NA	Y	Y:PR-5	Y:PR-5	Y	Y	QUARTERLY		
IP-239A	SLC	2	H-126	B-5	NA	Y	Y	Y	Y	Y	QUARTERLY		
IP-230B	SLC	2	H-126	C-5	NA	Y	Y	Y	Y	Y	QUARTERLY		

PREPARED BY : NUTECH
PROGRAM : PRISIM

INSERVICE TESTING PROGRAM
IST CLASS 1, 2, 3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

PAGE : 3
IST PROGRAM REVISION : 005 , 12/23/83

PUMP IST PROGRAM REMARKS

NOTE 001: Although the diesel fuel oil transfer pumps (JP-44A & B) are included in the program, they do not strictly fall within the jurisdiction of the ASME B & PV Code, Section XI. (Reference ASME response to WPPSS inquiry, File no. BC 77-666/NI 77-371 dated 1/8/79) See Relief Request No. PR-10 for further discussion of this issue.

APPENDIX B
VALVE TESTING PROGRAM

OPERATED BY PHITECH
FURNISHED BY PHITECH

TEST SERVICE TESTING FOLIO KIT

151 CLASS 1, 2,
3, AND NC VALVES

SHANE AIRCRAFT FACTORY CENTER

VALVE C51-1-7 REVISION 00
SYSTEM NEUTRON MONITORING

151 FOLIO KIT REVISION 00
PAGE 1

VALVE NUMBER	FLD COOR	1ST CLASS	VALVE CAT	VALVE SIZE	ACTUATOR TYPE	NOMINAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
11P-BAL A	---	NC	A	-	BAL	SD	C	A1-1 BIC P11	RK OP 2Y	NR	VR-2
11P-BAL B	---	NC	A	-	BAL	SD	C	A1-1 BIC P11	RK OP 2Y	NR	VR-1
11P-BAL C	---	NC	A/C	-	BAL	SD	C	A1-1 BIC P11	RK OP 2Y	NR	VR-2
11P-CK	---	NC	A/C	-	CK	SA	C	A1-1 C1-CC P11	RK OP 2Y	NR	VR-3
11P-SHA	---	NC	D	-	SH	EXP	0	DT	RR		
11P-SWB	---	NC	D	-	SH	EXP	0	DT	RR		
11P-SWH	---	NC	D	-	SH	EXP	0	DT	RR		

PREPARED BY : MOTECH
FRTUKEAN TRUSTH

INSERVICE TESTING, FRTUKEAN
1ST CLASS 1, 2,
3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

LUMA ELECTRIC LIGHT
AND POWER

PART : H-199 REVISION 21
SYSTEM : CONDENSATE & DEMINERALIZED WATER

1ST FLGOKAH REVISIION : 065 , 12/23/83

VALVE NUMBER	P/N	1ST CLASS CODE	VALVE SIZE	VALVE CAT	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
V-09-055	6-2	NC	A	1	6A	H	C/LC	A1-A	RR	NA	NR-29	
V-09-111	6-2	NC	A	1	6A	H	C/LC	A1-A	RR	NA	NR-29	

PREPARED BY RUTECHE
PROGRAM : PRISTM

MASTER TESTING PROGRAM
LST CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

F&ID : M-112
SYSTEM : REACTOR BUILDING CHILLING WATER

REVISION 12
LST PROGRAM REVISION : 005 , 3
F&ID : 12/23/83

VALVE NUMBER	F&ID	LST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE	MAXIMUM LEAKAGE	RELIEF REQUIREMENT	REMARKS
(M)-4041A	E-3	NC	A	4	GA	NO	0	AI-1	RR	C ²	0.20	NA	
(M)-4041B	F-3	NC	A	4	GA	NO	0	AI-1	RR	C ²	0.20	NA	

PREPARED BY : MUNTECH
PROGRAM : PRLSM

INSERVICE TESTING PROGRAM
ISI CLASS 1, 2, 3, AND NC VALVES
DUANE ARNDT ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FAID : H-113 REVISION 17
SYSTEM : RHR & EMERGENCY SERVICE WATER

ISI PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	FAID CODE	ISI CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR POSITION	NORMAL POSITION	TEST FREQ	STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-1956A	H-3	3	B 4	6A	AO	C/F0	B10 FST	0F 0F	005	VR-35 VR-17	
CV-1956B	H-2	3	B 4	6A	AO	C/F0	B10 FST	0F 0F	005	VR-35 VR-17	
CV-2080	G-5	3	B 6	6L	AO	C/F0	B10 FST	0F 0F	005		
CV-2081	G-5	3	B 6	6L	AO	C/F0	B10 FST	0F 0F	005	VR-17	
RI-1943A	G-H	3	B 12	6A	AO	C/RL	B1C FII	0F 2Y	005	VR-17	
RI-1943B	G-H	3	B 12	6A	AO	C/RL	B1C FII	0F 2Y	005	VR-17	
RI-1943A	H-4	3	B 4	6A	AO	0	B1C FII	0F 2Y	005	VR-17	
RI-1943B	H-3	3	B 4	6A	AO	0	B1C FII	0F 2Y	005	VR-17	
RI-1943C	H-3	3	B 4	6A	AO	0	B1C FII	0F 2Y	005	VR-17	
PSV-2068	E-7	3	B/C 7S	KV	SA	C	C1-SP	S1			
PSV-2068	E-6	3	B/C 7S	KV	SA	C	C1-SP	S1			

PREPARED BY : NUTECH
FIRBRAH : FRUSIM

INSERVICE TESTING PROGRAM

IST CLASS 1, 2, 3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

VALVE ID : H-113
SYSTEM : RHR & EMERGENCY SERVICE WATER
REVISIOn : 17

VALVE NUMBER	VALVE ID	IST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST STROKE TIME	MAXIMUM LEAKAGE	TEST REQUEST	REQUEST
5V-1956A	H-3	NC	B	—	3WY	S0	NE	BID	OP	NA	VR-2
5V-1956B	H-2	NC	B	—	3WY	S0	NE	BID	OP	NA	VR-2
5V-20B0	6-5	NC	B	—	3WY	S0	NE	BID	OP	NA	VR-2
5V-20B1	6-5	NC	B	—	3WY	S0	NE	BID	OP	NA	VR-2

VALVE ID : 5

FATL : 12/23/83

IST PROGRAM REVISION : 005

PREPARED BY : MITECH
PRUDHVI : KRISHNA

**INSERVICE TESTING PROGRAM
CLASS 1, 2, 3, AND NC VALVE
DUANE ARTHOLD ENERGY CENTER**

IOWA ELECTRIC LIGHT
AND POWER

PART II
NUCLEAR BOILER
SYSTEM :
REVISION 15
N-114

P&ID SYSTEM : N-114 REVISION 15										LST PROGRAM REVISION 15										PAGE 6	
VALVE NUMBER	P&ID CODE	LST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR	NORMAL POSITION	TEST POSITION	TEST FREQ	TEST TIME	MAXIMUM LEAKAGE	RELIEF	REQUEST	REMARKS								
AF-4412A	6-3	NC	H	-	4WY	AF	NE	BID	OF	NA	NA	NA	NA	VR-2	VR-17						
AF-4412B	6-3	NC	B	-	4WY	AF	NE	BID	OF	NA	NA	NA	NA	VR-2	VR-17						
AF-4413A	6-1	NC	H	-	4WY	AF	NE	BID	OF	NA	NA	NA	NA	VR-2	VR-17						
AF-4413B	6-1	NC	B	-	4WY	AF	NE	BID	OF	NA	NA	NA	NA	VR-2	VR-17						
AF-4415A	---	NC	H	-	4WY	AF	NE	BID	OF	NA	NA	NA	NA	VR-2	VR-17						
AF-4415B	---	NC	B	-	4WY	AF	NE	BID	OF	NA	NA	NA	NA	VR-2	VR-17						
AF-4416A	---	NC	H	-	4WY	AF	NE	BID	OF	NA	NA	NA	NA	VR-2	VR-17						
AF-4416B	---	NC	B	-	4WY	AF	NE	BID	OF	NA	NA	NA	NA	VR-2	VR-17						
AF-4419A	---	NC	H	-	4WY	AF	NE	BID	OF	NA	NA	NA	NA	VR-2	VR-17						
AF-4419B	---	NC	B	-	4WY	AF	NE	BID	OF	NA	NA	NA	NA	VR-2	VR-17						

PREPARED BY : RITECH
PROGRAM : PRISM

CHASSIS TESTING PROGRAM

TSI CLASS 1, 2,
3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

F&ID : H-114
SYSTEM : NUCLEAR BUFFER
REVISION : 15

TSI PROGRAM REVISION : 005 , 7/23/83

VALVE NUMBER	F&ID CODE	TSI CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQUENCY	TEST STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
HV-4420A	NC	B	-	4WY	AP	NE	BID	0P	NA	VR-2	VR-17	
HV-4420B	NC	B	-	4WY	AP	NE	BID	0P	NA	VR-2	VR-17	
HV-4421A	NC	B	-	4WY	AP	NE	BID	0P	NA	VR-2	VR-17	
HV-4421B	NC	B	-	4WY	AP	NE	BID	0P	NA	VR-2	VR-17	
HV-4421C	E-7	A	20	6L	AO	O/FC	A1-1	RR	NA	NA	VR-2	VR-17
HV-4423	E-2	A	20	6L	AO	O/FC	B1C	0P	005	NA	VR-17	
HV-4425	C-7	A	20	6L	AO	O/FC	FST	0P	2Y	NA	VR-17	
HV-4426	C-8	A	20	6L	AO	O/FC	F1T	2Y	NA	NA	VR-17	
HV-4428	C-3	A	20	6L	AO	O/FC	A1-1	RR	005	NA	VR-17	

PREPARED BY : POLYTECH
FORWARDER : PRISM

INSERVICE TESTING PROGRAM
UST CLASS 1, 2, 3, AND NC VALVES
PHASE AHEAD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

F&P# : H-114
SYSTEM : NUCLEAR BUILK

REVISION #: 15

UST PROGRAM Revision #: 005 , H
Date : 12/23/83

VALVE NUMBER	F&P#	UST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	MAX TRIM	STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-4419	C-2	1	A	.20	GL	AI	0/FC	AI-1	RR	NA	OP	0.05	MR-17	
CV-4420	E-7	1	A	.20	GL	AI	0/FC	AI-1	RR	NA	OP	0.05	MR-17	
CV-4421	E-8	1	A	.20	GL	AI	0/FC	AI-1	RR	NA	OP	0.05	MR-17	
CV-4422	H-6	1	B	.5	GL	AI	0/FC	AI-1	RR	NA	OP	0.05	MR-17	
CV-4423	H-7	1	B	.5	GL	AI	0	BIC	CS	0.60				
CV-4423	H-3	1	A	.3	LA	MO	0	BIC	CS	0.60				
CV-4424	H-3	1	A	.3	LA	MO	0	AI-1	RR	NA	OP	.015	MR-29	
CV-4424	H-7	1	A/C	.16	SAC	SAC	0/R1	AI-1	RR	NA	OP	.015	MR-29	
CV-4425	H-7	1	A/C	.16	SAC	SAC	0/R1	BIC	CS	05.3				
CV-4425	H-7	1	A/C	.16	SAC	SAC	0/R1	AI-1	RR	NA	OP	.015	MR-29	

PROTECTED BY NUCLEAR
PROTECTION PRISM

CAESAR II TESTING PROGRAM
LST CLASS 1, 2, 3, AND KC VALVES
DIANE ARNOLD ENERGY CENTER

100A ELECTRIC LIGHT
AND POWER

F&ID H-114
SYSTEM : NUCLEAR BOILER

REVISION 15
LST PROGRAM REVISION 005 , 12/23/83

VALVE	F&ID	LST CLASS	VALVE CAT	VALVE SIZE	ACTUATOR TYPE	NOMAL POSITION	TEST FREQ	STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
P&V-4401	E-5	1	B/C	6	KV	SAP	C	B10 C1-SP	SP SP	NA	VR-6
P&V-4402	E-6	1	B/C	6	KV	SAP	C	B10 C1-SP	SP SP	NA	VR-6
P&V-4403	E-4	1	B/C	6	KV	SAP	C	B10 C1-SP	SP SP	NA	VR-6
P&V-4404	E-5	1	B/C	6	KV	SAP	C	B10 C1-SP	SP SP	NA	VR-6
P&V-4405	E-4	1	B/C	6	KV	SAP	C	B10 C1-SP	SP SP	NA	VR-6
P&V-4406	E-6	1	B/C	6	KV	SAP	C	B10 C1-SP	SP SP	NA	VR-6
P&V-4407	E-6	1	B/C	6	KV	SAP	C	B10 C1-SP	SP SP	NA	VR-6
P&V-4439A	B-4	3	B/C	6	KV	SA	C	C1-CC C1-C0 C1-SP	SY SY SY	VR-7	VR-7
P&V-4439B	B-4	3	B/C	6	KV	SA	C	C1-CC C1-C0 C1-SP	SY SY SY	VR-7	VR-7
P&V-4439C	B-5	3	B/C	6	KV	SA	C	C1-CC C1-C0 C1-SP	SY SY SY	VR-7	VR-7
P&V-4439D	B-4	3	B/C	6	KV	SA	C	C1-CC C1-C0 C1-SP	SY SY SY	VR-7	VR-7

PERFORMED BY: NUCLECH
FACILITY: FRISTIN

TEST SERVICE TESTED: FRICTION
151 CLASS 1, 2,
3, AND NC VALVES
ORION ARNOLD ENERGY CENTER

OMA ELECTRIC LIGHT
AND POWER

FAIL SYSTEM: 6-114
REV 15

FAIL SYSTEM: ISOLATOR BOILER

VALVE NUMBER	FAIL CLASS	LST CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	PAGE : 10	
										RELIEF REQUIREMENT	FRAMES
FSV-4439E	A-4	3	B/C	6	KV	SA	C	C1-EC C1-CO C1-SP	5Y 5Y 5Y	VR-7 VR-7 VR-7	
SV-4400	E-5	NC	H	-	3WY	SD	HD	BIE	SF	NA	VR-7
SV-4401	E-4	NC	H	-	3WY	SD	HD	BIE	SF	NA	VR-7
SV-4402	E-6	NC	H	-	3WY	SD	HD	BIE	SF	NA	VR-6
SV-4405	E-4	NC	H	-	3WY	SD	HD	BIE	SF	NA	VR-6
SV-4406	E-6	NC	H	-	3WY	SD	HD	BIE	SF	NA	VR-6
SV-4407	E-6	NC	H	-	3WY	SD	HD	BIE	SF	NA	VR-6
SV-4412H	6-8	NC	H	-	3WY	SD	HD	BID	OF	NA	VR-6
SV-4413H	F-2	NC	H	-	3WY	SD	NE	BID	OF	NA	VR-2
SV-4414H	F-2	NC	H	-	3WY	SD	NE	BID	OF	NA	VR-2
SV-4415H	G-0	NC	H	-	3WY	SD	NE	BID	OF	NA	VR-2
SV-4416H	G-0	NC	H	-	3WY	SD	NE	BID	OF	NA	VR-2
SV-4417H	G-0	NC	H	-	3WY	SD	NE	BID	OF	NA	VR-2
SV-4418H	G-0	NC	H	-	3WY	SD	NE	BID	OF	NA	VR-2
SV-4419H	G-0	NC	H	-	3WY	SD	NE	BID	OF	NA	VR-2
SV-4420H	G-0	NC	H	-	3WY	SD	NE	BID	OF	NA	VR-2

PREPARED BY : NITECH
PROGRAM : PRISTIM

INSERVICE TESTING PROGRAM
LST CLASS 1, 2, 3, AND HC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FILED : H-114
SYSTEM : NUCLEAR BOILER
REVISION 15

LST PROGRAM REVISION : 005 , 12/23/83
PAGE : 11

VALVE NUMBER	FILED COLOR	LST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NOMINAL POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
SV-4418A	6-B	NC	B	-	3WY	S0	NE	BID	0P	NA	VR-2	
SV-4418B	6-B	HC	B	-	3WY	S0	NE	BID	0P	NA	VR-2	
SV-4419A	6-B	HC	B	-	3WY	S0	HE	BID	0P	NA	VR-2	
SV-4419B	6-B	NC	B	-	3WY	S0	HE	BID	0P	NA	VR-2	
SV-4420A	6-B	NC	B	-	3WY	S0	HE	BID	0P	NA	VR-2	
SV-4420B	6-B	NC	B	-	3WY	S0	NE	BID	0P	NA	VR-2	
SV-4421A	6-B	NC	B	-	3WY	S0	NE	BID	0P	NA	VR-2	
SV-4421B	6-B	NC	B	-	3WY	S0	NE	BID	0P	NA	VR-2	
SV-4422B	H-6	NC	B	-	3WY	S0	ND	BID	CS	NA	VR-2	
SV-4422	H-7	NC	B	-	3WY	S0	ND	BID	CS	NA	VR-2	
SV-4429	H-6	1	A/C	16	CX	SA	0	AT-A CT-CC CT-C0	RR RR RR	NA		
SV-4400	005	H-4	1	A/C	16	CX	SA	0	AT-A CT-CC CT-C0	RR RR RR	NA	
SV-4400	005	F-6	H0	C	2	CX	SA	C	CT-CC	RR	VR-19	
SV-4401A	0-6	H0	C	2	CX	SA	C	CT-CC	RR	VR-19		
SV-4401S	H-5	HC	C	2	CX	SA	C	CT-CC	RR	VR-19		
SV-4401B	0-5	H0	C	2	CX	SA	C	CT-CC	RR	VR-19		

PREPARED BY : NUCLECH
FRIKAN : FRIKAN

INSERVICE TESTING, FRIKAN
1ST CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FAD : H-114
SYSTEM : NUCLEAR BOILER
REVISION 15

PAGE : 12
1ST FRIKAN REVISION : 005 , 12/23/83

VALVE NUMBER	FAD CODE	1ST CLASS	VALVE CAT	VALVE SIZE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	RELIEF REQUEST	RELIEF REQUEST
V-14-032	F-1	NC	C	.75	CK	SA	0	CT-CC	RR	VR-19
V-14-100	6-8	NC	C	.75	CK	SA	0	CT-CC	RR	VR-19
V-14-104	6-8	NC	C	.75	CK	SA	0	CT-CC	RR	VR-19
V-34-108	6-8	NC	C	.75	CK	SA	0	CT-CC	RR	VR-19
V-14-132	6-9	NC	C	.75	CK	SA	0	CT-CC	RR	VR-19
V-14-136	6-9	NC	C	.75	CK	SA	0	CT-CC	RR	VR-19
V-14-170	6-9	NC	C	.75	CK	SA	0	CT-CC	RR	VR-19
V-14-174	6-9	NC	C	.75	CK	SA	0	CT-CC	RR	VR-19
24V-4453H	E-3	A/C	1	XF/C	SA	0	A1-2	RF	VR-H	
24V-4453H	D-3	A/C	1	XF/C	SA	0	A1-2	RF	VR-B	
24V-4453H	E-3	A/C	1	XF/C	SA	0	CT-CC	RR	VR-B	
24V-4453H	D-3	A/C	1	XF/C	SA	0	CT-CC	RR	VR-B	

PREPARED BY : NOTECH
PROGRAM : PRISM

IN-SERVICE TESTING PROGRAM

IST CLASS 1, 2, 3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

FAID : H-114
SYSTEM : NUCLEAR BOILER
REVISION 15

PAGE : 005 , 12/23/83
LIST PROGRAM REVISION : 13

VALVE NUMBER	FAID	1ST CLASS	VALVE SIZE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
VFV-4455B	C-3	A/C	1	XFC	SA	0	AI-2 CI-CC PII 2Y	RR RR RR 2Y	VK-B	
VFV-4456A	C-3	A/C	1	XFC	SA	0	AI-2 CI-CC PII 2Y	RR RR RR 2Y	VK-B	
VFV-4457A	E-7	A/C	1	XFC	SA	0	AI-2 CI-CC PII 2Y	RR RR RR 2Y	VK-B	
VFV-4457B	D-7	A/C	1	XFC	SA	0	AI-2 CI-CC PII 2Y	RR RR RR 2Y	VK-B	
VFV-4458B	E-7	A/C	1	XFC	SA	0	AI-2 CI-CC PII 2Y	RR RR RR 2Y	VK-B	
VFV-4459B	D-7	A/C	1	XFC	SA	0	AI-2 CI-CC PII 2Y	RR RR RR 2Y	VK-B	
VFV-4459A	E-7	A/C	1	XFC	SA	0	AI-2 CI-CC PII 2Y	RR RR RR 2Y	VK-B	
VFV-4459B	C-7	A/C	1	XFC	SA	0	AI-2 CI-CC PII 2Y	RR RR RR 2Y	VK-B	

PREPARED BY : NUITECH
PROGRAM : PRISM

INSERVICE TESTING PROGRAM

151 CLASS 1, 2, 3, AND 4C VALVES

DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

P&ID : H-114
SYSTEM : NUCLEAR BOILER

REVISION 15

1ST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	P&ID CLASS	1ST CLASS CODE	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST TIME	STROKE TIME	MAXIMUM LEAKAGE	RELIEF RELIEF	REMARKS
XV-4460A	C-7	1	A/C	1	XFC	SA	0	A1-2	RR			VR-B
XV-4460B	C-7	1	A/C	1	XFC	SA	0	A1-2	RR			VR-B

PERFORMED BY : MOITECH
PROGRAM : PFTSM

INSERVICE TESTING PROGRAM
IST CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

F&ID : M-115 REVISION 0
SYSTEM : REACTOR VESSEL INSTRUMENTATION

VALVE NUMBER	FIELD CLASS	TEST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	FELT REQUEST		REMARKS
											TEST FREQ	MAXIMUM LEAKAGE	
SV-45940	B-3	2	A	1	BAL	SB	C	AT-1 FST	RR OP	005	AT-3 FST	VR-32 VR-17	
SV-45940B	B-3	2	A	1	BAL	SD	C	AT-1 FST	RR OP	005	AT-3 FST	VR-32 VR-17	
SV-4501A	E-3	1	A	1	XFC	SA	0	AT-1 FST	RR OP	005	AT-2 CT-CC PIT	VR-0	
SV-4501B	E-3	1	A	1	XFC	SA	0	AT-1 FST	RR OP	005	AT-2 CT-CC PIT	VR-0	
SV-4503	E-3	1	A	1	XFC	SA	0	AT-2 PIT	RR 2Y		AT-2 CT-CC PIT	VR-0	
SV-4504	E-6	1	A	1	XFC	SA	0	AT-2 PIT	RR 2Y		AT-2 CT-CC PIT	VR-0	
SV-4505	E-3	1	A	1	XFC	SA	0	AT-2 PIT	RR 2Y		AT-2 CT-CC PIT	VR-0	
SV-4506	B-3	1	A	1	XFC	SA	0	AT-2 PIT	RR 2Y		AT-2 CT-CC PIT	VR-0	
SV-4507	B-3	1	A	1	XFC	SA	0	AT-2 PIT	RR 2Y		AT-2 CT-CC PIT	VR-0	

PREPARED BY : RUTCH
FREDERICK PRISIN

INSERVICE TESTING PROGRAM
1ST CLASS 1, 2,
3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

PAID
SYSTEM : R-115
REVISION 0
REACTOR VESSEL INSTRUMENTATION

PAGE : 16
1ST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	PAID CODE	1ST CLASS CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	SET LIFEF REQUEST	REMARKS
XFV-4508	H-3	A	1	XFC	SA	0	AI-2 CT-CC PIT	RR 2Y	-	VR-B	
XFV-4510A	E-6	A	1	XFC	SA	0	AI-2 CT-CC PIT	RR 2Y	-	VR-B	
XFV-4516B	E-7	A	1	XFC	SA	0	AI-2 CT-CC PIT	RR 2Y	-	VR-B	
XFV-4511	H-3	A	1	XFC	SA	0	AI-2 CT-CC PIT	RR 2Y	-	VR-B	
XFV-4512	H-3	A	1	XFC	SA	0	AI-2 CT-CC PIT	RR 2Y	-	VR-B	
XFV-4513	H-3	A	1	XFC	SA	0	AI-2 CT-CC PIT	RR 2Y	-	VR-B	
XFV-4514	H-3	A	1	XFC	SA	0	AI-2 CT-CC PIT	RR 2Y	-	VR-B	
XFV-4515	H-3	A	1	XFC	SA	0	AI-2 CT-CC PIT	RR 2Y	-	VR-B	
XFV-4516	H-3	A	1	XFC	SA	0	AI-2 CT-CC PIT	RR 2Y	-	VR-B	

PREPARED BY : WUTCH
PREPARED BY : KRISTIN

UNSERVICE TESTING PROGRAM
LST CLASS 1, 2, 3, AND NC VALVES
DOE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FID : M-115 REVISION 0
SYSTEM : REACTOR VESSEL INSTRUMENTATION

VALVE NUMBER	FID	LST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM LEAKAGE	RELIEF REQUIREMENT		REMARKS
										TEST FREQ	TEST TIME	
XFV-4518	B-6	A	1	XFC	SA	0	AI-2	RR	RR	CT-CC	RR	VR-B
XFV-4519	B-3	A	1	XFC	SA	0	AI-2	RR	RR	CT-CC	RR	VR-B
XFV-4520	B-6	A	1	XFC	SA	0	AI-2	RR	RR	CT-CC	RR	VR-B
XFV-4522	E-3	A	1	XFC	SA	0	AI-2	RR	RR	CT-CC	RR	VR-B
XFV-4524	F-6	A	1	XFC	SA	0	AI-2	RR	RR	CT-CC	RR	VR-B
XFV-4529	F-6	A	1	XFC	SA	0	AI-2	RR	RR	CT-CC	RR	VR-B
XFV-4530	F-6	A	1	XFC	SA	0	AI-2	RR	RR	CT-CC	RR	VR-B
XFV-4531	E-6	A	1	XFC	SA	0	AI-2	RR	RR	CT-CC	RR	VR-B

DEVELOPED BY : MOTTECH
PROGRADED : PRISIM

ON-SERVICE TESTING PROGRAM
LST CLASS 1, 2, 3, AND NC VALVES
DIAINE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

P&ID : H-115 REVISION 0
SYSTEM : REACTOR VESSEL INSTRUMENTATION

LST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	P&ID	LST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
xFV-4583	E-6	1	A	1	XFC	SA	0	AI-2 CL-CC PII	RR RR 2Y	VR-B		
xFV-4584	D-6	1	A	1	XFC	SA	0	AI-2 CL-CC PII	RR RR 2Y	VR-B		
xFV-4585	D-6	1	A	1	XFC	SA	0	AI-2 CL-CC PII	RR RR 2Y	VR-B		
xFV-4586	F-3	1	A	1	XFC	SA	0	AI-2 CL-CC PII	RR RR 2Y	VR-B		
xFV-4587	F-3	1	A	1	XFC	SA	0	AI-2 CL-CC PII	RR RR 2Y	VR-B		
xFV-4588	F-3	1	A	1	XFC	SA	0	AI-2 CL-CC PII	RR RR 2Y	VR-B		
xFV-4589	E-3	1	A	1	XFC	SA	0	AI-2 CL-CC PII	RR RR 2Y	VR-B		
xFV-4590	D-3	1	A	1	XFC	SA	0	AI-2 CL-CC PII	RR RR 2Y	VR-B		
xFV-4591	G-3	1	A	1	XFC	SA	0	AI-2 CL-CC PII	RR RR 2Y	VR-B		

PREPARED BY : MOTECH
PROGRAM : PRISM

IN-SERVICE TESTING PROGRAM
LST CLASS 1, 2,
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

P&ID H-116 REVISION 12
SYSTEM : REACTOR RECIRCULATION

VALVE NUMBER	P&ID NUMBER	LST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST		REMARKS
										LST PROGRAM REVISION	PAGE	
HV-4639	F-6	1	A	.75	6L	A0	C	AT-1 BIC PIT	RR 0P 2Y	005	NA	
HV-4639	F-6	1	B	22	6A	H0	0	BIC PIT	CS 0P 2Y	036	NA	
HV-4639	C-8	1	B	22	6A	H0	0	BIC PIT	CS 0P 2Y	036	NA	
HV-4639	C-3	1	B	4	6A	H0	C	BIC PIT	CS 0P 2Y	036	NA	
HV-4630	C-8	1	B	4	6A	H0	C	BIC PIT	CS 0P 2Y	036	NA	
HV-4639	F-6	MC	B	-	3WY	S0	ND	BID	0P	NA	VR-2	
HV-4640	F-6	MC	B	-	3WY	S0	ND	BID	0P	NA	VR-2	
HV-4639	A-5	1	A/C	1	8FC	SA	0	AT-2 C1-CC PIT	RR 0P 2Y	0	VR-8	
HV-4630	A-5	1	A/C	1	8FC	SA	0	AT-2 C1-CC PIT	RR 0P 2Y	0	VR-8	
HV-4631	A-5	1	A/C	1	8FC	SA	0	AT-2 C1-CC PIT	RR 0P 2Y	0	VR-8	

PREPARED BY : MUECH
PRINCIPAL : PRISIM

IN-SERVICE TESTING PROGRAM
1ST CLASS 1, 2, 3, AND NC VALVES
DIANE ARTHUR ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FIELD ID : H-116
SYSTEM : REACTOR REGULATION
REVISION 12

PAGE : 20
1ST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	FIELD COPR	1ST CLASS	VALVE SIZE	VALVE CAT	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	RELIEF REQUEST
XFV-46412	A-5	A/C	1	XFC	SA	0	A1-2 PII	RR 2Y	RR	VR-B	
XFV-4637	E-6	A/C	1	XFC	SA	0	A1-2 PII	RR 2Y	RR	VR-B	
XFV-4634H	E-6	A/C	1	XFC	SA	0	A1-2 PII	RR 2Y	RR	VR-B	
XFV-4641A	H-7	A/C	1	XFC	SA	0	A1-2 PII	RR 2Y	RR	VR-B	
XFV-4641B	H-3	A/C	1	XFC	SA	0	A1-2 PII	RR 2Y	RR	VR-B	
XFV-4641D	L-7	A/C	1	XFC	SA	0	A1-2 PII	RR 2Y	RR	VR-B	
XFV-4642H	G-3	A/C	1	XFC	SA	0	A1-2 PII	RR 2Y	RR	VR-B	
XFV-4643A	G-7	A/C	1	XFC	SA	0	A1-2 PII	RR 2Y	RR	VR-B	

PREPARED BY: MOTECH
FONDRAH: FONDRAH

UNSERVICE TESTING PROGRAM
I.E.I. CLASS 1, 2, 3, AND AC VALVES
DOANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

F&ID: H-116 REVISION 1.2
SYSTEM: REACTOR RECIRCULATION

VALVE NUMBER	F&ID COOR	TEST CLASS	VALVE CAT	VALVE SIZE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
4F V-4644A	6-7	1	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR 2Y		VR-B	
4F V-4644B	6-3	1	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR 2Y		VR-B	
4F V-4663	F-4	1	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR 2Y		VR-B	
4F V-4664	F-4	1	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR 2Y		VR-B	
4F V-4665	F-4	1	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR 2Y		VR-B	
4F V-4666	F-4	1	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR 2Y		VR-B	
4F V-4667	E-4	1	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR 2Y		VR-B	
4F V-4668	E-4	1	A/C	1	XFC	SA	0	AT-2 CT-CC PIT	RR 2Y		VR-B	

PREPARED BY : MOTECH
FIREREF : PRISM

INSERVICE TESTING PROGRAM

ISI CLASS 1, 2, 3, AND NC VALVES
DIANE ARTHUR ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

F&ID H-116
SYSTEM REACTOR RECIRCULATION

REVISION 1.2

ISI PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	F&ID COOR	ISI CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE	MAXIMUM LEAKAGE	RELIEF REQUEST	REQUESTS
XFV-4670	E-4	A/C	1	XFC	SA	0	A1-2	RR	CI-CC	RR	VR-B	
XFV-4671	E-4	A/C	1	XFC	SA	0	A1-2	RR	CI-CC	RR	VR-B	
XFV-4672	E-4	A/C	1	XFC	SA	0	A1-2	RR	CI-CC	RR	VR-B	
XFV-4673	E-4	A/C	1	XFC	SA	0	A1-2	RR	CI-CC	RR	VR-B	
XFV-4674	E-4	A/C	1	XFC	SA	0	A1-2	RR	CI-CC	RR	VR-B	
XFV-4675	D-4	A/C	1	XFC	SA	0	A1-2	RR	CI-CC	RR	VR-B	
XFV-4676	D-4	A/C	1	XFC	SA	0	A1-2	RR	CI-CC	RR	VR-B	
XFV-4677	D-4	A/C	1	XFC	SA	0	A1-2	RR	CI-CC	RR	VR-B	
XFV-4678	D-4	A/C	1	XFC	SA	0	A1-2	RR	CI-CC	RR	VR-B	

PREPARED BY : PHOTEC
PUBLISHER : PRISM

INSERVICE TESTING PROGRAM
IOWA ELECTRIC LIGHT
AND POWER
IST CLASS 1, 2,
3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FAD ID : M-116
SYSTEM : REACTOR RECHARGEATION

PAGE : 005 , 12/23/85

VALVE NUMBER	FAD ID NUMBER	IST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	
											REMARKS	REMARKS
XFV-4619	A-1	1	A/C	1	XFC	SA	0	AT-2	RR	RR	VR-9	
								PII	2Y			
XFV-4619	A-7	1	A/C	1	XFC	SA	0	AT-2	RR	RR	VR-9	
								PII	2Y			
XFV-46B1	A-3	1	A/C	1	XFC	SA	0	AT-2	RR	RR	VR-9	
								PII	2Y			
XFV-46B2	A-3	1	A/C	1	XFC	SA	0	AT-2	RR	RR	VR-9	
								PII	2Y			

PREPARED BY : RITECH
FREIGHT : PRISM

IN-SERVICE TESTING PROGRAM

ISI CLASS 1, 2, 3, AND HC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

F&ID : A-117
SYSTEM : CONTROL ROD DRIVE HYDRAULIC
REVISION 17

ISI PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	F&ID CODE	ISI CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	TEST STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	RELIEF REQUEST
V-1004A	A-5	1	A	1	GL	A0	0	AT-1 B1C PIT	RR 0F 2Y	0.05	NA	VR-2
V-1004B	A-5	1	A	1	GL	A0	0	AT-1 B1C PIT	RR 0F 2Y	0.05	NA	VR-2
V-17-052	E-3	1	A/C	3	CK	SA	C	AT-1 C1-CC	RR RR	NA	VR-30	VR-30
V-17-053	E-2	1	A/C	3	CK	SA	C	AT-1 C1-CC	RR RR	NA	VR-30	VR-30
V-17-083	A-6	1	A/C	1	CK	SA	0	AT-1 C1-CC	RR RR	NA	VR-12	VR-12
V-17-098	A-4	1	A/C	1	CK	SA	0	AT-1 C1-CC	RR RR	NA	VR-12	VR-12

PERFORMED BY : MOTECH
PROGRAM : PRISM

IN-SERVICE TESTING PROGRAM
ISI CLASS 1, 2, 3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

PART # H-118
SYSTEM : CONTROL KOD DRIVE HYDRAULIC

PAGE : 25
REVISION #: 005 , 12/23/83

VALVE NUMBER	PART CODE	ISI CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	RELIEF REQUEST
CV-1049	P-7	1	B	.75	6A	A0	C/F0	BIG FST	SP SP	NA	VR-13 VR-17
CV-1050	D-6	1	B	.75	6A	A0	C/F0	BIG FST	SP SP	NA	VR-13 VR-17
CV-1059	G-4	1	B	1	6L	A0	O/FC	BIG FST	CS CS	0.30	VR-17
CV-10596	G-4	1	B	1	6L	A0	O/FC	BIG FST	CS CS	0.30	VR-17
CV-10598	G-4	1	B	1	6L	A0	O/FC	BIG FST	CS CS	0.30	VR-17
CV-1067	D-5	1	B	2	6L	A0	O/FC	BIG FST	CS CS	0.32	VR-17
CV-10670	D-5	1	B	2	6L	A0	O/FC	BIG FST	CS CS	0.32	VR-17
CV-10674	D-5	1	B	2	6L	A0	O/FC	BIG FST	CS CS	0.32	VR-17
CV-10831	C-7	1	B	.5	6A	S0	C/FC	BIG FST	SP SP	NA	VR-14 VR-17
CV-10832	C-7	1	B	.75	6A	S0	C/FC	BIG FST	SP SP	NA	VR-14 VR-17

PREPARED BY : MOTECH
FRIKAN : FRISTIHL

INSERVICE TESTING PROGRAM
LST CLASS 1, 2,
AND AC VALVES
DUANE ARNOLD ENERGY CENTER

LOWE ELECTRIC LIGHT
AND POWER

F&ID : M-110
SYSTEM : CONTROL ROD DRIVE HYDRAULIC

REVISION 08
LST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	F&ID	LST CLASS	VALVE SIZE	VALVE CAT	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
SV-1053	C-7	1	B	.5	6A	SD	C/FC	BIG FST	SP SP	NA NA	VR-14 NOTE-001 VR-17
SV-1054	C-7	1	B	.75	6A	SG	C/FC	BIG FST	SP SP	NA NA	VR-14 NOTE-001 VR-17
SV-1055	E-6	NC	B	-	3WY	SD	NE	BID	SP	NA	VR-13
SV-1056	E-6	NC	B	-	3WY	SD	NE	BID	SP	NA	VR-13
SV-1060	D-4	NC	B	.25	3WY	SD	NE	BID	SP	NA	VR-2
SV-1069	D-4	NC	B	.25	3WY	SD	NE	BID	0P	NA	VR-2
SV-1070	B-8	1	C	.5	CK	SA	C	CT-CC	SP	NA	VR-13 NOTE-002
SV-10919	E-7	1	C	.5	CK	SA	0	CT-CC	SP	NA	VR-13 NOTE-003
SV-10933	B-8	1	C	.5	CK	SA	C	CT-CO	SP	NA	VR-13 NOTE-004

PREPARED BY : MOTECH
FTEUKAM : FTEUKAM

INSERVICE TESTING, FTEUKAM
LSTI CLASS 1, 2, 3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

LIMA ELECTRIC LIGHT
AND POWER

FID ID : H-119
SYSTEM : RESIDUAL HEAT REMOVAL
REVISION 1.6

PAGE : 27
LSTI FTEUKAM REVISION : 005 , 12/23/83

VALVE NUMBER	FID CODE	LSTI CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-1906	E-7	1	A/C	20	CK	SAT	C	AT-5 CT-CC CT-CG FIT	RR CS CS 2Y	NA	VR-29	
HU-1900	H-0	1	A	4	6A	HO	C	AT-1 AT-5 BIC FIT	RR RR CS 2Y	NA	VR-29	
HU-1901	H-7	1	A	4	6A	HO	C	AT-1 AT-5 BIC FIT	RR RR CS 2Y	NA	VR-29	
HU-1902	H-7	2	B	10	6A	HO	C	BIC FIT	OP 2Y	014		
HU-1903	G-6	2	B	10	6L	HO	C/R1	BIC FIT	OP 2Y	014		
HU-1904	E-6	2	B	20	AN6	HO	O	B10 FIT	OP 2Y	037		
HU-1905A	E-6	1	A/B	20	6A	HO	C	AT-5 BIC B10 FIT	RR CS OP 2Y	037 037		
HU-1906	E-0	1	A	10	6A	HO	O	AT-1 AT-5 BIC FIT	RR RR CS 2Y	NA	VR-29	
HU-1907	E-0	1	A	10	6A	HO	C	AT-1 AT-5 BIC FIT	RR RR CS 2Y	NA	VR-29	

PREPARED BY : MOTECH
PROGRAM : PRISM

ON-SERVICE TESTING PROGRAM
LST CLASS 1, 2, 3, AND NC VALVES
DIANE ARTHUR ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

F&ID : M-119
SYSTEM : RESIDUAL HEAT REMOVAL

REVISION 16
LST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	F&ID	LST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR POSITION	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
RI-1912	C-7	2	B	18	6A	H0	C	BIC FIT	0P 2Y	0B4	0B4	
RI-1913	C-7	2	B	18	6A	H0	0/RL	BIC B10 FIT	0P 2Y	0B4	0B4	
RI-1920	C-8	2	B	18	6A	H0	C	BIC B10 FIT	0P 2Y	0B4	0B4	
RI-1921	C-7	2	B	18	6A	H0	0/RL	BIC B10 FIT	0P 2Y	0B4	0B4	
RI-1932	F-5	2	B	12	6A	H0	C/RL	BIC B10 FIT	0P 2Y	0B3	0B3	
RI-1933	F-5	2	B	4	6L	H0	C	BIC B10 FIT	0P 2Y	0B9	0B9	
RI-1934	F-5	2	B	12	6L	H0	C	BIC B10 FIT	0P 2Y	0A1	0A1	
RI-1935	C-5	2	B	3	6A	H0	0	BIC B10 FIT	0P 2Y	019	019	
RI-1936	P-6	2	B	4	6L	H0	C	BIC B10 FIT	0P 2Y	0A6	0A6	
RI-1937	0-6	2	B	4	6A	H0	C	BIC B10 FIT	0P 2Y	019	019	
RI-1938	P-4	2	B	12	6L	H0	0/RL	BIC B10 FIT	0P 2Y	0B6	0B6	

PREPARED BY : MUNTECH
PROGRAM : FRISTIM

INSERVICE TESTING PROGRAM
ISI CLASS 1, 2, 3, AND HC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FAID H-119 REVISION 16
SYSTEM : RESIDUAL HEAT REMOVAL

PAGE : 29
ISI PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	FAID CODE	ISI CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
110-1940	E-4	2	B	18	6L	H0	H0	0	BIC B10 P11	0P 0P 2Y	000 060	
110-1941	E-3	2	B	18	6A	H0	0/KL		BIC B10 P11	0P 0P 2Y	080 080	
110-1949A	D-4	2	B	1	6L	H0	C		BIC P11	0P 2Y	018	
110-1949B	D-4	2	B	1	6L	H0	C		BIC P11	0P 2Y	018	
110-1967	E-2	2	B	4	6A	H0	C		BIC B10 P11	0P 0P 2Y	030 030	
110-1970	E-3	2	B	4	6A	H0	C		BIC P11	0P 2Y	017	
110-1989	D-7	2	B	24	6A	H0	0/R0		BIC B10 P11	0P 0P 2Y	140 140	
F5V-1911	D-0	2	B/C	1	KV	SA	C		C1-SF	SY		
F5V-1952	B-4	2	B/C	4	KV	SA	C		C1-SF	SY		
V-19-001	A-7	2	C	12	CK	SA	C		C1-CC C1-C0	0P		
V-19-003	0-5	2	C	12	CK	SA	C		C1-CC C1-C0	0P		
V-19-014	A-0	2	C	3	CK	SA	C		C1-CC C1-C0	0P		

PREPARED BY : MOTEC
FOLKAK : PRISM
FOLKAK

INSERVICE TESTING PROGRAM
1ST CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FILE #: H-119
SYSTEM : RESIDUAL HEAT REMOVAL
REVISION 16

1ST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	FILE CNR	1ST CLASS	VALVE CAT	VALVE SIZE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE LEAKAGE	RELIEF REQUEST	REQUEST
V-19-016	H-5	2	C	3	CK	SA	C	C	CT-CC CT-CO	OF	OF
V-19-020	B-6	2	B/C	1	SK	MSA	0	CT-CC	OF		
V-19-023	B-6	2	B/C	1	SK	MSA	0	CT-CC	OF		
V-19-128	B-6	2	B/C	1	SK	MSA	0	CT-CC	OF		

PREPARED BY : MOTECH
FOLKAKH : PRISM

INSERVICE TESTING FOLKAKH
IST CLASS 1, 2, 3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FID ID : H-120
SYSTEM : RESIDUAL HEAT REMOVAL
REVISION 14

IST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	FID ID CODE	FID CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
H0-2000	6-2	2	B	19	GA	H0	C/KL	AT-5 BIC PIT	0F 2Y	014		
H0-2001	6-4	2	B	16	GL	H0	C/KL	AT-5 BIC PIT	0F 2Y	014		
H0-2003	F-4	1	A/B	20	GA	H0	C	AT-5 BIC B10 PIT	0F 0P 2Y	037 037		
H0-2004	F-4	2	B	20	ARG	H0	0	B10 PIT	0F 2Y	037		
H0-2005	6-4	2	B	12	GA	H0	C/KL	BIC B10 PIT	0F 0P 2Y	083 083		
H0-2006	F-4	2	B	4	GL	H0	C	BIC B10 PIT	0F 0P 2Y	009		
H0-2007	F-5	2	B	12	GL	H0	C	BIC B10 PIT	0F 0P 2Y	041 041		
H0-2009	C-4	2	B	3	GA	H0	0	BIC B10 PIT	0F 0P 2Y	019 019		
H0-2011	C-3	2	B	14	GA	H0	C	BIC PIT	0F 2Y	084		

PREFACE BY MITECH
PROGRAM : PRISM

INSERVICE TESTING PROGRAM

1ST CLASS 1, 2, 3, AND NC VALVES DUANE DENNOD ENERGY CENTER

SOMA ELECTRIC LIGHT
AND POWER

PART		REVISED		REVISION 14		PART		REVISED		REVISION 14	
SYSTEM		H-120		RESIDUAL HEAT REMOVAL		SYSTEM		H-120		RESIDUAL HEAT REMOVAL	
VALVE	FIELD	VALVE	FIELD	VALVE	FIELD	VALVE	FIELD	VALVE	FIELD	VALVE	FIELD
NUMBER	COLOR	CLASS	CAT	SIZE	CAT	TYPE	POSITION	TEST	FREQ	TEST	REQUEST
valve-2012	C-3	2	B	14	GA	HO	0/KL	BIC	0F	0B4	REMARKS
								B10	0F	0B4	
								PIT	2Y		
valve-2016	C-2	2	B	14	GA	HO	0/KL	BIC	0F	0B4	
								B10	0F	0B4	
								PIT	2Y		
valve-2039	D-5	2	B	12	GA	HO	0	BIC	0F	0B0	
								B10	0F	0B0	
								PIT	2Y		
valve-2050	E-5	2	B	18	GA	HO	0	BIC	0F	0B0	
								B10	0F	0B0	
								PIT	2Y		
valve-2051	E-7	2	B	12	GA	HO	0	BIC	0F	0B0	
								B10	0F	0B0	
								PIT	2Y		
valve-2056	E-8	2	B	4	GA	HO	C	BIC	0F	034	
								B10	0F	030	
								PIT	2Y		
valve-2038	E-7	2	B	1	GA	HO	C	BIC	0F	017	
								B10	0F	018	
								PIT	2Y		

PREPARED BY : HUTCHIN
FOLKAM : FOLKAM

IN SERVICE TESTING, FOLKAM
LST CLASS 1, 2, 3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

P/T ID : M-120
SYSTEM : RESIDUAL HEAT REMOVAL
REVISION 1.4

PAGE : 33
LST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	P/T ID NUMBER	FAD CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
01-2069	B-3	2	B	24	EA	H0	0/KL	BTC B10 PIT	OF OF OF	140 140 2Y	
PSV-2043	D-6	2	B/C	4	RV	SA	C	CT-SP	5V		
V-20-001	B-3	2	C	12	CK	SA	C	CT-CC CT-CD	OF OF		
V-20-003	A-5	2	C	12	CK	SA	C	CT-CC CT-CD	OF OF		
V-20-006	B-4	2	C	3	CK	SA	C	CT-CC CT-CD	OF OF		
V-20-008	B-2	2	L	3	CK	SA	C	CT-CC CT-CD	OF OF		

PREPARED BY : MITECH
PROGRAM : PRISM

INSERVICE TESTING PROGRAM
I.S.I. CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

PLATE N-121
SYSTEM : CORE SKYAY
REVISION 1.5

PAGE : 34
1.S.I. PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	PLATE CLASS	1.S.I. CLASS	VALVE CAT	VALVE SIZE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
E.V.-2118	F-6	1	A/C	8	CK	SAT	C	AT-5 CT-CC CT-CO PIT	RR RR RR 2Y	VR-33 VR-33	
E.V.-2138	E-6	1	A/C	8	CK	SAT	C	AT-5 CT-CC CT-CO PIT	RR RR RR 2Y	VR-33 VR-33	
H0-2106	H-5	2	B	12	6A	HO	O/R/L	B10 PIT	0P 2Y	078	
H0-2104	D-3	2	B	2	6A	HO	O	B1C PIT	0P 2Y	013	
H0-2112	F-5	2	B	8	6I	HO	C	B1C PIT	0P 2Y	033	
H0-2115	G-5	2	A	B	6A	HO	O	AT-1 B1C B10 PIT	RR 0P 0P 2Y	NA 008 008	
H0-2117	G-5	1	A	0	6A	HO	C	AT-1 AT-5 B1C B10 PIT	RR RR 0P 0P 2Y	NA 078	VR-29
H0-2120	C-5	2	B	12	6A	HO	O/R/L	B10 PIT	0P 2Y		
H0-2124	P-4	2	B	2	6A	HO	O	B1C PIT	0P 2Y	013	

PREPARED BY : NOOTECH
FROM KAM FRISTIN

INSERVICE TESTLIST FOR KAH
LSI CLASS 1, 2, 3, AND NC VALVES
DUGANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FILED : H-124
SYSTEM : CORE SPRAY

PAGE : 35
REV LIST : 1.3
1ST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	FILED CLOCK	FILED CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
H0-2432	E-5	2	H	B	6A	HO	C	BIC PIT	0F 2Y	0.33		
H0-2435	E-5	2	A	B	6A	HO	0	AT-1 BIC BIO PIT	RR 0F 0F 2Y	0.08 0.08	NA	VR-29
H0-2437	E-6	1	A	B	6A	HO	C	AT-1 BIC BIO PIT	RR 0F 0F 2Y	0.08 0.08	NA	VR-29
H0-2446	C-5	2	B	42	6A	HO	0/R/L	BIC BIO PIT	0F 0F 2Y	0.78 0.78		
H0-2447	H-5	2	B	42	6A	HO	0/R/L	BIC BIO PIT	0F 0F 2Y	0.78 0.78		
F-SV-2109	E-4	2	B/C	2	RV	SA	C	CI-S/P	5Y			
F-SV-2129	E-4	2	B/C	2	16	UK	SA	C	CI-C/D	0F		
V-21-007	B-3	2	C	2	UK	SA	C	CI-S/P	5Y			
V-21-009	B-3	2	C	2	UK	SA	C	CI-C/D	0F			
V-21-010	B-4	2	C	10	UK	SA	C	CI-C/D	0F			
V-21-012	B-4	2	C	2	UK	SA	C	CI-C/D	0F			
SV-2119	E-7	1	A/C	1	xF/C	SA	0	AT-2 CT-CC PIT	RR 2Y		VR-B	

RELEASED BY : MO TECH

IN SERVICE TESTING PROGRAM

LSTI CLASS 1, 2, 3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

F&ID M-124 REVISION 13
SYSTEM : CORE SPRAY

IOWA ELECTRIC LIGHT
AND POWER

LSI FINGER-PRINTED REVISION PAGE : 36 12/23/83

Wk-8
XFC 1 A/C 0 SA 0 A1-2 RR
CT-CC RR
PT 2Y

PERFORMED BY : MOTECH
PROGRAM : PRISM

IN-SERVICE TESTING PROGRAM
1ST CLASS 1, 2, 3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

TOKA ELECTRIC LIGHT
AND POWER

P&ID : H-422
SYSTEM : HFCL - STEAM SIDE
REVISION 14

PAGE : 37
1ST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	P&ID	1ST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-2206	D-2	2	B	1	6A	A0	C/FC	BIC FST PIT	0F 0F 2Y	005	VR-17
CV-2204	C-2	2	A	1	6A	A0	O/FC	AI-1 BIC FST PIT	RR 0F 0F 2Y	005	VR-29
CV-2212	C-2	2	A	1	6A	A0	O/FC	AI-1 BIC FST PIT	RR 0F 0F 2Y	005	VR-17
CV-2235	C-5	2	B	1	6A	A0	C/FC	BIC FST PIT	0F 0F 2Y	005	VR-17
HV-2204	E-3	2	B	10	6L	H0	C	BIG PIT	0F 2Y	030	
HV-2202	E-3	2	B	10	6A	H0	C	BIG PIT	0F 2Y	024	
H0-2238	G-6	1	A	10	6A	H0	O	AI-1 BIC BIG PIT	RR 0F 0F 2Y	013	NA
H0-2239	G-5	1	A	10	6A	H0	O	AI-1 BIC BIG PIT	RR 0F 0F 2Y	013	NA
H0-2247	H-5	2	B	2	6L	H0	C	BIG PIT	0F 2Y	014	

PREPARED BY : MTECH
FROOKAH : FRELIN

IN-SERVICE TESTING FROOKAH
1ST CLASS 1, 2,
AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

F&ID : R-1122
SYSTEM : HFCL - STEAM SIDE
REVISION 14

PAGE : 39
1ST FROOKAH REVISION : 005 , 12/23/83

VALVE NUMBER	F&ID	1ST COOR	1ST CLASS	VALVE SIZE	VALVE CAT	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
W0-2290A	H-8	2	A	2	6A	HO	0	AI-1	RR		NA		
								BIG	OP	010			
								BIO	OP	010			
								PIT	2Y				
W0-2290B	H-8	2	A	2	6A	HO	0	AI-1	RR		NA		
								BIG	OP	010			
								BIO	OP	010			
								PIT	2Y				
PSV-2223	C-3	2	B/C	1.25	RV	SA	C	CT-SP	SY				
							C	CT-SP	SY				
PSV-222B	C-4	2	B/C	1	RV	SA	C	CT-SP	SY				
							C	CT-SP	SY				
SV-2206	D-2	HC	B	-	3WY	S0	ND	BID	OP	NA		VR-2	
								BID	OP				
SV-2254	C-2	HC	B	-	3WY	S0	NE	BID	OP			VR-2	
								BID	OP				
SV-2252	C-2	HC	B	-	3WY	S0	NE	BID	OP			VR-2	
								BID	OP				
SV-2219	C-4	2	B	1	6L	S0	C	BIC	OP	NA		VR-1B	
							C	BIC	OP				
SV-2235	C-5	HC	B	-	3WY	S0	ND	BID	OP	NA		VR-2	
								BID	OP				
W-22-016	H-7	2	A/C	16	CK	SA	C	AI-1	RR		NA		
							C	AI-1	RR				
								CT-CC	CS				
								CT-CC	OP				
W-22-017	H-7	2	C	16	CK	SA	C/A/O	CT-CB	OP				
							C	CT-CB	OP				
W-22-018	H-7	2	A/C	2	CK	SA	C	AI-1	RR		NA		
							C	AI-1	RR				
								CT-CC	CS				
								CT-CC	OP				
W-22-022	B-7	2	C	2	CK	NSA	C 1.0	CT-CO	OP				

PREPARED BY : MOTECHE
PROGRAM : PRISM

INSERVICE TESTING PROGRAM
1ST CLASS 1, 2,
3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

PART N-122
SYSTEM : HFCL - STEAM SIDE
REVISION 1.4

PAGE : 39
1ST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	PART NUMBER	PART COLOR	1ST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR	NORMAL POSITION	TEST FREQ	TEST STROKE TIME	MAXIMUM LEAKAGE	KELIEF REQUEST	KELIEF REQUEST
V-22-026	B-3	C	2	CK	2	CK	SA	C	CT-CC	0P			
V-22-026	B-4	C	2	CK	2	CK	SA	C	CT-CO	0P			
V-22-029	B-5	C	2	CK	2	CK	SA	C	CT-CO	0P			
V-22-063	B-8	C	3	CK	3	CK	SA	C	CT-CC	CS			
V-22-064	B-9	C	3	CK	3	CK	SA	C	CT-CC	CS			
XIV V-2246A	F-6	A	1	XFC	1	XFC	SA	0	AT-2	RR			VR-B
XIV V-2246B	F-6	A	1	XFC	1	XFC	SA	0	AT-2	RR			VR-B
XIV V-2246C	F-6	A	1	XFC	1	XFC	SA	0	AT-2	RR			VR-B
XIV V-2246D	F-6	A	1	XFC	1	XFC	SA	0	AT-2	RR			VR-B

PREPARED BY : PHOTEC
PROGRAM : PRISM

INSERVICE TESTING PROGRAM
IST CLASS 1, 2,
3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

F&ID : H-123 REVISION 16
SYSTEM : HFCL - WATER SIDE

PAGE : 46
IST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	F&ID NUMBER	IST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	TEST FREQ	KELIEF REQUEST	REMARKS
EV-2313	C-7	1	C	12	CK	SAT	C	CT-CC C1-C0	CS CS		
							PIT	2Y			
H0-2314	F-4	2	B	14	6A	H0	0	BIC PIT	0P 2Y	077	
H0-2314	C-6	2	B	12	6A	H0	0	BIO PIT	0P 2Y	01B	
H0-2312	C-7	1	A	12	6A	H0	C	AT-1 BIC	RR 0P	020	NA
							PIT	2Y			
H0-2316	E-6	2	B	8	6A	H0	C	BIC PIT	0P 2Y	024	
H0-2318	C-5	2	B	4	6L	H0	C	BIC PIT	0P 2Y	01B 01B	
H0-2321	A-7	2	B	14	6A	H0	C	BIC PIT	0P 2Y	077	
H0-2322	F-4	2	B	14	6A	H0	C	BIO PIT	0P 2Y	077	
EV-2304	F-3	2	B/C	1.5	EV	SA	C	CT-SP	5Y		
V-24-001	A-6	2	C	14	CK	SA	C	CT-CD	EE		
V-23-014	C-4	2	C	4	CK	SA	C	CT-CD	0P		

VR-21

PREPARED BY : MOTEC
FIREMAN : FRITHJAHN

1 SERVICE TESTING PROGRAM
LET CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FALD : H-124 REVISION 12
SYSTEM : RICC - STEAM SIDE

1ST PROGRAM REVISION : 12
PAGE : 41
DATE : 12/23/83

VALVE NUMBER	FALD CODE	1ST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-2409	E-2	2	B	1	GA	A0	0/FC	AT-1 B1C FST P1T	RR 0P 0P 2Y	005	NR-17
CV-2410	D-3	2	A	1	GA	A0	0/FC	AT-1 B1C FST P1T	RR 0P 0P 2Y	005	NR-29
CV-2411	D-3	2	A	1	GA	A0	0/FC	AT-1 B1C FST P1T	RR 0P 0P 2Y	005	NR-17
CV-2436	B-5	2	B	1	GA	A0	0/FC	AT-1 B1C FST P1T	RR 0P 0P 2Y	005	NR-17
CV-2400	C-6	1	A	4	GA	H0	0	AT-1 B1C B10 P1T	RR 0P 0P 2Y	005	NR-29
CV-2401	B-5	1	A	4	GA	H0	0	AT-1 B1C B10 P1T	RR 0P 0P 2Y	005	NR-17
CV-2404	B-3	2	B	4	GA	H0	0	AT-1 B1C B10 P1T	RR 0P 0P 2Y	016	NR-17
CV-2405	F-3	2	B	3	6t	H0	0	AT-1 B1C B10 P1T	RR 0P 0P 2Y	015	NR-17
CV-2435	D-6	2	B	1	6t	H0	0	AT-1 B1C B10 P1T	RR 0P 0P 2Y	014	NR-17

PREPARED BY : ROTECH
PROGRAM : PRISM

INSERVICE TESTING PROGRAM
LSTI CLASS 1, 2, 3, AND NC VALVES
DIANE ARTHUR ENERGY CENTER

F&ID : M-124 REVISION 1.2
SYSTEM : RUCIC - STEAM SIDE

PAGE : 42
LSTI PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	F&ID COOR	LSTI CLASS	VALVE CAT	VALVE SIZE	ACTUATOR TYPE	NOMINAL POSITION	TEST FREQ	TEST TIME	MAXIMUM RELIEF REQUEST	ET MARKS
V-34-74	C-3	2	R/C	1.25	RV	SA	C	CT-SP	5Y	VR-2
V-34-09	E-2	NC	B	-	3WY	SD	ND	BD	OP	NA
V-34-00	D-3	NC	B	-	3WY	SD	NE	BD	OP	VR-2
V-34-11	D-3	NC	B	-	3WY	SD	NE	BD	OP	VR-2
V-24-36	B-5	NC	B	-	3WY	SD	NE	BD	OP	NA
V-24-90B	B-7	2	C	10	SK	NSA	C/LD	CT-CO	OP	NOTE -005
V-24-012	C-6	2	C	2	CK	SA	C	CT-CO	OP	NOTE -005
V-24-023	B-7	2	A/C	10	CK	SA	C	AI-1	RR	NA
								CT-CC	CF	
								CT-CO	OP	
V-34-046	B-7	2	C	3	CK	SA	C	CT-CC	CS	
V-24-047	B-7	2	C	3	CK	SA	C	CT-CC	CS	
								CT-CD	OP	
4-V-3443A	F-6	1	A/C	1	XFC	SA	0	AI-2	RR	VR-8
								CT-CC	RR	
								PII	2Y	
4-V-3443B	F-6	1	A/C	1	XFC	SA	0	AI-2	RR	VR-B
								CT-CC	RR	
								PII	2Y	

PREPARED BY : MOTECH
PROGRAM : PRISM

INSERVICE TESTING PROGRAM
1ST CLASS 1, 2, 3, AND NC VALVES
DUANE KENNEDY ENERGY CENTER

LOMA ELECTRIC LIGHT
AND POWER

PART : H-124
SYSTEM : KCIC - STEAM SIDE
REVISION 12

1ST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	PART NUMBER	PART CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
XFV-2443D	F-6	1	A/C	1	XFC	SA	0	AT-2 CT-CC FIT	RR RR 2Y	VR-8		

PREPARED BY : MOTECHE
PRINTER : PRISH
FBIORAI : PRISH

INSERVICE TESTING PROGRAM
LSI CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FAIL ID : R-125
SYSTEM : RICC -- WATER SIDE

FAIL ID : R-125
SYSTEM : RICC -- WATER SIDE

VALVE NUMBER	FAIL CODE	FAIL CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST		MAXIMUM STROKE TIME	TEST FREQ	RELIEF REQUISTI-	REMARKS
							FIT	PII				
EV-2543	D-6	1	C	4	CK	SAT	C	C	CT-CC CT-CO	CS CS	PII 2Y	
EV-2540	F-4	2	B	6	GA	NO	NO	BIC	0P PII	0P 2Y	040	
EV-2540	C-4	2	B	2	GL	NO	C	BIC	0P BIO PII	0P 0P 2Y	013 013	
EV-2541	D-5	2	B	4	GA	NO	NO	BIO	0P PII	0P 2Y	015	
EV-2542	D-6	1	A	4	GA	NO	C	AI-1	RR		NA	
EV-2547	A-5	2	B	6	GA	NO	C	BIC	0P BIO PII	0P 0P 2Y	015 015	
EV-2547	F-4	2	B	6	GA	NO	C	BIO	0P PII	0P 2Y	040	
EV-2541	F-4	2	B/C	1	RV	SA	C	CT-SP	5Y			
EV-2540	A-S	2	C	6	CK	SA	C	CT-CO	RR		MR-24	
EV-25405	F-4	2	C	6	CK	SA	C	CT-CL	0P			
EV-25406	C-4	2	C	2	CK	SA	C	CT-CH	0P			

PREPARED BY : MOTECH
F-KULKAM : F-KULKAM

IN-SERVICE TESTING, F-KULKAM
IST CLASS 1, 2, 3, AND NC VALVES
DIANE AFNUD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FID ID : M-126 REVISION 09
SYSTEM : STANDBY LIQUID CONTROL

IST PROGRAM REVISION : 005 , 45
PAGE : 12/23/83

VALVE NUMBER	FID ID	CLASS CODE	1ST CLASS	VALVE SIZE	VALVE CAT	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
FSV-2607	E-5	2	B/C	1	RV	SA	C	CT-SP	SY			
FSV-2609	B-5	2	B/C	1	RV	SA	C	CT-SP	SY			
V-26-004	D-5	2	C	1.5	CK	SA	C	CT-CC	0F			
V-26-006	C-5	2	C	1.5	CK	SA	C	CT-CC	0P			
V-26-008	F-7	1	A/C	1.5	CK	SA	C	CT-CC	0P			
V-26-009	D-8	1	A/C	1.5	CK	SA	C	A1-A	RR	NA	VR-20	
								CT-CC	RR		VR-20	
								CT-C0	RR			
XSV-2610A	F-6	2	D	1.5	GA	EXP	C	DT	RR			
XSV-2610B	B-6	2	D	1.5	GA	EXP	C	DT	RR			

PREPARED BY : MOTECHE
PROGRAM : PRISM

MAINTENANCE TESTING PROGRAM
LST CLASS 1, 2,
3, AND NC VALVES
DUAME ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

F&ID : H-127
SYSTEM : REACTOR WATER CLEANUP

REVISION 15
LST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	F&ID NUMBER	LST CLASS	VALVE CAT	VALVE SIZE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
010-2790	F-8	1	A	4	6A	H0	H0	0	AI-1 BIC PIT	RR 0F 2Y	0.20
010-2704	F-7	1	A	4	6A	H0	H0	0	AI-1 BIC PIT	RR 0F 2Y	0.20
010-2749	G-4	1	A	4	6L	H0	H0	0	AI-1 BIC PIT	RR 0F 2Y	0.10

PREPARED BY : MOTECH
FROM KAN : PRISTIN

INSERVICE TESTING PROGRAM
1ST CLASS 1, 2, 3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

PAID #129 REVISION 11
SYSTEM : RIVER WATER SUPPLY - INTAKE

PAGE : 47
1ST PROGRAM REVISION : 063 , 12/23/83

VALVE NUMBER	PAID CODE	1ST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	KERMARKS
V-29-004	D-6	NC	C	18	CK	SA	0	CI-CC CI-CO	OP		
V-29-003	D-5	NC	C	18	CK	SA	0	CI-CC CI-CO	OP		
V-29-005	D-5	NC	C	18	CK	SA	0	CI-CC CI-CO	OP		
V-29-007	D-4	NC	C	18	CK	SA	0	CI-CC CI-CO	OP		

PREPARED BY : MOITECH
PROGRAM : PRISM

IN-SERVICE TESTING PROGRAM
LST CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

PART : M-130 REVISION 16
SYSTEM : COMPRESSED AIR

PAGE : 48
LST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	PART NUMBER	LST CLASS	VALVE SIZE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM LEAKAGE	RELIEF REQUIRE	REMARKS
V-30-207	B-B	NC	A	1	6A	H	C/LC	AI-1	RR	NA

PREPARED BY : MUNTECH
PRUGKAN : PRISIM

INSERVICE TESTING PROGRAM
LST CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

PART #: H-132 REVISION 16
SYSTEM : DIESEL GENERATOR SYSTEMS

PAGE : 49
LST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	PART NUMBER	LST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	RELIEF REQUEST	REMARKS
V-32-005	B-3	2	NC	1.5	CK	SA	C	CT-CC CT-CO	OP OP				
V-32-010	B-2	2	NC	1.5	CK	SA	C	CT-CC CT-CO	OP OP				

PREPAVED PT : MOTECH
PROGRAM : PRISM

MAINSERVICE TESTING PROGRAM

IST CLASS 1, 2, 3, AND AC VALVES
DUANE ARNOLD ENERGY CENTER

F&ID : H-137
SYSTEM : RADWASTE SUPP
REVISION 12

PAGE : 005 , 12/23/83

VALVE NUMBER	F&ID	IST CLASS	VALVE CAT	VALVE SIZE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	MARKS
UV-3704	H-7	3	A	3	6A	AO	0/FC	AI-1 BIC FST PIT	RR 0P 0P 2Y	NA	VR-29
UV-3705	H-7	3	A	3	6A	AO	0/FC	AI-1 BIC FST PIT	RR 0P 0P 2Y	NA	VR-17
UV-3708	D-6	3	A	3	6A	AO	0/FC	AI-1 BIC FST PIT	RR 0P 0P 2Y	NA	VR-29
UV-3729	D-6	3	A	3	6A	AO	0/FC	AI-1 BIC FST PIT	RR 0P 0P 2Y	NA	VR-17
UV-3744	G-7	NC	B	-	3WY	SO	NE	BID	OP	NA	VR-2
UV-3705	G-7	NC	B	-	3WY	SO	NE	BID	OP	NA	VR-2
UV-3720	G-6	NC	B	-	3WY	SO	NE	BID	OP	NA	VR-2
UV-3729	G-6	NC	B	-	3WY	SO	NE	BID	OP	NA	VR-2

PREPARED BY : NUTECH
 PROGRAM : PRISM

INSERVICE TESTING PROGRAM
 1ST CLASS 1, 2, 3, AND NC VALVES
 DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
 AND POWER

PAID M-143 REVISION 2B
 SYSTEM : CONTAINMENT ATMOSPHERE CONTROL

PAGE : 51
 1ST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	P&ID COOR	1ST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-4300	C-7	NC	A	18	BTF	AO	C/FC	AT-1 BTC FST PIT	RR OP OP 2Y	005	NA	VR-17	
CV-4301	C-8	NC	A	18	BTF	AO	C/FC	AT-1 BTC FST PIT	RR OP OP 2Y	005	NA	VR-17	
CV-4302	D-7	NC	A	18	BTF	AO	C/FC	AT-1 BTC FST PIT	RR OP OP 2Y	005	NA	VR-17	
CV-4303	D-7	NC	A	18	BTF	AO	C/FC	AT-1 BTC FST PIT	RR OP OP 2Y	005	NA	VR-17	
CV-4304	B-7	NC	A	20	BTF	AO	C/FO	AT-1 BTC BTO FST PIT	RR OP OP OP 2Y	005 042	NA	VR-17	
CV-4305	B-7	NC	A	20	BTF	AO	C/FO	AT-1 BTC BTO FST PIT	RR OP OP OP 2Y	005 042	NA	VR-17	
CV-4306	E-1	NC	A	18	BTF	AO	C/FC	AT-1 BTC FST PIT	RR OP OP 2Y	005	NA	VR-17	

PREPARED BY : MULCH
PROGRAM : PRISTIN

INSERVICE TESTING PROGRAM
LST CLASS 1, 2,
3, AND MC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FAIL ID : H-143
SYSTEM : CONTAINMENT ATMOSPHERE CONTROL
REVISIION 2B

LST PROGRAM REVISION : 005 , 12/23/83
PAGE : 52

VALVE NUMBER	FAIL CODE	LST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
UV-4307	E-3	NC	A	18	BIF	AO	C/FC	AI-1 BIC FST PIT	RR 0F 0F 2Y	005	NA	VR-17		
UV-4308	E-3	NC	A	18	BIF	AO	C/FC	AI-1 BIC FST PIT	RR 0F 0F 2Y	005	NA	VR-17		
UV-4309	D-7	NC	A	2	6A	AO	C/FC	AI-1 BIC FST PIT	RR 0F 0F 2Y	005	NA	VR-17		
UV-4310	D-7	NC	A	2	6A	AO	C/FC	AI-1 BIC FST PIT	RR 0F 0F 2Y	005	NA	VR-17		
UV-4311	F-3	NC	A	6	6A	AO	C/FC	AI-1 BIC FST PIT	RR 0F 0F 2Y	005	NA	VR-17		
UV-4312	F-3	NC	A	6	6A	AO	C/FC	AI-1 BIC FST PIT	RR 0F 0F 2Y	005	NA	VR-17		
UV-4313	F-3	NC	A	6	6A	AO	C/FC	AI-1 BIC FST PIT	RR 0F 0F 2Y	005	NA	VR-17		
UV-4316	G-7	NC	A/C	16	CR	SAT	C	AI-1 C1-C2 C1-C3 PIT	RR 0F 0F 2Y	005	NA	VR-17		

PREPARED BY : MOTECHE
PURDUE : FRISTI

INSERVICE TESTING PROGRAM

1ST CLASS 1, 2,
3, AND NC VALVES
DIANE AEMOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FID ID : H-143
SYSTEM : CONTAINMENT ATMOSPHERE CONTROL

REVISION 2B
TEST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	FID COOR	1ST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	TEST TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
CV-4327H	C-7	NC	A/C	1B	CK	SAT	C	A1-A	RR		NA	VR-11	
								CT-CC	OP				
								CT-CO	OP				
								PTI	2Y				
CV-4327C	C-7	NC	A/C	1B	CK	SAT	C	A1-A	RR		NA	VR-11	
								CT-CC	OP				
								CT-CO	OP				
								PTI	2Y				
CV-4327F	C-7	NC	A/C	1B	CK	SAT	C	A1-A	RR		NA	VR-11	
								CT-CC	OP				
								CT-CO	OP				
								PTI	2Y				
CV-4327G	C-7	NC	A/C	1B	CK	SAT	C	A1-A	RR		NA	VR-11	
								CT-CC	OP				
								CT-CO	OP				
								PTI	2Y				
CV-4327H	C-5	NC	A	2	CK	AD	AD	O/F/C	A1-A	RR	005	NA	VR-17
								BIC	OP				
								FST	OP				
								PTI	2Y				
CV-4327I	F-5	HC	H/C	2	CK	AD	AD	O/F/C	A1-A	RR	005	NA	VR-17
								BIC	OP				
								FST	OP				
								PTI	2Y				

PREPARED BY : MOTECH
PROGRAM : PRISTIN

TEST SERVICE TESTING PROGRAM
1ST CLASS 1, 2,
3, AND HC VALVES
DUANE ARNOLD ENERGY CENTER

100A ELECTRIC LIGHT
AND POWER

F&ID : H-143 REVISION 2B
SYSTEM : CONTAINMENT ATMOSPHERE CONTROL

VALVE NUMBER	F&ID COLOR	1ST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
V-4370A	E-5	NC	A	2	6A	A0	0/FC	AI-1 B1C FST PIT	RR 0P 0P 2Y	NA	VR-17
V-4370B	E-5	NC	A	2	6A	A0	0/FC	AI-1 B1C FST PIT	RR 0P 0P 2Y	NA	VR-17
H-4323A	C-3	2	B	2	6A	H0	C	B1C B10 F-T	0P 0P 0P 2Y	012	012
H-4323B	C-4	2	B	2	6A	H0	C	B1C B10 F-T	0P 0P 0P 2Y	012	012
H-4323C	B-3	2	B	2	6L	H0	C	B10 F-T	0P 0P 0P 2Y	040	040
H-4323H	H-4	2	B	2	6L	H0	C	B10 F-T	0P 0P 0P 2Y	040	040
V-4399	C-7	HC	B	-	3W	S0	ND	B1D B10 F-T	0P 0P 0P 2Y	NA	VR-2
V-4301	C-B	HC	B	-	3W	S0	ND	B1D B10 F-T	0P 0P 0P 2Y	NA	VR-2
V-4302	D-7	HC	B	-	3W	S0	ND	B1D B10 F-T	0P 0P 0P 2Y	NA	VR-2
V-4303	D-7	HC	B	-	3W	S0	ND	B1D B10 F-T	0P 0P 0P 2Y	NA	VR-2
V-4304	H-7	HC	B	-	3W	S0	HE	B1D B1E F-T	0P 0P 0P 2Y	NA	VR-2
SV-4305	H-7	HC	B	-	3W	S0	HE	B1D B1E F-T	0P 0P 0P 2Y	NA	VR-2

PREPARED BY : MOTECHE
PROGRAM : FRISTIM

IN-SERVICE TESTING PROGRAM
LST CLASS 1, 2,
AND NC VALVES
DUANE ARNOLD ENERGY CENTER

F&ID H-143
REVISION 2B
SYSTEM : CONTAINMENT ATMOSPHERE CONTROL

PAGE : 55
LST PROGRAM REVISION : 00 , 12/23/83

VALVE NUMBER	F&ID	LST CDR CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST STROKE	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
SV-4306	E-1	NC	B	-	3WY	SO	ND	0P	0P	NA	VR-2	
SV-4307	E-3	NC	B	-	3WY	SO	ND	0P	0P	NA	VR-2	
SV-4308	E-3	NC	B	-	3WY	SO	ND	0P	0P	NA	VR-2	
SV-4309	D-7	NC	B	-	3WY	SO	ND	0P	0P	NA	VR-2	
SV-4310	D-7	NC	B	-	3WY	SO	ND	0P	0P	NA	VR-2	
SV-4311	F-3	NC	B	-	3WY	SO	ND	0P	0P	NA	VR-2	
SV-4312	F-3	NC	B	-	3WY	SO	ND	0P	0P	NA	VR-2	
SV-4313	F-3	NC	B	-	3WY	SO	ND	0P	0P	NA	VR-2	
SV-43310	C-2	NC	A	2	6A	SO	C/KC	AI-1	RR	NA	VR-34	
								BTC	0P	0.05	VR-34	
								B10	0P	0.05	VR-34	
								FST	0P		VR-17	
								FII	2Y			
SV-43314	C-2	NC	A	2	6A	SO	C/KC	AI-1	RR	NA	VR-34	
								BTC	0P	0.05	VR-34	
								B10	0P	0.05	VR-34	
								FST	0P		VR-17	
								FII	2Y			
SV-43318	C-2	NC	A	2	6A	SO	C/KC	AI-1	RR	NA	VR-34	
								BTC	0P	0.05	VR-34	
								B10	0P	0.05	VR-34	
								FST	0P		VR-17	
								FII	2Y			

PREPARED BY : NUITECH
 PROGRAM : PRISIM

INSERVICE TESTING PROGRAM

LSI CLASS 1, 2, 3, AND NC VALVES
 DIANE ARNOLD ENERGY CENTER

PAID SYSTEM : M-143 REVISION 2B
 CONTAINMENT ATMOSPHERE CONTROL

LSI PROGRAM REVISION : 005 , 12/23/03

VALVE NUMBER	PAID FLOOR	LSI CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUIRE STI	REMARKS
SV-4333A	C-2	NC	A	2	GA	SO	C/KC	AI-1	RR	0.05	NA	VR-34	
								BIC	0P			VR-34	
								BIO	0P			VR-47	
								FST	0P				
								PII	2Y				
SV-4333B	C-2	NC	A	2	GA	SO	C/KC	AI-1	RR	0.05	NA	VR-34	
								BIC	0P			VR-34	
								BIO	0P			VR-17	
								FST	0P				
								PII	2Y				
SV-4334A	B-2	NC	A	2	GA	SO	C/KC	AI-1	RR	0.05	NA	VR-34	
								BIC	0P			VR-34	
								BIO	0P			VR-34	
								FST	0P			VR-17	
								PII	2Y				
SV-4334B	B-2	NC	A	2	GA	SO	C/KC	AI-1	RR	0.05	NA	VR-34	
								BIC	0P			VR-34	
								BIO	0P			VR-34	
								FST	0P			VR-17	
								PII	2Y				
SV-43710	E-5	NC	B	-	3WY	SO	NE	BID	0P	NA	NA	VR-2	
SV-43711	E-5	NC	B	-	3WY	SO	NE	BID	0P	NA	NA	VR-2	
SV-43712	E-5	NC	B	-	3WY	SO	NE	BID	0P	NA	NA	VR-2	
V-43713	E-5	NC	C	-PS	CK	SA	C	CL-CC	CS			VR-2	
V-43714	B-8	NC	C	-PS	CK	SA	C	CL-CC	CS			VR-2	

PREPARED BY : MOTECH
FOR KRAI : FRISTM

ON-SERVICE TESTING PROGRAM
LST CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FALID : N-143 REVISION 2B
SYSTEM : CONTAINMENT ATMOSPHERE CONTROL

LST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	FALID CODE	LST CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR POSITION	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE	MAXIMUM LEAKAGE	RELIEF REQUEST	REQUEST	REMARKS
V-43-0B2	C-3	2	C	2	CK	SA	C	CT-CO	RR	"	"	"	"	VR-24
V-43-0B4	C-3	2	C	2	CK	SA	C	CT-CO	RR	"	"	"	"	VR-24
V-43-0B6	C-3	2	C	2	CK	SA	C	CT-CO	RR	"	"	"	"	VR-24
V-43-0BH	B-3	2	C	2	CK	SA	C	CT-CO	RR	"	"	"	"	VR-24
V-43-16B	A-7	NC	A/C	20	CK	SA	C	AI-1	RR	"	"	"	"	NA
V-43-169	A-7	NC	A/C	20	CK	SA	C	AI-1	RR	"	"	"	"	NA
V-43-214	F-4	NC	A/C	2	CK	SA	C	AI-1	RR	"	"	"	"	VR-25

DETAILED BY : MTECH
PROGRAM : PRISM

IN-SERVICE TESTING PROGRAM
LST CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

PART ID : H-146 REVISION 15
SYSTEM : SERVICE WATER PIPE HOUSE

LST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	FAID CODE	LST CLASS	VALVE CAT	VALVE SIZE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	RELIEF REQUEST
V-46-011	B-5	3	C	12	CK	SA	C	CT-CC OF	CT-CO OF		
V-46-013	B-5	3	C	12	CK	SA	C	CT-CC OF	CT-CO OF		
V-46-018	C-6	3	C	8	CK	SA	C	CT-CC RR	CT-CO RR		
V-46-021	C-6	3	C	8	CK	SA	C	CT-CC RR	CT-CO RR		
V-46-026	D-7	3	C	12	CK	SA	C	CT-CC OF	CT-CO OF		
V-46-030	D-7	3	C	12	CK	SA	C	CT-CC OF	CT-CO OF		

PREPARED BY : NUITECH
 PREPARED BY : NUITECH
 PFKURKAN : PFKURKAN

IN-SERVICE TESTING PROGRAM
 I.S.I. CLASS 1, 2, 3, AND NC VALVES
 DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
 AND POWER

P&ID : M-157
 SYSTEM : DRYWELL COOLING WATER
 REVISION 0B

VALVE NUMBER	P&ID CODE	I.S.I. CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS	PAGE : 005 , 12/23/83
CV-5703A	F-7	3	A	3	6L	H	C	A1-1 P1T	RR 2Y	NA	NA	NA	
CV-5704A	H-6	3	A	4	6L	A0	0/F0	A1-1 B1C B10 FST P1T	RR 0P 0P 0P 2Y	005 005 005	VR-17	VR-17	
CV-5710A	H-8	3	P	4	6L	A0	0/F0	A1-1 B1C B10 FST P1T	RR 0P 0P 0P 2Y	005 005 005	VR-17	VR-17	
CV-5710B	A-8	3	A	4	6L	A0	0/F0	A1-1 B1C B10 FST P1T	RR 0P 0P 0P 2Y	005 005 005	VR-17	VR-17	
CV-5710C	A-7	3	A	3	6L	H	C	A1-1 P1T	RR 2Y	NA	NA	NA	

PREPARED BY : MOTECH
PROGRAM : FRISTI

INSERVICE TESTING PROGRAM

IST CLASS 1, 2, 3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

F&ID : H-157
SYSTEM : DRYWELL COOLING WATER

REVISION OF
REV 08

IST PROGRAM REVISION : 005 , 12/23/85

VALVE NUMBER	F&ID CODE	F&ID CLASS	VALVE CAT	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	RELIEF REQUEST
SV-5704A	H-6	NC	B	-	3WY	SO	ND	BTD BIE	OF OF	OF	NA	NA	VR-2	VR-2
SV-5704B	H-6	NC	B	-	3WY	SO	ND	BTD BIE	OF OF	OF	NA	NA	VR-2	VR-2
SV-5710A	B-B	NC	B	-	3WY	SO	ND	BTD BIE	OF OF	OF	NA	NA	VR-2	VR-2
SV-5710B	A-B	NC	B	-	3WY	SO	ND	BTD BIE	OF OF	OF	NA	NA	VR-2	VR-2

PREPARED BY : HUTCHINSON
PROGRAM : FRISTIKA

INSERVICE TESTING PROGRAM

LSI CLASS 1, 2, 3, AND MC VALVES
DIANE ARNOLD ENERGY CENTER

TOMA ELECTRIC LIGHT

AND POWER

PART NO-191 REVISION 10
SYSTEM : CONTAINMENT ATMOSPHERE MONITORING

LSI PROGRAM REVISION

PAGE : 64
005 , 12/23/83

VALVE NUMBER	PART NUMBER	LSI CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUIREMENT	REMARKS
SV-B101A	F-5	NC	A 1	GL	SD	0/FC	AI-1 BIC FST	KK 0P 0P	NA	NA	VR-32 VR-17
SV-B101B	F-4	NC	A 1	GL	SD	0/FC	AI-1 BIC FST	KK 0P 0P	NA	NA	VR-32 VR-17
SV-B102A	F-5	NC	A 1	GL	SD	0/FC	AI-1 BIC FST	KK 0P 0P	NA	NA	VR-32 VR-17
SV-B102B	F-4	NC	A 1	GL	SD	0/FC	AI-1 BIC FST	KK 0P 0P	NA	NA	VR-32 VR-17
SV-B103A	F-5	NC	A 1	GL	SD	0/FC	AI-1 BIC FST	KK 0P 0P	NA	NA	VR-32 VR-17
SV-B103B	F-4	NC	A 1	GL	SD	0/FC	AI-1 BIC FST	KK 0P 0P	NA	NA	VR-32 VR-17
SV-B104A	F-5	MC	A 1	GL	SD	0/FC	AI-1 BIC FST	KK 0P 0P	NA	NA	VR-32 VR-17
SV-B104B	F-4	NC	A 1	GL	SD	0/FC	AI-1 BIC FST	KK 0P 0P	NA	NA	VR-32 VR-17

PREPARED BY : MOTECH
PROGRAM : PRISM

1 SERVICE TESTING PROGRAM
1ST CLASS 1, 2, 3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FID : H-181
SYSTEM : CONTAINMENT ATMOSPHERE MONITORING
REVISION 10

PAGE : 62
12/23/83

VALVE NUMBER	FID	1ST CLASS CODE	VALVE SIZE	VALVE CAT	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	MAXIMUM STRIKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
SV-8105F	E-5	NC	A	1	GL	SO	0/FC	A1-1	ER 0P FSI	NA	VR-32 VR-47	
SV-8105J	J	NC	A	1	GL	SO	0/FC	A1-1	ER 0P FSI	NA	VR-32 VR-47	
SV-8105K	K	NC	A	1	GL	SO	0/FC	A1-1	ER 0P FSI	NA	VR-32 VR-47	
SV-8106B	B-4	NC	A	1	GL	SO	0/FC	A1-1	ER 0P FSI	NA	VR-32 VR-47	
SV-8106D	D-5	NC	A	1	GL	SO	0/FC	A1-1	ER 0P FSI	NA	VR-32 VR-47	
SV-8106H	H-4	NC	A	1	GL	SO	0/FC	A1-1	ER 0P FSI	NA	VR-32 VR-47	
SV-8106A	A-5	NC	A	1	GL	SO	0/FC	A1-1	ER 0P FSI	NA	VR-32 VR-47	
SV-8106C	C-4	NC	A	1	GL	SO	0/FC	A1-1	ER 0P FSI	NA	VR-32 VR-47	
SV-8106E	E-4	NC	A	1	GL	SO	0/FC	A1-1	ER 0P FSI	NA	VR-32 VR-47	

PREPARED BY : MOTTECH
PRISM : PRISM

TEST SERVICE TESTING PROGRAM
LSI CLASS 1, 2,
3, AND AC VALVES
DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

FADID H-181 REVISION 10
SYSTEM : CONTAINMENT ATMOSPHERE MONITORING

LSI PROGRAM REVISION : 005 , 12/23/83

VALVE	FADID	LSI CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST FREQ	TEST STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
SV-H110A	D-5	NC	A	1	GL	S0	O/FC	AT-1 BIC FST	NR OP OP	NR NA	VR-32 VR-17
SV-H110B	D-4	NC	A	1	GL	S0	O/FC	AT-1 BIC FST	NR OP OP	NR	VR-32 VR-17

PREPARED BY : MOTECH
PROGRAM : PRISIM

IN-SERVICE TESTING PROGRAM
IST CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

FILED : R-104 REVISION 05
SYSTEM : RSTV LEAKAGE CONTROL

PAGE : 005 , 12/23/83

VALVE NUMBER	FILED CLASS	LIST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	MAXIMUM LEAKAGE		RELIEF REQUEST	REQUEST
									STROKE TIME	LEAKAGE		
MO-B401A	F-3	1	B	1	GA	HO	C	BIC	0P	0.20		
								FIT	2Y			
MO-B401B	F-3	1	B	1	GA	HO	C	BIC	0P	0.20		
								B10	0P	0.20		
								FIT	2Y			
MO-B401C	F-3	1	B	1	GA	HO	C	BIC	0P	0.20		
								B10	0P	0.20		
								FIT	2Y			
MO-B402A	F-3	2	B	1	GA	HO	C	BIC	0P	0.20		
								B10	0P	0.20		
								FIT	2Y			
MO-B402B	F-3	2	B	1	GA	HO	C	BIC	0P	0.20		
								B10	0P	0.20		
								FIT	2Y			
MO-B402C	F-3	2	B	1	GA	HO	C	BIC	0P	0.20		
								B10	0P	0.20		
								FIT	2Y			
MO-B402D	F-3	2	B	1	GA	HO	C	BIC	0P	0.20		
								B10	0P	0.20		
								FIT	2Y			

PREPARED BY : NUCTECH
PROGRAM : PFTSM

IN-SERVICE TESTING PROGRAM
LST CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

F&ID : M-184 REVISION 05
SYSTEM : HSIV LEAKAGE CONTROL

PAGE : 65
LST PROGRAM REVISION : E-5 , 12/23/83

VALVE NUMBER	F&ID	LST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR TYPE	NORMAL POSITION	TEST POSITION	TEST FREQ	MAXIMUM STROKE TIME	MAXIMUM LEAKAGE	RELIEF REQUEST	REMARKS
(H)-1403B	F-4	2	B	1	GA	H0	C	BIC	0P	0.20		
								B10	0P	0.20		
								PIT	2Y			
(H)-1403C	F-4	2	B	1	GA	H0	C	BIC	0P	0.20		
								B10	0P	0.20		
								PIT	2Y			
(H)-1403D	F-4	2	B	1	GA	H0	C	BIC	0P	0.20		
								B10	0P	0.20		
								PIT	2Y			

PREPARED BY : MUECH
PROGRAM : PRISM

INSERVICE TESTING PROGRAM

IST CLASS 1, 2, 3, AND NC VALVES
DIANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

P&ID : H-187
SYSTEM : POST ACCIDENT SAMPLING SYSTEM

REVISION 0
IST PROGRAM REVISION : 005 , 12/23/83

VALVE NUMBER	P&ID COOR	IST CLASS	VALVE SIZE	VALVE TYPE	ACTUATOR POSITION	NORMAL POSITION	TEST FREQ	TEST TIME	MAXIMUM STROKE	MAXIMUM LEAKAGE	RELIEF REQUIRE	REMARKS
SV-8772A	E-1	A	1	BAL	S0	C	A1-1	RR	0P	005	VR-32	VR-17
SV-8772B	E-1	A	1	BAL	S0	C	A1-1	RR	0P	005	VR-32	VR-17

PREPARED BY : NUTECH
PROGRAM : PRISIM

INSERVICE TESTING PROGRAM
ISI CLASS 1, 2, 3, AND NC VALVES
DUANE ARNOLD ENERGY CENTER

IOWA ELECTRIC LIGHT
AND POWER

PAGE : 67
IST PROGRAM REVISION : 005 , 12/23/83

VALVE IST PROGRAM REMARKS

- NOTE 001: There are 89 CRD hydraulic control modules and each CRD hydraulic control module contains one of these valves. The valve number listed in the valve IST program is typical of 89.
- NOTE-002: Valve No. V-18-0118 is as typical valve number from a group of 89 valves. The complete set of numbers is V-18-0118 thru and including V-18-0206.
- NOTE-003: Valve No. V-18-0919 is a typical valve number from a group of 89 valves. The complete set of numbers is V-18-0919 thru and including V-18-1007.
- NOTE-004: Valve No. V-18-1453 is a typical valve number from a group of 89 valves. The complete set of numbers is V-18-1453 thru and including V-18-1541.
- NOTE-005: This valve is verified to operate to its safety-related position during periodic testing of the RCIC Pump.

APPENDIX C

ASME LETTER TO WPPSS RE
SECTION XI, DIVISION, IWA-1100
SCOPE OF SECTION XI, DIVISION 1

**The American Society of Mechanical Engineers**

United Engineering Center / 345 E. 47th St., New York, N.Y. 10017 / 212 644-7815

February 16, 1978

THE BOILER AND
PRESSURE VESSEL
COMMITTEEDate 1/8/79
Revision 0

Chairman L.P. Zick

L. T. Harrold, Supervisor, ISI Programs
Washington Public Power Supply System
PO Box 968

Vice-Chairman W.L. HARDING

3000 George Washington Way
Richland, WA 99352

Secretary W.B. HOYT

Subject: Section XI, Division 1, IWA-1100
Scope of Section XI, Division 1

C.W. ALLISON

Reference: Your letter of September 19, 1977 (APO 77-59)
ASME File #: BC 77-666
NI 77-371

B.W. BACE

R.D. BONNER

R.J. BOSNAK

P.M. BRISTER

H.M. CANAVAN

R.J. CEPLUCH

L.J. CHOCKIE

W.E. COOPER

W.D. DOTY

G.E. FRATCHER

R.C. GRIFFIN

S.F. HARRISON

E.J. HEMZY

W.P. JOHNSON

E.L. KEMMLER

E.L. KIME

J.E. LATTAN

J.L. MCORFF

J.R. MACKAY

R.H. MOELLER

T.E. NORTHUP

C.E. RAWLINS

W.R. SMITH SR.

W.E. SOMERS

Dear Mr. Harrold:

Your inquiry and our response are as stated below:

QUESTION:

Is it the intent of Subarticle IWA-1100 that the rules and requirements of Section XI, Division 1 for inservice inspection of Class 1, 2 & 3 pressure retaining components (and their supports) be applied only to water and steam systems in light water cooled nuclear power plants?

REPLY:

Systems containing other than steam or water were not originally considered by the Committee in formulating the rules in Section XI; they may, however, be included for further consideration and for revisions to future editions of Section XI. The requirements shown in Section XI, Article IWA-1000 on Scope and Responsibility, specifically Paragraph IWA-1400, requires the Owner of the nuclear plant to determine the appropriate Code, Class or Classes for each component of the nuclear power plant to be examined according to Section XI rules.

Very truly yours,

Kenneth I. Baron,
Assistant Secretary

/fs

DETAILED SUMMARY OF IST PROGRAM CHANGES

This attachment addresses, in detail, the changes between Revision 4 and Revision 5 of the Duane Arnold Energy Center Inservice Testing (IST) Program for Pumps and Valves.

1. Format/editorial changes - The format of the program is modified to conform to the standard DAEC format for controlled documents. As a result of this transformation, several editorial changes of no technical consequence are added.
2. Effective date - The effective date of the program is extended to the end of the current inspection interval.
3. Relief Request PR-2 - This relief request, which pertains to measurement of bearing temperatures of the Emergency Service Water (ESW) pumps, was expanded as requested.
4. Relief Request PR-3 - This relief request, which pertains to measurements of vibration and bearing temperatures of the HPCI and RCIC pumps, is changed to include a commitment for future compliance.
5. Relief Request PR-4 - This relief request, which pertains to the calculation of suction pressure for various pumps, is changed by the addition of the Standby Liquid Control (SBLC) pumps.
6. Relief Request PR-8 - This new relief request provides for the option of measuring pump vibration in units of velocity as well as displacement.
7. Screen Wash Pumps - The screen wash pumps are a new addition to the program. Relief Request PR-9 is submitted to account for existing system design details that may not conform to Code requirements.
8. Relief Request PR-10 - Based on an ASME Code interpretation, the test acceptance criteria for testing of the diesel fuel oil transfer pump is afforded an optional treatment.
9. Pressure isolation valve testing - In compliance with an NRC request, leaktesting of pressure isolation valves is added to the Program. Table 3.1-1 and Appendix B are revised accordingly.
10. Several relief requests are voided per NRC request.
11. Excess flow check valves - Relief Request VR-8 is rewritten to eliminate the requirement for quantitative leaktesting of the excess flow check valves.
12. Relief Request VR-11 - Typographical correction -- CV-4327E replaced by CV-4327H. The tabulation in Appendix B is corrected accordingly.
13. Relief Request VR-13 - This relief request, which pertains to testing of CRD system valves, is expanded to provide further technical justification for the request.

14. Relief Request VR-29 - This request is corrected as follows:
CV-3729 & CV-4311 are deleted; test is done in correct direction
CV-4301 & CV-4639 are deleted; these are not gate valves
CV-3728 & MOV-2400 are added; inadvertently omitted from Revision 4
15. Relief Request VR-32 - Four (4) recently installed Post-Accident Sampling System (PASS) valves are added (SV-4594 A & B and SV-8772 A & B)
16. Core Spray check valves - Relief request VR-33 is submitted shifting the test frequency of CV-2118 and CV-2138 from quarterly to each refueling.
17. ESW valves CV-1956 A & B - These valves have no remote position indication, thus, position indication testing is deleted. Furthermore, the stroke time measurement is replaced by a qualitative evaluation of valve operation. (See Relief Request VR-35)
18. Excess flow check valves - Position indication tests are added.
19. CRD valves CV-1849 and CV-1850 - These valves have no individual position indicators, thus, position indication testing is deleted.
20. CRD valves CV-1859 and CV-1867 - These valves have been replaced by CV-1859 A & B and CV-1867 A & B as a result of a recent backfit. These additional valves are added to the list. Note: The next revision to the program will eliminate CV-1859 and CV-1867 from the listing.
21. Relief Request VR-32 - Four (4) PASS valves are added to this relief request.
22. Relief Request VR-34 - The evaluation of stroke time test results for quick-acting solenoid valves is revised.
23. ESW check valves - The test requirements for valves V-46-18 and V-46-21 are changed to add a closure test and extend the test frequency to once per operating cycle.
24. Well water valves - Requirements for position indicator tests are added for valves CV-5703 A & B and CV-5729 A & B.

25. Valve categories changed as follows:

PSV 1988	B/C vs C	CV 1906	A/C vs C
PSV 2068	B/C vs C	CV 1905A	A/B vs C
PSV 4400	B/C vs A/C	PSV 1911	B/C vs C
PSV 4401	B/C vs A/C	PSV 1952	B/C vs C
PSV 4402	B/C vs A/C	CV-2002	A/C vs C
PSV 4403	B/C vs A/C	MO 2003	A/B vs B
PSV 4404	B/C vs A/C	PSV 2043	B/C vs C
PSV 4405	B/C vs A/C	CV 2118	A/C vs C
PSV 4406	B/C vs A/C	CV 2138	A/C vs C
PSV 4407	B/C vs A/C	PSV 2109	B/C vs C
PSV 4439 A	B/C vs C	PSV 2129	B/C vs C
PSV 4439 B	B/C vs C	PSV 2223	B/C vs C
PSV 4439 C	B/C vs C	PSV 2228	B/C vs C
PSV 4439 D	B/C vs C	PSV 2301	B/C vs C
PSV 4439 E	B/C vs C	PSV 2474	B/C vs C
PSV 4439 F	B/C vs C	V-24-8	C vs A/C
		V-24-12	C vs A/C
		PSV 2501	B/C vs C
		PSV 2607	B/C vs C
		PSV 2609	B/C vs C

STATUS OF CONTINUING ENGINEERING EVALUATION OF THE IST PROGRAM

During the first year of implementing Revision 4 of the DAEC Inservice Testing (IST) Program with the computer trending system, the DAEC engineering staff has been conducting an ongoing review of the Program. As a result, several items of operational concern have been identified and are being, or have been resolved. A report of the final resolution of all items will be described, in detail, as part of the 180-day response to NRC's Safety Evaluation Report (SER). Each of these concerns are discussed below.

1. Instrument Sensing Lines

ASME Section XI, Paragraph IWP-4210, requires that tubing leading to pressure sensing instruments shall be installed or vented such that the error related to the static head of the water in the tubing does not impact the test data. A detailed evaluation of the routing of various sensing lines for instruments used in the IST Program has recently been completed. The results of this study indicate that several procedures require changes to ensure that all instrument sensing lines are properly filled during pump testing. These changes are currently being implemented.

2. Instrument Ranges

A detailed study is currently underway regarding IST instrumentation compatibility with ASME Section XI, Table IWP-4110-1, and Paragraph IWP-4120. As a result of a preliminary review of this study, it appears that several instruments do not strictly conform to the requirements of the Code. Although Relief Request PR-7 references deviation with respect to accuracy, recent information suggests that, in some cases, instruments do not meet the maximum range criteria.

3. Check Valves

The IST Program requires that the diesel fuel transfer pump check valves be exercised in the open and closed direction every three (3) months. During pump flow tests, the valves are exercised in the open direction; however, there is no definitive written procedure to verify the check valves stroked to the closed position. A procedure has been developed and is being implemented to verify valve closure. Since there have been no spurious alarms associated with the day tank level, it can be deduced that these check valves are operating properly.

4. Technical Specifications

During the development of the Program with the NRC staff and their contractors, there was an agreement made to review the DAEC Technical Specifications according to "NRC Staff Guidelines for Excluding Exercising (Cycling) Tests of Certain Valves During Plant Operation." There is no record indicating that such a review has ever been conducted. This review will be completed as soon as practical.

Iowa Electric recognizes the importance of the DAEC IST Program and will continue to monitor its implementation for both technical adequacy and content. Problems, when identified, will be resolved on a priority basis.