

APPENDIX A

NOTICE OF VIOLATION

Southern California Edison Company
2244 Walnut Grove Avenue
Rosemead, California 91770

Docket No. 50-361
License No. NPF-10

As a result of the inspection conducted on January 17-21, 1983, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 47 FR 9987 (March 9, 1982) one violation of a license condition was identified.

Technical Specification 3.12.2, LAND USE CENSUS requires in part that: "With a land use census identifying a location(s) which yields a calculated dose or dose commitment greater than the values currently being calculated in Specification 4.11.2.3, in lieu of any other report required by Specification 6.9.1., prepare and submit to the Commission within 30 days, pursuant to Specification 6.9.2, a Special Report which identifies the new location(s)."

Contrary to this requirement, the land use census dated November 12, 1982 identified a near site resident, (located at 0.38 miles Northwest) which would receive a calculated dose about four times greater than the resident identified by the Offsite Dose Calculation Manual (Table 2-6, 1.8 miles Northwest) and a Special Report had not been submitted as of January 21, 1983.

This is a Severity Level V Violation (Supplement I).

Pursuant to the provisions of 10 CFR 2.201, the Southern California Edison Company is hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further items of noncompliance; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

FEB 04 1983

Dated

(S)

F. A. Wenslawski, Chief
Reactor Radiation Protection Section