LICENSEE EVENT REPORT — UPDATE REPORT

PREVIOUS REPORT DATE 12/21/82

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(2) LICENSEE CODE: TNSNP1 | (3) LICENSE NUMBER: 00-0000-00 | (4) LICENSE TYPE: 4 | (5) CAT 58: 1111

CON'T

REPORT SOURCE: L (6) | DOCKET NUMBER: 050003272 (7) | EVENT DATE: 112282 (8) | REPORT DATE: 022483 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

Unit 1 in mode 5 with the RCS temperature and pressure at 112 degrees F and 0 psig. During the review of surveillance instruction (SI) 196, three of four level switches on the UHI system were found to be out of tolerance. This condition was discovered in mode 5 but could have existed in applicable modes per LCO 3.5.1. There was no effect upon public health and safety. Previous occurrences - none.

SYSTEM CODE (11)	CAUSE CODE (12)	CAUSE SUBCODE (13)	COMPONENT CODE (14)	COMP. SUBCODE (15)	VALVE SUBCODE (16)
SF	E	E	INSTRUMENT	S	Z

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 — SEQUENTIAL REPORT NO. 135 / OCCURRENCE CODE 03 — REPORT TYPE X — REVISION NO. 1

ACTION TAKEN (18)	FUTURE ACTION (19)	EFFECT ON PLANT (20)	SHUTDOWN METHOD (21)	HOURS (22)	ATTACHMENT SUBMITTED (23)	NPRD-4 FORM SUB. (24)	PRIME COMP. SUPPLIER (25)	COMPONENT MANUFACTURER
E	E	Z	Z	0000	N	N	N	I204

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1-LS-87-21, -22, and -24 were out of tolerance as specified in surveillance requirement 4.5.1.2.c.1. The probable cause was instrument drift of the Barton Model 288A level switches. They were calibrated and returned to service. All four level switches will be checked for calibration on or before 02/01/83. If they are out of tolerance, they will be rechecked every 30 days; if not, every 90 days. This will continue for 1 year or until a solution is found.

FACILITY STATUS (28)	% POWER (29)	OTHER STATUS (30)	METHOD OF DISCOVERY (31)	DISCOVERY DESCRIPTION (32)
G	000	NA	B	Surveillance test.

ACTIVITY RELEASED (33)	OF RELEASE (34)	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
Z	Z	NA	NA

PERSONNEL EXPOSURES

NUMBER (37)	TYPE (38)	DESCRIPTION (39)
000	Z	NA

PERSONNEL INJURIES

NUMBER (40)	DESCRIPTION (41)
000	NA

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE (42)	DESCRIPTION
Z	NA

PUBLICITY

ISSUED (44)	DESCRIPTION (45)
N	NA

8303040641 830224
PDR ADOCK 05000327
S PDR

NRC USE ONLY

Name of Preparer: W. C. Ludwig /M. R. Harding Phone: (615) 751-0349