NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

CAR-1448

LICENSEE EVENT REPORT

CONTROL BLOCK: ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

Line	Field	Value
01	Licensee Code ②	NYREG1
01	License Number ③	00-00000-00
01	License Type ④	41111
01	CAT ⑤	
01 (CON'T)	Report Source ⑥	L
01 (CON'T)	Docket Number ⑦	05000244
01 (CON'T)	Event Date ⑧	032983
01 (CON'T)	Report Date ⑨	042583

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

During the refueling calibration of the A and B steam generator level transmitters, Technicians found LT-461, LT-462, LT-463, LT-471, LT-472 and LT-473 outputs shifted low by 2 t o 2½% of span, which is approximately 2" water level. These transmitters provide signals for reactor protection logic (low level plus FW < SF and low-low level), and for the safeguard logic (F.W. Isolation on high level). See T.S. Table 3.5-5. This item is reportable by T.S. 6.9.2.b.(1).

System Code ⑪	Cause Code ⑫	Cause Subcode ⑬	Component Code ⑭	Comp. Subcode ⑮	Valve Subcode ⑯
IB	E	E	INSTRU	T	Z

⑰ LER/RO REPORT NUMBER

Event Year		Sequential Report No.		Occurrence Code	Report Type		Revision No.
83	—	014	/	03	L	—	0

Action Taken ⑱	Future Action ⑲	Effect on Plant ⑳	Shutdown Method ㉑	Hours ㉒	Attachment Submitted ㉓	NPRD-4 Form Sub. ㉔	Prime Comp. Supplier ㉕	Component Manufacturer ㉖
E	Z	Z	Z	0000	N	N	L	F180

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ㉗

These errors were due to instrument drift. The transmitters were recalibrated in accordance with plant procedures and returned to service. The transmitters are a Foxboro Model N-E13DM.

Facility Status ㉘	% Power ㉙	Other Status ㉚	Method of Discovery ㉛	Discovery Description ㉜
G	000	N/A		Calibration Intest

Activity Released ㉝	Content of Release ㉞	Amount of Activity ㉟	Location of Release ㊱
Z	Z	N/A	N/A

PERSONNEL EXPOSURES

Number ㊲	Type ㊳	Description ㊴
000	Z	N/A

PERSONNEL INJURIES

Number ㊵	Description ㊶
000	N/A

8305110328 830425
PDR ADOCK 05000244
S PDR

LOSS OF OR DAMAGE TO FACILITY ㊸

Type ㊷	Description
Z	N/A

PUBLICITY

Issued ㊹	Description ㊺
N	N/A

NRC USE ONLY

NAME OF PREPARER: E. C. Edgar

PHONE: (315)-524-4446 Ext. 248